


| | | |
|---|--|------------------------|
|  | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Page 1 of 21 |

INFORMATION REQUEST REFERENCE INFORMATION

| Agency | Date of Request | Letter Request No. | AGDC ID No. |
|--------|-----------------|--------------------|-------------|
| ADEC | 12-3-2019 | N/A | N/A |

REQUEST:

Provide additional information to support the use of facility specific cost factors and vendor data to the EPA Cost Control Manual equations (6th edition) used to evaluate cost effectiveness for Selective Catalytic Reduction. Alternatively, provide updated cost effectiveness calculations using EPA default cost factors and equations.


RESPONSE:

AGDC has reviewed the cost-effectiveness calculations and updated them based on ADEC input. The revised cost effectiveness calculations continue to demonstrate that installation of a selective catalytic reduction (SCR) system on the Gas Treatment Plant (GTP) and Liquefaction (LNG) facility turbines is not cost effective under both the procedures described in the 2002 (6th Edition) and 2019 versions (7th Edition) of the EPA Cost Control Manual. The updated results are summarized in the table below, and backup for the calculations are included in Appendix A (6th edition) and Appendix B (7th edition):

| Facility | Unit | EPA 6th Edition Cost Manual (\$/ton NOx Removed) | EPA 7th Edition Cost Manual (\$/ton NOx Removed) |
|----------|-------------------------------------|---|---|
| | | Facility Specific Cost Factors Applied | EPA Default Calculation Tool Applied |
| GTP | CO ₂ Compressor Turbines | \$16,333 | \$10,941 |
| GTP | Power Generation Turbines | \$25,402 | \$13,428 |
| GTP | Treated Gas Compressor Turbines | \$14,200 | \$10,895 |
| LNG | Compressor Turbines | \$18,164 | \$11,241 |
| LNG | Power Generation Turbines | \$24,588 | \$10,904 |

The 6th edition cost estimates were updated as follows:

- AGDC obtained vendor quotes for the potential turbine models being considered for the Project. Appendix C to this response provides the budgetary cost quotations.
- Appendix C to this response provides back-up documentation to support the site-specific assumptions used in the cost calculations. Some of the assumptions used in prior cost effectiveness calculations have been updated based on a review of the current engineering data.


| | | |
|---|--|------------------------|
|  | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Page 2 of 21 |

- AGDC has updated the baseline NOx assumptions used in the cost-effectiveness calculations for the compressor turbines at the LNG plant. AGDC has surveyed possible turbine vendors and determined that baseline NOx values are between 9 and 15ppmv @ 15% O₂. For the purposes of the analysis, AGDC has assumed the upper bound of the range (i.e., 15ppmv NOx), consistent with the analysis for the other GTP and LNG turbines proposed for the Project.
- Where supplemental fire is anticipated for the turbine operations, the NOx from duct fire burning has also been considered in the cost-effectiveness calculations. Duct firing is expected at the GTP CO₂ and Treated Gas Compressors.
- The controlled NOx emissions target in the cost effectiveness calculations is assumed to be 2ppmv @ 15% O₂. While this level of control has been achieved elsewhere in BACT/LAER determinations, we believe it is an aggressive level of NOx control, considering the environment where these turbines will operate. AGDC believes that 5ppmv NOx would be a more reasonable level. Nevertheless, to assure the cost effectiveness calculations are conservative, a 2ppmv NOx target was used in the analysis.

For completeness, AGDC modeled cost effectiveness using both the EPA 6th and 7th editions. However, it is important to note the 6th edition cost-effectiveness results are likely more accurate for the Alaska LNG Project than the 7th edition results, because the 7th edition has limited capability for the user to enter site specific information. Site-specific conditions for both the GTP and the Liquefaction Facility are significantly different from the 'standard' EPA model because of the increased transportation requirements to get equipment to Alaska and the operating conditions. The 7th edition cost effectiveness calculations are biased low in the following respects:

- SCR cost data for simple cycle gas turbines is based on limited vendor data collected in the 1990's for typical units expected to be installed within the contiguous United States.
- EPA vendor data does not reflect additional expenses of installing large scale equipment in Alaska including the costs of modularization of the turbines and the unique installation method on the North Slope (i.e., sea lifts to the facility locations);
- The study does not appear to leverage any other data or information that is specific to installations in the Alaska.

The cost effectiveness calculations and supporting data are attached to this response. The key assumptions used to prepare the calculations are summarized below.

| | | |
|---|--|------------------------|
|  | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Page 3 of 21 |


GTP ASSUMPTIONS:

The key facility-specific cost factors which differ from the typical EPA factors described in the 6th edition cost effectiveness calculation method for GTP include:

| Cost Category | GTP | Comments Regarding AGDC Approach |
|---|-------|---|
| Direct Capital Costs | | |
| Purchased Equipment Costs | --- | AeriNOx Quote (1/7/2020) |
| Ammonia System | 0% | Included in Purchased Equipment Costs |
| Instrumentation & Controls | 0% | Included in Purchased Equipment Costs |
| Freight | 10.7% | Updated based on ratios from the GTP estimated freight costs provided in Appendix C. |
| Taxes (Enter sales tax rate in "% Applied") | 0% | No sales tax in Alaska. |
| Direct Installation Costs: | | |
| Foundation & Supports | 8.8% | 50% of North Slope module pile foundations and supporting structural steel installation cost ratio Supporting information is provided in Appendix C. |
| Erection and Handling | 31% | Includes 30% of the Structural Steel portion of the installation cost ratio and 1% of the mechanical portion. . See Appendix C. |
| Electrical | 3.8% | 50% of Electrical portion of the installation cost ratio, includes instrumentation |
| Piping | 5.2% | 10% of Piping portion of the installation cost ratio |
| Insulation | 6.8% | 30% Insulation portion of the installation cost ratio |
| Indirect Costs: | | |
| Engineering & Supervision | 16% | Site engineering and construction management plus North Slope engineering and construction management. |
| Construction and Field Expenses | 0% | Did not include. |
| Contractor Fees | 0% | Did not include. |
| Startup-up | 0% | Did not include. |
| Performance Testing | 0% | Did not include. |

Other facility-specific costs included in the cost effectiveness evaluation for GTP:

| Data Element | 6 th Edition Values Applied | Sources for Value |
|---------------------------|--|--|
| Purchased Equipment Costs | \$4,100,000 | January 2020 Quote - Power Generation Units |
| | \$3,500,000 | January 2020 Quote - CO2 Compression Units |
| | \$4,100,000 | January 2020 Quote – Treated Gas Compression Units |
| Site Preparation | \$45,000 | January 2020 Quote |

| | | |
|---|--|------------------------|
|  | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Page 4 of 21 |

| Data Element | 6 th Edition Values Applied | Sources for Value |
|--------------------------------------|--|--|
| Construction and Field Expenses | \$120,000 | January 2020 Quote – Construction Supervision |
| Reagent Cost (\$/gallon) | \$5.67/gallon | Ammonia cost per Brenntag quote (June 15, 2015). See Appendix C. |
| Electricity Cost (\$/kWh) | 0.16 | Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska in 2017: https://www.eia.gov/electricity/data.php#sales |
| Higher Heating Value (HHV) (Btu/scf) | 1077 | HHV per GTP Fuel Gas specifications. |


LNG ASSUMPTIONS:

The LNG facility-specific cost factors that were applied generally fall within the typical EPA factors described in the 6th edition cost effectiveness calculation method. Cost factors specifically applied for LNG cost estimates are summarized below:

| Cost Category | LNG | Comments Regarding AGDC Approach |
|---|------|---------------------------------------|
| Purchased Equipment: | | |
| Purchased Equipment Costs | --- | AeriNOx Quote (1/7/2020) |
| Ammonia System | 0% | Included in Purchased Equipment Costs |
| Instrumentation & Controls | 0% | Included in Purchased Equipment Costs |
| Taxes (Enter sales tax rate in "% Applied") | 0.0% | No sales tax in Alaska |

Other facility-specific costs included in the cost effectiveness evaluation for LNG:

| Data Element | 6 th Edition Values Applied | Sources for Value |
|--------------------------------------|--|--|
| Purchased Equipment Costs | \$7,800,000 | January 2020 Quote - Compression Units |
| | \$4,100,000 | January 2020 Quote - Power Generation Units |
| Site Preparation | \$45,000 | January 2020 Quote |
| Construction and Field Expenses | \$120,000 | January 2020 Quote – Construction Supervision |
| Reagent Cost (\$/gallon) | \$2.24/gallon | Ammonia cost based on \$0.30/pound (Weekly Fertilizer Review, 4/2015) |
| Electricity Cost (\$/kWh) | 0.16 | Updated electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska in 2017: https://www.eia.gov/electricity/data.php#sales |
| Higher Heating Value (HHV) (Btu/scf) | 1087 | HHV per LNG Fuel Gas specifications. |

| | | |
|---|--|------------------------|
|  | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Page 5 of 21 |

APPENDICES:

Appendix A – 6th Edition Cost Effectiveness Calculations – Facility Specific Cost Factor Analysis:

- Appendix A.1 – GTP Power Generation Turbines
- Appendix A.2 – GTP CO2 Compressor Turbines
- Appendix A.3 – GTP Treated Gas Compressor Turbines
- Appendix A.4 – LNG Power Generation Turbines
- Appendix A.5 – LNG Compressor Turbines

Appendix B – 7th Edition Cost Effectiveness Calculations – EPA Default Analysis:

- Appendix B.1 – GTP Power Generation Turbines
- Appendix B.2 – GTP CO2 Compressor Turbines
- Appendix B.3 – GTP Treated Gas Compressor Turbines
- Appendix B.4 – LNG Power Generation Turbines
- Appendix B.5 – LNG Compressor Turbines

Appendix C – Supporting Information:

- Appendix C.1 – AeriNOx SCR quote (January 2020)
- Appendix C.2 – Brentag ammonia cost quote (2015)
- Appendix C.3 – GTP Cost Estimate Basis for SCR Cost Evaluation (Confidential)

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix A |

**APPENDIX A - 6TH EDITION COST EFFECTIVENESS CALCULATIONS – FACILITY
SPECIFIC COST FACTOR ANALYSIS**

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix A.1 |

APPENDIX A.1

GTP Power Generation Turbines

GTP BACT ANALYSIS
6th Edition EPA Cost Control Manual

Alaska LNG Project
 Natural Gas Turbines
 Power Gen SCR Cost Effectiveness Analysis

Cost Quantification:

| Cost Category | Project Cost | Default Estimate | Default % Applied | EPA Equation / Estimate Basis | Reference |
|---|--------------------|------------------|-------------------|--------------------------------------|---|
| Direct Capital Costs | | | | | |
| Purchased Equipment: | | | | | |
| Purchased Equipment Costs | \$4,100,000 | | - | A | AeriNOx Quote (1/7/2020) |
| Ammonia System | \$0 | | - | B | Included in Purchased Equipment Costs |
| Instrumentation & Controls | | \$0 | 0% | C = 0.00 x A | Included in Purchased Equipment Costs |
| Freight | | \$438,700 | 10.7% | D = 0.11 x (A+B) | Cost factor based on ratios from the GTP estimate equipment to freight costs |
| Taxes (Enter sales tax rate in "% Applied") | | \$0 | 0.0% | TaxRate x (A+B+C) | No sales tax in Alaska |
| Total Purchased Equipment Cost (PE) | \$4,538,700 | | - | PE | |
| Direct Installation Costs: | | | | | |
| Foundation & Supports | | \$399,406 | 9% | 0.09 x PE | 50% of North Slope module pile foundations and supporting structural steel installation cost ratio |
| Erection and Handling | | \$1,393,381 | 31% | 0.31 x PE | Includes 30% of the Structural Steel portion of the installation cost ratio and 1% of the mechanical portion. |
| Electrical | | \$170,877 | 4% | 0.04 x PE | 50% of Electrical portion of the installation cost ratio, includes instrumentation |
| Piping | | \$235,009 | 5% | 0.05 x PE | 10% of Piping portion of the installation cost ratio |
| Insulation | | \$309,067 | 7% | 0.07 x PE | 30% Insulation portion of the installation cost ratio |
| Painting | | \$0 | 0% | 0.00 x PE | Part of Foundation and Supports |
| Site Preparation | \$45,000 | | - | Project-Specific | AeriNOx Quote (1/7/2020) |
| Total Direct Installation Cost (DI) | \$2,552,740 | | - | DI | |
| Total Direct Capital Costs (DC) | \$7,091,440 | | - | DC = PE + DI | |
| Indirect Capital Costs | | | | | |
| Indirect Costs: | | | | | |
| Engineering & Supervision | | \$726,192 | 16% | 0.16 x PE | Site engineering and construction management plus North Slope engineering and construction management. |
| Construction and Field Expenses | | \$120,000 | | | AeriNOx Quote (1/7/2020) |
| Contractor Fees | | \$0 | 0% | 0.00 x PE | Did not include. |
| Startup-up | | \$0 | 0% | 0.00 x PE | Did not include. |
| Performance Testing | | \$0 | 0% | 0.00 x PE | Did not include. |
| Total Indirect Costs (TIC) | \$846,192 | | - | IC | |
| Capital Investment: | | | | | |
| Project Contingency | | \$1,190,644.78 | 15% | E = 0.15 x (DC+IC) | OAQPS (15% of DC & TIC) |
| Preproduction Cost | | \$273,848.30 | 3% | F = 0.03 x (DC+IC+Cont) | OAQPS (2% of DC & TIC & Proj Contingency) |
| Inventory Capital (initial reagent fill) | | \$10,031 | - | G = [Storage Gal] x [Reagent \$/gal] | See parameters below |
| Total Capital Investment | \$9,412,156 | | - | TCI = DC + IC + E + F + G | |

GTP BACT ANALYSIS
6th Edition EPA Cost Control Manual

Alaska LNG Project
 Natural Gas Turbines
 Power Gen SCR Cost Effectiveness Analysis

| Direct Annual Costs | | | | | |
|----------------------------------|--|------------------|------|----------------------|---|
| Direct Annual Costs: | | | | | |
| Operating Labor | | | - | | EPA assumes equipment is managed by existing staff. |
| Supervisory Labor | | \$0 | 15% | 15% of Op. Labor | OAQPS (15% of Op Labor) |
| Maintenance Labor | | \$141,182 | 1.5% | 0.015 x TCI | OAQPS (1.5% of TCI) |
| Maintenance Materials | | \$141,182 | - | 100% of Maint. Labor | OAQPS (15% of Maint. Labor) |
| Annual Reagent Cost | | \$261,522 | - | q*Cost*[op hr/yr] | See parameters below |
| Annual Electricity Cost | | \$152,882 | - | See parameters below | See parameters below |
| Catalyst Replacement | | \$76,236 | - | See parameters below | See parameters below |
| Catalyst Disposal Cost | | \$7,624 | 10% | 0.100 x Cat Repl | Engineering Estimate |
| Fuel Penalty Costs (specify) | | | - | | Vendor Supplied |
| Other Maintenance Cost (specify) | | | - | | Vendor Supplied |
| Total Direct Annual Costs | | \$780,628 | | DAC | |

| Indirect Annual Costs | | | | | |
|------------------------------------|--|------------------|-------|-------------------------------------|---|
| Indirect Annual Costs: | | | | | |
| Overhead | | \$169,419 | 60.0% | 0.600 x Op/Super/Maint Labor & Mtls | OAQPS (60% of Op/Super/Maint. Labor & Mtls) |
| Property Tax | | \$94,122 | 1.0% | 0.0100 x TCI | OAQPS (1%) |
| Insurance | | \$94,122 | 1.0% | 0.010 x TCI | OAQPS (1%) |
| General Administrative | | \$188,243 | 2.0% | 0.020 x TCI | OAQPS (2%) |
| Total Indirect Annual Costs | | \$545,905 | | DAC | |

| Capital Recovery Cost | | | | | |
|------------------------------------|--------|------------------|---|------------------------------|--|
| Equipment Life (years) | | 20 | - | n | EPA Default |
| Interest Rate | 7.00% | 7.00% | - | i | 7% per Agrium US Inc, Kenai Nitrogen Operations Facility Air Quality Control Construction Permit AQ0083CPT06 |
| Capital Recovery Factor | 0.0944 | | - | CRF = $i / (1 - (1+i)^{-n})$ | - |
| Capital Recovery Cost (CRC) | | \$888,441 | | | OAQPS Eqn 2.54 (Section 4.2, Ch. 2) |

| | | | | | |
|---------------------------|--|--------------------|--|------------------------------|-------------------------------------|
| Total Annual Costs | | \$2,214,974 | | TAC = DA + IDAC + CRC | OAQPS Eqn 2.56 (Section 4.2, Ch. 2) |
|---------------------------|--|--------------------|--|------------------------------|-------------------------------------|

Cost Effectiveness Analysis:

| | |
|--------------------------------|--------|
| Uncontrolled NOx (tpy) | 100.61 |
| Controlled NOx Emissions (tpy) | 13.41 |
| NOx Reduction (tpy) | 87.20 |

| | |
|---------------------------------------|-----------------|
| Total Annual Costs | \$2,214,974 |
| Cost Effectiveness (\$/ton/yr) | \$25,402 |

Reference

| |
|------------------|
| Calculated below |
| Calculated below |
| Calculated below |

| |
|-------------------------------------|
| Calculated above |
| OAQPS Eqn 2.58 (Section 4.2, Ch. 2) |

GTP BACT ANALYSIS 6th Edition EPA Cost Control Manual

Alaska LNG Project
Natural Gas Turbines
Power Gen SCR Cost Effectiveness Analysis

Design Parameters:

Enter values in boxes below. Where default value is available, entered value will override default.
Required data is highlighted yellow.

Combustion Unit Sizing

| | | | |
|---|--------|----------|------------------|
| | | | Reference |
| Turbine heat capacity: | 418.00 | MMBtu/hr | |
| Duct burner heat capacity, if applicable: | | MMBtu/hr | |

NOx Emission Rates

| | | | |
|---|----|---------------|--|
| | | | Reference |
| Turbine uncontrolled NOx concentration: | | lb NOx/MMBtu | |
| | | lb NOx/MMscf | |
| | 15 | ppmv @ 15% O2 | Assumption for baseline/uncontrolled emissions |
| or (default) | | ppmv @ 15% O2 | |
| Duct burner uncontrolled NOx concentration: | | lb NOx/MMBtu | |
| | | lb NOx/MMscf | |
| | | ppmv @ 3% O2 | |
| or (default) | | ppmv @ 3% O2 | |
| Controlled NOx concentration: | | lb NOx/MMBtu | |
| | | lb NOx/MMscf | |
| | 2 | ppmv @ 15% O2 | EPA specified BACT limit. |

Natural Gas Properties

| | | | |
|---|------|------------|--|
| | | | Reference |
| HHV [Default: 1050 Btu/scf] | 1077 | Btu/scf | GTP Fuel Gas Specification |
| F-factor (dry) [Default: 8710 dscf/MMBtu] | | dscf/MMBtu | EPA 40 CFR Part 60 Appendix A, Method 19, Table 19-2 |

Operational Parameters

| | | | |
|---|------|-------|------------------|
| | | | Reference |
| Max annual op hours [Default: 8760 hr/yr] | 8760 | hr/yr | |

Annual Electricity Costs: Enter values below. Where default value is available, entered number overrides default.

| | | | |
|--|-------|--------|---|
| | | | Reference |
| Power demand: | | kW | Calculated below |
| If power demand is not known, estimate on the basis of the parameters below: | | | |
| delta P duct [Default: 3 in H2O] | | | OAQPS Eqn 2.48 (Section 4.2, Ch. 2) |
| delta P catalyst (per layer) [Default: 1 in H2O] | | | OAQPS Eqn 2.48 (Section 4.2, Ch. 2) |
| number of layers of catalyst | 2 | | |
| Calculated Power demand: | 111.8 | kW | OAQPS Eqn 2.48 (Section 4.2, Ch. 2) |
| Electricity Cost [Default: 0.1572 \$/kWh] | 0.16 | \$/kWh | Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska in 2017. |

Aqueous Ammonia Costs: Enter values below or parameters to estimate.

| | | | |
|---------------------------------|--------|-------------|--|
| | | | Reference |
| Aqueous ammonia cost: | \$5.67 | \$/gallon | Ammonia cost per Brenntag quote (June 15, 2015). |
| Aqueous ammonia storage volume: | | gallons | |
| | or 14 | days' worth | Engineering Estimate |

GTP BACT ANALYSIS
6th Edition EPA Cost Control Manual

Alaska LNG Project
 Natural Gas Turbines
 Power Gen SCR Cost Effectiveness Analysis

| | | |
|---|-------|--------|
| Aqueous ammonia consumption rate: | | gal/hr |
| If aqueous ammonia consumption rate not known, estimate on the basis of the parameters below: | | |
| Stored NH3 concentration [Default: 19.4%] | | wt% |
| NH3 solution mass flow rate (m _{sol}) | 40.97 | lb/hr |
| NH3 solution density [Default: 7.782 lb/gal] | 7.782 | lb/gal |
| Calculated Aqueous ammonia consumption rate: | 5.3 | gal/hr |

| |
|--|
| |
| |
| OAQPS (Section 4.2, Ch. 2) |
| Engineering Data |
| OAQPS Eqn 2.32-2.34 (Section 4.2, Ch. 2) |

Catalyst Costs:

| | | |
|----------------------------------|-----------|-------|
| Initial catalyst cost: | \$245,091 | |
| Catalyst replacement frequency: | 3 | years |
| Interest Rate | 7.00% | % |
| Annual Catalyst Replacement Cost | \$76,236 | |

| | |
|-------------------------------------|--|
| Reference | |
| OAQPS (Section 4.2, Ch. 2) | |
| | |
| ADEC Default | |
| OAQPS Eqn 2.51 (Section 4.2, Ch. 2) | |

* OAQPS refers to the EPA Air Pollution Control Cost Manual, Sixth Edition and subsequent revisions.

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix A.2 |

APPENDIX A.2

GTP CO₂ Compressor Turbines

GTP BACT ANALYSIS
6th Edition EPA Cost Control Manual

Alaska LNG Project
 Natural Gas Turbines
 CO₂ Compression SCR Cost Effectiveness Analysis

Cost Quantification:

| Cost Category | Project Cost | Default Estimate | Default % Applied | EPA Equation / Estimate Basis | Reference |
|---|--------------------|------------------|-------------------|--------------------------------------|---|
| Direct Capital Costs | | | | | |
| Purchased Equipment: | | | | | |
| Purchased Equipment Costs | \$3,500,000 | | - | A | AeriNOx Quote (1/7/2020) |
| Ammonia System | \$0 | | - | B | Included in Purchased Equipment Costs |
| Instrumentation & Controls | | \$0 | 0% | C = 0.00 x A | Included in Purchased Equipment Costs |
| Freight | | \$374,500 | 10.7% | D = 0.11 x (A+B) | Cost factor based on ratios from the GTP estimate equipment to freight costs |
| Taxes (Enter sales tax rate in "% Applied") | | \$0 | 0.0% | TaxRate x (A+B+C) | No sales tax in Alaska |
| Total Purchased Equipment Cost (PE) | \$3,874,500 | | - | PE | |
| Direct Installation Costs: | | | | | |
| Foundation & Supports | | \$340,956 | 9% | 0.09 x PE | 50% of North Slope module pile foundations and supporting structural steel installation cost ratio |
| Erection and Handling | | \$1,189,472 | 31% | 0.31 x PE | Includes 30% of the Structural Steel portion of the installation cost ratio and 1% of the mechanical portion. |
| Electrical | | \$145,871 | 4% | 0.04 x PE | 50% of Electrical portion of the installation cost ratio, includes instrumentation |
| Piping | | \$200,617 | 5% | 0.05 x PE | 10% of Piping portion of the installation cost ratio |
| Insulation | | \$263,838 | 7% | 0.07 x PE | 30% Insulation portion of the installation cost ratio |
| Painting | | \$0 | 0% | 0.00 x PE | Part of Foundation and Supports |
| Site Preparation | \$45,000 | | - | Project-Specific | AeriNOx Quote (1/7/2020) |
| Total Direct Installation Cost (DI) | \$2,185,754 | | - | DI | |
| Total Direct Capital Costs (DC) | \$6,060,254 | | - | DC = PE + DI | |
| Indirect Capital Costs | | | | | |
| Indirect Costs: | | | | | |
| Engineering & Supervision | | \$619,920 | 16% | 0.16 x PE | Site engineering and construction management plus North Slope engineering and construction management. |
| Construction and Field Expenses | | \$120,000 | | | AeriNOx Quote (1/7/2020) |
| Contractor Fees | | \$0 | 0% | 0.00 x PE | Did not include. |
| Startup-up | | \$0 | 0% | 0.00 x PE | Did not include. |
| Performance Testing | | \$0 | 0% | 0.00 x PE | Did not include. |
| Total Indirect Costs (TIC) | \$739,920 | | - | IC | |
| Capital Investment: | | | | | |
| Project Contingency | | \$1,020,026.03 | 15% | E = 0.15 x (DC+IC) | OAQPS (15% of DC & TIC) |
| Preproduction Cost | | \$234,605.99 | 3% | F = 0.03 x (DC+IC+Cont) | OAQPS (2% of DC & TIC & Proj Contingency) |
| Inventory Capital (initial reagent fill) | | \$12,327 | - | G = [Storage Gal] x [Reagent \$/gal] | See parameters below |
| Total Capital Investment | \$8,067,132 | | - | TCI = DC + IC + E + F + G | |

GTP BACT ANALYSIS
6th Edition EPA Cost Control Manual

Alaska LNG Project
Natural Gas Turbines
CO₂ Compression SCR Cost Effectiveness Analysis

| Direct Annual Costs | | | | | |
|----------------------------------|--|------------------|------|----------------------|---|
| Direct Annual Costs: | | | | | |
| Operating Labor | | | - | | EPA Assumes equipment is managed by existing staff. |
| Supervisory Labor | | \$0 | 15% | 15% of Op. Labor | OAQPS (15% of Op Labor) |
| Maintenance Labor | | \$121,007 | 1.5% | 0.015 x TCI | OAQPS (1.5% of TCI) |
| Maintenance Materials | | \$121,007 | - | 100% of Maint. Labor | OAQPS (15% of Maint. Labor) |
| Annual Reagent Cost | | \$321,376 | - | q*Cost*[op hr/yr] | See parameters below |
| Annual Electricity Cost | | \$158,395 | - | See parameters below | See parameters below |
| Catalyst Replacement | | \$93,268 | - | See parameters below | See parameters below |
| Catalyst Disposal Cost | | \$9,327 | 10% | 0.100 x Cat Repl | Engineering Estimate |
| Fuel Penalty Costs (specify) | | | - | | Vendor Supplied |
| Other Maintenance Cost (specify) | | | - | | Vendor Supplied |
| Total Direct Annual Costs | | \$824,380 | | DAC | |

| Indirect Annual Costs | | | | | |
|------------------------------------|--|------------------|-------|-------------------------------------|---|
| Indirect Annual Costs: | | | | | |
| Overhead | | \$145,208 | 60.0% | 0.600 x Op/Super/Maint Labor & Mtls | OAQPS (60% of Op/Super/Maint. Labor & Mtls) |
| Property Tax | | \$80,671 | 1.0% | 0.0100 x TCI | OAQPS (1%) |
| Insurance | | \$80,671 | 1.0% | 0.010 x TCI | OAQPS (1%) |
| General Administrative | | \$161,343 | 2.0% | 0.020 x TCI | OAQPS (2%) |
| Total Indirect Annual Costs | | \$467,894 | | DAC | |

| Capital Recovery Cost | | | | | |
|------------------------------------|--------|--------------------|---|------------------------------|--|
| Equipment Life (years) | | 20 | - | n | EPA Default |
| Interest Rate | 7.00% | 7.00% | - | i | 7% per Agrium US Inc, Kenai Nitrogen Operations Facility Air Quality Control Construction Permit AQ0083CPT06 |
| Capital Recovery Factor | 0.0944 | | - | CRF = $i / (1 - (1+i)^{-n})$ | - |
| Capital Recovery Cost (CRC) | | \$761,480 | | | OAQPS Eqn 2.54 (Section 4.2, Ch. 2) |
| Total Annual Costs | | \$2,053,754 | | TAC = DA + IDAC + CRC | OAQPS Eqn 2.56 (Section 4.2, Ch. 2) |

Cost Effectiveness Analysis:

| | |
|---------------------------------------|--------------------|
| Uncontrolled NOx (tpy) | 141.86 |
| Controlled NOx Emissions (tpy) | 16.12 |
| NOx Reduction (tpy) | 125.74 |
| Total Annual Costs | \$2,053,754 |
| Cost Effectiveness (\$/ton/yr) | \$16,333 |

| Reference |
|-------------------------------------|
| Calculated below |
| Calculated below |
| Calculated below |
| Calculated above |
| OAQPS Eqn 2.58 (Section 4.2, Ch. 2) |

GTP BACT ANALYSIS

6th Edition EPA Cost Control Manual

Alaska LNG Project
Natural Gas Turbines
CO₂ Compression SCR Cost Effectiveness Analysis

Design Parameters:

Enter values in boxes below. Where default value is available, entered value will override default.
Required data is highlighted yellow.

Combustion Unit Sizing

Turbine heat capacity: MMBtu/hr
Duct burner heat capacity, if applicable: MMBtu/hr

Reference

NOx Emission Rates

Turbine uncontrolled NOx concentration:
or
or ppmv @ 15% O₂
or (default) ppmv @ 15% O₂

Reference

Duct burner uncontrolled NOx concentration:
or
or
or (default) ppmv @ 3% O₂

Controlled NOx concentration:
or
or ppmv @ 15% O₂

Assumption for baseline/uncontrolled emissions

EPA specified BACT limit.

Natural Gas Properties

HHV [Default: 1050 Btu/scf] Btu/scf
F-factor (dry) [Default: 8710 dscf/MMBtu] dscf/MMBtu

Reference

GTP Fuel Gas Specification
EPA 40 CFR Part 60 Appendix A, Method 19, Table 19-2

Operational Parameters

Max annual op hours [Default: 8760 hr/yr] hr/yr

Reference

Annual Electricity Costs: Enter values below. Where default value is available, entered number overrides default.

Power demand: kW
If power demand is not known, estimate on the basis of the parameters below:
delta P duct [Default: 3 in H₂O]
delta P catalyst (per layer) [Default: 1 in H₂O]
number of layers of catalyst
Calculated Power demand: kW

Reference

Calculated below

OAQPS Eqn 2.48 (Section 4.2, Ch. 2)

OAQPS Eqn 2.48 (Section 4.2, Ch. 2)

OAQPS Eqn 2.48 (Section 4.2, Ch. 2)

Electricity Cost [Default: 0.1572 \$/kWh] \$/kWh

Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska in 2017.

Aqueous Ammonia Costs: Enter values below or parameters to estimate.

Aqueous ammonia cost: \$/gallon
Aqueous ammonia storage volume:
or days' worth

Reference

Ammonia cost per Brenntag quote (June 15, 2015).

Engineering Estimate

GTP BACT ANALYSIS
6th Edition EPA Cost Control Manual

Alaska LNG Project
 Natural Gas Turbines
 CO₂ Compression SCR Cost Effectiveness Analysis

| | | |
|---|----------------------|--------|
| Aqueous ammonia consumption rate: | <input type="text"/> | gal/hr |
| If aqueous ammonia consumption rate not known, estimate on the basis of the parameters below: | | |
| Stored NH3 concentration [Default: 19.4%] | <input type="text"/> | wt% |
| NH3 solution mass flow rate (m _{sol}) | 50.35 | lb/hr |
| NH3 solution density [Default: 7.782 lb/gal] | 7.782 | lb/gal |
| Calculated Aqueous ammonia consumption rate: | 6.5 | gal/hr |

| |
|--|
| Calculated below |
| |
| OAQPS (Section 4.2, Ch. 2) |
| Engineering Data |
| OAQPS Eqn 2.32-2.34 (Section 4.2, Ch. 2) |

Catalyst Costs:

| | | |
|----------------------------------|-----------|-------|
| Initial catalyst cost: | \$299,848 | |
| Catalyst replacement frequency: | 3 | years |
| Interest Rate | 7.00% | % |
| Annual Catalyst Replacement Cost | \$93,268 | |

| Reference |
|-------------------------------------|
| OAQPS (Section 4.2, Ch. 2) |
| Vendor Supplied |
| ADEC Default |
| OAQPS Eqn 2.51 (Section 4.2, Ch. 2) |

* OAQPS refers to the EPA Air Pollution Control Cost Manual, Sixth Edition and subsequent revisions.

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix A.3 |

APPENDIX A.3

GTP Treated Gas Compressor Turbines

GTP BACT ANALYSIS
6th Edition EPA Cost Control Manual

Alaska LNG Project
 Natural Gas Turbines
 TG Compression SCR Cost Effectiveness Analysis

Cost Quantification:

| Cost Category | Project Cost | Default Estimate | Default % Applied | EPA Equation / Estimate Basis | Reference |
|---|--------------------|------------------|-------------------|---|---|
| Direct Capital Costs | | | | | |
| Purchased Equipment: | | | | | |
| Purchased Equipment Costs | \$4,100,000 | | - | A | AeriNOx Quote (1/7/2020) |
| Ammonia System | \$0 | | - | B | Included in Purchased Equipment Costs |
| Instrumentation & Controls | | \$0 | 0% | $C = 0.00 \times A$ | Included in Purchased Equipment Costs |
| Freight | | \$438,700 | 10.7% | $D = 0.11 \times (A+B)$ | Cost factor based on ratios from the GTP estimate equipment to freight costs |
| Taxes (Enter sales tax rate in "% Applied") | | \$0 | 0.0% | $\text{TaxRate} \times (A+B+C)$ | No sales tax in Alaska |
| Total Purchased Equipment Cost (PE) | \$4,538,700 | | - | PE | |
| Direct Installation Costs: | | | | | |
| Foundation & Supports | | \$399,406 | 9% | $0.09 \times \text{PE}$ | 50% of North Slope module pile foundations and supporting structural steel installation cost ratio |
| Erection and Handling | | \$1,393,381 | 31% | $0.31 \times \text{PE}$ | Includes 30% of the Structural Steel portion of the installation cost ratio and 1% of the mechanical portion. |
| Electrical | | \$170,877 | 3.8% | $0.04 \times \text{PE}$ | 50% of Electrical portion of the installation cost ratio, includes instrumentation |
| Piping | | \$235,009 | 5.2% | $0.05 \times \text{PE}$ | 10% of Piping portion of the installation cost ratio |
| Insulation | | \$309,067 | 6.8% | $0.07 \times \text{PE}$ | 30% Insulation portion of the installation cost ratio |
| Painting | | \$0 | 0% | $0.00 \times \text{PE}$ | Part of Foundation and Supports |
| Site Preparation | \$45,000 | | - | Project-Specific | AeriNOx Quote (1/7/2020) |
| Total Direct Installation Cost (DI) | \$2,552,740 | | - | DI | |
| Total Direct Capital Costs (DC) | \$7,091,440 | | - | $\text{DC} = \text{PE} + \text{DI}$ | |
| Indirect Capital Costs | | | | | |
| Indirect Costs: | | | | | |
| Engineering & Supervision | | \$726,192 | 16% | $0.16 \times \text{PE}$ | Site engineering and construction management plus North Slope engineering and construction management. |
| Construction and Field Expenses | | \$120,000 | | | AeriNOx Quote (1/7/2020) |
| Contractor Fees | | \$0 | 0% | $0.00 \times \text{PE}$ | Did not include. |
| Startup-up | | \$0 | 0% | $0.00 \times \text{PE}$ | Did not include. |
| Performance Testing | | \$0 | 0% | $0.00 \times \text{PE}$ | Did not include. |
| Total Indirect Costs (TIC) | \$846,192 | | - | IC | |
| Capital Investment: | | | | | |
| Project Contingency | | \$1,190,644.78 | 15% | $E = 0.15 \times (\text{DC} + \text{IC})$ | OAQPS (15% of DC & TIC) |
| Preproduction Cost | | \$273,848.30 | 3% | $F = 0.03 \times (\text{DC} + \text{IC} + \text{Cont})$ | OAQPS (2% of DC & TIC & Proj Contingency) |
| Inventory Capital (initial reagent fill) | | \$17,266 | - | $G = [\text{Storage Gal}] \times [\text{Reagent } \$/\text{gal}]$ | See parameters below |
| Total Capital Investment | \$9,419,391 | | - | $\text{TCI} = \text{DC} + \text{IC} + \text{E} + \text{F} + \text{G}$ | |

GTP BACT ANALYSIS
6th Edition EPA Cost Control Manual

Alaska LNG Project
Natural Gas Turbines
TG Compression SCR Cost Effectiveness Analysis

| Direct Annual Costs | | | | | |
|----------------------------------|--|--------------------|------|----------------------|---|
| Direct Annual Costs: | | | | | |
| Operating Labor | | | - | | EPA Assumes equipment is managed by existing staff. |
| Supervisory Labor | | \$0 | 15% | 15% of Op. Labor | OAQPS (15% of Op Labor) |
| Maintenance Labor | | \$141,291 | 1.5% | 0.015 x TCI | OAQPS (1.5% of TCI) |
| Maintenance Materials | | \$141,291 | - | 100% of Maint. Labor | OAQPS (15% of Maint. Labor) |
| Annual Reagent Cost | | \$450,161 | - | q*Cost*[op hr/yr] | See parameters below |
| Annual Electricity Cost | | \$212,891 | - | See parameters below | See parameters below |
| Catalyst Replacement | | \$130,613 | - | See parameters below | See parameters below |
| Catalyst Disposal Cost | | \$13,061 | 10% | 0.100 x Cat Repl | Engineering Estimate |
| Fuel Penalty Costs (specify) | | | - | | Vendor Supplied |
| Other Maintenance Cost (specify) | | | - | | Vendor Supplied |
| Total Direct Annual Costs | | \$1,089,309 | - | DAC | |

| Indirect Annual Costs | | | | | |
|------------------------------------|--|------------------|-------|-------------------------------------|---|
| Indirect Annual Costs: | | | | | |
| Overhead | | \$169,549 | 60.0% | 0.600 x Op/Super/Maint Labor & Mtls | OAQPS (60% of Op/Super/Maint. Labor & Mtls) |
| Property Tax | | \$94,194 | 1.0% | 0.0100 x TCI | OAQPS (1%) |
| Insurance | | \$94,194 | 1.0% | 0.010 x TCI | OAQPS (1%) |
| General Administrative | | \$188,388 | 2.0% | 0.020 x TCI | OAQPS (2%) |
| Total Indirect Annual Costs | | \$546,325 | - | DAC | |

| Capital Recovery Cost | | | | | |
|------------------------------------|--------|------------------|---|------------------------------|--|
| Equipment Life (years) | | 20 | - | n | EPA Default |
| Interest Rate | 7.00% | 7.00% | - | i | 7% per Agrium US Inc, Kenai Nitrogen Operations Facility Air Quality Control Construction Permit AQ0083CPT06 |
| Capital Recovery Factor | 0.0944 | | - | CRF = $i / (1 - (1+i)^{-n})$ | - |
| Capital Recovery Cost (CRC) | | \$889,124 | - | | OAQPS Eqn 2.54 (Section 4.2, Ch. 2) |

| | | | | | |
|---------------------------|--|--------------------|---|------------------------------|-------------------------------------|
| Total Annual Costs | | \$2,524,757 | - | TAC = DA + IDAC + CRC | OAQPS Eqn 2.56 (Section 4.2, Ch. 2) |
|---------------------------|--|--------------------|---|------------------------------|-------------------------------------|

Cost Effectiveness Analysis:

| | |
|--------------------------------|--------|
| Uncontrolled NOx (tpy) | 200.35 |
| Controlled NOx Emissions (tpy) | 22.55 |
| NOx Reduction (tpy) | 177.80 |

| | |
|---------------------------------------|-----------------|
| Total Annual Costs | \$2,524,757 |
| Cost Effectiveness (\$/ton/yr) | \$14,200 |

Reference

| |
|------------------|
| Calculated below |
| Calculated below |
| Calculated below |

| |
|-------------------------------------|
| Calculated above |
| OAQPS Eqn 2.58 (Section 4.2, Ch. 2) |

GTP BACT ANALYSIS 6th Edition EPA Cost Control Manual

Alaska LNG Project
Natural Gas Turbines
TG Compression SCR Cost Effectiveness Analysis

Design Parameters:

Enter values in boxes below. Where default value is available, entered value will override default.
Required data is highlighted yellow.

Combustion Unit Sizing

| | | Reference |
|---|---|-----------|
| Turbine heat capacity: | <input style="background-color: yellow;" type="text" value="418.00"/> | MMBtu/hr |
| Duct burner heat capacity, if applicable: | <input style="background-color: yellow;" type="text" value="284.64"/> | MMBtu/hr |

NOx Emission Rates

| | | Reference |
|---|--|---------------------------|
| Turbine uncontrolled NOx concentration: | <input type="text"/> | lb NOx/MMBtu |
| or | <input type="text"/> | lb NOx/MMscf |
| or | <input style="background-color: yellow;" type="text" value="15.00"/> | ppmv @ 15% O2 |
| or (default) | <input type="text"/> | ppmv @ 15% O2 |
| Duct burner uncontrolled NOx concentration: | <input style="background-color: yellow;" type="text" value="0.08"/> | lb NOx/MMBtu |
| or | <input type="text"/> | lb NOx/MMscf |
| or | <input type="text"/> | ppmv @ 3% O2 |
| or (default) | <input type="text"/> | ppmv @ 3% O2 |
| Controlled NOx concentration: | <input type="text"/> | lb NOx/MMBtu |
| or | <input type="text"/> | lb NOx/MMscf |
| or | <input style="background-color: yellow;" type="text" value="2"/> | ppmv @ 15% O2 |
| | | EPA specified BACT limit. |

Natural Gas Properties

| | | Reference |
|---|---|--|
| HHV [Default: 1050 Btu/scf] | <input style="background-color: yellow;" type="text" value="1077"/> | Btu/scf |
| F-factor (dry) [Default: 8710 dscf/MMBtu] | <input type="text"/> | dscf/MMBtu |
| | | GTP Fuel Gas Specification EPA 40 CFR Part 60 Appendix A, Method 19, Table 19-2 |

Operational Parameters

| | | Reference |
|---|---|-----------|
| Max annual op hours [Default: 8760 hr/yr] | <input style="background-color: yellow;" type="text" value="8760"/> | hr/yr |

Annual Electricity Costs: Enter values below. Where default value is available, entered number overrides default.

| | | Reference |
|--|--|---|
| Power demand: | <input type="text"/> | kW |
| If power demand is not known, estimate on the basis of the parameters below: | | Calculated below |
| delta P duct [Default: 3 in H2O] | <input type="text"/> | |
| delta P catalyst (per layer) [Default: 1 in H2O] | <input type="text"/> | |
| number of layers of catalyst | <input style="background-color: yellow;" type="text" value="4"/> | |
| Calculated Power demand: | <input style="background-color: yellow;" type="text" value="155.7"/> | kW |
| Electricity Cost [Default: 0.1572 \$/kWh] | <input style="background-color: yellow;" type="text" value="0.16"/> | \$/kWh |
| | | Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska in 2017. |

Aqueous Ammonia Costs: Enter values below or parameters to estimate.

| | | Reference |
|---------------------------------|---|--|
| Aqueous ammonia cost: | <input style="background-color: yellow;" type="text" value="\$5.67"/> | \$/gallon |
| Aqueous ammonia storage volume: | <input type="text"/> | gallons |
| or | <input style="background-color: yellow;" type="text" value="14"/> | days' worth |
| | | Ammonia cost per Brenntag quote (June 15, 2015). Engineering Estimate |

GTP BACT ANALYSIS
6th Edition EPA Cost Control Manual

Alaska LNG Project
 Natural Gas Turbines
 TG Compression SCR Cost Effectiveness Analysis

Aqueous ammonia consumption rate:

| |
|--|
| |
|--|

 gal/hr
 If aqueous ammonia consumption rate not known, estimate on the basis of the parameters below:
 Stored NH3 concentration [Default: 19.4%]

| |
|--|
| |
|--|

 wt%
 NH3 solution mass flow rate (m_{sol})

| |
|-------|
| 70.53 |
|-------|

 lb/hr
 NH3 solution density [Default: 7.782 lb/gal]

| |
|-------|
| 7.782 |
|-------|

 lb/gal
 Calculated Aqueous ammonia consumption rate:

| |
|-----|
| 9.1 |
|-----|

 gal/hr

| |
|--|
| |
| |
| OAQPS (Section 4.2, Ch. 2) |
| Engineering Data |
| OAQPS Eqn 2.32-2.34 (Section 4.2, Ch. 2) |

Catalyst Costs:

Initial catalyst cost:

| |
|-----------|
| \$419,909 |
|-----------|

 Catalyst replacement frequency:

| |
|---|
| 3 |
|---|

 years
 Interest Rate

| |
|-------|
| 7.00% |
|-------|

 %
 Annual Catalyst Replacement Cost

| |
|-----------|
| \$130,613 |
|-----------|

| Reference |
|-------------------------------------|
| OAQPS (Section 4.2, Ch. 2) |
| Vendor Supplied |
| ADEC Default |
| OAQPS Eqn 2.51 (Section 4.2, Ch. 2) |

* OAQPS refers to the EPA Air Pollution Control Cost Manual, Sixth Edition and subsequent revisions.

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix A.4 |

APPENDIX A.4

LNG Power Generation Turbines

LNG BACT ANALYSIS
6th Edition EPA Cost Control Manual
Alaska LNG Project
Power Generation Natural Gas Turbine
Power Gen SCR Cost Effectiveness Analysis

Cost Quantification:

| Cost Category | Project Cost | Default Estimate | Default % Applied | EPA Equation / Estimate Basis | Reference |
|---|---------------------|------------------|-------------------|--------------------------------------|---|
| Direct Capital Costs | | | | | |
| Purchased Equipment: | | | | | |
| Purchased Equipment Costs | \$4,100,000 | | - | A | AeriNOx Quote (1/7/2020) |
| Ammonia System | \$0 | | - | B | Included in Purchased Equipment Costs |
| Instrumentation & Controls | | \$0 | 0% | C = 0.00 x A | Included in Purchased Equipment Costs |
| Freight | | \$205,000 | 5% | D = 0.05 x (A+B) | OAQPS (5% of PE) |
| Taxes (Enter sales tax rate in "% Applied") | | \$0 | 0.0% | TaxRate x (A+B+C) | No sales tax in Alaska |
| Total Purchased Equipment Cost (PE) | \$4,305,000 | | - | PE | |
| Direct Installation Costs: | | | | | |
| Foundation & Supports | | \$430,500 | 10% | 0.10 x PE | OAQPS (4-12% of PE) |
| Erection and Handling | | \$1,506,750 | 35% | 0.35 x PE | OAQPS (14-50% of PE) |
| Electrical | | \$258,300 | 6% | 0.06 x PE | OAQPS (1-8% of PE) |
| Piping | | \$344,400 | 8% | 0.08 x PE | OAQPS (1-30% of PE) |
| Insulation | | \$86,100 | 2% | 0.02 x PE | OAQPS (1-7% of PE) |
| Painting | | \$172,200 | 4% | 0.04 x PE | OAQPS (1-4% of PE) |
| Site Preparation | \$45,000 | | - | Project-Specific | AeriNOx Quote (1/7/2020) |
| Total Direct Installation Cost (DI) | \$2,843,250 | | - | DI | |
| Total Direct Capital Costs (DC) | \$7,148,250 | | - | DC = PE + DI | |
| Indirect Capital Costs | | | | | |
| Indirect Costs: | | | | | |
| Engineering & Supervision | | \$645,750 | 15% | 0.15 x PE | OAQPS (10-20% of PE) |
| Construction and Field Expenses | | \$430,500 | 10% | 0.10 x PE | OAQPS (5-20% of PE) |
| Contractor Fees | | \$215,250 | 5% | 0.05 x PE | OAQPS (0-10% of PE) |
| Startup-up | | \$43,050 | 1% | 0.01 x PE | OAQPS (1-2% of PE) |
| Performance Testing | | \$43,050 | 1% | 0.01 x PE | OAQPS (1% of PE) |
| Total Indirect Costs (TIC) | \$1,377,600 | | - | IC | |
| Capital Investment: | | | | | |
| Project Contingency | | \$1,278,877.50 | 15% | E = 0.15 x (DC+IC) | OAQPS (15% of DC & TIC) |
| Preproduction Cost | | \$196,094.55 | 2% | F = 0.02 x (DC+IC+Cont) | OAQPS (2% of DC & TIC & Proj Contingency) |
| Inventory Capital (initial reagent fill) | | \$4,077 | - | G = [Storage Gal] x [Reagent \$/gal] | See parameters below |
| Total Capital Investment | \$10,004,899 | | - | TCI = DC + IC + E + F + G | |

LNG BACT ANALYSIS
6th Edition EPA Cost Control Manual
Alaska LNG Project
Power Generation Natural Gas Turbine
Power Gen SCR Cost Effectiveness Analysis

| Direct Annual Costs | | | | | |
|----------------------------------|--|------------------|------|----------------------|---|
| Direct Annual Costs: | | | | | |
| Operating Labor | | | - | | EPA Assumes equipment is managed by existing staff. |
| Supervisory Labor | | \$0 | 15% | 15% of Op. Labor | OAQPS (15% of Op Labor) |
| Maintenance Labor | | \$150,073 | 1.5% | 0.015 x TCI | OAQPS (1.5% of TCI) |
| Maintenance Materials | | \$150,073 | - | 100% of Maint. Labor | OAQPS (15% of Maint. Labor) |
| Annual Reagent Cost | | \$106,283 | - | q*Cost*[op hr/yr] | See parameters below |
| Annual Electricity Cost | | \$188,137 | - | See parameters below | See parameters below |
| Catalyst Replacement | | \$78,424 | - | See parameters below | See parameters below |
| Catalyst Disposal Cost | | \$7,842 | 10% | 0.100 x Cat Repl | Engineering Estimate |
| Fuel Penalty Costs (specify) | | | - | | |
| Other Maintenance Cost (specify) | | | - | | |
| Total Direct Annual Costs | | \$680,834 | - | DAC | |

| Indirect Annual Costs | | | | | |
|------------------------------------|--|------------------|-------|-------------------------------------|---|
| Indirect Annual Costs: | | | | | |
| Overhead | | \$180,088 | 60.0% | 0.600 x Op/Super/Maint Labor & Mtls | OAQPS (60% of Op/Super/Maint. Labor & Mtls) |
| Property Tax | | \$100,049 | 1.0% | 0.0100 x TCI | OAQPS (1%) |
| Insurance | | \$100,049 | 1.0% | 0.010 x TCI | OAQPS (1%) |
| General Administrative | | \$200,098 | 2.0% | 0.020 x TCI | OAQPS (2%) |
| Total Indirect Annual Costs | | \$580,284 | - | DAC | |

| Capital Recovery Cost | | | | | |
|------------------------------------|--------|------------------|---|------------------------------|---|
| Equipment Life (years) | | 20 | - | n | EPA Default |
| Interest Rate | 7.00% | 7.00% | - | i | 7% per Agrium US Inc, Kenai Nitrogen Operations Facility Air Quality Control Construction Permit AQ0083CPT06 |
| Capital Recovery Factor | 0.0944 | | - | CRF = $i / (1 - (1+i)^{-n})$ | - |
| Capital Recovery Cost (CRC) | | \$944,392 | - | | OAQPS Eqn 2.54 (Section 4.2, Ch. 2) |

| | | | | | |
|---------------------------|--|--------------------|---|------------------------------|-------------------------------------|
| Total Annual Costs | | \$2,205,510 | - | TAC = DA + IDAC + CRC | OAQPS Eqn 2.56 (Section 4.2, Ch. 2) |
|---------------------------|--|--------------------|---|------------------------------|-------------------------------------|

Cost Effectiveness Analysis:

| | | Reference |
|---------------------------------------|-----------------|-------------------------------------|
| Uncontrolled NOx (tpy) | 103.50 | Calculated below |
| Controlled NOx Emissions (tpy) | 13.80 | Calculated below |
| NOx Reduction (tpy) | 89.70 | Calculated below |
| | | |
| Total Annual Costs | \$2,205,510 | Calculated above |
| Cost Effectiveness (\$/ton/yr) | \$24,588 | OAQPS Eqn 2.58 (Section 4.2, Ch. 2) |

LNG BACT ANALYSIS
6th Edition EPA Cost Control Manual
Alaska LNG Project
Power Generation Natural Gas Turbine
Power Gen SCR Cost Effectiveness Analysis

Design Parameters:

Enter values in boxes below. Where default value is available, entered value will override default.
 Required data is highlighted yellow.

Combustion Unit Sizing

| | | Reference |
|---|--|-----------|
| Turbine heat capacity: | <input style="width: 80px;" type="text" value="430.00"/> | MMBtu/hr |
| Duct burner heat capacity, if applicable: | <input style="width: 80px;" type="text"/> | MMBtu/hr |

NOx Emission Rates

| | | Reference |
|---|--|--|
| Turbine uncontrolled NOx concentration: | <input style="width: 80px;" type="text"/> | lb NOx/MMBtu |
| or | <input style="width: 80px;" type="text"/> | lb NOx/MMscf |
| or | <input style="width: 80px;" type="text" value="15"/> | ppmv @ 15% O2 |
| or (default) | <input style="width: 80px;" type="text"/> | ppmv @ 15% O2 |
| | | Assumption for baseline/uncontrolled emissions |
| Duct burner uncontrolled NOx concentration: | <input style="width: 80px;" type="text"/> | lb NOx/MMBtu |
| or | <input style="width: 80px;" type="text"/> | lb NOx/MMscf |
| or | <input style="width: 80px;" type="text"/> | ppmv @ 3% O2 |
| or (default) | <input style="width: 80px;" type="text"/> | ppmv @ 3% O2 |
| Controlled NOx concentration: | <input style="width: 80px;" type="text"/> | lb NOx/MMBtu |
| or | <input style="width: 80px;" type="text"/> | lb NOx/MMscf |
| or | <input style="width: 80px;" type="text" value="2"/> | ppmv @ 15% O2 |
| | | Most stringent limit identified as BACT |

Natural Gas Properties

| | | Reference |
|---|--|--|
| HHV [Default: 1050 Btu/scf] | <input style="width: 80px;" type="text" value="1087"/> | Btu/scf |
| F-factor (dry) [Default: 8710 dscf/MMBtu] | <input style="width: 80px;" type="text"/> | dscf/MMBtu |
| | | LNG Fuel Gas Specification |
| | | EPA 40 CFR Part 60 Appendix A, Method 19, Table 19-2 |

Operational Parameters

| | | Reference |
|---|--|-----------|
| Max annual op hours [Default: 8760 hr/yr] | <input style="width: 80px;" type="text" value="8760"/> | hr/yr |
| | | |

Annual Electricity Costs: Enter values below. Where default value is available, entered number overrides default.

| | | Reference |
|--|---|-------------------------------------|
| Power demand: | <input style="width: 80px;" type="text"/> | kW |
| If power demand is not known, estimate on the basis of the parameters below: | | Calculated below |
| delta P duct [Default: 3 in H2O] | <input style="width: 80px;" type="text"/> | |
| delta P catalyst (per layer) [Default: 1 in H2O] | <input style="width: 80px;" type="text"/> | |
| number of layers of catalyst | <input style="width: 80px;" type="text" value="3"/> | |
| Calculated Power demand: | <input style="width: 80px;" type="text" value="137.6"/> | kW |
| | | OAQPS Eqn 2.48 (Section 4.2, Ch. 2) |
| | | OAQPS Eqn 2.48 (Section 4.2, Ch. 2) |
| | | OAQPS Eqn 2.48 (Section 4.2, Ch. 2) |

LNG BACT ANALYSIS
6th Edition EPA Cost Control Manual
Alaska LNG Project
Power Generation Natural Gas Turbine
Power Gen SCR Cost Effectiveness Analysis

Electricity Cost [Default: 0.1572 \$/kWh]

| |
|------|
| 0.16 |
|------|

\$/kWh

Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska in 2017.

Aqueous Ammonia Costs: Enter values below or parameters to estimate.

Aqueous ammonia cost:

| |
|--------|
| \$2.24 |
|--------|

\$/gallon

Aqueous ammonia storage volume:

| |
|--|
| |
|--|

gallons

or

| |
|----|
| 14 |
|----|

days' worth

Aqueous ammonia consumption rate:

| |
|--|
| |
|--|

gal/hr

If aqueous ammonia consumption rate not known, estimate on the basis of the parameters below:

Stored NH3 concentration [Default: 19.4%]

| |
|--|
| |
|--|

wt%

NH3 solution mass flow rate (m_{sol})

| |
|-------|
| 42.15 |
|-------|

lb/hr

NH3 solution density [Default: 7.782 lb/gal]

| |
|-------|
| 7.782 |
|-------|

lb/gal

Calculated Aqueous ammonia consumption rate:

| |
|-----|
| 5.4 |
|-----|

gal/hr

Reference

Ammonia cost based on \$0.30/pound (Weekly Fertilizer Review, 4/2015)

Engineering Estimate

OAQPS

Engineering Data
 OAQPS Eqn 2.32-2.34 (Section 4.2, Ch. 2)

Catalyst Costs:

Initial catalyst cost:

| |
|-----------|
| \$252,127 |
|-----------|

Catalyst replacement frequency:

| |
|---|
| 3 |
|---|

years

Interest Rate

| |
|-------|
| 7.00% |
|-------|

%

Annual Catalyst Replacement Cost

| |
|----------|
| \$78,424 |
|----------|

Reference

OAQPS (Section 4.2, Ch. 2)

ADEC Default

OAQPS Eqn 2.51 (Section 4.2, Ch. 2)

* OAQPS refers to the EPA Air Pollution Control Cost Manual, Sixth Edition and subsequent revisions.

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix A.5 |

APPENDIX A.5

LNG Compressor Turbines

LNG BACT ANALYSIS
6th Edition EPA Cost Control Manual
Alaska LNG Project
Compressor Driver Natural Gas Turbine
SCR Cost Effectiveness Analysis

Cost Quantification:

| Cost Category | Project Cost | Default Estimate | Default % Applied | EPA Equation / Estimate Basis | Reference |
|---|---------------------|------------------|-------------------|--------------------------------------|---|
| Direct Capital Costs | | | | | |
| Purchased Equipment: | | | | | |
| Purchased Equipment Costs | \$7,800,000 | | - | A | AeriNOx Quote (1/7/2020) |
| Ammonia System | \$0 | | - | B | Included in Purchased Equipment Costs |
| Instrumentation & Controls | | \$0 | 0% | C = 0.00 x A | Included in Purchased Equipment Costs |
| Freight | | \$390,000 | 5% | D = 0.05 x (A+B) | OAQPS (5% of PE) |
| Taxes (Enter sales tax rate in "% Applied") | | \$0 | 0.0% | TaxRate x (A+B+C) | No sales tax in Alaska |
| Total Purchased Equipment Cost (PE) | \$8,190,000 | | - | PE | |
| Direct Installation Costs: | | | | | |
| Foundation & Supports | | \$819,000 | 10% | 0.10 x PE | OAQPS (4-12% of PE) |
| Erection and Handling | | \$2,866,500 | 35% | 0.35 x PE | OAQPS (14-50% of PE) |
| Electrical | | \$491,400 | 6% | 0.06 x PE | OAQPS (1-8% of PE) |
| Piping | | \$655,200 | 8% | 0.08 x PE | OAQPS (1-30% of PE) |
| Insulation | | \$163,800 | 2% | 0.02 x PE | OAQPS (1-7% of PE) |
| Painting | | \$327,600 | 4% | 0.04 x PE | OAQPS (1-4% of PE) |
| Site Preparation | \$45,000 | | - | Project-Specific | AeriNOx Quote (1/7/2020) |
| Total Direct Installation Cost (DI) | \$5,368,500 | | - | DI | |
| Total Direct Capital Costs (DC) | \$13,558,500 | | - | DC = PE + DI | |
| Indirect Capital Costs | | | | | |
| Indirect Costs: | | | | | |
| Engineering & Supervision | | \$1,228,500 | 15% | 0.15 x PE | OAQPS (10-20% of PE) |
| Construction and Field Expenses | | \$819,000 | 10% | 0.10 x PE | OAQPS (5-20% of PE) |
| Contractor Fees | | \$409,500 | 5% | 0.05 x PE | OAQPS (0-10% of PE) |
| Startup-up | | \$81,900 | 1% | 0.01 x PE | OAQPS (1-2% of PE) |
| Performance Testing | | \$81,900 | 1% | 0.01 x PE | OAQPS (1% of PE) |
| Total Indirect Costs (TIC) | \$2,620,800 | | - | IC | |
| Capital Investment: | | | | | |
| Project Contingency | | 2426895 | 15% | E = 0.15 x (DC+IC) | OAQPS (15% of DC & TIC) |
| Preproduction Cost | | \$372,123.90 | 2% | F = 0.02 x (DC+IC+Cont) | OAQPS (2% of DC & TIC & Proj Contingency) |
| Inventory Capital (initial reagent fill) | | \$11,035 | - | G = [Storage Gal] x [Reagent \$/gal] | See parameters below |
| Total Capital Investment | \$18,989,354 | | - | TCI = DC + IC + E + F + G | |

LNG BACT ANALYSIS
6th Edition EPA Cost Control Manual
Alaska LNG Project
Compressor Driver Natural Gas Turbine
SCR Cost Effectiveness Analysis

| Direct Annual Costs | | | | | |
|----------------------------------|--|--------------------|------|----------------------|---|
| Direct Annual Costs: | | | | | |
| Operating Labor | | | - | | EPA Assumes equipment is managed by existing staff. |
| Supervisory Labor | | \$0 | 15% | 15% of Op. Labor | OAQPS (15% of Op Labor) |
| Maintenance Labor | | \$284,840 | 1.5% | 0.015 x TCI | OAQPS (1.5% of TCI) |
| Maintenance Materials | | \$284,840 | - | 100% of Maint. Labor | OAQPS (15% of Maint. Labor) |
| Annual Reagent Cost | | \$287,707 | - | q*Cost*[op hr/yr] | See parameters below |
| Annual Electricity Cost | | \$425,728 | - | See parameters below | See parameters below |
| Catalyst Replacement | | \$212,293 | - | See parameters below | See parameters below |
| Catalyst Disposal Cost | | \$21,229 | 10% | 0.100 x Cat Repl | Engineering Estimate |
| Fuel Penalty Costs (specify) | | | - | | |
| Other Maintenance Cost (specify) | | | - | | |
| Total Direct Annual Costs | | \$1,516,638 | - | DAC | |

| Indirect Annual Costs | | | | | |
|------------------------------------|--|--------------------|-------|-------------------------------------|---|
| Indirect Annual Costs: | | | | | |
| Overhead | | \$341,808 | 60.0% | 0.600 x Op/Super/Maint Labor & Mtls | OAQPS (60% of Op/Super/Maint. Labor & Mtls) |
| Property Tax | | \$189,894 | 1.0% | 0.0100 x TCI | OAQPS (1%) |
| Insurance | | \$189,894 | 1.0% | 0.010 x TCI | OAQPS (1%) |
| General Administrative | | \$379,787 | 2.0% | 0.020 x TCI | OAQPS (2%) |
| Total Indirect Annual Costs | | \$1,101,383 | - | DAC | |

| Capital Recovery Cost | | | | | |
|------------------------------------|--------|--------------------|---|--------------------------|---|
| Equipment Life (years) | | 20 | - | n | EPA Default |
| Interest Rate | 7.00% | 7.00% | - | i | 7% per Agrium US Inc, Kenai Nitrogen Operations Facility Air Quality Control Construction Permit AQ0083CPT06 |
| Capital Recovery Factor | 0.0944 | | - | CRF = $i/(1-(1+i)^{-n})$ | - |
| Capital Recovery Cost (CRC) | | \$1,792,461 | - | | OAQPS Eqn 2.54 (Section 4.2, Ch. 2) |

| | | | | | |
|---------------------------|--|--------------------|---|------------------------------|-------------------------------------|
| Total Annual Costs | | \$4,410,481 | - | TAC = DA + IDAC + CRC | OAQPS Eqn 2.56 (Section 4.2, Ch. 2) |
|---------------------------|--|--------------------|---|------------------------------|-------------------------------------|

Cost Effectiveness Analysis:

| | | Reference |
|--|-----------------|-------------------------------------|
| Uncontrolled NO _x (tpy) | 280.17 | Calculated below |
| Controlled NO _x Emissions (tpy) | 37.36 | Calculated below |
| NO _x Reduction (tpy) | 242.81 | Calculated below |
| | | |
| Total Annual Costs | \$4,410,481 | Calculated above |
| Cost Effectiveness (\$/ton/yr) | \$18,164 | OAQPS Eqn 2.58 (Section 4.2, Ch. 2) |

LNG BACT ANALYSIS
6th Edition EPA Cost Control Manual
Alaska LNG Project
Compressor Driver Natural Gas Turbine
SCR Cost Effectiveness Analysis

Design Parameters:

Enter values in boxes below. Where default value is available, entered value will override default.
 Required data is highlighted yellow.

Combustion Unit Sizing

| | | Reference |
|---|--|-----------|
| Turbine heat capacity: | <input style="background-color: yellow;" type="text" value="1164.00"/> | MMBtu/hr |
| Duct burner heat capacity, if applicable: | <input type="text"/> | MMBtu/hr |

NOx Emission Rates

| | | Reference |
|---|--|--|
| Turbine uncontrolled NOx concentration: | <input type="text"/> | lb NOx/MMBtu |
| or | <input type="text"/> | lb NOx/MMscf |
| or | <input style="background-color: yellow;" type="text" value="15.00"/> | ppmv @ 15% O2 |
| or (default) | <input type="text"/> | ppmv @ 15% O2 |
| | | Assumption for baseline/uncontrolled emissions |
| Duct burner uncontrolled NOx concentration: | <input type="text"/> | lb NOx/MMBtu |
| or | <input type="text"/> | lb NOx/MMscf |
| or | <input type="text"/> | ppmv @ 3% O2 |
| or (default) | <input type="text"/> | ppmv @ 3% O2 |
| Controlled NOx concentration: | <input type="text"/> | lb NOx/MMBtu |
| or | <input type="text"/> | lb NOx/MMscf |
| or | <input style="background-color: yellow;" type="text" value="2"/> | ppmv @ 15% O2 |
| | | Most stringent limit identified as BACT |

Natural Gas Properties

| | | Reference |
|---|---|--|
| HHV [Default: 1050 Btu/scf] | <input style="background-color: yellow;" type="text" value="1087"/> | Btu/scf |
| F-factor (dry) [Default: 8710 dscf/MMBtu] | <input type="text"/> | dscf/MMBtu |
| | | LNG Fuel Gas Specification |
| | | EPA 40 CFR Part 60 Appendix A, Method 19, Table 19-2 |

Operational Parameters

| | | Reference |
|---|---|-----------|
| Max annual op hours [Default: 8760 hr/yr] | <input style="background-color: yellow;" type="text" value="8760"/> | hr/yr |
| | | |

Annual Electricity Costs: Enter values below. Where default value is available, entered number overrides default.

| | | Reference |
|--|--|-------------------------------------|
| Power demand: | <input type="text"/> | kW |
| If power demand is not known, estimate on the basis of the parameters below: | | |
| delta P duct [Default: 3 in H2O] | <input type="text"/> | |
| delta P catalyst (per layer) [Default: 1 in H2O] | <input type="text"/> | |
| number of layers of catalyst | <input style="background-color: yellow;" type="text" value="2"/> | |
| Calculated Power demand: | <input style="background-color: yellow;" type="text" value="311.4"/> | kW |
| | | Calculated below |
| | | OAQPS Eqn 2.48 (Section 4.2, Ch. 2) |
| | | OAQPS Eqn 2.48 (Section 4.2, Ch. 2) |
| | | OAQPS Eqn 2.48 (Section 4.2, Ch. 2) |

LNG BACT ANALYSIS
6th Edition EPA Cost Control Manual
Alaska LNG Project
Compressor Driver Natural Gas Turbine
SCR Cost Effectiveness Analysis

Electricity Cost [Default: 0.1572 \$/kWh]

| |
|------|
| 0.16 |
|------|

\$/kWh

Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska in 2017.

Aqueous Ammonia Costs: Enter values below or parameters to estimate.

Aqueous ammonia cost:

| |
|--------|
| \$2.24 |
|--------|

\$/gallon

Aqueous ammonia storage volume:

| |
|--|
| |
|--|

gallons

or

| |
|----|
| 14 |
|----|

days' worth

Aqueous ammonia consumption rate:

| |
|--|
| |
|--|

gal/hr

If aqueous ammonia consumption rate not known, estimate on the basis of the parameters below:

Stored NH3 concentration [Default: 19.4%]

| |
|--|
| |
|--|

wt%

NH3 solution mass flow rate (m_{sol})

| |
|--------|
| 114.10 |
|--------|

lb/hr

NH3 solution density [Default: 7.782 lb/gal]

| |
|-------|
| 7.782 |
|-------|

lb/gal

Calculated Aqueous ammonia consumption rate:

| |
|------|
| 14.7 |
|------|

gal/hr

Reference

Ammonia cost based on \$0.30/pound (Weekly Fertilizer Review, 4/2015)

Calculated below
 Engineering Estimate

Calculated below

Calculated below
 Engineering Data
 OAQPS Eqn 2.32-2.34 (Section 4.2, Ch. 2)

Catalyst Costs:

Initial catalyst cost:

| |
|-----------|
| \$682,502 |
|-----------|

Catalyst replacement frequency:

| |
|---|
| 3 |
|---|

years

Interest Rate

| |
|-------|
| 7.00% |
|-------|

%

Annual Catalyst Replacement Cost

| |
|-----------|
| \$212,293 |
|-----------|

Reference

OAQPS (Section 4.2, Ch. 2)
 Vendor Supplied
 ADEC Default
 OAQPS Eqn 2.51 (Section 4.2, Ch. 2)

* OAQPS refers to the EPA Air Pollution Control Cost Manual, Sixth Edition and subsequent revisions.

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix B |

APPENDIX B – 7TH EDITION COST EFFECTIVENESS CALCULATIONS – EPA DEFAULT ANALYSIS

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix B.1 |

APPENDIX B.1

GTP Power Generation Turbines

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Industrial

What type of fuel does the unit burn?

Natural Gas

Is the SCR for a new boiler or retrofit of an existing boiler?

New Construction

Complete all of the highlighted data fields:

What is the maximum heat input rate (QB)?

418 MMBtu/hour

What is the higher heating value (HHV) of the fuel?

1,077 Btu/scf

HHV per GTP Fuel Gas specifications.

What is the estimated actual annual fuel consumption?

3,399,888,579 scf/Year

Enter the net plant heat input rate (NPHR)

9.486 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

| Fuel Type | Default NPHR |
|-------------|--------------|
| Coal | 10 MMBtu/MW |
| Fuel Oil | 11 MMBtu/MW |
| Natural Gas | 8.2 MMBtu/MW |

Plant Elevation

46 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Not Applicable

Enter the sulfur content (%S) =

percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

| Coal Type | Fraction in Coal Blend | %S | HHV (Btu/lb) |
|----------------|------------------------|------|--------------|
| Bituminous | 0 | 1.84 | 11,841 |
| Sub-Bituminous | 0 | 0.41 | 8,826 |
| Lignite | 0 | 0.82 | 6,685 |

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

- Method 1
- Method 2
- Not applicable

Enter the following design parameters for the proposed SCR:

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

| | |
|--|-----------------|
| Number of days the SCR operates (t_{SCR}) | 365 days |
| Number of days the boiler operates (t_{plant}) | 365 days |
| Inlet NO_x Emissions ($NO_{x,in}$) to SCR | 0.055 lb/MMBtu |
| Outlet NO_x Emissions ($NO_{x,out}$) from SCR | 0.0074 lb/MMBtu |
| Stoichiometric Ratio Factor (SRF) | 1.050 |

*The SRF value of 1.05 is a default value. User should enter actual value, if known.

Notes: Inlet Nox 15 ppmv per Gas Turbine Vendor. Outlet NOx 2 ppmv per EPA.

| | |
|--|------------------|
| Estimated operating life of the catalyst ($H_{catalyst}$) | 26,280 hours |
| Estimated SCR equipment life | 20 Years* |
| * For industrial boilers, the typical equipment life is between 20 and 25 years. | |
| Concentration of reagent as stored (C_{stored}) | 19 percent |
| Density of reagent as stored (ρ_{stored}) | 58 lb/cubic feet |
| Number of days reagent is stored ($t_{storage}$) | 14 days |

Select the reagent used

| | |
|---|------------------|
| Number of SCR reactor chambers (n_{scr}) | 1 |
| Number of catalyst layers (R_{layer}) | 1 |
| Number of empty catalyst layers (R_{empty}) | 1 |
| Ammonia Slip (Slip) provided by vendor | 5 ppm |
| Volume of the catalyst layers ($Vol_{catalyst}$) (Enter "UNK" if value is not known) | 1,578 Cubic feet |
| Flue gas flow rate ($Q_{fluegas}$) (Enter "UNK" if value is not known) | 590350 acfm |

| | |
|---|---|
| Gas temperature at the SCR inlet (T) | 750 °F |
| Base case fuel gas volumetric flow rate factor (Q_{fuel}) | 1412.32 ft ³ /min-MMBtu/hour |

| | |
|---|------------------------|
| <u>Densities of typical SCR reagents:</u> | |
| 50% urea solution | 71 lbs/ft ³ |
| 29.4% aqueous NH ₃ | 56 lbs/ft ³ |

Enter the cost data for the proposed SCR:

| | |
|--|--|
| Desired dollar-year | 2017 |
| CEPCI for 2017 | 567.5 Enter the CEPCI value for 2017 541.7 2016 CEPCI |
| Annual Interest Rate (i) | 5.5 Percent* |
| Reagent (Cost _{reag}) | 5.670 \$/gallon for 19% ammonia |
| Electricity (Cost _{elect}) | 0.1600 \$/kWh |
| Catalyst cost (CC _{replace}) | \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst) 227.00 |
| Operator Labor Rate | 60.00 \$/hour (including benefits)* |
| Operator Hours/Day | 4.00 hours/day* |

CEPCI = Chemical Engineering Plant Cost Index

* 5.5 percent is the default bank prime rate. User should enter current bank prime rate (available at <https://www.federalreserve.gov/releases/h15/>)

Ammonia cost per Brenntag quote (June 15, 2015).

Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska: <https://www.eia.gov/electricity/data.php#sales>

* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.

* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

| | |
|---------------------------------------|-------|
| Maintenance Cost Factor (MCF) = | 0.005 |
| Administrative Charges Factor (ACF) = | 0.03 |

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

| Parameter | Equation | Calculated Value | Units | |
|---|---|------------------|------------|---|
| Maximum Annual Heat Input Rate (Q_B) = | HHV x Max. Fuel Rate = | 418 | MMBtu/hour | |
| Maximum Annual fuel consumption (mfuel) = | $(Q_B \times 1.0E6 \times 8760)/HHV =$ | 3,399,888,579 | scf/Year | |
| Actual Annual fuel consumption (Mactual) = | | 3,399,888,579 | scf/Year | |
| Heat Rate Factor (HRF) = | NPHR/10 = | 0.95 | | |
| Total System Capacity Factor (CF_{total}) = | $(M_{actual}/M_{fuel}) \times (t_{scr}/t_{plant}) =$ | 1.000 | fraction | |
| Total operating time for the SCR (t_{op}) = | $CF_{total} \times 8760 =$ | 8760 | hours | |
| NO _x Removal Efficiency (EF) = | $(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$ | 86.6 | percent | |
| NO _x removed per hour = | $NO_{x_{in}} \times EF \times Q_B =$ | 19.91 | lb/hour | |
| Total NO _x removed per year = | $(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$ | 87.19 | tons/year | |
| NO _x removal factor (NRF) = | EF/80 = | 1.08 | | |
| Volumetric flue gas flow rate ($q_{flue\ gas}$) = | $Q_{fuel} \times Q_B \times (460 + T)/(460 + 700)n_{scr} =$ | 590,350 | acfm | |
| Space velocity (V_{space}) = | $q_{flue\ gas}/Vol_{catalyst} =$ | 374.11 | /hour | |
| Residence Time | $1/V_{space}$ | 0.00 | hour | |
| Coal Factor (CoalF) = | 1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends) | 1.00 | | |
| SO ₂ Emission rate = | $(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$ | | | Not applicable; factor applies only to coal-fired boilers |
| Elevation Factor (ELEV) = | 14.7 psia/P = | | | Not applicable; elevation factor does not apply to plants located at elevations below 500 feet. |
| Atmospheric pressure at sea level (P) = | $2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144)^* =$ | 14.7 | psia | |
| Retrofit Factor (RF) | New Construction | 0.80 | | |

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

Catalyst Data:

| Parameter | Equation | Calculated Value | Units |
|--|--|------------------|-----------------|
| Future worth factor (FWF) = | $(\text{interest rate}) / (1 / ((1 + \text{interest rate})^Y - 1))$, where $Y = H_{\text{catalysts}} / (t_{\text{SCR}} \times 24 \text{ hours})$ rounded to the nearest integer | 0.3157 | Fraction |
| Catalyst volume (Vol_{catalyst}) = | $2.81 \times Q_B \times EF_{\text{adj}} \times Slip_{\text{adj}} \times NOx_{\text{adj}} \times S_{\text{adj}} \times (T_{\text{adj}} / N_{\text{scr}})$ | 1,578.00 | Cubic feet |
| Cross sectional area of the catalyst (A_{catalyst}) = | $q_{\text{flue gas}} / (16\text{ft/sec} \times 60 \text{ sec/min})$ | 615 | ft ² |
| Height of each catalyst layer (H_{layer}) = | $(Vol_{\text{catalyst}} / (R_{\text{layer}} \times A_{\text{catalyst}})) + 1$ (rounded to next highest integer) | 4 | feet |

SCR Reactor Data:

| Parameter | Equation | Calculated Value | Units |
|--|---|------------------|-----------------|
| Cross sectional area of the reactor (A_{SCR}) = | $1.15 \times A_{\text{catalyst}}$ | 707 | ft ² |
| Reactor length and width dimensions for a square reactor = | $(A_{\text{SCR}})^{0.5}$ | 26.6 | feet |
| Reactor height = | $(R_{\text{layer}} + R_{\text{empty}}) \times (7\text{ft} + h_{\text{layer}}) + 9\text{ft}$ | 30 | feet |

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

Reagent Data:

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 58 lb/ft³

| Parameter | Equation | Calculated Value | Units |
|---|--|------------------|---|
| Reagent consumption rate (m_{reagent}) = | $(\text{NOx}_{\text{in}} \times Q_{\text{B}} \times \text{EF} \times \text{SRF} \times \text{MW}_{\text{R}}) / \text{MW}_{\text{NOx}} =$ | 8 | lb/hour |
| Reagent Usage Rate (m_{sol}) = | $m_{\text{reagent}} / \text{Csol} =$ | 41 | lb/hour |
| | $(m_{\text{sol}} \times 7.4805) / \text{Reagent Density}$ | 5 | gal/hour |
| Estimated tank volume for reagent storage = | $(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24) / \text{Reagent Density} =$ | 1,800 | gallons (storage needed to store a 14 day reagent supply rounded to t |

Capital Recovery Factor:

| Parameter | Equation | Calculated Value |
|---------------------------------|--|------------------|
| Capital Recovery Factor (CRF) = | $i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i = Interest Rate | 0.0837 |

| Other parameters | Equation | Calculated Value | Units |
|-------------------------------|---|------------------|-------|
| Electricity Usage: | | | |
| Electricity Consumption (P) = | $A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = (0.1 x QB) for industrial boilers. | 228.83 | kW |

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

Cost Estimate

Total Capital Investment (TCI)

TCI for Oil and Natural Gas Boilers

| | |
|---|---|
| For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW: | $TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$ |
| For Oil and Natural Gas-Fired Utility Boilers >500 MW: | $TCI = 62,680 \times B_{MW} \times ELEV \times RF$ |
| For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour : | $TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV \times RF$ |
| For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour : | $TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV \times RF$ |
| For Oil-Fired Industrial Boilers >5,500 MMBtu/hour: | $TCI = 5,700 \times Q_B \times ELEV \times RF$ |
| For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour: | $TCI = 7,640 \times Q_B \times ELEV \times RF$ |

| | | |
|----------------------------------|-------------|-----------------|
| Total Capital Investment (TCI) = | \$5,952,307 | in 2017 dollars |
|----------------------------------|-------------|-----------------|

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

Annual Costs

Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

| | |
|--|------------------------------------|
| Direct Annual Costs (DAC) = | \$724,437 in 2017 dollars |
| Indirect Annual Costs (IDAC) = | \$501,193 in 2017 dollars |
| Total annual costs (TAC) = DAC + IDAC | \$1,225,630 in 2017 dollars |

Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Catalyst Cost})$$

| | | |
|------------------------------------|--|----------------------------------|
| Annual Maintenance Cost = | $0.005 \times \text{TCI} =$ | \$29,762 in 2017 dollars |
| Annual Reagent Cost = | $m_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$ | \$260,858 in 2017 dollars |
| Annual Electricity Cost = | $P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$ | \$320,732 in 2017 dollars |
| Annual Catalyst Replacement Cost = | $n_{\text{scr}} \times \text{Vol}_{\text{cat}} \times (\text{CC}_{\text{replace}} / R_{\text{layer}}) \times \text{FWF}$ | \$113,086 in 2017 dollars |
| Direct Annual Cost = | | \$724,437 in 2017 dollars |

Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

| | | |
|--------------------------------------|--|----------------------------------|
| Administrative Charges (AC) = | $0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$ | \$2,985 in 2017 dollars |
| Capital Recovery Costs (CR)= | $\text{CRF} \times \text{TCI} =$ | \$498,208 in 2017 dollars |
| Indirect Annual Cost (IDAC) = | AC + CR = | \$501,193 in 2017 dollars |

Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

| | |
|-----------------------------|--|
| Total Annual Cost (TAC) = | \$1,225,630 per year in 2017 dollars |
| NOx Removed = | 87 tons/year |
| Cost Effectiveness = | \$14,056 per ton of NOx removed in 2017 dollars |

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix B.2 |

APPENDIX B.2

GTP CO₂ Compressor Turbines

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Is the SCR for a new boiler or retrofit of an existing boiler?

What type of fuel does the unit burn?

Complete all of the highlighted data fields:

What is the maximum heat input rate (QB)?

What is the higher heating value (HHV) of the fuel?
HHV per GTP Fuel Gas specifications.

What is the estimated actual annual fuel consumption?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

| Fuel Type | Default NPHR |
|-------------|--------------|
| Coal | 10 MMBtu/MW |
| Fuel Oil | 11 MMBtu/MW |
| Natural Gas | 8.2 MMBtu/MW |

Plant Elevation

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) = percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

| Coal Type | Fraction in Coal Blend | %S | HHV (Btu/lb) |
|----------------|------------------------|------|--------------|
| Bituminous | 0 | 1.84 | 11,841 |
| Sub-Bituminous | 0 | 0.41 | 8,826 |
| Lignite | 0 | 0.82 | 6,685 |

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

- Method 1
- Method 2
- Not applicable

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates (t_{SCR})

Number of days the boiler operates (t_{plant})

Number of SCR reactor chambers (n_{SCR})

Number of catalyst layers (R_{layer})

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

| | |
|--|------------------|
| Inlet NO _x Emissions (NO _{x,in}) to SCR | 0.06452 lb/MMBtu |
| Outlet NO _x Emissions (NO _{x,out}) from SCR | 0.0074 lb/MMBtu |
| Stoichiometric Ratio Factor (SRF) | 1.050 |

*The SRF value of 1.05 is a default value. User should enter actual value, if known.

| | |
|---|------------------|
| Number of empty catalyst layers (R _{empty}) | 1 |
| Ammonia Slip (Slip) provided by vendor | 5 ppm |
| Volume of the catalyst layers (Vol _{catalyst}) (Enter "UNK" if value is not known) | 1,929 Cubic feet |
| Flue gas flow rate (Q _{fluegas}) (Enter "UNK" if value is not known) | 268183 acfm |

Notes: Weighted average inlet Nox (Main Burner - 0.055 lb/MMBtu, Supplemental Firing - 0.08 lb/MMBtu) per Gas Turbine Vendor. Outlet NOx 2 ppmv per EPA.

| | |
|---|--------------|
| Estimated operating life of the catalyst (H _{catalyst}) | 26,280 hours |
| Estimated SCR equipment life | 20 Years* |

* For industrial boilers, the typical equipment life is between 20 and 25 years.

| | |
|---|--|
| Gas temperature at the SCR inlet (T) | 750 °F |
| Base case fuel gas volumetric flow rate factor (Q _{fuel}) | 534.00 ft ³ /min-MMBtu/hour |

| | |
|---|------------------|
| Concentration of reagent as stored (C _{stored}) | 19 percent |
| Density of reagent as stored (ρ _{stored}) | 58 lb/cubic feet |
| Number of days reagent is stored (t _{storage}) | 14 days |

| | |
|---|------------------------|
| <u>Densities of typical SCR reagents:</u> | |
| 50% urea solution | 71 lbs/ft ³ |
| 29.4% aqueous NH ₃ | 56 lbs/ft ³ |

Select the reagent used

Enter the cost data for the proposed SCR:

| | |
|--|---|
| Desired dollar-year | 2017 |
| CEPCI for 2017 | 567.5 Enter the CEPCI value for 2017 |
| Annual Interest Rate (i) | 5.5 Percent* |
| Reagent (Cost _{reag}) | 5.670 \$/gallon for 19% ammonia |
| Electricity (Cost _{elect}) | 0.1600 \$/kWh |
| Catalyst cost (CC _{replace}) | 227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst) |
| Operator Labor Rate | 60.00 \$/hour (including benefits)* |
| Operator Hours/Day | 4.00 hours/day* |

CEPCI = Chemical Engineering Plant Cost Index

* 5.5 percent is the default bank prime rate. User should enter current bank prime rate (available at <https://www.federalreserve.gov/releases/h15/>.)

Ammonia cost per Brenntag quote (June 15, 2015).

Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska: <https://www.eia.gov/electricity/data.php#sales>

* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.

* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

| | |
|---------------------------------------|-------|
| Maintenance Cost Factor (MCF) = | 0.005 |
| Administrative Charges Factor (ACF) = | 0.03 |

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

| Parameter | Equation | Calculated Value | Units |
|--|---|------------------|------------|
| Maximum Annual Heat Input Rate (Q _B) = | HHV x Max. Fuel Rate = | 502 | MMBtu/hour |
| Maximum Annual fuel consumption (mfuel) = | (QB x 1.0E6 x 8760)/HHV = | 4,084,909,192 | scf/Year |
| Actual Annual fuel consumption (Mactual) = | | 4,084,909,192 | scf/Year |
| Heat Rate Factor (HRF) = | NPHR/10 = | 1.14 | |
| Total System Capacity Factor (CF _{total}) = | (Mactual/Mfuel) x (tscr/tplant) = | 1.000 | fraction |
| Total operating time for the SCR (t _{op}) = | CF _{total} x 8760 = | 8760 | hours |
| NO _x Removal Efficiency (EF) = | (NO _x _{in} - NO _x _{out})/NO _x _{in} = | 88.6 | percent |
| NO _x removed per hour = | NO _x _{in} x EF x Q _B = | 28.70 | lb/hour |
| Total NO _x removed per year = | (NO _x _{in} x EF x Q _B x t _{op})/2000 = | 125.70 | tons/year |
| NO _x removal factor (NRF) = | EF/80 = | 1.11 | |
| Volumetric flue gas flow rate (q _{flue gas}) = | Q _{fuel} x QB x (460 + T)/(460 + 700)n _{scr} = | 268,183 | acfm |
| Space velocity (V _{space}) = | q _{flue gas} /Vol _{catalyst} = | 139.03 | /hour |
| Residence Time | 1/V _{space} | 0.01 | hour |
| Coal Factor (CoalF) = | 1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends) | 1.00 | |
| SO ₂ Emission rate = | (%S/100)x(64/32)*1x10 ⁶ /HHV = | | |
| Elevation Factor (ELEVF) = | 14.7 psia/P = | | |
| Atmospheric pressure at sea level (P) = | 2116 x [(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* = | 14.7 | psia |
| Retrofit Factor (RF) | New Construction | 0.80 | |

Not applicable; factor applies only to coal-fired boilers

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgrc.nasa.gov/education/rocket/atmos.html>.

Catalyst Data:

| Parameter | Equation | Calculated Value | Units |
|-----------------------------|---|------------------|----------|
| Future worth factor (FWF) = | (interest rate)(1/((1+ interest rate) ^Y -1)), where Y = H _{catalysts} /(t _{SCR} x 24 hours) rounded to the nearest integer | 0.3157 | Fraction |

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

| | | | |
|---|--|----------|-----------------|
| Catalyst volume ($Vol_{catalyst}$) = | $2.81 \times Q_B \times EF_{adj} \times Slip_{adj} \times NOx_{adj} \times S_{adj} \times (T_{adj}/N_{scr})$ | 1,929.00 | Cubic feet |
| Cross sectional area of the catalyst ($A_{catalyst}$) = | $q_{flue\ gas} / (16ft/sec \times 60\ sec/min)$ | 279 | ft ² |
| Height of each catalyst layer (H_{layer}) = | $(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer) | 3 | feet |

SCR Reactor Data:

| Parameter | Equation | Calculated Value | Units |
|--|--|------------------|-----------------|
| Cross sectional area of the reactor (A_{SCR}) = | $1.15 \times A_{catalyst}$ | 321 | ft ² |
| Reactor length and width dimensions for a square reactor = | $(A_{SCR})^{0.5}$ | 17.9 | feet |
| Reactor height = | $(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$ | 50 | feet |

Reagent Data:

| | | | |
|----------------------|---------|------------------------------------|-----------------------|
| Type of reagent used | Ammonia | Molecular Weight of Reagent (MW) = | 17.03 g/mole |
| | | Density = | 58 lb/ft ³ |

| Parameter | Equation | Calculated Value | Units |
|--|---|------------------|---|
| Reagent consumption rate ($m_{reagent}$) = | $(NOx_{in} \times Q_B \times EF \times SRF \times MW_R) / MW_{NOx} =$ | 11 | lb/hour |
| Reagent Usage Rate (m_{sol}) = | $m_{reagent} / C_{sol} =$ | 59 | lb/hour |
| | $(m_{sol} \times 7.4805) / \text{Reagent Density}$ | 8 | gal/hour |
| Estimated tank volume for reagent storage = | $(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$ | 2,600 | gallons (storage needed to store a 14 day reagent supply rounded to t |

Capital Recovery Factor:

| Parameter | Equation | Calculated Value |
|---------------------------------|--|------------------|
| Capital Recovery Factor (CRF) = | $i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate | 0.0837 |

| Other parameters | Equation | Calculated Value | Units |
|--|---|------------------|-------|
| Electricity Usage: Electricity Consumption (P) = | $A \times 1,000 \times 0.0056 \times (CoalF \times HRF)^{0.43} =$ where A = (0.1 x QB) for industrial boilers. | 297.52 | kW |

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

Cost Estimate

Total Capital Investment (TCI)

TCI for Oil and Natural Gas Boilers

For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:

$$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$$

For Oil and Natural Gas-Fired Utility Boilers >500 MW:

$$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$$

For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :

$$TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$$

For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :

$$TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$$

For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:

$$TCI = 5,700 \times Q_B \times ELEV F \times RF$$

For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:

$$TCI = 7,640 \times Q_B \times ELEV F \times RF$$

| | | |
|----------------------------------|-------------|-----------------|
| Total Capital Investment (TCI) = | \$6,706,591 | in 2017 dollars |
|----------------------------------|-------------|-----------------|

Annual Costs

Total Annual Cost (TAC)

$$TAC = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

| | |
|---------------------------------------|-----------------------------|
| Direct Annual Costs (DAC) = | \$872,673 in 2017 dollars |
| Indirect Annual Costs (IDAC) = | \$564,372 in 2017 dollars |
| Total annual costs (TAC) = DAC + IDAC | \$1,437,045 in 2017 dollars |

Direct Annual Costs (DAC)

$$DAC = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Catalyst Cost})$$

| | | |
|---------------------------|---|---------------------------|
| Annual Maintenance Cost = | $0.005 \times TCI =$ | \$33,533 in 2017 dollars |
| Annual Reagent Cost = | $m_{sol} \times \text{Cost}_{reag} \times t_{op} =$ | \$376,057 in 2017 dollars |
| Annual Electricity Cost = | $P \times \text{Cost}_{elect} \times t_{op} =$ | \$417,003 in 2017 dollars |

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

| | | |
|------------------------------------|---|---------------------------|
| Annual Catalyst Replacement Cost = | | \$46,080 in 2017 dollars |
| | $n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$ | |
| Direct Annual Cost = | | \$872,673 in 2017 dollars |

Indirect Annual Cost (IDAC)
IDAC = Administrative Charges + Capital Recovery Costs

| | | |
|-------------------------------|--|---------------------------|
| Administrative Charges (AC) = | $0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$ | \$3,030 in 2017 dollars |
| Capital Recovery Costs (CR)= | $CRF \times TCI =$ | \$561,342 in 2017 dollars |
| Indirect Annual Cost (IDAC) = | $AC + CR =$ | \$564,372 in 2017 dollars |

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

| | | |
|---------------------------|--|---|
| Total Annual Cost (TAC) = | | \$1,437,045 per year in 2017 dollars |
| NOx Removed = | | 126 tons/year |
| Cost Effectiveness = | | \$11,432 per ton of NOx removed in 2017 dollars |

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix B.5 |

APPENDIX B.3

GTP Treated Gas Compressor Turbines

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Is the SCR for a new boiler or retrofit of an existing boiler?

What type of fuel does the unit burn?

Complete all of the highlighted data fields:

What is the maximum heat input rate (QB)?

What is the higher heating value (HHV) of the fuel?
HHV per GTP Fuel Gas specifications.

What is the estimated actual annual fuel consumption?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

| Fuel Type | Default NPHR |
|-------------|--------------|
| Coal | 10 MMBtu/MW |
| Fuel Oil | 11 MMBtu/MW |
| Natural Gas | 8.2 MMBtu/MW |

Plant Elevation

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) = percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

| Coal Type | Fraction in Coal Blend | %S | HHV (Btu/lb) |
|----------------|------------------------|------|--------------|
| Bituminous | 0 | 1.84 | 11,841 |
| Sub-Bituminous | 0 | 0.41 | 8,826 |
| Lignite | 0 | 0.82 | 6,685 |

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

- Method 1
- Method 2
- Not applicable

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates (t_{SCR})

Number of days the boiler operates (t_{plant})

Number of SCR reactor chambers (n_{SCR})

Number of catalyst layers (R_{layer})

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

| | |
|--|-----------------|
| Inlet NO _x Emissions (NO _{x,in}) to SCR | 0.0651 lb/MMBtu |
| Outlet NO _x Emissions (NO _{x,out}) from SCR | 0.0074 lb/MMBtu |
| Stoichiometric Ratio Factor (SRF) | 1.050 |

*The SRF value of 1.05 is a default value. User should enter actual value, if known.

Notes: Weighted average inlet Nox (Main Burner - 0.055 lb/MMBtu, Supplemental Firing - 0.08 lb/MMBtu) per Gas Turbine Vendor. Outlet NOx 2 ppmv per EPA.

| | |
|---|--------------|
| Estimated operating life of the catalyst (H _{catalyst}) | 26,280 hours |
| Estimated SCR equipment life | 20 Years* |

* For industrial boilers, the typical equipment life is between 20 and 25 years.

| | |
|---|------------------|
| Concentration of reagent as stored (C _{stored}) | 19 percent |
| Density of reagent as stored (ρ _{stored}) | 58 lb/cubic feet |
| Number of days reagent is stored (t _{storage}) | 14 days |

Select the reagent used

| | |
|---|------------------|
| Number of empty catalyst layers (R _{empty}) | 1 |
| Ammonia Slip (Slip) provided by vendor | 5 ppm |
| Volume of the catalyst layers (Vol _{catalyst}) (Enter "UNK" if value is not known) | 2,692 Cubic feet |
| Flue gas flow rate (Q _{fluegas}) (Enter "UNK" if value is not known) | 385879 acfm |

| | |
|---|--|
| Gas temperature at the SCR inlet (T) | 750 °F |
| Base case fuel gas volumetric flow rate factor (Q _{fuel}) | 549.18 ft ³ /min-MMBtu/hour |

| | |
|---|------------------------|
| <u>Densities of typical SCR reagents:</u> | |
| 50% urea solution | 71 lbs/ft ³ |
| 29.4% aqueous NH ₃ | 56 lbs/ft ³ |

Enter the cost data for the proposed SCR:

| | |
|--|---|
| Desired dollar-year | 2017 |
| CEPCI for 2017 | 567.5 Enter the CEPCI value for 2017 |
| Annual Interest Rate (i) | 5.5 Percent* |
| Reagent (Cost _{reag}) | 5.670 \$/gallon for 19% ammonia |
| Electricity (Cost _{elect}) | 0.1600 \$/kWh |
| Catalyst cost (CC _{replace}) | 227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst) |
| Operator Labor Rate | 60.00 \$/hour (including benefits)* |
| Operator Hours/Day | 4.00 hours/day* |

CEPCI = Chemical Engineering Plant Cost Index

* 5.5 percent is the default bank prime rate. User should enter current bank prime rate (available at <https://www.federalreserve.gov/releases/h15/>.)

Ammonia cost per Brenntag quote (June 15, 2015).

Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska: <https://www.eia.gov/electricity/data.php#sales>

* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.

* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

| | |
|---------------------------------------|-------|
| Maintenance Cost Factor (MCF) = | 0.005 |
| Administrative Charges Factor (ACF) = | 0.03 |

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

| Parameter | Equation | Calculated Value | Units |
|--|---|------------------|------------|
| Maximum Annual Heat Input Rate (Q _B) = | HHV x Max. Fuel Rate = | 703 | MMBtu/hour |
| Maximum Annual fuel consumption (mfuel) = | (Q _B x 1.0E6 x 8760)/HHV = | 5,715,066,295 | scf/Year |
| Actual Annual fuel consumption (Mactual) = | | 5,715,066,295 | scf/Year |
| Heat Rate Factor (HRF) = | NPHR/10 = | 1.59 | |
| Total System Capacity Factor (CF _{total}) = | (Mactual/Mfuel) x (tscr/tplant) = | 1.000 | fraction |
| Total operating time for the SCR (t _{op}) = | CF _{total} x 8760 = | 8760 | hours |
| NO _x Removal Efficiency (EF) = | (NO _x _{in} - NO _x _{out})/NO _x _{in} = | 88.7 | percent |
| NO _x removed per hour = | NO _x _{in} x EF x Q _B = | 40.58 | lb/hour |
| Total NO _x removed per year = | (NO _x _{in} x EF x Q _B x t _{op})/2000 = | 177.74 | tons/year |
| NO _x removal factor (NRF) = | EF/80 = | 1.11 | |
| Volumetric flue gas flow rate (q _{flue gas}) = | Q _{fuel} x Q _B x (460 + T)/(460 + 700)n _{scr} = | 385,879 | acfm |
| Space velocity (V _{space}) = | q _{flue gas} /Vol _{catalyst} = | 143.34 | /hour |
| Residence Time | 1/V _{space} | 0.01 | hour |
| Coal Factor (CoalF) = | 1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends) | 1.00 | |
| SO ₂ Emission rate = | (%S/100)x(64/32)*1x10 ⁶ /HHV = | | |
| Elevation Factor (ELEVF) = | 14.7 psia/P = | | |
| Atmospheric pressure at sea level (P) = | 2116 x [(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* = | 14.7 | psia |
| Retrofit Factor (RF) | New Construction | 0.80 | |

Not applicable; factor applies only to coal-fired boilers

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

Catalyst Data:

| Parameter | Equation | Calculated Value | Units |
|-----------------------------|--|------------------|----------|
| Future worth factor (FWF) = | (interest rate)(1/((1+ interest rate) ^Y -1), where Y = H _{catalysts} /(t _{SCR} x 24 hours) rounded to the nearest integer | 0.3157 | Fraction |

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

| | | | |
|---|--|----------|-----------------|
| Catalyst volume ($Vol_{catalyst}$) = | $2.81 \times Q_B \times EF_{adj} \times Slip_{adj} \times NOx_{adj} \times S_{adj} \times (T_{adj}/N_{scr})$ | 2,692.00 | Cubic feet |
| Cross sectional area of the catalyst ($A_{catalyst}$) = | $q_{flue\ gas} / (16ft/sec \times 60\ sec/min)$ | 402 | ft ² |
| Height of each catalyst layer (H_{layer}) = | $(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer) | 3 | feet |

SCR Reactor Data:

| Parameter | Equation | Calculated Value | Units |
|--|--|------------------|-----------------|
| Cross sectional area of the reactor (A_{SCR}) = | $1.15 \times A_{catalyst}$ | 462 | ft ² |
| Reactor length and width dimensions for a square reactor = | $(A_{SCR})^{0.5}$ | 21.5 | feet |
| Reactor height = | $(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$ | 50 | feet |

Reagent Data:

| | | | |
|----------------------|---------|------------------------------------|-----------------------|
| Type of reagent used | Ammonia | Molecular Weight of Reagent (MW) = | 17.03 g/mole |
| | | Density = | 58 lb/ft ³ |

| Parameter | Equation | Calculated Value | Units |
|--|---|------------------|---|
| Reagent consumption rate ($m_{reagent}$) = | $(NOx_{in} \times Q_B \times EF \times SRF \times MW_R) / MW_{NOx} =$ | 16 | lb/hour |
| Reagent Usage Rate (m_{sol}) = | $m_{reagent} / C_{sol} =$ | 83 | lb/hour |
| | $(m_{sol} \times 7.4805) / \text{Reagent Density}$ | 11 | gal/hour |
| Estimated tank volume for reagent storage = | $(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$ | 3,600 | gallons (storage needed to store a 14 day reagent supply rounded to t |

Capital Recovery Factor:

| Parameter | Equation | Calculated Value |
|---------------------------------|--|------------------|
| Capital Recovery Factor (CRF) = | $i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate | 0.0837 |

| Other parameters | Equation | Calculated Value | Units |
|--|---|------------------|-------|
| Electricity Usage: Electricity Consumption (P) = | $A \times 1,000 \times 0.0056 \times (CoalF \times HRF)^{0.43} =$ where A = (0.1 x QB) for industrial boilers. | 480.91 | kW |

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

Cost Estimate

Total Capital Investment (TCI)

TCI for Oil and Natural Gas Boilers

For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:

$$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$$

For Oil and Natural Gas-Fired Utility Boilers >500 MW:

$$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$$

For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :

$$TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$$

For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :

$$TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$$

For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:

$$TCI = 5,700 \times Q_B \times ELEV F \times RF$$

For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:

$$TCI = 7,640 \times Q_B \times ELEV F \times RF$$

| | | |
|----------------------------------|-------------|-----------------|
| Total Capital Investment (TCI) = | \$8,342,517 | in 2017 dollars |
|----------------------------------|-------------|-----------------|

Annual Costs

Total Annual Cost (TAC)

$$TAC = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

| | |
|---------------------------------------|-----------------------------|
| Direct Annual Costs (DAC) = | \$1,311,798 in 2017 dollars |
| Indirect Annual Costs (IDAC) = | \$701,397 in 2017 dollars |
| Total annual costs (TAC) = DAC + IDAC | \$2,013,195 in 2017 dollars |

Direct Annual Costs (DAC)

$$DAC = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Catalyst Cost})$$

| | | |
|---------------------------|---|---------------------------|
| Annual Maintenance Cost = | $0.005 \times TCI =$ | \$41,713 in 2017 dollars |
| Annual Reagent Cost = | $m_{sol} \times \text{Cost}_{reag} \times t_{op} =$ | \$531,735 in 2017 dollars |
| Annual Electricity Cost = | $P \times \text{Cost}_{elect} \times t_{op} =$ | \$674,044 in 2017 dollars |

GTP BACT ANALYSIS
7th Edition EPA Cost Control Manual

| | | |
|------------------------------------|---|-----------------------------|
| Annual Catalyst Replacement Cost = | | \$64,306 in 2017 dollars |
| | $n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$ | |
| Direct Annual Cost = | | \$1,311,798 in 2017 dollars |

Indirect Annual Cost (IDAC)
IDAC = Administrative Charges + Capital Recovery Costs

| | | |
|-------------------------------|--|---------------------------|
| Administrative Charges (AC) = | $0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$ | \$3,129 in 2017 dollars |
| Capital Recovery Costs (CR)= | $CRF \times TCI =$ | \$698,269 in 2017 dollars |
| Indirect Annual Cost (IDAC) = | $AC + CR =$ | \$701,397 in 2017 dollars |

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

| | | |
|---------------------------|--|---|
| Total Annual Cost (TAC) = | | \$2,013,195 per year in 2017 dollars |
| NOx Removed = | | 178 tons/year |
| Cost Effectiveness = | | \$11,327 per ton of NOx removed in 2017 dollars |

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix B.5 |

APPENDIX B.4

LNG Power Generation Turbines

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Is the SCR for a new boiler or retrofit of an existing boiler?

What type of fuel does the unit burn?

Complete all of the highlighted data fields:

What is the maximum heat input rate (QB)?

What is the higher heating value (HHV) of the fuel?
HHV per LNG Fuel Gas specifications - RR9 - Appendix D.

What is the estimated actual annual fuel consumption?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

| Fuel Type | Default NPHR |
|-------------|--------------|
| Coal | 10 MMBtu/MW |
| Fuel Oil | 11 MMBtu/MW |
| Natural Gas | 8.2 MMBtu/MW |

Plant Elevation

Elevation per RR9 - Appendix D, Section 1.1.

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) = percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

| Coal Type | Fraction in Coal Blend | %S | HHV (Btu/lb) |
|----------------|------------------------|------|--------------|
| Bituminous | 0 | 1.84 | 11,841 |
| Sub-Bituminous | 0 | 0.41 | 8,826 |
| Lignite | 0 | 0.82 | 6,685 |

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

- Method 1
- Method 2
- Not applicable

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates (t_{SCR})

Number of days the boiler operates (t_{plant})

Inlet NO_x Emissions (NO_{x,in}) to SCR

Outlet NO_x Emissions (NO_{x,out}) from SCR

Stoichiometric Ratio Factor (SRF)

Number of SCR reactor chambers (n_{scr})

Number of catalyst layers (R_{layer})

Number of empty catalyst layers (R_{empty})

Ammonia Slip (Slip) provided by vendor

Volume of the catalyst layers ($Vol_{catalyst}$) (Enter "UNK" if value is not known)

LNG BACT Analysis
7th Edition EPA Cost Control Manual

*The SRF value of 1.05 is a default value. User should enter actual value, if known.

Notes: Inlet Nox 15 ppmv per Gas Turbine Vendor. Outlet NOx 2 ppmv per EPA.

Estimated operating life of the catalyst ($H_{catalyst}$)

26,280 hours

Estimated SCR equipment life

20 Years*

* For industrial boilers, the typical equipment life is between 20 and 25 years.

Concentration of reagent as stored (C_{stored})

19 percent

Density of reagent as stored (ρ_{stored})

58 lb/cubic feet

Number of days reagent is stored ($t_{storage}$)

14 days

Flue gas flow rate ($Q_{fluegas}$)
(Enter "UNK" if value is not known)

351168 acfm

Gas temperature at the SCR inlet (T)

341 °F

Base case fuel gas volumetric flow rate factor (Q_{fuel})

816.67 ft³/min-MMBtu/hour

Densities of typical SCR reagents:

50% urea solution 71 lbs/ft³
29.4% aqueous NH₃ 56 lbs/ft³

Select the reagent used

Ammonia

Enter the cost data for the proposed SCR:

Desired dollar-year

2017

CEPCI for 2017

567.5 Enter the CEPCI value for 2017 541.7 2016 CEPCI

CEPCI = Chemical Engineering Plant Cost Index

Annual Interest Rate (i)

5.5 Percent*

* 5.5 percent is the default bank prime rate. User should enter current bank prime rate (available at <https://www.federalreserve.gov/releases/h15/>.)

Reagent (Cost_{reag})

2.240 \$/gallon for 19% ammonia

Ammonia cost based on \$0.30/pound (Weekly Fertilizer Review, 4/2015)

Electricity (Cost_{elect})

0.1600 \$/kWh

Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska: <https://www.eia.gov/electricity/data.php#sales>

Catalyst cost (CC_{replace})

227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)

* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.

Operator Labor Rate

60.00 \$/hour (including benefits)*

* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.

Operator Hours/Day

4.00 hours/day*

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =

0.005

Administrative Charges Factor (ACF) =

0.03

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

| Parameter | Equation | Calculated Value | Units |
|--|---|------------------|------------|
| Maximum Annual Heat Input Rate (Q _B) = | HHV x Max. Fuel Rate = | 430 | MMBtu/hour |
| Maximum Annual fuel consumption (mfuel) = | (Q _B x 1.0E6 x 8760)/HHV = | 3,465,317,387 | scf/Year |
| Actual Annual fuel consumption (Mactual) = | | 3,465,317,387 | scf/Year |
| Heat Rate Factor (HRF) = | NPHR/10 = | 0.98 | |
| Total System Capacity Factor (CF _{total}) = | (Mactual/Mfuel) x (tscr/tplant) = | 1.000 | fraction |
| Total operating time for the SCR (t _{op}) = | CF _{total} x 8760 = | 8760 | hours |
| NO _x Removal Efficiency (EF) = | (NO _{xin} - NO _{xout})/NO _{xin} = | 86.7 | percent |
| NO _x removed per hour = | NO _{xin} x EF x Q _B = | 20.61 | lb/hour |
| Total NO _x removed per year = | (NO _{xin} x EF x Q _B x t _{op})/2000 = | 90.26 | tons/year |
| NO _x removal factor (NRF) = | EF/80 = | 1.08 | |
| Volumetric flue gas flow rate (q _{flue gas}) = | Q _{fuel} x Q _B x (460 + T)/(460 + 700)n _{scr} = | 351,168 | acfm |
| Space velocity (V _{space}) = | q _{flue gas} /Vol _{catalyst} = | 214.78 | /hour |
| Residence Time | 1/V _{space} | 0.00 | hour |
| Coal Factor (CoalF) = | 1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends) | 1.00 | |
| SO ₂ Emission rate = | (%S/100)x(64/32)*1x10 ⁶ /HHV = | | |
| Elevation Factor (ELEV) = | 14.7 psia/P = | | |
| Atmospheric pressure at sea level (P) = | 2116 x [(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* = | 14.6 | psia |
| Retrofit Factor (RF) | New Construction | 0.80 | |

Not applicable; factor applies only to coal-fired boilers

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

Catalyst Data:

| Parameter | Equation | Calculated Value | Units |
|---|---|------------------|-----------------|
| Future worth factor (FWF) = | (interest rate)(1/((1+ interest rate) ^Y -1) , where Y = H _{catalysts} /(t _{SCR} x 24 hours) rounded to the nearest integer | 0.3157 | Fraction |
| Catalyst volume (Vol _{catalyst}) = | 2.81 x Q _B x EF _{adj} x Slipadj x NO _{xadj} x S _{adj} x (T _{adj} /N _{scr}) | 1,635.00 | Cubic feet |
| Cross sectional area of the catalyst (A _{catalyst}) = | q _{flue gas} / (16ft/sec x 60 sec/min) | 366 | ft ² |

LNG BACT Analysis
7th Edition EPA Cost Control Manual

| | | | |
|---|--|---|------|
| Height of each catalyst layer (H_{layer}) = | $(Vol_{catalyst}/(R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer) | 3 | feet |
|---|--|---|------|

SCR Reactor Data:

| Parameter | Equation | Calculated Value | Units |
|--|--|------------------|-----------------|
| Cross sectional area of the reactor (A_{SCR}) = | $1.15 \times A_{catalyst}$ | 421 | ft ² |
| Reactor length and width dimensions for a square reactor = | $(A_{SCR})^{0.5}$ | 20.5 | feet |
| Reactor height = | $(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$ | 40 | feet |

Reagent Data:

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 58 lb/ft³

| Parameter | Equation | Calculated Value | Units |
|--|---|------------------|---|
| Reagent consumption rate ($m_{reagent}$) = | $(NOx_{in} \times Q_B \times EF \times SRF \times MW_R)/MW_{NOx} =$ | 8 | lb/hour |
| Reagent Usage Rate (m_{sol}) = | $m_{reagent}/C_{sol} =$ | 42 | lb/hour |
| | $(m_{sol} \times 7.4805)/\text{Reagent Density}$ | 5 | gal/hour |
| Estimated tank volume for reagent storage = | $(m_{sol} \times 7.4805 \times t_{storage} \times 24)/\text{Reagent Density} =$ | 1,900 | gallons (storage needed to store a 14 day reagent supply rounded to t |

Capital Recovery Factor:

| Parameter | Equation | Calculated Value |
|---------------------------------|---|------------------|
| Capital Recovery Factor (CRF) = | $i(1+i)^n/(1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate | 0.0837 |

| Other parameters | Equation | Calculated Value | Units |
|--|---|------------------|-------|
| Electricity Usage: Electricity Consumption (P) = | $A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = (0.1 x QB) for industrial boilers. | 238.28 | kW |

Cost Estimate

Total Capital Investment (TCI)

TCI for Oil and Natural Gas Boilers

For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:

$$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$$

For Oil and Natural Gas-Fired Utility Boilers >500 MW:

$$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$$

For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :

$$TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$$

For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :

$$TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$$

For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:

$$TCI = 5,700 \times Q_B \times ELEV F \times RF$$

For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:

$$TCI = 7,640 \times Q_B \times ELEV F \times RF$$

| | | |
|----------------------------------|-------------|-----------------|
| Total Capital Investment (TCI) = | \$6,062,828 | in 2017 dollars |
|----------------------------------|-------------|-----------------|

Annual Costs

Total Annual Cost (TAC)

$$TAC = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

| | |
|---------------------------------------|-----------------------------|
| Direct Annual Costs (DAC) = | \$529,557 in 2017 dollars |
| Indirect Annual Costs (IDAC) = | \$510,450 in 2017 dollars |
| Total annual costs (TAC) = DAC + IDAC | \$1,040,007 in 2017 dollars |

Direct Annual Costs (DAC)

$$DAC = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Catalyst Cost})$$

| | | |
|------------------------------------|---|---------------------------|
| Annual Maintenance Cost = | $0.005 \times TCI =$ | \$30,314 in 2017 dollars |
| Annual Reagent Cost = | $m_{sol} \times Cost_{reag} \times t_{op} =$ | \$106,678 in 2017 dollars |
| Annual Electricity Cost = | $P \times Cost_{elect} \times t_{op} =$ | \$333,980 in 2017 dollars |
| Annual Catalyst Replacement Cost = | $n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$ | \$58,585 in 2017 dollars |

LNG BACT Analysis
7th Edition EPA Cost Control Manual

| | |
|----------------------|---------------------------|
| Direct Annual Cost = | \$529,557 in 2017 dollars |
|----------------------|---------------------------|

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

| | | |
|-------------------------------|--|---------------------------|
| Administrative Charges (AC) = | 0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) = | \$2,992 in 2017 dollars |
| Capital Recovery Costs (CR)= | CRF x TCI = | \$507,459 in 2017 dollars |
| Indirect Annual Cost (IDAC) = | AC + CR = | \$510,450 in 2017 dollars |

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

| | |
|---------------------------|---|
| Total Annual Cost (TAC) = | \$1,040,007 per year in 2017 dollars |
| NOx Removed = | 90 tons/year |
| Cost Effectiveness = | \$11,522 per ton of NOx removed in 2017 dollars |

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix B.5 |

APPENDIX B.5

LNG Compressor Turbines

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Is the SCR for a new boiler or retrofit of an existing boiler?

What type of fuel does the unit burn?

Complete all of the highlighted data fields:

What is the maximum heat input rate (QB)?

What is the higher heating value (HHV) of the fuel?
HHV per LNG Fuel Gas specifications - RR9 - Appendix D.

What is the estimated actual annual fuel consumption?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

| Fuel Type | Default NPHR |
|-------------|--------------|
| Coal | 10 MMBtu/MW |
| Fuel Oil | 11 MMBtu/MW |
| Natural Gas | 8.2 MMBtu/MW |

Plant Elevation

Elevation per RR9 - Appendix D, Section 1.1.

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) = percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

| Coal Type | Fraction in Coal Blend | %S | HHV (Btu/lb) |
|----------------|------------------------|------|--------------|
| Bituminous | 0 | 1.84 | 11,841 |
| Sub-Bituminous | 0 | 0.41 | 8,826 |
| Lignite | 0 | 0.82 | 6,685 |

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

- Method 1
- Method 2
- Not applicable

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates (t_{SCR})

Number of days the boiler operates (t_{plant})

Inlet NO_x Emissions (NO_{x,in}) to SCR

Outlet NO_x Emissions (NO_{x,out}) from SCR

Stoichiometric Ratio Factor (SRF)

Number of SCR reactor chambers (n_{scr})

Number of catalyst layers (R_{layer})

Number of empty catalyst layers (R_{empty})

Ammonia Slip (Slip) provided by vendor

Volume of the catalyst layers ($Vol_{catalyst}$) (Enter "UNK" if value is not known)

LNG BACT Analysis
7th Edition EPA Cost Control Manual

*The SRF value of 1.05 is a default value. User should enter actual value, if known.

Flue gas flow rate (Q_{fluegas})
(Enter "UNK" if value is not known) 1535885 acfm

Notes: Updated assumes inlet Nox 15 ppmv. Outlet NOx 2 ppmv per EPA.

Estimated operating life of the catalyst (H_{catalyst}) 26,280 hours

Estimated SCR equipment life 20 Years*

* For industrial boilers, the typical equipment life is between 20 and 25 years.

Gas temperature at the SCR inlet (T) 970 °F

Concentration of reagent as stored (C_{stored}) 19 percent

Density of reagent as stored (ρ_{stored}) 58 lb/cubic feet

Number of days reagent is stored (t_{storage}) 14 days

Base case fuel gas volumetric flow rate factor (Q_{fuel}) 1319.49 ft³/min-MMBtu/hour

| Densities of typical SCR reagents: | |
|------------------------------------|------------------------|
| 50% urea solution | 71 lbs/ft ³ |
| 29.4% aqueous NH ₃ | 56 lbs/ft ³ |

Select the reagent used Ammonia

Enter the cost data for the proposed SCR:

| | |
|--|---|
| Desired dollar-year | 2017 |
| CEPCI for 2017 | 567.5 Enter the CEPCI value for 2017 541.7 2016 CEPCI |
| Annual Interest Rate (i) | 5.5 Percent* |
| Reagent (Cost _{reag}) | 2.240 \$/gallon for 19% ammonia |
| Electricity (Cost _{elect}) | 0.1600 \$/kWh |
| Catalyst cost (CC _{replace}) | 227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst) |
| Operator Labor Rate | 60.00 \$/hour (including benefits)* |
| Operator Hours/Day | 4.00 hours/day* |

CEPCI = Chemical Engineering Plant Cost Index

* 5.5 percent is the default bank prime rate. User should enter current bank prime rate (available at <https://www.federalreserve.gov/releases/h15/>.)

Ammonia cost based on \$0.30/pound (Weekly Fertilizer Review, 4/2015)

Electricity pricing per Department of Energy, annual retail sales of electricity to industrial customers in Alaska: <https://www.eia.gov/electricity/data.php#sales>

* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.

* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) = 0.005

Administrative Charges Factor (ACF) = 0.03

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

| Parameter | Equation | Calculated Value | Units |
|--|---|------------------|------------|
| Maximum Annual Heat Input Rate (Q _B) = | HHV x Max. Fuel Rate = | 1,164 | MMBtu/hour |
| Maximum Annual fuel consumption (mfuel) = | (Q _B x 1.0E6 x 8760)/HHV = | 9,380,533,579 | scf/Year |
| Actual Annual fuel consumption (Mactual) = | | 9,380,533,579 | scf/Year |
| Heat Rate Factor (HRF) = | NPHR/10 = | 2.64 | |
| Total System Capacity Factor (CF _{total}) = | (Mactual/Mfuel) x (t _{scr} /t _{plant}) = | 1.000 | fraction |
| Total operating time for the SCR (t _{op}) = | CF _{total} x 8760 = | 8760 | hours |
| NOx Removal Efficiency (EF) = | (NO _{xin} - NO _{xout})/NO _{xin} = | 86.7 | percent |
| NOx removed per hour = | NO _{xin} x EF x Q _B = | 55.78 | lb/hour |
| Total NO _x removed per year = | (NO _{xin} x EF x Q _B x t _{op})/2000 = | 244.32 | tons/year |
| NO _x removal factor (NRF) = | EF/80 = | 1.08 | |
| Volumetric flue gas flow rate (q _{flue gas}) = | Q _{fuel} x Q _B x (460 + T)/(460 + 700)n _{scr} = | 1,535,885 | acfm |
| Space velocity (V _{space}) = | q _{flue gas} /Vol _{catalyst} = | 376.44 | /hour |
| Residence Time | 1/V _{space} | 0.00 | hour |
| Coal Factor (CoalF) = | 1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends) | 1.00 | |
| SO ₂ Emission rate = | (%S/100)x(64/32)*1x10 ⁶ /HHV = | | |
| Elevation Factor (ELEV) = | 14.7 psia/P = | | |
| Atmospheric pressure at sea level (P) = | 2116 x [(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* = | 14.6 | psia |
| Retrofit Factor (RF) | New Construction | 0.80 | |

Not applicable; factor applies only to coal-fired boilers
Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

Catalyst Data:

| Parameter | Equation | Calculated Value | Units |
|---|---|------------------|-----------------|
| Future worth factor (FWF) = | (interest rate)(1/((1+ interest rate) ^Y -1) , where Y = H _{catalysts} /(t _{SCR} x 24 hours) rounded to the nearest integer | 0.3157 | Fraction |
| Catalyst volume (Vol _{catalyst}) = | 2.81 x Q _B x EF _{adj} x Slip _{adj} x NO _{xadj} x S _{adj} x (T _{adj} /N _{scr}) | 4,080.00 | Cubic feet |
| Cross sectional area of the catalyst (A _{catalyst}) = | q _{flue gas} /(16ft/sec x 60 sec/min) | 1,600 | ft ² |

LNG BACT Analysis
7th Edition EPA Cost Control Manual

| | | | |
|---|--|---|------|
| Height of each catalyst layer (H_{layer}) = | $(Vol_{catalyst}/(R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer) | 2 | feet |
|---|--|---|------|

SCR Reactor Data:

| Parameter | Equation | Calculated Value | Units |
|--|--|------------------|-----------------|
| Cross sectional area of the reactor (A_{SCR}) = | $1.15 \times A_{catalyst}$ | 1,840 | ft ² |
| Reactor length and width dimensions for a square reactor = | $(A_{SCR})^{0.5}$ | 42.9 | feet |
| Reactor height = | $(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$ | 37 | feet |

Reagent Data:

| | | | |
|----------------------|---------|------------------------------------|-----------------------|
| Type of reagent used | Ammonia | Molecular Weight of Reagent (MW) = | 17.03 g/mole |
| | | Density = | 58 lb/ft ³ |

| Parameter | Equation | Calculated Value | Units |
|--|---|------------------|---|
| Reagent consumption rate ($m_{reagent}$) = | $(NOx_{in} \times Q_B \times EF \times SRF \times MW_R)/MW_{NOx} =$ | 22 | lb/hour |
| Reagent Usage Rate (m_{sol}) = | $m_{reagent}/C_{sol} =$ | 114 | lb/hour |
| | $(m_{sol} \times 7.4805)/\text{Reagent Density}$ | 15 | gal/hour |
| Estimated tank volume for reagent storage = | $(m_{sol} \times 7.4805 \times t_{storage} \times 24)/\text{Reagent Density} =$ | 5,000 | gallons (storage needed to store a 14 day reagent supply rounded to t |

Capital Recovery Factor:

| Parameter | Equation | Calculated Value |
|---------------------------------|---|------------------|
| Capital Recovery Factor (CRF) = | $i(1+i)^n/(1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate | 0.0837 |

| Other parameters | Equation | Calculated Value | Units |
|-------------------------------|---|------------------|-------|
| Electricity Usage: | | | |
| Electricity Consumption (P) = | $A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = (0.1 x QB) for industrial boilers. | 989.80 | kW |

Cost Estimate

Total Capital Investment (TCI)

TCI for Oil and Natural Gas Boilers

For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:

$$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$$

For Oil and Natural Gas-Fired Utility Boilers >500 MW:

$$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$$

For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :

$$TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$$

For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :

$$TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$$

For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:

$$TCI = 5,700 \times Q_B \times ELEV F \times RF$$

For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:

$$TCI = 7,640 \times Q_B \times ELEV F \times RF$$

| | | |
|----------------------------------|--------------|-----------------|
| Total Capital Investment (TCI) = | \$11,582,176 | in 2017 dollars |
|----------------------------------|--------------|-----------------|

Annual Costs

Total Annual Cost (TAC)

$$TAC = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

| | |
|---------------------------------------|-----------------------------|
| Direct Annual Costs (DAC) = | \$1,880,178 in 2017 dollars |
| Indirect Annual Costs (IDAC) = | \$972,751 in 2017 dollars |
| Total annual costs (TAC) = DAC + IDAC | \$2,852,930 in 2017 dollars |

Direct Annual Costs (DAC)

$$DAC = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Catalyst Cost})$$

| | | |
|------------------------------------|---|-----------------------------|
| Annual Maintenance Cost = | $0.005 \times TCI =$ | \$57,911 in 2017 dollars |
| Annual Reagent Cost = | $m_{sol} \times Cost_{reag} \times t_{op} =$ | \$288,765 in 2017 dollars |
| Annual Electricity Cost = | $P \times Cost_{elect} \times t_{op} =$ | \$1,387,308 in 2017 dollars |
| Annual Catalyst Replacement Cost = | $n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$ | \$146,194 in 2017 dollars |

LNG BACT Analysis
7th Edition EPA Cost Control Manual

| | |
|----------------------|-----------------------------|
| Direct Annual Cost = | \$1,880,178 in 2017 dollars |
|----------------------|-----------------------------|

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

| | | |
|-------------------------------|--|---------------------------|
| Administrative Charges (AC) = | $0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$ | \$3,323 in 2017 dollars |
| Capital Recovery Costs (CR)= | $\text{CRF} \times \text{TCI} =$ | \$969,428 in 2017 dollars |
| Indirect Annual Cost (IDAC) = | $\text{AC} + \text{CR} =$ | \$972,751 in 2017 dollars |

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

| | |
|---------------------------|---|
| Total Annual Cost (TAC) = | \$2,852,930 per year in 2017 dollars |
| NOx Removed = | 244 tons/year |
| Cost Effectiveness = | \$11,677 per ton of NOx removed in 2017 dollars |

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix C |

APPENDIX C –SUPPORTING INFORMATION LNG COMPRESSOR TURBINES

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix C.1 |

APPENDIX C.1

AeriNOx SCR Quote (January 2020)

Lisa Kiehl

From: Loran Novacek <lnovacek@aerinox-inc.com>
Sent: Tuesday, January 7, 2020 5:08 PM
To: Joel LeBlanc
Cc: Bart Leininger; Lisa Kiehl
Subject: RE: SCR Sizing and Quote

Hi Joel,

Below is a very rough budgetary but should get you ballpark. This is for a horizontal duct from the turbine outlet flange to the top of the stack. I am assuming a 150ft stack height for now. We will need more customer requirements to pull together better pricing for the entire exhaust and SCR system. If CEMS is required we can include this in our scope since it allows us to drop our analyzer, used for closed loop control and use the CEMS for the feedback.

I am planning to be in the Houston area next week. Would you have time for a meeting?

| ITEM | DESCRIPTION | BUDGETARY PRICE (USD) |
|------|--|---|
| 001 | <p>SCR-OXICAT SYSTEM (Per Unit)</p> <ul style="list-style-type: none"> ▪ 1 x Ducting / SCR Housing / Silencer <ul style="list-style-type: none"> ○ 1 Layer of SCR Catalyst with CS modules ○ Ducting from Turbine Outlet to SCR ○ Expansion joint at Turbine Outlet ○ Ducting from SCR to Tailpipe ○ Silencer / Tailpipe with Test Ports, 150ft Height ▪ 1 x Tempering Air System (2 x Blowers) ▪ 1 x Ammonia Injection Grid ▪ 1 x Recycle Gas Skid, each including: <ul style="list-style-type: none"> ○ 1 x Two-Phase Injection Lance for ammonia/air ○ 1 x Static mixer ○ 1 x Ventilator fan ▪ 1 x SCR Control System with Touch-screen and PLC ▪ 1 x Ammonia/Air Dosing Panel ▪ 1 x Ammonia Pump Station (2 x 100% pumps) ▪ 1 x Ammon Storage Tank, SS304 ▪ Engineering, Operation & Maintenance Documentation | <p>GTP TG COMP \$4,100,000</p> <p>GTP ACID GC \$3,500,000</p> <p>GTP LNG \$4,100,000</p> <p>LNG MRC \$7,800,000</p> |
| 002 | <p>COMMISSIONING</p> <p>(Based on Time and Material Only – Per Unit)</p> <p><u>Estimated</u> 10 man-days <u>(Per Turbine)</u> for the commissioning of the emission control system to meet the required emissions levels, plus all travel expenses and accommodations. We can provide qualified personnel to supervise installation at the rate of \$1,350 per man-day, plus all travel expenses. Commissioning time/expenses will be billed per the time and material rates.</p> | \$45,000 |
| 003 | <p>CONSTRUCTION SUPERVISION</p> <p>(Based on Time and Material Only – Per Unit)</p> <p><u>Estimated</u> 60 man-days <u>(Per Turbine)</u> for the construction supervision/support of the emission control system. Includes</p> | \$120,000 |

| |
|--|
| estimated travel expenses and accommodations. Construction supervision is based time/expenses will be billed per the time and material rates. NOT REQUIRED |
|--|

PRICE

The given prices for the SCR Emissions Control System are net prices, FCA Point of Manufacture per Incoterms 2010. All prices are in US dollars. Not included are duties, fees or taxes. Taxes will be included on each invoice unless a tax-exempt certificate is supplied.

PAYMENT

- 25% of the order value upon initial order;
- 20% of the order value with approval of engineering documents
- 20% of the order value upon release for manufacturing
- 30% of the order value with 'ready to ship' of hardware
- 5% of the order value after successful commissioning, not to exceed six (6) months after delivery

All payments are to be paid within 30 days after each date of invoice, net.

SCHEDULING & DELIVERY

Delivery of the drawings and technical documents is as follows:

- Preliminary Engineering Drawings – Approximately 20 weeks after receipt of a purchase order for preliminary drawings with final drawings approximately 12 weeks after customer review/approval
- Ready for Shipment of the hardware is approximately 32 weeks after engineering approval

EMISSION CONTROL SYSTEM DESIGN PARAMETERS:

| Parameter | Unit | GTP TG COMP | GTP GAS COMP | GTP LNG COMP | LNG MRC |
|---|--------------------|-------------|--------------|--------------|---------|
| Estimated Reagent Flow Rate, Based on 19% Aqueous Ammonia, Per Turbine | GPH | 8.5 | 5.5 | 8.5 | 14 |
| Aqueous NH3 Tank Size | USG | 15,000 | 10,000 | 15,000 | 25,000 |
| Total System Backpressure Contribution (AIG + SCR + Ducting / Silencer / Tailpipe) | inH ₂ O | <10 | <10 | <10 | <10 |
| Air Consumption, Per Turbine (Based on 87 psi nominal, max 160 psi, Per ISO 1.2.4 | cfm | 25 | 15 | 25 | 25 |

EMISSIONS GUARANTEE & WARRANTY

| Emission* | Units | Current Turbine Out | Required Stack Out* |
|---------------------------|-------------------------|---------------------|---------------------|
| NOx as NO ₂ ** | ppm @15% O ₂ | 15 | 2 |

* based on 1 hour averaging with the turbine operating at 100% load

**Maximum 20% volume of NOx is present as NO₂

Not included in the scope of supply:

- Load signal from the turbine (4-20 mA or 0-5 VDC)

Appendix C.1 -BACT Cost Effectiveness

- Unit running signal (Digital dry contact, closed when turbine is running)
- Internet connection for remote SCR PLC access and data logging
- Ethernet connection for service requirements
- Structural and civil work necessary to complete the installation
- Aqueous Ammonia Solution (assumed to be delivered to the site)
- Heat tracing of Ammonia tank or Ammonia lines
- Air compressor for aqueous ammonia atomization (available as an option)
- Provision for electricity and connection of the power supply to the enclosure
- System integration (design and engineering) with the building structure
- Connection to the local supply and disposal network
- Platforms and other support structures not listed herein
- Any 3rd party emission certification of stack test
- Installation of all hardware
- Shipping and crating

Regards,

Loran Novacek
Chief Executive Officer

AeriNOx® Inc.

100 S. Cherry Ave, Ste 6B
Eaton, CO 80615
Main: 970-454-5639, Ext10
Cell: 970-443-3868
Email: lnovacek@aerinox-inc.com
Web: www.aerinox-inc.com



From: Joel LeBlanc <jleblanc@algcorp.com>
Sent: Friday, January 3, 2020 5:01 PM
To: Loran Novacek <lnovacek@aerinox-inc.com>
Cc: Bart Leininger <bleininger@algcorp.com>; Lisa Kiehl <lkiehl@algcorp.com>
Subject: RE: SCR Sizing and Quote

We made some updates to the data, some of which include a correction for power output. The updates are included in the attachment.


With regards to the NOx emissions requirement, the SCR outlet should meet 2 ppm NOx.

ALG ASHWORTH LEININGER GROUP
Los Angeles • San Francisco • Houston • Denver
Joel LeBlanc, P.E. | Houston General Manager
T: 281.806.5830 | C: 346.246.8036 | F: 805.764.6011
2219 Sawdust Rd, Suite 1604, Spring, TX 77380
jleblanc@algcorp.com | www.algcorp.com

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix C.2 |

APPENDIX C.2

Brentag Ammonia Cost Quote (2015)

| | | | | | | |
|---|-------------------|----------------------------|------------------|--|--|------------|
|  | | <h2>CALCULATION SHEET</h2> | | | Calculation No. USAG-EC-PCCAL-00-000147 | |
| | | | | | Project No. 31409 | |
| Project Title: Alaska LNG | | | | | Sheet No. <u>1</u> of <u>6</u> | |
| Subject/Feature: SCR, CO, and Ammonia Costs for Pre-BACT | | | | | Rev: A | |
| SCR Ammonia | | | | | | |
| Supplier | | Brenntag | Univar | Comments | | Ref |
| 19% Aq. Ammonia | \$/gal | \$5.67 | \$3.20 | | | 1, 2 |
| ISO Container Size | gallons | 6000 | 5000 | | | 1, 2 |
| Density | lb/gal | 7.74 | 7.83 | Brenntag did not supply density. Assumed value of 7.74 | | 2 |
| Container Weight | lb | 46,440 | 39,150 | | | |
| FOB | | Prudhoe Bay Area | Anchorage | | | |
| Trucking Cost | | | | | | |
| # Trucks | | 1 | 1 | | | |
| From | | Prudhoe Bay Area | Anchorage | | | |
| To | | Prudhoe Bay Area | Prudhoe Bay Area | | | |
| Distance | mi | 0 | 860 | Fairbanks to Prudhoe bay is 500 miles per Ref 3. | | 3 |
| Fuel Efficiency | mi/gal | 4 | 4 | Assumed average to/from site | | 3 |
| Truck Cost | \$/100 lb freight | \$0.00 | \$19.92 | Price for Fairbanks to Prudhoe Bay Ref 3, Escalated 2012 cost @ 3%/yr and adjusted for milage. | | 3 |
| Fuel Surcharge | \$/gal fuel | \$0.00 | \$5.98 | Assumed 30% | | |
| Total Transit Cost | per container | \$0 | \$10,370 | | | |
| | \$/gal | \$0.00 | \$2.07 | | | |
| Delivered Ammonia Cost | \$/gal | \$5.67 | \$5.27 | | | |

| | | |
|------------------------|---|--|
| URS | CALCULATION SHEET | Calculation No. USAG-EC-PCCAL-00-000147 |
| | | Project No. 31409 |
| Project Title: _____ | Alaska LNG | Sheet No. <u> 2 </u> of <u> 6 </u> |
| Subject/Feature: _____ | SCR, CO, and Ammonia Costs for Pre-BACT | Rev: A |

SCR Catalyst

| | | Case A | Case B | Case C | Case D | | | Ref. |
|-------------------------------|---------|---------------|---------------|---------------|---------------|---------------|---------------|------------------|
| Reference (for turbine data) | | [7] | [7] | [7] | [7] | [7] | [7] | [8] |
| Reference for Cost | | | | | | | | [3] |
| | | No heat | with heat | DLN1+ | DLN1 | | | |
| Gas Turbine | | LM6000 | LM6000 | Frame6 | Frame6 | Heater | PGT25+ | Frame 7EA |
| Drive | | Power Gen | Power Gen | Mechanical | Mechanical | | | Mechanical |
| Exhaust Stream | | | | | | | | |
| Mass Flow | [lb/hr] | 1,135,408 | 1,082,488 | 1,291,288 | 1,291,288 | 243,609 | 648,000.00 | 2,293,200.00 |
| Volume Flow | [ACFM] | 657,282 | 626,647 | 747,520 | 747,520 | 93,493 | 379,037.00 | 1,464,659 |
| | [SCFM] | 251,314 | 239,600 | 285,816 | 285,816 | 105,688 | 139,688 | 511,156 |
| Stack Diameter | [ft] | 10 | 10 | 13 | 10 | | | |
| SCR Catalyst Replacement Cost | | \$ 187,567.22 | \$ 178,824.94 | \$ 213,318.29 | \$ 213,318.29 | \$ 78,879.67 | \$ 104,255.47 | 350,000 |

Notes

1) Scaled costs from 2012 budgetary price for Frame 7EA [3] based on ACFM. New costs include 9% escalation to 2015 dollars as discussed in reference [5].

| | | |
|-------------------|--|------------------------|
| ALASKA LNG | Alaska Gasline Development Corporation Alaska Department of Environmental Conservation BACT AQ1524CPT01 and AQ1539CPT01 Information Request | Date: January 10, 2020 |
| | Public | Appendix C.3 |

APPENDIX C.3

GTP Cost Estimate Basis for SCR Cost Evaluation (Confidential)

PRIVILEGED AND CONFIDENTIAL - DO NOT RELEASE

GTP Cost Factors for SCR Cost Control Calculation

| Cost Category | GTP Cost Estimate Basis Line Item (see MFS and North Slope Estimate tabs) | Cost Estimate % | AGDC Factor ¹ | EPA Factor ² | Comments Regarding AGDC Approach |
|---|--|-----------------|--------------------------|-------------------------|--|
| Direct Capital Costs | | | | | |
| Instrumentation & Controls | | | 0% | 10% | Included in purchased equipment |
| Freight | | | | 5% | |
| | FREIGHT TO MODULE FABRICATION SITE | 10% | 11% | | Freight from US Vendor to MFS |
| | MISC FREIGHT TO NORTH SLOPE | 1% | | | Freight from Lower-48 to North Slope |
| | | | | | |
| Taxes (Enter sales tax rate in "% Applied") | | | 0% | 3% | No sales tax in Alaska. |
| Direct Installation Costs: | | | | | |
| Foundation & Supports | NS- EARTHWORK, STRUCTURAL STEEL | 9% | 9% | 8 - 12% | 50% of North Slope module pile foundations and supporting structural steel installation cost ratio |
| Erection and Handling | MFS -STRUCTURAL STEEL | 30% | 31% | 14 - 40% | 40% of the Structural Steel portion of the MFS installation cost ratio |
| | NS - MECHANICAL / HVAC EQUIPMENT | 1% | | | Mechanical portion of the MFS installation cost ratio |
| Electrical | MFS- ELECTRICAL, INSTRUMENTATION | 4% | 4% | 1 - 4% | 50% of Electrical portion of the MFS installation cost ratio, includes instrumentation |
| Piping | MFS - PIPING | 5% | 5% | 2% | 10% of Piping portion of the MFS installation cost ratio |
| Insulation | MFS-INSULATION | 7% | 7% | 1% | 30% Insulation portion of the MFS installation cost ratio |
| Indirect Capital Costs | | | | | |
| Indirect Costs: | | | | | |
| Engineering & Supervision | | | | 10% | |
| | MFS- GENERAL CONTRACTOR CM | 5% | 16% | | MFS site engineering and construction management |
| | NS- CONTRACTOR CM @ SITE | 11% | | | North Slope engineering and construction management |
| Project Contingency | | | 15% | 3% | Level IV Cost Estimate Basis contingency |

1 - Cost factors updated in January 2020 based on revised evaluation of potential costs.

2 - EPA factors as described in EPA Air Pollution Control Cost Manual, 6th Edition, EPA/452/B-01-001, January 2002.

PRIVILEGED AND CONFIDENTIAL - DO NOT RELEASE

Source **Gas Treatment Plant Class IV Estimate Optimization Phase**
 Document: **AKLNG-4010-BBB-EST-DOC-00001(Confidential)**

CLIENT: Alaska LNG
 PROJECT: Gas Treatment Plant
 LOCATION: Prudhoe Bay, Alaska
 JOB NO.: 31409
 REV NO.: 0

DATE: 07-Jul-16
 PREPARED BY: IJH / MLH
 WAGE RATE (Blended): \$25.18



**OPTIMIZATION PHASE - GAS TREATMENT PLANT
 OVERALL MFS SUMMARY**

| ACCT. | DESCRIPTION | DIRECT HIRE | | | TOTAL | [%] COSTS | WEIGHT [ST] | WEIGHT [MT] |
|-------|--------------------------------------|-------------------|------------------------|------------------------|------------------------|--------------|----------------|----------------|
| | | HOURS | LABOR | MATERIALS | | | | |
| 01 | DEMOLITION | | | | | | | |
| 02 | IMPROVEMENTS TO SITE | | | | | | | |
| 03 | EARTHWORK | | | | | | | |
| 04 | CONCRETE | | | | | | | |
| 05 | STRUCTURAL STEEL | 31,158,788 | \$784,221,019 | \$276,495,489 | \$1,060,716,508 | 43% | 111,420 | 100,359 |
| 06 | MECHANICAL / HVAC EQUIPMENT | 362,723 | \$8,893,708 | \$779,091,787 | \$787,985,495 | 32% | 49,923 | 45,172 |
| 11 | PIPING | 4,993,879 | \$123,298,190 | \$114,826,059 | \$238,124,249 | 10% | 31,587 | 28,601 |
| 12 | ELECTRICAL | 421,615 | \$10,959,269 | \$146,699,119 | \$157,658,388 | 6% | 13,759 | 12,432 |
| 13 | INSTRUMENTATION | 225,375 | \$5,735,712 | \$58,324,827 | \$64,060,539 | 3% | 1,154 | 1,045 |
| 14 | PAINTING | 84,698 | \$2,163,784 | \$10,497,706 | \$12,661,490 | 1% | 1,108 | 998 |
| 15 | INSULATION | 844,154 | \$23,414,643 | \$79,739,753 | \$103,154,396 | 4% | 8,048 | 7,117 |
| 16 | ARCHITECTURAL | 179,802 | \$5,065,259 | \$20,823,161 | \$25,888,421 | 1% | 5,517 | 4,911 |
| | DIRECT COSTS | 38,271,034 | \$963,751,585 | \$1,486,497,901 | \$2,450,249,486 | 100% | 222,516 | 200,636 |
| 31 | GENERAL CONTRACTOR CM | 846,644 | \$135,463,000 | | \$135,463,000 | | | |
| 32 | CRAFT LABOR RELATED EXPENSES | | | | INCL. IN WAGE RATE | | | |
| 33 | TEMPORARY FACILITIES | | | | INCL. IN WAGE RATE | | | |
| 41 | CONSTR EQUIP, TOOLS, SUPPLIES | | | | INCL. IN WAGE RATE | | | |
| 42 | SMALL TOOLS & CONSUMABLES | | | | INCL. IN WAGE RATE | | | |
| 49 | CONSTRUCTION CAMP (Not Included) | | | | INCL. IN WAGE RATE | | | |
| 51 | STARTUP CRAFT SUPPORT ALLOWANCE | | | | INCL. IN WAGE RATE | | | |
| 22 | FREIGHT TO MODULE FABRICATION SITE | 10% of Materials | | \$148,649,790 | \$148,649,790 | | | |
| | INDIRECT COST | 846,644 | \$135,463,000 | \$148,649,790 | \$284,112,790 | | | |
| | TOTAL MODULE FABRICATION SHOP | 39,117,678 | \$1,099,214,585 | \$1,635,147,691 | \$2,734,362,276 | | | |

PRIVILEGED AND CONFIDENTIAL - DO NOT RELEASE

Source: Gas Treatment Plant Class IV Estimate Optimization Phase AKLNG-4010-
 Document: BBB-EST-DOC-00001(Confidential)

CLIENT: Alaska LNG
 PROJECT: Gas Treatment Plant
 LOCATION: Prudhoe Bay, Alaska
 JOB NO.: 31409
 REV NO.: 0
 OPTIMIZATION PHASE - GAS TREATMENT PLANT
 NORTH SLOPE SITEWORK



DATE: 07-Jul-16
 PREPARED BY: IJH / MLH
 WAGE RATE (Blended): \$87.95

| ACCT. | DESCRIPTION | FABRICATION (CHINA & NORTH AMERICA) | | | DIRECT HIRE | | | SPECIALTY SUBCONTRACTORS | | TOTAL | [%] Costs | WEIGHT [ST] | WEIGHT [MT] |
|-------|---|-------------------------------------|---------------------|----------------------|-------------------|------------------------|----------------------|--------------------------|------------------------|------------------------|-------------|--------------|--------------|
| | | HOURS | LABOR | MATERIALS | HOURS | LABOR | MATERIALS | HOURS | Total | | | | |
| 01 | DEMOLITION | | | | | | | | | | | | |
| 02 | IMPROVEMENTS TO SITE | | | | | | | | | | | | |
| 03 | EARTHWORK | 417,136 | \$19,509,499 | \$82,356,940 | 594,618 | \$52,326,431 | \$15,886,804 | 659,829 | \$324,191,851 | \$494,271,525 | 51% | | |
| 04 | CONCRETE | | | | | | | | | | | | |
| 05 | STRUCTURAL STEEL | 410,317 | \$9,740,919 | \$5,760,672 | 543,342 | \$47,814,108 | \$12,096,622 | | | \$75,412,321 | 8% | 14 | 13 |
| 06 | MECHANICAL / HVAC EQUIPMENT | | | | 326,428 | \$28,725,665 | \$638,919 | | | \$29,364,584 | 3% | 3,128 | 2,838 |
| 11 | PIPING | 56,066 | \$1,331,011 | \$84,565,274 | 219,249 | \$19,293,890 | \$13,318,545 | | | \$118,508,719 | 12% | 520 | 472 |
| 12 | ELECTRICAL | | | | 455,918 | \$40,117,666 | \$26,005,762 | | | \$66,123,428 | 7% | 1,421 | 1,289 |
| 13 | INSTRUMENTATION | | | | 11,826 | \$849,691 | \$27,375,692 | | | \$28,225,383 | 3% | 664 | 603 |
| 14 | PAINTING | | | | 21 | \$1,859 | \$5,776 | | | \$7,635 | 0% | 0 | 0 |
| 15 | INSULATION | | | | 2,694 | \$237,031 | \$30,217 | | | \$267,248 | 0% | 5 | 5 |
| 16 | ARCHITECTURAL MODULE INTERCONNECTS | | | | 1,778,464 | \$156,504,832 | | | | \$156,504,832 | 16% | | |
| | DIRECT FIELD COSTS | 883,519 | \$30,581,428 | \$172,682,886 | 3,932,559 | \$345,871,173 | \$95,358,337 | 659,829 | \$324,191,851 | \$968,685,675 | 84% | 5,753 | 5,220 |
| 32 | CRAFT LABOR RELATED EXPENSES & INDIRECT CRAFT | | | | 1,110,073 | \$97,631,689 | \$0 | | | \$97,631,689 | 4% | | |
| 32 | CRAFT TRAVEL | | | | | | \$31,067,241 | | | \$31,067,241 | | | |
| 41 | SCAFFOLDING | | | | 705,193 | \$62,022,218 | \$6,004,627 | | | \$68,026,845 | 2% | | |
| 51 | START-UP & COMMISSIONING | | | | 509,572 | \$44,817,168 | | | | \$44,817,168 | 2% | | |
| 42 | SMALL TOOLS AND CONSUMABLES | | | | | | | | | INCL. IN WAGE RATE | | | |
| 41 | TEMPORARY FACILITIES | | | | 1,547,992 | \$136,146,942 | \$39,466,880 | | | \$175,613,822 | 6% | | |
| 41 | CONSTRUCTION EQUIPMENT | | | | 1,107,891 | \$97,439,752 | \$103,460,869 | | | \$200,900,621 | 7% | | |
| 41 | CONSTRUCTION EQUIPMENT HEAVY LIFT CRANES | | | | 356,446 | \$31,349,625 | \$38,500,000 | | | \$69,849,625 | | | |
| 41 | CRAFT BUSSING | | | | 499,846 | \$43,961,772 | \$4,500,000 | | | \$48,461,772 | 2% | | |
| 22 | MISC FREIGHT TO NORTH SLOPE | | | | | | | | \$18,000,000 | \$18,000,000 | 1% | | |
| 22 | LOGISTICS | | | | | | | | \$695,642,241 | \$695,642,241 | 25% | | |
| 51 | CONTRACTOR CM @ SITE | | | | 1,758,387 | \$304,201,000 | | | | \$304,201,000 | 11% | | |
| 51 | CONTRACTOR CM @ ANCHORAGE | | | | 236,234 | \$30,237,952 | | | | \$30,237,952 | 1% | | |
| | INDIRECT FIELD COSTS | 883,519 | \$30,581,428 | \$172,682,886 | 11,764,194 | \$1,193,679,289 | \$318,357,955 | 659,829 | \$1,037,834,092 | \$2,753,135,650 | 100% | 2.84 | |