

# STATE OF ALASKA

SEAN PARNELL, GOVERNOR

DEPT. OF ENVIRONMENTAL CONSERVATION

**DIVISION OF SPILL PREVENTION AND RESPONSE  
CONTAMINATED SITES PROGRAM**

555 Cordova Street  
Anchorage, AK 99501  
PHONE (907) 269-3077  
FAX (907) 269-7649  
www.dec.state.ak.us

File No: 2649.38.001

January 6, 2012

Keith Barnack, Remedial PM  
United States Air Force  
611 Air Support Group  
Environmental Restoration Section  
10471 20th Street Ste 302  
JBER, AK 99506-2200

Re: Eareckson Air Station Leaking Underground Storage Tank 522-2  
ADEC Tank #75 Site Closure


Dear Mr. Barnack:

The Alaska Department of Environmental Conservation (ADEC) Federal Facilities Oversight group is concerned about a large number of Leaking Underground Storage Tanks (LUST) sites that are located at Eareckson Air Station. Tank 522-2 was a 20,000 gallon diesel storage tank that contained the fuel supply for heating at Building 522.

ADEC has reviewed the available information regarding Tank 522-2 (ADEC Tank #75) and its removal in July 1997. Based on the sampling and analysis performed in 1997 and again in 1999, the maximum concentration of DRO was 706 mg/kg in 1999. However, this concentration was observed adjacent to the building where the pipeline was removed and a small amount of fuel was released from the pipe during its removal. No other release was associated with the tank or its pipeline during its operation. The extent of the impacted soil is small and has been delineated horizontally and vertically. This site will be closed on the ADEC Contaminated Sites database.

The State appreciates your continued coordination on this and other projects at Eareckson Air Station. If you have any questions regarding this letter, please contact me at (907) 269-3077 or [jonathan.schick@alaska.gov](mailto:jonathan.schick@alaska.gov).

Sincerely,



Jonathan Schick  
Environmental Program Specialist