

STATE OF ALASKA

**DEPT. OF ENVIRONMENTAL CONSERVATION
DIVISION OF SPILL PREVENTION AND RESPONSE
CONTAMINATED SITES PROGRAM**

Frank Murkowski, Governor

43335 K-Beach Road, Suite 11
Soldotna, AK 99669
PHONE: (907) 262-5210
FAX: (907) 262-2294
<http://www.state.ak.us/dec/>

File: 2331.38.003

14 January 04

Mr. Duane Parlow
Homer Electric Association, Inc.
3977 Lake Street
Homer, Alaska 99603

FILE COPY

Re: HEA Seldovia Transformer; ADEC Spill # 2003230127201
No Further Remedial Action Required

Dear Mr. Parlow:

The Department has received the *Soil Sampling, Seldovia Transformer Release* report dated 24 November 03. This site has been entered into the ADEC Contaminated Sites database with the site name and spill number referenced above. Please include this information on any future correspondence regarding this site.

Based on our review of the data included in the report, the Department has determined that no further remedial action is required at this time. However, should activities at the site provide access to the contaminated soils beneath the transformer, additional assessment and/or corrective action will be required at that time.

Please provide documentation on the removal and proper disposal of the drum of approximately 20 gallons of contaminated water that was removed from the excavation.

In conclusion, ADEC has determined that no further remedial action is required for the Seldovia transformer site at this time. However, please be advised that should the contaminated soils become accessible, or if contamination is identified in the future that may pose a risk to human health or the environment, additional investigative and/or corrective action work may be required.

If you have any questions or need further assistance, please contact me at (907) 262-5210, ext. 233.

Any person who disagrees with this decision may request an adjudicatory hearing in accordance with 18 AAC 15.195 - 18 AAC 15.340 or an informal review by the Division Director in accordance with 18 AAC 15.185. Informal review requests must be delivered to the Division Director, 410 Willoughby Avenue, Suite 303, Juneau, Alaska 99801, within 15 days after receiving the department's decision reviewable under this section. Adjudicatory hearing requests

must be delivered to the Commissioner of the Department of Environmental Conservation, 410 Willoughby Avenue, Suite 303, Juneau, Alaska 99801, within 30 days after the date of issuance of this letter, or within 30 days after the department issues a final decision under 18 AAC 15.185. If a hearing is not requested within 30 days, the right to appeal is waived.

Sincerely,



Don Seagren
Environmental Specialist

CC: John Frohrip, City of Seldovia
Nino Muniz, Hart Crowser, Inc./Anchorage

FILE COPY