

Tesoro Alaska Company LLC

Kenai Refinery 54741 Tesoro Road Kenai, AK 99611 Tel: 907-776-8191

July 1, 2020

Pete Campbell
Environmental Specialist.
Alaska Department of Environmental Conservation
43335 K-Beach Road, Suite 11
Soldotna, Alaska 99669

Submitted via email: Peter.Campbell@alaska.gov

Re: Treated Groundwater Injection Permit Quarterly Report

Dear Mr. Campbell:

Enclosed is the report for Tesoro's Kenai Refinery groundwater remediation system for April 1 through June 30, 2020. This data is to be submitted on a quarterly basis required by the Treated Groundwater Injection Plan.

The Treated Groundwater Injection Plan (plan) was revised and approved by the Alaska Department of Environmental Conservation, Contaminated Sites Program (ADEC), on October 31st 2017. As per the revised plan, Trihydro Corporation supplied a Qualified Environmental Professional (QEP) to collect and report the required data.

If you have any questions, please contact me at (907) 776-2090.

Sincerely,

Stephanie Plate, PE Environmental Engineer

Enclosure (1)



APRIL, MAY, JUNE 2020 TREATED GROUNDWATER REPORT PREPARED FOR TESORO ALASKA COMPANY, LLC

July 1, 2020

Project #: 39B-003-005

SUBMITTED BY: Tesoro Alaska Company, LLC

54741 Tesoro Road, Kenai, AK 99611

PREPARED BY: Trihydro Corporation

312 Tyee Street, Soldotna, AK 99669

CERTIFICATION STATEMENT

APRIL, MAY, JUNE 2020

TREATED GROUNDWATER REPORT

PREPARED FOR TESORO ALASKA COMPANY, LLC

I certify that the work presented in this report was performed by me or under my supervision. To the best of my knowledge, the data contained herein are true and accurate and the work was performed in accordance with professional standards.



Brianna Force, Project Manager

Qualified Environmental Professional in accordance with 18 AAC 75.333

Introduction

This report summarizes the treated groundwater activities for the first quarter of 2020 (April, May, and June) at the Marathon Kenai Refinery; as required by Treated Groundwater Injection Plan.

Results Summary

The PM system is inactive; therefore, all groundwater continues to be diverted to the Calgon treatment system. Samples were collected monthly from the Calgon treatment system effluent and analyzed for the constituents listed on Table 1. The Calgon effluent samples were all below criteria for benzene and non-detect for all other constituents. All Calgon system flow limits and effluent concentrations were below ADEC criteria for the quarter. The latest carbon replacement occurred on October 8, 2019.

Table 1 summarizes flow and sample results for the Calgon treatment system.



TABLE 1. TREATED WATER FLOW AND EFFLUENT ANALYTICAL RESULTS MARATHON KENAI REFINERY APRIL, MAY, JUNE 2020

Calgon Unit		APRIL	MAY	JUNE
	Limit			
Total Flow (gpd)*	1,000,000	237,600	257,760	240,480
Sample Collection Date		4/1/2020	5/4/2020	6/2/2020
Effluent Limits (μg/L)				
Benzene	4.6	U (0.4)	0.521	0.599
Toluene	1,100	U (1.0)	U (1.0)	U (1.0)
Ethylbenzene	15	U (1.0)	U (1.0)	U (1.0)
Total Xylenes	190	U (3.0)	U (3.0)	U (3.0)
n-Butylbenzene	1,000	U (1.0)	U (1.0)	U (1.0)
sec-Butylbenzene	2,000	U (1.0)	U (1.0)	U (1.0)
tert-Butylbenzene	690	U (1.0)	U (1.0)	U (1.0)
Isopropylbenzene(cumene)	450	U (1.0)	U (1.0)	U (1.0)
Napthalene	1.7	U (1.0)	U (1.0)	U (1.0)
1,2,4-Trimethylbenzene	15	U (1.0)	U (1.0)	U (1.0)
1,3,5-Trimethylbenzene	120	U (1.0)	U (1.0)	U (1.0)

μg/L - micrograms per liter

U - Non-Detectable at (detection limit)

gpd- gallons per day

Bolded results are above ADEC standards

^{*}Flow at time of sample collection