

April 2011 SNC List

Contact Information and Acronym Definitions list at bottom of List.

Note: Column titled "Estimated New SNC Score" is the new score based on the violations that have Returned to Compliance (RTC'd) during the Quarter. Please note that this score will likely change on the next quarter's List due to further violations being generated.

OFFICE	STAFF	Estimated New SNC Score	RMW	SYSTEM INFORMATION	10 Point		5 Point					1 Point							General Status Comments	How to Return to Compliance	Known Hardware Problems Comments	
					SW	Nitrate	TCR	SW	Nitrate	Arsenic	Stage 1	LCR	TCR	SW	Arsenic	Stage 1	LCR	IOC				VOC
Southcentral/ANC	DRAKE, HANNAH	20	No RMW	ALASKA WEST KANEKTOK RIVER CAMP / AK2272003 (TNCWS / 45)																Failed to sample for Nitrate and did not turn in operator reports since August 2010.	Sample for Nitrate and turn in operator report.	No known hardware problems.
Kenai/Southeast	BJORKMAN, JAMIE	50	SEARHC	ANGOON PUBLIC WATER / AK2130017 (CWS / 450)																System has elevated HAA5s.	Obtain one quarter without RAA MCL violations for HAA5s.	Water treatment plant is in the process of being upgraded in order to address elevated DBPs.
Southcentral/ANC	EDMUNDS, DAVID	18	No RMW	BAYVIEW TERRACE / AK2261460 (CWS / 120)																System has received violations for Nitrate, arsenic, TCR, and Lead and Copper.	System needs to sample for TCR, Nitrate, arsenic and lead and Copper to Return to Compliance.	No known hardware problems.
Kenai/Southeast	BJORKMAN, JAMIE	82	No RMW	BEAR TRACK INN / AK2111472 (TNCWS / 46)	8															System needs to address their turbidity problems.	Meet turbidity requirements for the next monitoring round.	Upgrades to treatment system may be needed to address ongoing elevated turbidity. Further evaluation needed.
Southcentral/ANC	EDMUNDS, DAVID	15	No RMW	BRISTOL BAY CONTRACTORS WELL / AK2262636 (TNCWS / 79)																System received violations for Nitrate and TCR.	System needs to submit nitrate and TCR to Return to Compliance.	No known hardware problems.
Northern	WILLIAMS, ELLEN	80	Manilaq	BUCKLAND WATER SYSTEM / AK2340125 (CWS / 417)																System is having a problem with high DBP's (TTHM) RAA MCL.	System needs treatment plant upgrade to address TTHM RAA MCL and needs to continue to post PN for this.	In January 2011 DEC provided VSW comments on treatability study to support conventional treatment package plant; request for construction approval is expected this spring. In 2010 the PWS had problems with the existing "interim" water treatment plant (WTP) not meeting turbidity performance criteria. VSW has recently (May 2011) submitted plans for upgrades to the existing WTP including installation of an SCD, bypass of contact clarifiers and thermal conditioning of the raw water so they can improve performance of the existing filtration system until new filtration plant is constructed.
Kenai/Southeast	BJORKMAN, JAMIE	11	No RMW	CAMP BEAR BARGE / AK2131123 (TNCWS / 43)	1															SW TT for turbidity violation	Meet turbidity requirements for next monitoring round.	System has moved onto a new source and may need to upgrade to the system to address turbidity problems. System is currently in plan review.
Kenai/Southeast	BJORKMAN, JAMIE	15	No RMW	CLEARWATER BARGE / AK2121409 (NTNCWS / 32)	1															SW TT for turbidity violation	Meet turbidity requirements for next monitoring round.	System has moved onto a new source and may need to upgrade to the system to address turbidity problems. System is currently in plan review.
Southcentral/ANC	EDMUNDS, DAVID	14	No RMW	COFFEE POINT SEAFOODS / AK2262678 (TNCWS / 65)																System received violations for Nitrate.	System needs to submit Nitrate Sample to Return to compliance.	No known hardware problems.
Kenai/Southeast	BJORKMAN, JAMIE	15	No RMW	DECANTER INN HOTEL / AK2249978 (TNCWS / 31)																Seasonal System, owner will take nitrate sample as soon as they open.	Collect and submit a nitrate sample and a total Coliform sample.	No known hardware problems.
Southcentral/ANC	EDMUNDS, DAVID	16	No RMW	DILLINGHAM WATER SYSTEM / AK2260197 (CWS / 962)																System has received violations for nitrate, Lead and copper.	System needs to submit nitrate, Lead and Copper to Return to Compliance.	No known hardware problems.
Mat-Su	SMITH, LEANN	11	No RMW	EAST BIG LAKE MALL / AK2224581 (NTNCWS / 25)																Need complete Engineering submittal	RTC is achieved when analytical results demonstrate that the RAA is less than the arsenic MCL at the sampling point of exceedance after a <b>minimum of two consecutive quarters</b> at the sampling point for a <b>ground water system</b> .	No known hardware problems.
Southcentral/ANC	EDMUNDS, DAVID	13	No RMW	EDDIES FIREPLACE INN / AK2261486 (TNCWS / 64)																System received violations for Nitrate.	System needs to submit Nitrate Sample to Return to compliance.	No known hardware problems.
Southcentral/ANC	TADINA, LETICIA	13	No RMW	ESTELL S/D, LOT 2 / AK2216902 (CWS / 90)																System exceeds the MCL for Arsenic.	Connect to Anchorage Water and Wastewater Utility or install treatment.	No known hardware problems.
Southcentral/ANC	EDMUNDS, DAVID	17	No RMW	FOX CREEK TOWNHOUSES / AK2261101 (CWS / 36)																System has received violations for TCR, Nitrate, and Lead and copper, and CCR.	System needs to submit nitrate, Lead and Copper, and CCR to Return to Compliance.	No known hardware problems.
Mat-Su	SMITH, LEANN	13	No RMW	GLENNALLEN HEIGHTS GHWSA / AK2291504 (CWS / 32)																Continuing Engineering approval for Point of Use (POU) devices.	RTC achieved when the system reports one complete round of valid lead and copper tap samples.	No known hardware problems.
Northern	WILLIAMS, ELLEN	87	NSHC	GOLOVIN COMMUNITY WATER SYSTEM / AK2340214 (CWS / 150)																System is having problems with high DBP's (TTHM/HAA5) RAA MCL's. System has a Copper first draw Action Level exceedance. System needs to submit Sanitary Survey.	System needs treatment plant upgrades to address TTHM/HAA5 RAA MCL's and Copper Action Level, and needs to continue to post PN for both. A completed sanitary survey report needs to be submitted for the system.	Needs new treatment system as soon as possible to address high TTHM/HAA5 & meet LT1/LT2. Has 2 sand filters followed by a cartridge filter, followed by 3 bag filters in parallel. Alternative filtration does not meet LT1. New WTP is in planning stages but there have been delays on this ANTHC lead project.
Southcentral/ANC	DRAKE, HANNAH	55	YKHC	GRAYLING WATER SYSTEM / AK2280066 (CWS / 195)																Failed to sample for Nitrate and other contaminants, and does not turn in water operator reports.	Sample for Nitrate, Arsenic, TTHM & HAA5, VOC, SOC waiver 2011-2013. Turn in completed monthly operator report and have all required chlorine and turbidity samples.	ANTHC water distribution mains replacement project construction postponed w/ lack of funding & unmet RUBA essential indicators & SNC status. System on Boil Water Notice due to inadequate filtration.
Mat-Su	SMITH, LEANN	13	No RMW	GREEN STORE, THE / AK2226795 (TNCWS / 48)																Need confirmation GWR TCRs/Engineering Plan	RTC is achieved when the PWS complies with monitoring parameters which caused the violation, during the next month of operation	No known hardware problems.





OFFICE	STAFF	Estimated New SNC Score	RMW	SYSTEM INFORMATION	10 Point		5 Point					1 Point										General Status Comments	How to Return to Compliance	Known Hardware Problems Comments
					SW	Nitrate	TCR	SW	Nitrate	Arsenic	Stage 1	LCR	TCR	SW	Arsenic	Stage 1	LCR	IOC	VOC	SOC	Birds			

**Contact Information**

**Matsu** = Office located in Wasilla, AK covers the Matsu area (Staff: Tee Little (EPS) 376-1860, LeeAnn Smith (EPS) 376-1844, Jeff Warner (Program Coordinator ) 376-1861, Roy Robertson (Engineer) 376-1862.

**Northern** = Office located in Fairbanks, AK covers the Northern Alaska PWSs (Staff: Linda Grantham (EPS) 451-2137, Ellen Williams (EPS) 451-2231, Dawn Bodyfelt (EPS) 451-2170, Audrey Lammers (EPS) 451-3038, Lee Johnson (Engineer) 451-2179)

**Southcentral / ANC** Office located in Anchorage, AK covers Anchorage bowl, Bethel/YK Delta, Dillingham area, Aleutian Chain, Pribilof and Kodiak Islands area PWSs (Staff: David Edmunds (EPS) 269-7653, Leah Guzman (EPS) 269-7518, James Latimer (EPS) 269-7521, Leticia Tadina (EPS) 269-7517, Hannah Drake (EPS) 269-7594, Sarah Rygh (Engineer) 269-3076

**GENERAL SNC QUESTIONS:** Jeanine Oakland (EPS) 269-2007 or Kelly Cobbs (EPS) 269-7630

**Kenai / Southeast** = Office located in Soldotna, AK covers the Kenai Peninsula and Southeast area. Staff: Eric Burg (EPS) 262-5210 x246, Jamie Bjorkman (EPS) 262-5210 ext251, Scott Forgue (Engineer) 262-5210 x243, David Khan (Engineer) 465-5317

**Remote Maintenance Worker (RMW) Service Area Abbreviations**

- APIA= Aleutian Pribilof Island Association
- BBAHC= Bristol Bay area Health Corporation
- DEC = AK Department of Environmental Conservation
- NSHC= Norton Sound Health Corporation
- SEARHC= Southeast Alaska Regional Health Consortium
- TC= Tanana Chiefs Conference
- YKHC= Yukon Kuskokwim Health Corporation
- No-RMW= Not served by Remote Maintenance Worker Programs

[To contact a local RMW please visit this site.](#)

**Definitions**

- AL= Action Level
- ANTHC= Alaska Native Tribal Health Consortium
- ARWA= Alaska Rural Water Association
- BACTI or t-Coli = Total Coliform Sample
- BWN = Boil Water Notice
- CCR = Consumer Confidence Report
- CFE= Combined Filter Effluent
- DPB = Disinfection by Products
- EHO= Environmental Health Officer
- EP= Entry Point
- EPA= Environmental Protection Agency
- EPRD= Entry Point Residual Distribution
- FANLs= Facility Analyte Level (refers to SW/Stage 1 monitoring requirements)
- HAA5 = Haloacetic Acids (Stage 1 Rule)
- IDSE = Initial Distribution System Evaluation (Stage 2 requirement)
- IFE= Individual Filter Effluent
- IOC = Inorganic Chemicals
- LEAD= Lead/Copper Rule
- LT1 = Long Term 1 Enhanced Surface Water Treatment Rule
- LT2 = Long Term 2 Enhanced Surface Water Treatment Rule
- M/R= Monitoring and Reporting (type of violation)
- MCL = Maximum Contaminant Level (type of violation)
- NOV= Notice of Violation
- OCC = optimal corrosion control or corrosion control program (Lead/Copper Rule)
- Pb/Cu= Lead and Copper
- PN= Public Notice
- PWS= Public Water System
- RAA= Running Annual Average
- RADS= Radionuclides Rule
- RMW= Remote Maintenance Worker
- RTC = Return to compliance (fall off SNC list)
- SOC = Synthetic Organic Chemicals
- STAGE 1 = Stage 1: Disinfectants and Disinfection By Products Rule
- Surface Water (SW)= Surface Water SNC for violations of SWTR and LT1
- SWTR = Surface Water Treatment Rule
- TC= Total Coliform
- TCR = Total Coliform Rule (Also called Bact)
- TT= Treatment Technique (violation)
- TTHM = Total Trihalomethanes (Stage 1 Rule)
- VOC = Volatile Organic Chemicals
- VSW= Village Safe Water
- WTP= Water Treatment Plant