



School Public Water System Report Card

4th Quarter 2004 (Oct. – Dec.)

Overall 4th Quarter Grade – *C*

Crow Village School
PWS ID # 270883

Are you an A+ System?

- A** = Outstanding Compliance in all areas - Health based standards are being met.
B = Above Average Compliance; no significant issues.
C = Areas that need improvement - Health based standards are not being met.
D = Below Average System; needs concentrated efforts for improvement.

2004 Quarter:		1 st	2 nd	3 rd	4 th	Comments
✓	Meeting All MCL's (Health Based Standards on submitted samples)	A	A	A	A	No Maximum Contaminant Limits have been exceeded.
✓	Meeting Monitoring Requirements	A	A	A	A	Completed all monitoring requirements
✓	Sanitary Survey Completed	S	S	S	S	System has a current survey.
✓	SNC List	S	S	S	S	
✓	Approval to Operate on file w/ADEC	U	U	U	U	Contact your ES to follow up on this issue.
✓	Previous Violations (returned to compliance/closed)	F	F	F	F	

Comments:

This system is overdue for complying with corrosion control requirements. Please review your current monitoring summary for the corrosion control steps that need to be taken.

Questions? Contact your Environmental Specialist, Doug Zellmer, at (907) 269-7623 or contact Kathy Kastens at (907) 269-7639