



School Public Water System Report Card

4th Quarter 2004 (Oct. – Dec.)

Overall 4th Quarter Grade –



Kipnuk High School
PWS ID # 270728

Are you an A+ System?

- A** = Outstanding Compliance in all areas - Health based standards are being met.
B = Above Average Compliance; no significant issues.
C = Areas that need improvement - Health based standards are not being met.
D = Below Average System; needs concentrated efforts for improvement.

2004 Quarter:		1 st	2 nd	3 rd	4 th	Comments
✓	Meeting All MCL's (Health Based Standards on submitted samples)	D	B	A	A	No Maximum Contaminant Limits have been exceeded.
✓	Meeting Monitoring Requirements	A	A	A	A	Completed all monitoring requirements
✓	Sanitary Survey Completed	S	S	S	U	Your system is overdue for a sanitary survey
✓	SNC List	U	U	U	U	
✓	Approval to Operate on file w/ADEC	U	U	U	U	Contact your ES to follow up on this issue.
✓	Previous Violations (returned to compliance/closed)	F	F	F	F	

Comments:

Your system is overdue for a sanitary Survey. ADEC has not received a submittal for the recent treatment upgrades. Please be sure to collect samples required by corrosion control requirements and complete/submit a desktop study by June 30, 2005. Please ensure that the required monitoring is performed for SWTR so this system can be removed from the SNC List.

Questions? Contact your Environmental Specialist, Doug Zellmer, at (907) 269-7623 or contact Kathy Kastens at (907) 269-7639