

October 2006 SNC List

UPDATED
(as of December 19, 2006)

CHANGES NOTED IN BOLD RED System that has returned to compliance (RTCd) for <u>ALL SNCs</u> noted by a <u>strikeout</u> through system name (also noted in comments) System that RTCd for a single rule noted by <u>strickethrough</u> of the rule (also noted in comments) Bolded/Blue System Name - Current or Pending EPA Enforcement Systems				RULE										Environmental Specialist Comments RED TEXT as of December 19, 2006 (Black Text As of October 30, 2006)	
Office	Drinking Water Program Staff	RMW Service Area	System Name / PWSID (System Type/Population)	TCR (Bacti)	Surface Water	STAGE1	NITRATE	IOC	VOC	ARSENIC	SOC	LEAD	RAD	CCR	
SC-Soldotna	David Litchfield	Non-RMW	AGRIUM KENAI NITROGEN/AK2240919 (NTNC/330)			▼									Last Stage 1 violation in April 2006 (5 of 12 months towards RTC)
SC-Anchorage	David-Edmunds	Kodiak/Kenai	AKHIOK/AK2250037 (CWS/90)		▼										COBC issued for SWTR and Stage 1 violations, system signed COBC in December.
SC-Anchorage	Doug Zellmer	YKHC	AKIACHAK WATER SYSTEM /AK2272747 (CWS/560)						▼						8/22/06 - Spoke w/ operator about overdue VOC sampling and recent violations. Told operator that he needed to contact the lab for a sample kit, which he said he would do, and also sent him an updated monitoring summary. 8/29/06 - Spoke w/ onsite contractor working w/ system about due and overdue samples. He said he would assist system in getting samples in. ***HOW TO RTC*** New water system must complete initial quarterly VOC monitoring to RTC. 9/6/06 - System collected 1st set of VOC samples and now needs to collect samples the next 3 consecutive quarters. System can RTC 2nd quarter of 2007.
SC-Anchorage	Doug Zellmer	YKHC	AKIAK COMMUNITY WATER SYSTEM/AK2272005 (C/200)			▼									8/14/06 - Reminder faxed to operators that they need to report a distribution chlorine level representing the same time and place as every total coliform sample. Reminder advised that failing to report these levels caused them to be placed on the SNC list and that they would have to be sure to report these levels to get off the list. 10/16/06 - Letter sent to system advising of July 2006 Stage1 violation, that they are on the SNC list for Stage1, and what they need to do to get off the SNC list. ***HOW TO RTC*** Last Stage1 violation July 2006. System needs 12 month without any Stage 1 violations to RTC. Earliest system can RTC for Stage1 is July 2007.
SC-Anchorage	Doug Zellmer	YKHC	ALAKANUK WATER SYSTEM /AK2270362 (CWS/570)			▼	▼								8/1/06 - Discussed SW M/R with operator at length and in detail, especially explaining how to fill out op rpt form. Operator said their online turbidimeter doesn't work and they are unable to continuously monitor CFE. 8/2/06 - Emailed VSW engineer advising that system is unable to meet LT1 due to lack of and/or broken monitoring equipment, and requested that she provide whatever assistance possible. 8/30/06 - Sent letter to operator discussing problems with operator reports that were submitted for April to June 2006 and advising that they had missed their quarterly TTHM/HAA5 samples as well as their monthly TOC/Alk samples. Letter also advised of SNC list and what they need to do to RTC. 10/23/06 - Sent letter to operator advising of July and August 2006 SW and Stage1 violations, that they are on the SNC list for these rules, and how/when they can RTC. ***HOW TO RTC*** Last LT1 and Stage 1 violations were in August of 2006. System needs 12 mo's without any Stage 1 violations and 6 mo's without any LT1 violations to RTC. Earliest system can RTC for LT1 is February 2007 and for Stage1 is August of 2007.
SC-Anchorage	David Edmunds	Non-RMW	ALASKA RAINBOW LODGE /AK2261680 (TNCWS/220)		▼										SWTR SNC is valid, last violation for not taking turbidity was in August 2006. The system does not have a turbidity meter, it has shutdown for the season. They are aware of the requirements.
SC-Soldotna	David Litchfield	Non-RMW	ALASKA VILLAGE MISSION /AK2245058 (NTNCWS/55)			▼									Last Stage 1 violation January 2006, 8 of 12 months towards RTC
Northern	Linda Grantham	TCC	ALLAKAKET PUBLIC WATER SYSTEM /AK2300816 (CWS/90)						▼						Last VOC sample collected 12/2005. On quarterly monitoring for new water system. SNC letter by 10/31/2006
SC-Anchorage	Jamie Yager	Non-RMW	AMERICAN LEGION POST 33 /AK2214227 (TNCWS/50)		▼										A letter was sent 8/16/06 informing that 1st and 2nd qt. coliform samples are overdue. I spoke system on 10/24/06 and discussed overdue samples, the PWS is on the SNC list and how to RTC, they plan to collect a coliform sample this week.
SC-Soldotna	David-Litchfield	SC	ANCHOR POINT WATERING POINT /AK2247490 (CWS/149)			▼									RTCd with November operator report.
MSSE	Carrie McMullen	SEARHC	ANGOON PUBLIC WATER /AK2130017 (CWS/662)		▼										Operating with only 2 filters since May 2006 and have continuous CFE monitoring but are still working with ANTHC to get continuous recorder set up. Last violation 9/06. 0 of 6 months toward RTC.
SC-Anchorage	Doug Zellmer	Non-RMW	ANYARAQMUITE OFFICE BUILDING /AK2271554 (TNCWS/35)		▼										System was determined to be GWUDISW and letter indicating this was sent to system dated 5/22/03. System should have began disinfecting by 11/22/03 and filtering by 11/22/04, but has not done so. System will be provided with info on disinfection/filtration requirements as well as surface water M&R requirements.
Northern	Marci Irwin	TCC	ARCTIC VILLAGE WATER SYSTEM /AK2300222 (CWS/130)		▼										SW: Known hardware problems. Is in compliance with both dist and EP Cl2 sampling. Turbidity violations due to a muddy source from excessive rain and hardware that is not capable of handling this problem. Last violation for treatment technique September 2006, earliest system can RTC is March 2007.
SC-Anchorage	David Edmunds	APIA	ATKA /AK2260058 (CWS/97)		▼										The system had some hardware issues (water leaks) which resulted in Treatment technique violation. Last SW violation was in September 2006. System needs six good months of operator reports to RTC for SW.
SC-Anchorage	Doug Zellmer	YKHC	ATMAUTLUAK WATER SYSTEM /AK2271033 (CWS/311)			▼									3/21/06 - Letter sent providing violation page (w/ 2005 Stage 1 vios shown), informed of common Stage 1 M&R vios and how to correct, and advised that their 2004 CCR is overdue and that their 2005 CCR is due in our office before July 1, 2006. Advised of organizations and reports available to them for assistance w/ completion of their 2005 CCR. A monitoring summary was included w/ the 3/21 letter which listed Stage 1 M&R and CCR requirements. 6/13/06 - A datadump was emailed to system's RMW at the RMW's request for completion of the system's 2005 CCR. ***HOW TO RTC*** Last Stage1 violation was February 2006. System needs 12 months without any Stage 1 violations to RTC. Earliest system can RTC for Stage1 is February 2007. System can RTC for CCR with submission of CCR currently due.
Northern	Marci Irwin	TCC	BEAVER WATER SYSTEM /AK2360230 (CWS/99)			▼									Stage 1: TTHM MCL and TTHM/HAA5 monitoring vios. System needs all 12 months with no violations. System is scheduled for interim and a final upgrades to the WTP that should address the Stage 1 issues. Last Stage1 violation June 2006. 3 of 12 months toward Stage 1 RTC with September operator report.
SC-Anchorage	Doug Zellmer	Non-RMW	BETHEL LONGHOUSE HOTEL /AK2270401 (TNCWS/76)		▼										Last TCR violation was 2nd qtr 2006. System collected a 3rd qtr 2006 sample, so they can now RTC with a sample collected in the 4th quarter of 2006.
SC-Anchorage	Doug Zellmer	Non-RMW	BETHEL-CITY S/D WATER /AK2271999 (CWS/700)			▼									8/17/06 - Letter sent to system advising that 1st and 2nd qtr TTHM/HAA5 samples were missed, that they are on the SNC list for Stage1, and what they need to do to RTC. ***HOW TO RTC*** System needs 12 mos. w/ no Stage1 vios to get off list for Stage1. Last stage 1 violation 2nd qtr of 2006 for failing to conduct quarterly TTHM/HAA5. System can RTC June 2007.

October 2006 SNC List

UPDATED
(as of December 19, 2006)

Office	Drinking Water Program Staff	RMW Service Area	System Name / PWSID (System Type/Population)	TCR (Bacti)	Surface Water	STAGE1	NITRATE	IOC	VOC	ARSENIC	SOC	LEAD	RAD	CCR	Environmental Specialist Comments RED TEXT as of December 19, 2006 (Black Text As of October 30, 2006)
SC-Anchorage	Jamie Yager	Non-RMW	BIRCHWOOD SHOOTING CLUB /AK2212851 (TNCWS/54)	▼											10/24/06- Spoke with the facility manager who has been collecting bacti samples and believes the lab has not forwarded analytical results to ADEC. He will contact the lab to get copies of results and forward them to Drinking Water Staff. PWS expected to RTC for all violations.
SC-Anchorage	David Edmunds	Non-RMW	BRISTOL BAY CONTRACTORS WELL /AK2262636 (TNCWS/79)			▼									Valid Nitrate SNC. Last sample collected 3/03.
Northern	Marci Irwin	Manilaq	BUCKLAND WATER SYSTEM /AK2340125 (CWS/417)			▼									Stage 1: TTHM MCL and TTHM/HAA5 monitoring vios. System needs all 12 months with no violations. System is scheduled for interim and a final upgrades to the WTP that should address the Stage 1 issues. Last Stage 1 violation October 2006, so earliest system can RTC October 2007.
Northern	Marci Irwin	TCC	CHALKYITSIK VILLAGE WATER /AK2300183 (CWS/110)	▼	▼										SWTR: 4 of 6 months no dist. Cl2 vios, 1 of 6 months no turbidity and EP Cl2 vios. Stage 1: 4 of 12 months no dist Cl2 vios. TTHM/HAA5 MCL and TTHM/HAA5 monitoring violations. System has hardware issues.
SC-Anchorage	Doug Zellmer	YKHC	CHEFORNAK WATER SYSTEM /AK2270338 (CWS/408)	▼	▼	▼									Valid Nitrate SNC. Last sample collected 9/03. 8/17/06 - Letter sent to system advising of missed Feb-June TCR M/R and associated Stage1 (Distribution Chlorine) M/R, as well as potential for formal enforcement actions. Enclosed TCR sampling guidance with letter. 10/17/06 - Sent letter to operator advising of July 2006 TCR/Stage1 M/R violations, that they are on the SNC list for TCR, Stage1, and Nitrate, and explained what they need to do to get off the SNC list. ***HOW TO RTC*** Last Stage1 Violation July 2006. System needs 12 mo's without any Stage 1 vios to RTC. Earliest system can RTC for Stage1 is July 2007. Last TCR violation was July 2007, so earliest system can RTC is January 2007. System can RTC for nitrate with submission of a Nitrate sample.
Northern	Marci Irwin	Non-RMW	CHICKEN COUNTRY STORE/AK2380688 (NC/57)		▼										Only vios for inconsistent dist. Cl2 readings. Needs 6 months to RTC, seasonal system does not open again until May 07
SC-Anchorage	David Edmunds	BBAHC	CHIGNIK LAGOON WATER SYSTEM /AK2261444 (CWS/350)		▼	▼									Valid Nitrate SNC. Last sample collected 8/03. Stage 1 (11 of 12 months towards RTC) expect to RTC with October distribution chlorine.
Northern	Linda Grantham	TCC	CIRCLE WASHETERIA/AK2300769 (C/100)		▼										Stage 1: Violations for inconsistent dist Cl2 monitoring. Have 4 of 12 months to RTC. Last Stage 1 violation June 2006, so earliest system can RTC is June 2007. Inconsistent reporting. Enforcement letter by 11/15/06
SC-Anchorage	David Edmunds	BBAHC	CLARKS POINT WATER SYSTEM /AK2260202 (CWS/92)			▼									Valid Nitrate SNC. Last sample collected 6/03.
MSSE	Carrie McMullen	Juneau	COFFMAN COVE /AK2120436 (CWS/280)			▼									Stage 1: Receiving treatment technique violations for not meeting the required TOC removal for the Enhanced Coagulation portion of the Stage 1 D/DBPR. System has been referred to David Khan (DW engineer) to help with Enhanced Coagulation issues. Recent changes in sampling location indicate that the system may well be operating within the required parameters but was not collecting treated water samples from the correct location. Sampling will be collected from the correct locations now. Last Stage 1 violation October 2006.
SC-Anchorage	David Edmunds	Non-RMW	D & D RESTAURANT /AK2262660 (TNCWS/25)	▼											0 of 6 months toward bacti RTC. Last sample collected 12/05.
MSSE	Carrie McMullen	Non-RMW	DALTON CACHE BORDER STATION/AK2111275 (NC/100)	▼											NOV issued for bacti SNC. Last bacti collected 6/06.
Northern	Marci Irwin	Manilaq	DEERING UTILITY SYSTEM /AK2340222 (CWS/150)		▼	▼									SW: System has monitoring and reporting issues for not submitting operator reports or taking dist. Cl2 readings; however, they just got a new operator so this issue may be resolved soon. Last SW violation November 2006. Earliest system can RTC is May 2007. Stage 1: violations for TTHM MCL, TTHM/HAA5 quarterly monitoring, and dist. Cl2 monitoring violations. Last violation November 2006, earliest system can RTC is October 2007. SNC letter by Nov. 31, 2006, after confirmation of system status with Health Corporation.
Northern	Marci Irwin	Non-RMW	DGSD - DELTA ELEMENTARY SCHOOL /AK2372677 (NTNCWS/285)						▼			▼			Lead SNC: Completed 1st 6 month sample 1/1/06-6/30/06, expected to RTC by 12/31/06 after 2nd set.
SC-Anchorage	David Edmunds	Non-RMW	DILLINGHAM WATER SYSTEM /AK2260197 (CWS/2341)			▼									Stage 1: System is aware of the requirement and is taking distribution chlorine same place and time as bacti. They have kept up with bacti sampling and are working towards compliance for Stage one. Last Stage 1 violation Feb 06. 6 of 12 months towards RTC (w/August report). Expect RTC in Feb 07.
MSSE	Carrie McMullen	Non-RMW	DOC WARNERS FISH CAMP/AK2111513 (NC/98)		▼										Closed for season, will reopen 6/07.
Northern	Marci Irwin	Non-RMW	DOOR OF HOPE CHURCH /AK2312601 (NTNCWS/700)	▼											NOV will be issued by Nov. 31, 2006
SC-Anchorage	David Edmunds	Non-RMW	EDDIES FIREPLACE INN /AK2261486 (TNCWS/64)			▼									Valid Nitrate SNC. Last sample collected 12/03.
SC-Anchorage	Doug Zellmer	YKHC	EEK WATER SYSTEM /AK2270281 (CWS/264)			▼									8/31/06 Letter sent to system advising of missed annual TTHM/HAA5 samples, that they are the SNC list for Stage1, and how to RTC. ***HOW TO RTC*** Last Stage 1 violation in 2005 for not collecting yearly TTHM/HAA5 sample. System collected their 2006 TTHM/HAA5 on 9/11/06. System can RTC for Stage1 in December 2006 if the do not accrue any further Stage1 violations for this year.
Northern	Marci Irwin	NSHC	ELIM WATER SUPPLY /AK2340345 (CWS/304)			▼									SW: Receiving treatment technique violations, as well as monitoring/reporting violations for turbidity and Cl2. Last SW violation May 2006. System can RTC with November operator report.
SC-Anchorage	Doug Zellmer	YKHC	EMMONAK WATER SYSTEM /AK2270299 (CWS/820)			▼	▼								8/31/06 - Letter sent to operator advising of unsatisfactory April to June 2006 operator reports and explaining what the problems were with the reports. Ltr also advised of missed TTHM/HAA5 and TOC/Alk M/R, and of the system's SNC listings. Advised how to RTC and potential for formal enforcement actions. 10/23/06 - Letter sent to system advising of July and August 2006 SW and Stage1 violations, SNC listings for Stage1 and SW, and how/when they can RTC. ***HOW TO RTC*** Last Stage1 violation was August 2006. System needs 12 mo's without any Stage 1 vios to RTC. Earliest system can RTC for Stage1 is August of 2007. Last SW violation was July of 2006 so the earliest the system can RTC for SW is January of 2007.
SC-Anchorage	Doug Zellmer	Non-RMW	FAA BETHEL WELL/AK2271981 (C/47)			▼									7 of 12 months towards Stage 1 RTC (w/Sept dist. Chlorine sample), expect to RTC w/January 2007 dist. Chlorine sample. Last Stage1 violations were in February 2006, so system can RTC February 2007 if there are no further Stage1 violations. System was receiving Stage1 violations for failure to report distribution chlorine levels but this problems appears to now be resolved.
SC-Anchorage	David Edmunds	APIA	FALSE PASS TREATMENT PLANT /AK2262199 (CWS/79)	▼											SW: System received new forms and June report look good for SW. Last violation was 8/06. Earliest system can RTC for SW is February 2007. Stage 1: Violations for not taking the required chlorine readings. Last violation was August 2006, so earliest system can RTC is August 2007.
Northern	Marci Irwin	Non-RMW	FARMERS LOOP MARKET /AK2313005 (NTNCWS/75)	▼											Collected sample for 3rd quarter and expected to RTC by 12/31/2006.

October 2006 SNC List

UPDATED
(as of December 19, 2006)

Office	Drinking Water Program Staff	RMW Service Area	System Name / PWSID (System Type/Population)	TCR (Bacti)	Surface Water	STAGE1	NITRATE	IOC	VOC	ARSENIC	SOB	LEAD	RAD	CCR	Environmental Specialist Comments RED TEXT as of December 19, 2006 (Black Text As of October 30, 2006)
Northern	Marci Irwin	Non-RMW	FNSB SD - WELER ELEMENTARY /AK2310251 (NTNCWS/700)												System is currently not disinfecting, and is using a temporary hauled system.
SC-Anchorage	David Edmunds	Non-RMW	FOX CREEK TOWNHOUSES /AK2261101 (CWS/30)												Valid Nitrate SNC. Last sample collected 8/03.
Northern	Marci Irwin	TCC	FT. YUKON PUBLIC WATER SYSTEM/AK2360256 (C/650)												Stage 1: Has been sampling TTHM/HAA5 quarterly but occasionally does not take dist Cl2 readings, had 4 months with no vios until they missed September and October dist Cl2. Last Stage 1 violation October 2006, earliest system can RTC is October 2007.
Northern	Linda Grantham	TCC	GALENA WATER SYSTEM /AK2360272 (CWS/750)												Stage 1: Continues to generate Stage 1 violations for exceeding TTHM&HAA5 MCLs. They are still working on adjusting treatment. Last Stage 1 violation Oct-Dec 2005 quarter. Can RTC this quarter (Oct-Dec 2006). SNC letter by 10/31/2006
Northern	Marci Irwin	NSHC	GAMBELL WATER SYSTEM /AK2340751 (CWS/669)												System working with TA Providers on resolving DW issues. SW: Occasionally has EP Cl2 treatment technique vios, inconsistent dist Cl2, and a few turbidity vios. Has 2 month with no dist. Cl2 and 1 month with no turb. vios; however they have 0 of 6 month System working with TA Providers on resolving DW issues. SW: Occasionally has EP Cl2 treatment technique vios, inconsistent dist Cl2, and a few turbidity vios. Has 2 month with no dist. Cl2 and 1 month with no turb. vios; however they have 0 of 6 months towards RTC due to tt EP Cl2 vios. Stage1: Has vios for inconsistent dist Cl2 and TTHM/HAA5 sampling. Has 2 of 12 months no vio; however, without TTHM/HAA5 samples taken before 12/31/06 more vios will be created!
Northern	Marci Irwin	NSHC	GOLOVIN COMMUNITY WATER SYSTEM /AK2340214 (CWS/150)												Major issues with SW and Stage 1violations. SW: No dist Cl2 and occasional issues with low EP Cl2 residuals. Last monitoring/reporting SW violation was October 2006, didn't send in October operator report. Earliest system can RTC is May 2007. Stage1: MCL and monitoring violations for TTHM/HAA5, no dist Cl2 monitoring. SNC letter sent by Nov. 31, 2006.
SC-Soldotna	David Litchfield	Non-RMW	GRACE EVANGELICAL LUTHERAN /AK2245325 (TNCWS/110)												NOV being issued this month for lead SNC.
SC-Anchorage	Doug Zellmer	YKHC	GRAYLING WATER SYSTEM /AK2280066 (CWS/195)												Stage1 violations for failing to report Dist.Chlorine residuals and for failing to collect TTHM/HAA5 samples. TTHM/HAA5 violations were resolved with collection of 8/15/06 TTHM/HAA5's. TCR samples are being missed which causes the system to receive Stage1 Dist. Chlorine vios. SWTR violations also for failing to report Dist. Chlorine residuals. 10/17/06 - Sent letter to system advising of July 2006 SWTR, TCR, Stage1 vios; that they are on the SNC list for these 3 rules; and how/when they can RTC. Last TCR and SWTR violations were July of 2006. so earliest system can RTC for TCR and SWTR is January of 2007. Last Stage1 violation was July of 2006, so the earliest system can RTC for Stage1 is July of 2007.
SC-Soldotna	David Litchfield	Non-RMW	GREATLAND VILLAGE PARK /AK2243771 (CWS/30)												New Operator - 2 of 6 months toward compliance
Northern	Marci Irwin	SC	GULKANA VILLAGE /AK2380214 (CWS/83)												Stage 1: Violations are from an TTHM/HAA5 MCL and some monitoring. Hardware issue: A source water study has been completed and they are going to get a new WTP to resolve TTHM/HAA5 MCL. In compliance with dist Cl2.
MSSE	Carrie McMullen	Non-RMW	HAINES /AK2110619 (CWS/1613)												Have installed online IFE turbidimeters, 5 of 6 months towards RTC (April-August), expect to RTC with September operator report.
MSSE	Carrie McMullen	Non-RMW	HAINES FERRY TERMINAL /AK2110855 (TNCWS/200)												ON Boil Water Notice due to ongoing chlorinator issues.
Northern	Linda Grantham	TCC	HUGHES PUBLIC WATER SUPPLY/AK2300272 (C/65)												Stage1: Not consistently reporting dist Cl2 data, last violation October 2006, so earliest system can RTC is October 2007.
Northern	Linda Grantham	TCC	HUSLIA PUBLIC WATER SUPPLY /AK2300191 (CWS/293)												Stage 1: On quarterly bacti sampling, haven't taken any dist. Cl2 readings. Last violation generated was the April-June quarter 2006. Earliest system can RTC is April-June quarter 2007. 0 of 4 quarters toward RTC. SNC letter by 10/31/2006
MSSE	Carrie McMullen	SEARHC	HYDABURG /AK2120224 (CWS/415)												SW: System not reporting IFE turbidity. SEARHC RMW made site visit during week of August 25th, and will work with operators to initiate appropriate reporting. Planning to issue NOV by Dec. 31, 2006.
MSSE	Carrie McMullen	SEARHC	KAKE MUNICIPAL WATER /AK2130083 (CWS/833)												SW: Receiving monitoring/reporting violations for SWTR. System does not have IFE turbidimeters. Working with ANTHC to ok use of money they currently have to install IFE turbidimeters. Stage 1: Violations for exceeding TTHM/HAA5 MCLs. Last violation Jan-March 2006 quarter. Needs 4 consecutive quarters with no Stage 1 violations to RTC. Will issue NOV by Dec. 31, 2006.
Northern	Marci Irwin	TCC	KALTAG PUBLIC WATER SYSTEM /AK2360141 (CWS/240)												SW: Has not submitted Sept or Oct operator reports. Vios for inconsistent dist Cl2, some low EP Cl2 levels. Inconsistent monitoring for dist. Cl2 residual, has sampled the last 2 months. Has a signed Bilateral Compliance Agreement.
MSSE	Carrie McMullen	SEARHC	KASAAN /AK2120606 (CWS/46)												Hardware inadequate - have funding for new WTP. SW: Receiving Treatment Technique violations for turbidity levels and violations for not monitoring/reporting all the required chlorine and turbidity samples. Last SW violation Sept. 2006. Stage 1: Violations for MCL exceedence for TTHM/HAA5 as well as monitoring and reporting vios for TTHM/HAA5. Last violation July-September 2006 quarter. Earliest system can RTC is July-September quarter 2007.
SC-Anchorage	Doug Zellmer	YKHC	KASIGLUK WASHETERIA (AKIUK) /AK2270794 (CWS/425)												System is on the SNC list for Stage1 for failing to report TTHM/HAA5 results (no results on record, annual vios for 2004 and 2005), and for failing to report dist. Chlorine levels. Many TCR samples are being missed which is causing system to automatically receive Stage1 dist. Chlorine vios. 8/31/06 - Sent letter to operator advising that April bacti and dist. Chlorine residual, 2005 TTHM/HAA5 samples, and 2005 nitrate were all missed. Letter advised on SNC list, the potential for enforcement actions, and how to RTC. 10/17/05 - Letter sent to system advising of July 2006 Stage1 vios, that they are on the SNC list for Stage1 and Nitrate, and how/when they can RTC.***HOW TO RTC*** Last annual Nitrate sample collected 7/03. System can RTC with submission of one Nitrate sample. Last Stage1 violation July 2006. System needs 12 mo's no Stage 1 vios to RTC. Earliest system can RTC for Stage1 is July 2007.
SC-Anchorage	Jamie Yager	Non-RMW	KATHY O ESTATES /AK2211897 (CWS/242)												10 or 12 months w/ no Stage 1 DBP violations. PWS expected to RTC at the end of 4th qt 2006.
MSSE	Carrie McMullen		KETCHIKAN PUBLIC UTILITIES /AK2120232 (CWS/8980)												Stage 1: Receiving Stage 1 violations for MCL exceedences for HAA5. Last violation July-September 2006 quarter. System has been working with Environmental Specialist on DBP issues. Will be issuing COBC following receipt of Q3 2006 results
SC-Anchorage	Doug Zellmer	YKHC	KIPNUK WATER SYSTEM /AK2270736 (CWS/470)												System is on SNC list for TCR b/c they are not submitting any bacti samples. There are currently no bacti samples on file. System is on SNC list for SWTR b/c they are not doing any SWTR M/R. 8/21/06 - Letter sent to system advising of overdue TCR and SWTR M/R, that system is on SNC list. 10/17/06 - Letter sent to system advising of July and August 2006 SWTR and TCR vios, that system is on SNC list for TCR/SWTR, and how/when they can RTC for both. Last TCR and SWTR violations were August of 2006 so earliest system can RTC for TCR/SWTR is February of 2007.
Northern	Marci Irwin	Manilaq	KIVALINA WATER SYSTEM /AK2340117 (CWS/325)												SW: Prior to August and after September violations were for EP Cl2 readings below 0.2mg/L (17 out of 20 days during October), and a few turbidity monitoring vios. In August and early September the system had problems with the turbidimeter. These were resolved by Manillaq Health Corporation. Last SW violation was October 2006, so earliest system can RTC is April 2006.

October 2006 SNC List

UPDATED
(as of December 19, 2006)

Office	Drinking Water Program Staff	RMW Service Area	System Name / PWSID (System Type/Population)	TCR (Bacti)	Surface Water	STAGE1	NITRATE	IOC	VOC	ARSENIC	SOC	LEAD	RAD	CCR	Environmental Specialist Comments RED TEXT as of December 19, 2006 (Black Text As of October 30, 2006)
MSSE	Carrie McMullen	SEARHC	KLAWOCK /AK2120169 (CWS/1000)	▼	▼										SW: Per SEARHC RMW, ANTHC has installed IFE turbidimeters. Receiving violation for failure to monitor/report chlorine and turbidity. Last SW violation was Sept. 2006. Stage 1: System will likely need changes in treatment to reduce DBPs (currently have MCL violations, caused by hardware/treatment). Last Stage 1 violation July-September 2006 quarter. Earliest system can RTC is July-September quarter 2007. Planning to issue an NOV by Dec. 31, 2006.
SC-Anchorage	Doug Zellmer	YKHC	KONGIGANAK WATER SYSTEM /AK2271025 (CWS/294)	▼											System is getting SW violations for combination of failing to report all of required information as well as treatment violations (chlorine and turbidity). System is receiving Stage 1 violations for failing to report dist. Chlorine residual levels and TTHM/HAA5s. 8/8/06 - Went through new operator reports with operator in detail over the phone. Operator advised that the system does not have the equipment to perform cont. monitoring as req'd under LT1. Last SW violation was August of 2006, so earliest system can RTC for SW is February 2007. Last Stage1 violation was August 2006 so earliest system can RTC for Stage1 is August 2007.
SC-Anchorage	Doug Zellmer	YKHC	KOTLIK WATER SYSTEM /AK2272004 (CWS/591)	▼											System is on the SNC list for SWTR for a combination of treatment techniques and M/R violations. 7/27/06 - Called operation and discovered that entry point Chlorine levels were being measured in the wrong place, so the issue was addressed during the call. Explained that entry point chlorine levels need to be recorded even when system is not filtering. During the call the operator also informed us that their online turbidimeters don't work so they aren't able to perform cont. monitoring req'd under LT1. 8/31/06 - Letter sent to operator advising of unsatisfactory April-June operator reports w/ a description of the problems w/ the reports. Letter also advised of SNC list and how to RTC. 9/11/06 - Spoke with operator about letter sent 8/31/06 and how to fill out there monthly operator report again. Advised that completing the report properly will resolve most of their SWTR M/R problems. Last SWTR violation June of 2006, so earliest system can RTC for SWTR is December of 2006. System is on the SNC list for SWTR for a combination of TT and M/R violations.
Northern	Marci Irwin	Non-RMW	KOTZEBUE MUN. WATER SYSTEM /AK2340060 (CWS/3290)		▼										Stage 1: Numerous MCL and monitoring violations of Stage 1 prior to April 2006, need hardware to meet rule. Treatment study complete for a new WTP. Last Stage 1 violation Jan-March 2006 quarter. Earliest system can RTC is Jan-March 2007 quarter.
Northern	Linda Grantham	TCC	KOYUKUK SAFEWATER FACILITY /AK2360214 (CWS/127)		▼										Stage 1: Missing numerous bacti and distribution chlorine samples. Last stage 1 violation August 2006. Earliest system can RTC is August 2007. SNC letter by 10/31/2006
SC-Anchorage	Doug Zellmer	Non-RMW	KSD JOE GREGORY UPPER KALSKAG /AK2270875 (NTNCWS/34)					▼							4/12/06 a letter was sent advising that 2nd qtr VOC samples need to be collected. Included with the 4/12/06 letter was a monitoring summary listing the system's VOC monitoring requirements as well as a violation page which listed the system's VOC violations. Last VOC violation rec'd for 2nd qtr of 2006.
SC-Anchorage	Doug Zellmer	YKHC	KWETHLUK UTILITIES COMMISSION/AK2261371 (C/627)		▼										System is receiving Stage1 violations for failing to report Dist. Chlorine residual levels. System is missing numerous bacti samples which they automatically receive Stage1 Dist. Chlorine vios for. 10/17/06 - A letter was sent to system advising of July and August 2006 Stage1 violations, that system is on the SNC list for Stage1. and how/when they can RTC. Last Stage1 violation was received August 2006, so the earliest system can RTC is August 2007.
SC-Anchorage	Doug Zellmer	YKHC	KWIGILLINGOK WASHETERIA /AK2271700 (CWS/332)	▼	▼	▼									System is receiving TCR violations for not performing any bacti monitoring. On SNC list for SWTR for not doing any SW M/R and on SNC list for Stage1 for not doing any Dist. Chlorine residual reporting or TTHM/HAA5 monitoring. 8/21/06 - Letter sent to system advising of 2006 M/R req's, that they are overdue for TCR and SWTR M/R, and that they are on the SNC list. Provided a monitoring summary, TCR sampling guidance, and blank operator reports with the letter. 10/17/06 - Letter sent to system advising of July and August 2006 Stage1, SWTR, and TCR vios; that system is on the SNC list for these things, and how/when they can RTC. 10/24/06 - Left message for operator that the bacti samples he collected did not make it to the lab in time so he needs to resample. 0 of 6 months toward bacti RTC. Last sample collected 7/05. Last TCR, SWTR, and Stage1 violations were from August 2006. Earliest system can RTC for TCR/SWTR is February 2007 and for Stage1 is August 2007.
SC-Anchorage	David Edmunds	Kodiak/Kenai	LARSEN BAY WATER SYSTEM /AK2250134 (CWS/335)	▼											SW: Treatment technique violations and monitoring violations for Stage one and SWTR. Missing reports and Hardware issues continual problem. They do not have adequate treatment to meet SWTR (primarily turbidity issues). They had operator issues, the main operator was off for training and the back up failed to do the reporting. This has since been corrected. Last SW violation September 2006. Earliest system can RTC is March 2007.
SC-Anchorage	Doug Zellmer	YKHC	LIME VILLAGE WATER SYSTEM /AK2272013 (CWS/50)					▼							8/17/06 - Sent letter to operator advising that 1st and 2nd qtr VOC samples were missed and of potential for enforcement actions. 10/12/06 - Spoke with administrator about monitoring and reporting requirements and sent an updated monitoring summary. Administrator said they are getting set up with a lab to get the required samples. 10/23/06 - Letter sent to system advising that they are on the SNC list for VOC's and how/when they can RTC. Last VOC violation was 2nd Quarter of 2006. New water system must complete initial quarterly VOC monitoring to RTC. System can RTC 2nd quarter of 2007.
Northern	Marci Irwin	Non-RMW	LITTLE DIOMEDE WATER SUPPLY /AK2340141 (CWS/184)	▼	▼	▼									Valid nitrate SNC for MCL exceedance from 12/05 sample. 4 of 6 months toward bacti RTC. Last sample collected 8/06.
SC-Anchorage	Doug Zellmer	Non-RMW	LKSD NAPAIAK HS & ELEM/AK2271253 (NTNC/124)		▼										6 of 12 months toward Stage 1 RTC (w/sept dist. Chlorine sample), expect RTC w/March 07 distribution chlorine. Last Stage1 violation January 2006, so system can RTC January 2007 with no further Stage1 violations. System is on the SNC list for failing to report Dist. Chlorine levels. 4/20/06 - Letter and monitoring summary sent to system which listed Dist. Chlorine level M/R req's. Recent M/R indicates this reporting issue has been corrected.
SC-Anchorage	Doug Zellmer	Non-RMW	LKSD NEWTOK AYAPRUN SCHOOL/AK2272007 (NTNC/135)		▼										Valid, several missed distribution chlorine. Last Stage1 violation March 2006, so earliest system can RTC is March 2007. System receiving Stage1 vios for failing to report Dist. Chlorine residual levels which is also somewhat tied to missed bacti samples. 4/20/06 - A letter and monitoring summary were sent to system which listed Stage1 monitoring req's.
SC-Anchorage	Doug Zellmer	YKHC	LOWER KALSKAG WATER SYSTEM /AK2270697 (CWS/302)									▼			3/8/06 - Spoke to utility manager, about rad samples due quarterly and system being on SNC list. Explained what the SNC list is and what they need to do to RTC for RADS. Utility Manager said they have containers & would be sure samples are collected. 3/28/06 - Discussed sampling procedures for radionuclides at length with operator. Operator said he plans on getting samples collected by 28th or 29th. 4/13/06 - Monitoring summary and cover letter sent to system advising of 2006 M&R req's, overdue M&R, and common M&R errors. 6/8/06 -Discussed rad sampling with Utility Manager who said they will be collecting a rad sample 6/12/06. 10/17/06 - Letter sent to system advising on SNC list for Rads and how/when they can RTC. Have had extreme difficulty in contacting system personnel from June to the present (10/25/06). 10/26/06 - Spoke with lab that is handling systems Rads samples and lab staf said that all 4 qtr had been taken, they are expecting to receive samples any day, and they should have results in November.
SC-Anchorage	David Edmunds	BBAHC	MANOKOTAK HEIGHTS W/S /AK2262246 (CWS/60)									▼			Valid-Spoke with RMW, they have completed Consecutive quarterly sampling. System will RTC with when results are received.
SC-Anchorage	David Edmunds	BBAHC	MANOKOTAK WATER SYSTEM /AK2260090 (CWS/370)									▼			RADS: Working with RMW, they did some composite sampling and had some problems, they will be collecting a gross alpha sample to get of the list. I called out to the system to get an update on Rads, waiting for a call from the RMW. They did some rads sampling and it looks like they will need fourth quarter to RTC.
SC-Anchorage	Doug Zellmer	YKHC	MARSHALL/AK2270273 (C/308)		▼										Last Stage1 violation was received for February 2006, so the earliest the system can RTC is February 2007. System on the SNC list due to failure to report Dist. Chlorine residual levels. 4/13/06 - Sent monsum and letter to system which listed Stage1 M/R req's. 5/31/06 - Emailed system's VSW engineer explaining why system is on the SNC list for Stage1. 6/13/06 - Spoke to David Fitka about SNC list for Stage1 and Dist. Chlorine reporting req's.

October 2006 SNC List

UPDATED
(as of December 19, 2006)

Office	Drinking Water Program Staff	RMW Service Area	System Name / PWSID (System Type/Population)	TCR (Bacti)	Surface Water	STAGE1	NITRATE	IOC	VOC	ARSENIC	SOC	LEAD	RAD	CCR	Environmental Specialist Comments RED TEXT as of December 19, 2006 (Black Text As of October 30, 2006)
SC-Anchorage	Jamie Yager	Non-RMW	MAXINES GLACIER CITY BISTRO /AK2212364 (TNCWS/72)	▼											PWS collected coliform samples on 7/19/06 and 10/5/06 during 3rd and 4th quarters. PWS should RTC at end of 4th qt.
SC-Anchorage	Doug Zellmer	TCC	MCGRATH WATER SYSTEM /AK2280155 (CWS/347)	▼	▼										RTCd with October operator report.
Northern	Linda Grantham	TCC	MINTO COMMUNITY WATER SYSTEM/AK2300159 (C/250)	▼	▼										Stage 1: System uses a GW source, but chlorinates. Occasionally gets violations for missing dist. Cl2 vios. Has 4 of 12 months towards RTC. Last Stage 1 violation June 2006, earliest system can RTC is July 2007. Enf letter by 11/15/06
	MSSE	Tee Little	Non-RMW	▼											NOV issued 10/24/06 - hired lab to sample. Should RTC 1st qtr 2007
Northern	Linda Grantham	Non-RMW	MOOSE CREEK APARTMENTS /AK2370552 (CWS/140)	▼											Valid SNC. Will issue NOV.
	MSSE	Carrie McMullen	Juneau	▼	▼										Valid SNC. Will issue NOV.
SC-Anchorage	David Edmunds	Non-RMW	MURPHYS /AK2262571 (TNCWS/39)	▼		▼									Valid Nitrate SNC. Last sample collected 12/03. Valid Bacti SNC, last quarterly sample collected 7/2005
SC-Anchorage	Jamie Yager	Non-RMW	NABORS CAMP KUSKOKWIM (4) /AK2333178 (TNCWS/50)	▼	▼										6 of 12 months w/ no Stage 1 violations.
SC-Soldotna	David Litchfield	Kodiak/Kenai	NANWALEK /AK2240464 (CWS/230)	▼	▼										SW: System's hardware issues were addressed this summer, and system has been meeting LT1 reporting requirements since August 2006. System could RTC for SNC issues the end of February 2007 provided they continue to complete reports as required. Operator reports continue to have some minor issues that need to be resolved and operator may still need technical assistance on how to read/report turbidity values. (RMW and DW Program staff are coordinating a visit to the village.)
SC-Anchorage	Doug Zellmer	YKHC	NAPAKIAK W.S. CENTRAL WELL /AK2262319 (CWS/330)	▼	▼										Stage1 - DS chlorine residual levels not being monitored/reported adequately. They recently collected their annual TTHM/HAA5 sample so if they keep on track with distribution chlorine samples they could RTC for Stage 1 in March 2007. Last Stage1 violations- March 2006.
SC-Anchorage	Doug Zellmer	YKHC	NAPASKIAK WATER SYSTEM /AK2260139 (CWS/367)	▼	▼										Last TCR violation August 2006, so earliest system can RTC for TCR is February 2007. 5/4/06 - Sent fax (after unable to reach by phone) to system advising that they are long overdue for bacti sampling and to send a sample in immediately. 5/8/06 - Letter ad monitoring summary sent to system advising of TCR req's and that they are overdue for TCR M/R. 9/6/06 - Letter sent to system advising of missed April and May bactis and that they are on the SNC list. 10/17/06 - Letter sent to system advising of July and August TCR vios, that they are on the SNC list for TCR, and how/when they can RTC.
SC-Anchorage	David Edmunds	APIA	NELSON LAGOON WATER SYSTEM /AK2260804 (CWS/83)	▼	▼										SW: The system has numerous violations mainly stemming from Chlorine residual falling below 0.2 mg/L Treatment Technique (41) on pump days and no turbidity readings (36). DBP violations are from missed Bacti samples (27). They are reporting chlorine residuals for the system on the operator reports. New Treatment plant has been installed and have new reporting requirements stemming from direct filtration LT1 requirements. Waiting to see how the new reporting goes. Last violation August 2006, so earliest system can RTC is February 2006.
Northern	Linda Grantham	TCC	NENANA MUNICIPAL WATER/AK2390065 (C/540)	▼	▼										Last Stage 1 violation 7/06. System needs 12 mo's without any Stage 1 violations. Earliest system can RTC is 7/07.
SC-Anchorage	Doug Zellmer	YKHC	NEWTOK WATER SYSTEM /AK2271431 (CWS/215)	▼	▼	▼		▼	▼						Valid Nitrate SNC. Last sample collected 9/02. Last SW violation was August 2006 - can RTC February 2007. Last Stage1 violation August 2006 - can RTC August 2007. On SNC list for Stage1 due to failing to report Dist. Chlorine residuals (compounded by lack of bacti sampling), failure to monitor for TTHM/HAA5's. Last nitrate sample taken 9/02 - can RTC with collection of a nitrate sample (due annually). Last Arsenic sample 8/02 - can RTC w/ collection of an Arsenic sample (due annually). Last VOC sample 10/02 - can RTC with collection of a VOC sample (due annually). 7/12/06 - Spoke to systems administrator about system being out of operation from January to mid-June due to lack of water. System resumed operating 6/10/06. Administrator said the tank was cleaned and filled, the new operator had been trained, a negative TC sample had been collected, and that they had a sample kit. 8/9/06 - Spoke w/ operator about SWTR reporting, new operator reports, went through new forms one by one answering op's questions as we went along. Op said system doesn't have a way to record turbidity continuously and that he does not know how to use unit for grab sampling. 10/17/06 - Sent letter to operator advising of July and Stage1 and SW violations; that system is on the SNC list for SW, Stage1, Nitrate, VOC's, and Arsenic; and how/when system can RTC.
SC-Soldotna	David Litchfield	SC	NIKOLAEVSK COMMUNITY WATER SYSTEM /AK2241648 (CWS/360)	▼	▼										SW: System's hardware issues were addressed, and system has been meeting the LT1 reporting requirements. Last SW violation was in September 2006. Expect system to RTC in March 2007.
SC-Anchorage	David Edmunds	APIA	NIKOLSKI VILLAGE /AK2260278 (CWS/44)	▼	▼	▼			▼						0 of 6 months toward bacti RTC. Last sample collected 5/06. SWTR violation for not installing filtration will remain open until filtration is installed. Stage 1 SNC valid
SC-Anchorage	David Edmunds	BBAHC	NONDALTON /AK2260260 (CWS/270)	▼	▼										COBC issued 4/5/2006 addressing SWTR and Stage 1 violations
Northern	Marci Irwin	Manilaq	NOORVIK WATER SYSTEM /AK2340109 (CWS/600)	▼	▼										SW: System had a CPE Sept. 19-23, 2005, and ADEC is working with the system to use the updated operator report forms, no IFE monitoring required. (Another CPE can be triggered after Sept. 2006 if turb. issues are not resolved.) Has turbidity vios for treatment technique and some monitoring (significant compliance with monitoring). A treatment study has been completed and they are working on the design of the WTP. Last SW violation October 2006.
SC-Anchorage	David Edmunds	Non-RMW	NORTH PACIFIC PROCESSORS, INC. /AK2261143 (TNCWS/300)	▼		▼									Valid Nitrate SNC. Last sample collected 6/03.
Northern	Linda Grantham	TCC	NORTHWAY WASHETERIA/CLINIC /AK2381422 (CWS/320)	▼	▼										Stage 1: Many Stage 1 violations for not taking distribution chlorine, and not monitoring quarterly for TTHM/HAA5s (on quarterly monitoring due to MCL violation for HAA5s). Last violation September 2006, so earliest system can RTC is September 2007.
Northern	Marci Irwin	Non-RMW	NSBU - WAINWRIGHT /AK2320086 (CWS/585)	▼	▼										NOV issued by Nov. 31, 2006. Vios for TTHM/HAA5 monitoring. Has 5 of the last 6 months dist. Cl2.

October 2006 SNC List

UPDATED
(as of December 19, 2006)

Office	Drinking Water Program Staff	RMW Service Area	System Name / PWSID (System Type/Population)	TCR (Bacti)	Surface Water	STAGE1	NITRATE	IOC	VOC	ARSENIC	SOC	LEAD	RAD	CCR	Environmental Specialist Comments RED TEXT as of December 19, 2006 (Black Text As of October 30, 2006)
SC-Anchorage	Doug Zellmer	YKHC	NUNAM IQUA /AK2270207 (CWS/213)	▼	▼							▼			Last LT1 and Stage 1 violations were in August of 2006. Earliest system can RTC for LT1 is February 2007 and for Stage1 is August of 2007. System on SNC list for Lead b/c of failure to collect their initial consecutive 6 month lead and copper samples. The system has multiple 2nd half (July to December) sample sets but has not yet collected a 1st half (January to June) sample set. System receiving SW vios for failing to monitor and report adequately as well as for failing to adequately treat the water. System receiving Stage1 violations for failing to monitor and report quarterly TTHM/HAA5's, Dist. Chlorine residuals, and TOC/Alk's. 8/31/06 - Ltr sent to operator advsing of unstatsfctry April - Jun 2006 op rprts w/ descrip of probs. Also advsd of msd Qtrly TTHM/HAA5's, TOC/ALK's, dist CL's. Advsd of SNC list, PN req's, pntial for enf actns/admin penlties. 9/6/06 - Spoke w/ operator at length re: new op rprt frm and how to fill out, answering his questions along the way. Also discussed overdue M&R especially TOC/Alk and TTHM/HAA5.
SC-Anchorage	Doug Zellmer	YKHC	NUNAPITCHUK WATER SYSTEM/AK2260820 (C/471)		▼										Last Stage1 violation was July 2006, so earliest system can RTC is July 2007. 5/9/06 - Sent letter and monsum to system advising of Stage1 M/R req's. 6/5/06 - Email sent to system's VSW engineer who had requested info on system's SNC status. Explained where system is at w/ Stage 1 and what they need to do to RTC. 9/6/06 - Letter sent to operator advising missed April, May & June dist Cl levels, and missed April bacti. Advised on SNC list for Stage1 & told how to RTC, potential for Enforcement Actions and admin penalties, and of PN req's. 10/17/06 - Sent letter advising of July 2006 TCR & Stage 1 D/DBPR vios. Advised on SNC list for Stage 1 and how/when they can RTC. Advised of PN req's.
SC-Anchorage	David Edmunds	Non-RMW	OFFSHORE SYSTEMS, DUTCH HARBOR /AK2262505 (CWS/999)		▼										Last Stage 1 violation 8/06 for not taking distribution chlorine.
SC-Anchorage	David Edmunds	Kodiak/Kenai	OLD HARBOR /AK2250061 (CWS/320)	▼	▼										SWTR SNC is valid, many treatment technique and monitoring violations. Stage 1 SNC valid, last Stage 1 violation 8/06 for not taking distribution chlorine. Earliest system can RTC is 8/07.
SC-Anchorage	Doug Zellmer	Non-RMW	OMNI - QFC 2 /AK2271984 (TNCWS/50)	▼											Last TCR vio was 2nd quarter of 2006, so earliest system can RTC for TCR is 4th quarter of 2006. 5/29/06 - Spoke w/ system representative about overdue TCR monitoring. She was under impression that they did not have to monitor anymore b/c people fill own water containers at store. I informed that they still need to collect quarterly samples. 8/1/06 - Monitoring summary and letter sent to system advising of M/R req's. 8/16/06 - Spoke w/ operator regarding overdue TCR M&R. He had stopped collecting TCR samples b/c thought he didn't need to b/c they are not bottling water anymore (people fill their own containers). I explained that they still need to collect quarterly bactis under DW reg's, which he said he would do.
SC-Anchorage	Doug Zellmer	YKHC	OSCARVILLE WATERING POINT /AK2270061 (CWS/75)	▼	▼										Last TCR and Stage1 violations were August of 2006, so earliest system can RTC for TCR is February 2007 and for Stage1 is August of 2007. Stage1 violations are being received for failing to report Dist. Chlorine levels, failure to monitor for TTHM/HAA5's, and missing TCR samples. 6/22/06 - NOV issued and letter sent with NOV advising of noncompliance w/ total coliform M&R requirements. Advised of SNC listing for TCR, health risks associated w/ microbial contamination, and potential for additional enforcement actions to be taken. 10/17/06 - Sent letter advising of August 2006 TCR & Stage 1 D/DBPR vios. Advised on SNC list for Stage 1 and TCR and how/when they can RTC. Advised of PN req's.
SC-Anchorage	Doug Zellmer	Non-RMW	PACIFICA HOUSE & DIANES REST. /AK2271982 (TNCWS/62)	▼											Last TCR violation was 2nd qtr 2006, so earliest system can RTC is 4th quarter of 2006. 7/31/06 - Letter sent to operator/owner advising of 2006 monitoring requirements. Advised of SNC list, how systems get on SNC list, & repercussions for getting on SNC list. Notified overdue for bacti & Nitrate, & on SNC list for TCR. Encl: Monsum, vio page. The 7/31/06 letter and monitoring summary was returned to our department unclaimed. 10/26/06 - Spoke with manager of facility which changed ownership in March of 2006. Notified of TCR and Nitrate M/R req's and faxed 7/31/06 letter w/ monitoring summary.
SC-Anchorage	David Edmunds	Non-RMW	PAUG VIK INC. WEST HOUSING /AK2260422 (CWS/25)		▼										Valid Stage 1 SNC not taking distribution chlorine last violation 8/06
SC-Anchorage	David Edmunds	BBAHC	PERRYVILLE WATER SYSTEM /AK2260359 (CWS/125)	▼	▼	▼									Stage 1-Last violation 3/06, 7 of 12 months towards RTC (as of October data) SWTR- Reports are looking good, making progress, had Treatment Technique vio in Sept. 06 SWTR- 1 of 6 months towards RTC with October 2006 operator report. TCR- 5 of 6 months towards RTC with November sample, need to collect December sample to RTC.
SC-Anchorage	Jamie Yager	Non-RMW	PETERS CREEK BAPTIST CHURCH/AK2218425 (NC/40)	▼											1 of 2 quarters toward bacti RTC. Last sample collected 7/06, need to collect sample before December 31, 2006 to RTC. Met w/ operator 10/25/06 and discussed importance of collecting a bacti sample to RTC. Operator assures me the sample will be collected this
SC-Anchorage	Jamie Yager	Non-RMW	PGS ONSHORE CAMP /AK2334124 (TNCWS/88)	▼											1 of 12 months with no LT1 violations. PWS operates seasonally and has been closed since April 2006. The operator will meet Drinking Water Staff to discuss compliance when the camp re-opens.
SC-Anchorage	Doug Zellmer	YKHC	PILOT STATION WATER SYSTEM/AK2260163 (C/536)		▼										Last Stage1 violation was February 2006 so earliest system can RTC for Stage1 is February 2007. System on SNC list for Stage1 due to failing to report Dist. Chlorine levels. 5/9/06 - Letter and monitoring summary sent to system advising of Stage1 M/R req's.
SC-Anchorage	Doug Zellmer	YKHC	PITKAS POINT WATER SYSTEM /AK2270100 (CWS/158)		▼	▼									Last SW violation June of 2006; so earliest system can RTC for SW is December 2006. Last Stage1 violation was April 2006, so the earliest system can RTC for Stage1 is April 2007. System receiving SW violations for a combination of reporting and treatment problems. System is receiving Stage1 violations for failure to report Dist. Chlorine residual levels and TTHM/HAA5's (resolved TTHM/HAA5 M/R w/ 2006 samples). 8/31/06 - Letter sent to Charlie Sallison advising of unsatisfactory April, May, & June op reports w/ description of problems. Also advised of missed bactis in April. Advised of SNC list, PN req's, potential for enforcement actions/admin penalties. 9/5/06 - Operator called to speak about letter he received dated 8/31/06 (SWTR vios, etc). Operator said that he resumed operating system late May to early June & that Operator working in interim was not performing necessary/required duties.
SC-Anchorage	Doug Zellmer	BBAHC	PLATINUM CITY WATER SYSTEM /AK2271059 (CWS/68)		▼										System does not have the hardware to meet SWTR at this time, and will have to install filtration and disinfection before able to RTC.
SC-Soldotna	David-Litehfield	Kodiak/Kenai	PORT GRAHAM /AK2240498 (CWS/190)	▼											RTCd for SW SNC October 2006.
MSSE	Carrie McMullen	Non-RMW	PWSAC - ESTHER HATCHERY /AK2293124 (TNCWS/55)		▼										Valid SNC. Drinking Water Staff will contact to remind about Dist. Chlorine readings with bactis.
SC-Anchorage	Doug Zellmer	YKHC	QUINHAGAK WATER SYSTEM /AK2271041 (CWS/620)		▼										Last Stage1 violation was 2nd Qtr of 2006, so earliest system can RTC is March of 2007. System was receiving Stage1 vios for failing to monitor and report quarterly TTHM/HAA5's. System is now aware of the problem and has begun collecting quarterly TTHM/HAA5's (last sample July 2006). 7/24/06 - System collected their 3rd quarter TTHM/HAA5 sample. 8/31/06 - Ltr sent to system advising of missed quarterly TTHM/HAA5's from 2004 to 2Q2006. Advised of SNC listing & how to RTC, PN req's, potential for enf actns/admin penalties. 10/10/06 - System called and requested information on what violations they currently have. I provided info on Stage1 violations as well as a monitoring summary.

October 2006 SNC List

UPDATED
(as of December 19, 2006)

Office	Drinking Water Program Staff	RMW Service Area	System Name / PWSID (System Type/Population)	TCR (Bacti)	Surface Water	STAGE1	NITRATE	IOC	VOC	ARSENIC	SOC	LEAD	RAD	CCR	Environmental Specialist Comments RED TEXT as of December 19, 2006 (Black Text As of October 30, 2006)
SC-Anchorage	David Edmunds	Non-RMW	ROADS END /AK2250469 (TNCWS/27)												Last Nitrate sample 11/04
SC-Anchorage	Doug Zellmer	Non-RMW	SACKETT CENTER - ANIAK /AK2271643 (TNCWS/70)	▼		▼									Valid Nitrate SNC. Last sample collected 1/03. Last TCR violation was August 2006, so earliest system can RTC for quarterly TCR M/R is March 2006. Last Nitrate samples was 1/03 - system can RTC with collection of a nitrate sample. 7/31/06 - Sent monitoring summary advising system of TCR and Nitrate M/R req's. 10/23/06 - Sent letter to operator advising of August 2006 TCR violation (missed 5 follow up routines). Advised on SNC list for TCR and Nitrate and how/when they can RTC. Also advised of PN req's. 10/26/06 - Spoke to system following operator's phone message regarding 10/23/06 letter about TCR violation from 8/06. Explained why they rec'd vio as well as routine and follow-up TCR M/R req's. Also told them to collect a Nitrate sample. 10/23/06 - Faxed system an updated monitoring summary.
SC-Anchorage	David Edmunds	APIA	SAINT PAUL WATER SYSTEM /AK2260286 (CWS/730)			▼									Last Stage 1 violation 6/06, 2 of 12 months towards RTC as of August.
Northern	Linda Grantham	NSHC	SAVOONGA WATER SUPPLY SYSTEM/AK2340183 (C/656)			▼									Stage 1: Was 7 months toward RTC, but received a violation for failing to collect a dist. Chlorine sample in March 2006. 7 of 12 months toward RTC with October operator report.
MSSE	Carrie McMullen	SEARHC	SAXMAN /AK2120127 (CWS/429)			▼									Stage 1: Receiving violations for MCL exceedences of TTHM/HAA5. Last violation July-September quarter 2006. Earliest system can RTC is July-September quarter 2007. Will issue NOV in early January for failure to meet the SWTR filtration requirements. Currently they use only pressure sand filters with no chemical addition. The NOV will also address corrosion control requirements for exceedences of the AL for lead and copper, as well as MCL exceedences for both TTHMs and HAA5s. The present configuration of the system prevents them from meeting these regulations.
SC-Anchorage	Doug Zellmer	YKHC	SCAMMON BAY WATER SYSTEM /AK2270184 (CWS/484)	▼	▼										System has RTC'd for TCR with 6 satisfactory months of TCR M/R (October sample pending migration into database was 6th month sample). Last SWTR violation was August 2006, so earliest system can RTC for SWTR is February 2006. System is receiving SWTR violations for failing to submit monthly operator reports and system also lacks hardware (filtration and turbidity monitoring) to meet SWTR. 3/30/06 - BCA signed between State and System. 9/18/06 - Spoke w/ administrator about compliance status. He thought they were in compliance b/c they were sending in all of their monthly bactis. He had rec'd recent letter noting noncompliance. I told him they have many additional req's & I would send him a monitoring summary. 10/10/06 - Monsum faxed to administrator in follow-up to September conversation in which James was under the impression that by sending in monthly bacti they were doing everything that they needed to do. 10/23/06 - Sent ltr to administrator advising of July & Aug 2006 SWTR & Stage 1 vios. Advsd on SNC list for Stage 1, and TCR & how/when they can RTC. Advsd of PN req's. CC'd operator.
Northern	Marci Irwin	YKHC	SELAWIK SAFEWATER FACILITY /AK2340379 (CWS/800)		▼	▼									NOV issued by Nov. 31, 2006. Vios for TTHM/HAA5 quarterly monitoring and TTHM/HAA5 MCLs. Incompliance with dist Cl2. Not submitting CFE monitoring page, but is sending in on-line turb monitoring data.
SC-Anchorage	Doug Zellmer	YKHC	SHAGELUK WATER SYSTEM /AK2280040 (CWS/150)			▼	▼								Valid Nitrate SNC. Last sample collected 1/03. Last Stage1 Violation February 2006; so earliest system can RTC for Stage1 is February 2007. Last nitrate sample was 3/03 - system can RTC with submission of a nitrate sample. System receiving Stage1 violations for failing to report Dist. Chlorine residual levels as well as TTHM/HAA5 results. 5/9/06 - Letter and monitoring summary sent advising of M&R req's for 2006, 2005 vios, SNC list info. Advised overdue for TTHM/HAA5 and nitrate. 10/23/06 - Sent letter to operator advising of Aug 2006 TCR vio. Advised on SNC list for Stage1 and Nitrate, & how/when they can RTC. Advised of PN req's.
Northern	Marci Irwin	NSHC	SHAKTOOLIK WATER SYSTEM /AK2340442 (CWS/230)			▼									SW: NOV issued 1/10/06, System is not submitting operator reports consistently and is not doing dist Cl2 monitoring consistently. Last SW violation October 2006 for a couple EP Cl2 levels being <0.02 mg/L. Earliest system can RTC is April 2007. Stage 1 vios for inconsistent dist Cl2 monitoring and TTHM/HAA5 monitoring. Lead operator took a leave of absence for the summer and the alternate operator did not complete the requirements. Operator returned at the end of Sept and he did submit an October operator report and is supposed to send in samples.
Northern	Marci Irwin	NSHC	SHISHMAREF WATER SYSTEM /AK2340484 (CWS/572)			▼	▼								SWTR: the majority of violations prior to October are for missing a few EP Cl2 readings. In October the system has had issues with turbidity and has been working with ADEC engineers to resolve the issue. Last SWTR violation October 2006. 0 of 6 months towards RTC as of October. Stage 1: Has TTHM/HAA5 vios for MCL and monitor. Last Stage 1 violation October 2006, so earliest system can RTC is October 2007.
SC-Anchorage	Doug Zellmer	YKHC	SLEETMUTE WATERING POINT /AK2271874 (CWS/100)			▼	▼		▼						Valid Nitrate SNC. Last sample collected 1/03. Last Stage1 violation was August 2006, so earliest system can RTC for Stage1 is August 2007. System is receiving Stage1 violations for failing to monitor and report Dist. Chlorine residual levels as well as annual TTHM/HAA5's. Last Nitrate (due annually) was 1/03 and last VOC sample (also due annually), was 12/03. System can RTC for nitrate and VOC's by collecting each of those samples ASAP. 5/9/06 - Letter and monitoring summary sent to system advising of Stage1, Nitrate, and VOC M/R req's. and that they are overdue for all of these. 10/23/06 - Sent letter to operator advising of July & Aug 2006 Stage 1 vios. Advised on SNC list for Stage1 & Nitrate & how/when they can RTC. Also advised of PN req's.
MSSE	Carrie McMullen	Non-RMW	SPORTSMANS COVE LODGE/AK2121093 (NC/55)			▼									Seasonal system, could RTC with August/Sept clean operator reports.
SC-Anchorage	Doug Zellmer	YKHC	ST. MARYS WATER SYSTEM /AK2270176 (CWS/521)			▼	▼								Last Stage1 violation was rec'd for 4th quarter 2005 so system can RTC December 2006 for Stage1. System rec'd Stage1 violations due to not monitoring for quarterly TTHM/HAA5's. Last SW violation was from May 2006, so earliest system can RTC for SW is November 2006. System receiving SW vios for treatment violations. 5/8/14/06 - Spoke w/ Andy Journey re: new operator report forms as well as their SWTR M&R req's. We went through each pg of forms 1by1 and discussed questions as we went along. Currently syst is not able to monitor or continuously record b/c they don't have equipment, but are working on getting that equipment. 10/11/06 - emailed operator an updated monitoring summary.
Northern	Marci Irwin	NSHC	STEBBINS CITY WATER SUPPLY /AK2340492 (CWS/552)			▼									BCA Issued 2/8/06 addressing Stage 1, SWTR, CCR. Have enough new SWTR violations to be SNC after BCA was issued. They have current hardware issues and cannot meet LT1. Majority of vios are from not taking enough EP Cl2 readings and having some readings below 0.2mg/L. Working with system and NSHC. Last violation October 2006. Earliest system can RTC is April 2007. A new WTP has been in the planning stages for many years.
Northern	Linda Grantham	TCC	STEVENS VILLAGE WATER SYSTEM /AK2360442 (CWS/87)			▼						▼			Stage 1: Violations for failure to monitor and report TTHM/HAA5 and distr. chlorine levels. Last violation April 2006. Earliest system can RTC is April 2007.
SC-Anchorage	David Edmunds	Non-RMW	SWSD ALEKNAGIK NORTHSHORE/AK2261185 (NTNC/38)			▼									Valid SNC.
SC-Anchorage	David Edmunds	Non-RMW	SWSD WM NELSON SCHOOL EKWOK/AK2260171 (NTNC/45)			▼									Valid SNC.
SC-Anchorage	Doug Zellmer	TCC	TAKOTNA WATER SYSTEM /AK2280463 (CWS/60)						▼						RTCd with 4th quarter VOC sample 12/15/06.

October 2006 SNC List

UPDATED
(as of December 19, 2006)

Office	Drinking Water Program Staff	RMW Service Area	System Name / PWSID (System Type/Population)	TCR (Bacti)	Surface Water	STAGE1	NITRATE	IOC	VOC	ARSENIC	SOC	LEAD	RAD	CCR	Environmental Specialist Comments RED TEXT as of December 19, 2006 (Black Text As of October 30, 2006)
Northern	Marci Irwin	TCC	TANANA SAFEWATER FACILITY /AK2360109 (CWS/351)	▼											SW: Violations for not taking dist. Cl2 readings. Last violation Oct 2006 and can RTC April 2006. Has 2 months with only vios for dist Cl2. Stage 1: Violations for not taking dist. Cl2 readings, is in compliance TTHM/HAA5 monitoring. Last violations in October 2006, system did take the November dist Cl2 reading.
MSSE	Carrie McMullen	SC	TATITLEK WATER SYSTEM /AK2291130 (CWS/124)	▼											SW: System receiving SW violations for failure to monitor/report turbidity an chlorine levels. Last violation July 2006. 3 of 6 months towards RTC as of October operator report, can RTC with satisfactory January operator report.
SC-Anchorage	David Edmunds	Non-RMW	THE PIT /AK2263027 (TNCWS/200)	▼											Valid Bacti SNC last sample collected 5/06. Needed sample in July-September quarter to RTC.
MSSE	Carrie McMullen	Non-RMW	THE SPORTS PAGE /AK2299019 (TNCWS/300)	▼											
MSSE	Carrie McMullen	Juneau	THORNE BAY /AK2120216 (CWS/612)			▼									Stage 1: Receiving Stage 1 violations for MCL exceedences for TTHM/HAA5. System may be having problems with coagulant dosage, need assistance to optimize treatment, will work with health corp/RMW. Last violation July-September 2006 quarter. Earliest system can RTC is July-September 2007 quarter. Will issue NOV by Dec. 31, 2006.
SC-Anchorage	Doug Zellmer	YKHC	TUNTUTULIAK WASHETERIA /AK2271211 (CWS/350)			▼	▼								Valid Nitrate SNC. Last sample collected 9/03. Last Stage1 violation June 2006, so earliest system can RTC for Stage1 is June 2007. System on SNC list for Stage1 due to failing to monitor and report Dist. Chlorine residuals and annual TTHM/HAA5. Last Nitrate sample 9/03 - system can RTC with collection of one nitrate sample. 9/7/06 - Ltr sent to system advising of Stage1 vios (missed dist CL and TTHM/HAA5's) and missed 2005 nitrate. Advised of PN req's, potential for EA's and Admin penalties, and that syst on SNC list and how to RTC. 9/11/06 - Spoke w/ system about financial situation system is in. They may have to shut syst down for winter b/c they don't have enough money for fuel, and individual had said can't perform M&R for same reasons. Syst may get some financial help but uncertain at this time.
SC-Anchorage	Doug Zellmer	YKHC	TUNUNAK WATER SYSTEM /AK2270231 (CWS/354)	▼	▼	▼	▼	▼	▼	▼	▼	▼	▼	▼	Last TCR, SWTR, and Stage1 violations were from August 2006. Earliest system can RTC for TCR/SWTR is February 2007 and for Stage1 is August 2007. System is receiving TCR violations for not performing req'd bacti monitoring. On SNC list for SWTR for not submitting mnthly op reports. On SNC list for Stage1 for not reporting Dist.Chlorine levels or TTHM/HAA5's. Last Arsenic, Nitrate, IOC, VOC samples were from June 200 and system can RTC for all of these with submission of one of each. Last Rad sample 1992 - system will need to comply w/ new req's to RTC. Last CCR was 2003 and system can RTC for CCR with submission of CCR currently due. 10/17/06 - Sent ltr to system advising of July & Aug 2006 TCR, SWTR & Stage 1 vios. Advised on SNC list for TCR, Stage 1, SWTR, Nit, Ars, IOC, VOC, Rad, CCR & how/when they can RTC. Advsd of PN req's. 10/24/06 - Spoke to operator in afternoon after he had rec'd the fax frm earlier in the day. We went ovr the op rpt frm & monsum & it seemed like he understood what is req'd. He will call YKHC to get more sample containers also spoke to administrator about M/R.
Northern	Marci Irwin	Non-RMW	UAF/IAB TOOLIK FIELD STATION/AK2350146 (NC/45)	▼											Missed 1 of 4 dist. Cl2 for the summer season 2006.
Northern	Marci Irwin	NSHC	UNALAKLEET CITY WATER SUPPLY /AK2340387 (CWS/757)	▼	▼										LT1 violations for not taking IFE-still waiting on computers to access data from on-line turbidimeters. Stage 1 vios for HAA5 MCL and TTHM/HAA5 monitoring. Is in compliance with dist Cl2 residuals. Working with system on these issues, need hardware improvements to address Stage 1 MCL.
Northern	Linda Grantham	Non-RMW	UNIVERSITY OF ALASKA /AK2310683 (CWS/5000)			▼									Last TTHM vio Q1 2006
SC-Anchorage	David Edmunds	Non-RMW	USAF KING SALMON /AK2260503 (CWS/50)			▼									Valid Stage 1 SNC for not collecting quarterly TTHM/HAA5 Samples. Last sample collected 3/2006. System on quarterly monitoring due to an MCL. The system is in the process of putting in a new source. The project is on stand-by until funding is available
MSSE	Carrie McMullen	Non-RMW	VALLENAR VIEW MOBILE HOME PARK /AK2120012 (CWS/225)	▼	▼										Valid SNC. Will issue NOV by Dec. 31, 2006.
Northern	Marci Irwin	TCC	VENETIE WATER SYSTEM/AK2300248 (C/202)			▼									Stage 1: Violations for not submitting dist Cl2 residual readings. Last Stage 1 violation October 2006. Earliest system can RTC is October 2007. SNC letter sent by Nov. 31, 2006.
SC-Anchorage	David Edmunds	Non-RMW	VFW KODIAK POST #7056 /AK2250493 (TNCWS/27)	▼											Valid SWTR SNC. Last violation was a treatment technique violation 8/06. 0 of 6 months toward RTC.
Northern	Marci Irwin	NSHC	WALES WATER SYSTEM /AK2340191 (CWS/173)	▼	▼							▼			Has 0 of 6 months with no TCR violations, last sample 6/06. SW violations for EP & Dist Cl2 residual and turbidity monitoring, and continues to generate violations for not turning in operator reports. Stage 1 violations for TTHM MCL and both TTHM/HAA5 for failure to submit quarterly monitoring. Lead SNC for failure to conduct initial lead/copper monitoring. System working with ADEC, NSHC and NSEDC. System has hired an operator and NSHC is providing training on sampling and operations/reporting. NSEDC is setting up a sampling contract with Analytica.
MSSE	Carrie McMullen	Non-RMW	WAL-MART /AK2121485 (NTNCWS/50)	▼	▼										Working under NOV. Contracting lab collecting bactis was not collecting CL2 at same time and place. Lab and system contacted in June. As of Sept. 06 should have 3 months towards RTC.
SC-Anchorage	David Edmunds	Non-RMW	WARDS COVE NAKNEK TRADING POST/AK2262862 (NC/33)	▼											1 of 2 quarters toward bacti RTC. Last sample collected 4/06, could RTC if sampled by Sept 30, 2006.
MSSE	Carrie McMullen	Non-RMW	WHALERS COVE LODGE /AK2133333 (TNCWS/65)				▼								System closed for season. Will issue NOV upon reopening in June 2007
Northern	Linda Grantham	NSHC	WHITE MOUNTAIN WATER SYSTEM /AK2340507 (CWS/203)			▼									Stage 1: Violations for not submitting dist. Cl2 residual readings. Last Stage 1 violation September 2006, so earliest system can RTC is September 2007. SNC letter by 10/31/06
MSSE	Carrie McMullen	SEARHC	YAKUTAT PWS /AK2130172 (CWS/740)			▼									COBC issued 3/06.
SC-Anchorage	Doug Zellmer	Non-RMW	YKHC HOSPITAL - BETHEL /AK2271083 (CWS/510)			▼									Valid SNC- missing TTHM/HAA5 quarterly monitoring. Last Stage1 violation was 2nd qtr of 2006, so earliest system can RTC is March of 2007. System is receiving Stage1 vios for failing to monitor and report quarterly TTHM/HAA5's. 5/9/06 - Letter sent advising of M&R req's for 2006, 2005 vios, SNC list info. Encl: mon sum & vio page. Advised overdue for TTHM/HAA5. 9/7/06 - Letter sent to system advising of Stage1 vios (missed dist CL and TTHM/HAA5's). Advised of PN req's, potential for EA's and Admin penalties, and SNC list.
Northern	Marci Irwin	Non-RMW	YKSD - ALLAKAKET PUBLIC WATER /AK2300206 (CWS/45)			▼									Vios for HAA5 monitoring and not taking dist. Cl2 residual readings. DEC is working with the operator and school district in resolving this.
SC-Anchorage	Doug Zellmer	Non-RMW	YUKON KUSKOKWIM CORRECTIONAL/AK2271334 (NTNC/98)			▼									8 of 12 months towards RTC (w/July 2006 distribution chlorine) Valid SNC? No Stage1 vios from 11/04 to 8/06. Last Stage1 Violation was 8/06. Violations received for not reporting Dist. Chlorine residuals. 5/9/06 - Letter sent advising of M&R req's for 2006, 2005 vios, SNC list info. Encl: mon sum & vio page. 5/10/06 - Spoke w/ operator about 2005 chlorine vios and '06 monitoring. Explained what 2005 vios were for and how to report Chlorine. 10/23/06 - Sent ltr to operator advising of Aug 2006 Stage 1 vios. Advised of SNC list and of PN req's.

October 2006 SNC List

UPDATED
(as of December 19, 2006)

Office	Drinking Water Program Staff	RMW Service Area	System Name / PWSID (System Type/Population)	TCR (Bacti)	Surface Water	STAGE1	NITRATE	IOC	VOC	ARSENIC	SOC	LEAD	RAD	CCR	Environmental Specialist Comments RED TEXT as of December 19, 2006 (Black Text As of October 30, 2006)
Contact Information:															
EPA REFERRAL = Public Water System that has been referred to the Environmental Protection Agency (EPA) for formal enforcement (Anchorage Office Staff: Jeanine Oakland 269-2007)															
MSSE = Office located in Wasilla, AK covers the MatSu area and Southeast Alaska PWSs (Staff: Carrie McMullen 465-5333, Tee Little 376-1860)															
NORTHERN = Office located in Fairbanks, AK covers the Northern Alaska PWSs (Staff:Linda Grantham 451-2137, Marci Irwin 451-2168)															
SC-ANCHORAGE = Office located in Anchorage, AK covers Anchorage Bowl, Bethel/YK Delta, Dillingham area, Aleutian Chain, Pribilof and Kodiak Islands area PWSs (Staff: David Edmunds 269-7653, Doug Zellmer 269-7623, Jamie Stazel 269-7624)															
SC-SOLDOTNA = Office located in Soldotna, AK covers the Kenai Peninsula area PWSs Staff: David Litchfield 262-5210 xtn 224)															
Remote Maintenance Worker (RMW) Service Area Abbreviations															
APIA - Aleutian Pribilof Island Association															
BBAHC= Bristol Bay area Health Corporation															
NSHC= Norton Sound Health Corporation															
SC= South Central															
SEARHC= SouthEast Alaska Regional Health Consortium															
TCC= Tanana Chiefs Conference															
YKHC= Yukon Kuskokwim Health Corporation															
DEFINITIONS:															
ANTHC= Alaska Native Tribal Health Consortium															
ARWA= Alaska Rural Water Association															
BACTI= Total Coliform Rule (TCR)															
BCA= Bilateral Compliance Agreement															
CCR = Consumer Confidence Report															
CFE= Combined Filter Effluent															
COBC= Compliance Order By Consent															
EHO= Environmental Health Officer															
EPA= Environmental Protection Agency															
IFE= Individual Filter Effluent															
IOC = Inorganic Chemicals															
LEAD= Lead/Copper Rule															
LT1 = Long Term1 Enhanced Surface Water Treatment Rule															
NOV= Notice of Violation															
OCC = optimal corrosion control or corrosion control program (Lead/Copper Rule)															
PN= Public Notice															
PWS= Public Water System															
RADs= Radionuclides Rule															
RMW= Remote Maintenance Worker															
RTC = Return to compliance (fall off SNC list)															
SOC = Synthetic Organic Chemicals															
STAGE 1 = Stage 1: Disinfectants and Disinfection By Products Rule															
Surface Water= Surface Water SNC for violations of SWTR and LT1															
SWTR = Surface Water Treatment Rule															
TCC= Tanana Chiefs Conference															
TCR = Total Coliform Rule (Bacti)															
VOC = Volatile Organic Chemicals															
VSW= Village Safe Water															
WTP= Water Treatment Plant															
YKHC= Yukon Kuskokwim Health Corporation															