



7 June 2022

Mr. Aaron Simpson
Alaska Department of Environmental Conservation
Division of Air Quality
410 Willoughby Avenue, Suite 303
Juneau, Alaska 99811-1800

Re: Permit Extension Request
Air Quality Control Construction Permit AQ0083CPT07
Kenai Nitrogen Operations
Kenai, Alaska

Dear Mr. Simpson:

Agrium U.S. Inc. (Agrium) was issued Air Quality Control Construction Permit AQ0083CPT07 on 26 March 2021 for the proposed restart of a portion of its Kenai Nitrogen Operations (KNO) fertilizer operation in Kenai, Alaska. Agrium requests that the Alaska Department of Environmental Conservation (ADEC) extend this permit for an additional eighteen (18) months to allow more time to commence construction as authorized by this permit. Additional information concerning this request is provided below.

Background

In May 2020 Agrium submitted a Prevention of Significant Deterioration (PSD) permit application to restart portions of the KNO fertilizer plant. This resulted in the issuance of Air Quality Construction Permit AQ0083CPT07 on 26 March 2021. Although Agrium has worked to secure necessary natural gas contracts for the facility since the issuance of this permit, for a variety of reasons these negotiations are still on-going. Agrium continues to believe that it will ultimately be able to obtain contracts for sufficient natural gas in order to assure viable operations at KNO. Agrium does not, however, wish to begin construction on the modifications necessary to the plant, which will involve a substantial capital investment, until such time as it has contractual assurances that sufficient natural gas is available to operate the facility at target production levels.

While Agrium is hopeful that it will be able to secure the desired contracts in the near future, the delay in securing necessary contracts will delay the date by which Agrium will wish to begin operation of the plant, resulting in the need to delay the date by which

construction will commence. An extension for an additional eighteen (18) months will allow time for negotiations to continue to secure necessary natural gas contracts.

Construction Permit and PSD Commence Construction Requirements

Condition 2 of the Construction Permit issued by ADEC specifies that “the Permittee shall commence construction of the modification to the stationary source authorized under Construction Permit AQ0083CPT07 within 18 months of the issuance of the permit unless granted an extension in writing from the Department”. Likewise, PSD rules contained in 40 CFR 52.21(r)(2) specify that approval to construct will become invalid if construction is not commenced within 18 months of permit issuance.

Neither the Construction nor PSD rule language provides any details on the appropriate content of an extension request or the information the Administrator may require in granting such an extension.

EPA Guidance

Current EPA guidance on the circumstances under which a PSD permit may be extended is contained in a memorandum from Stephen Page dated 31 January 2014 (Extension Memorandum)¹. As described in the Extension Memorandum and in accordance with 40 C.F.R. 52.21(r)(2), EPA indicates that such extensions should be evaluated on a case-by-case basis, and that such requests should be made in advance of the end of the 18-month period for commencing construction. The Extension Memorandum indicates that an extensive reevaluation of BACT and the air quality impacts analysis “should generally not be necessary for a first permit extension request”. The Extension Memorandum specifies that the applicant should provide a detailed justification as to the reasons that the extension is necessary.

BACT Update

Although EPA guidance states that an extensive reevaluation of BACT is not required as a part of the first permit extension request, Agrium has researched the RACT/BACT/LAER Clearinghouse (RBLC) to identify any permits issued since the date of the KNO Construction Permit that might contain a more stringent Best Available Control Technology (BACT) emission limit than was established for KNO. The results of this search for the principal emission units at KNO are discussed briefly below:

¹ “Guidance on Extension of Prevention of Significant Deterioration (PSD) Permits under 40 CFR 52.21(r)(2)”, Stephen D. Page, Director Office of Air Quality Planning and Standards, to Regional Air Division Directors, 31 January 2014.

- Primary Reformer (Unit 12) – New permit limits have been added to the RBLC database for El Dorado Chemical Company (AR-0170) and Midwest Fertilizer Company LLC (IN-0324). The BACT limits contained in these permits are no more stringent than limits contained in permits that were reviewed as a part of the BACT analysis submitted with the KNO permit application.
- CO2 Vent (Unit 14) – New permit limits have been added to the RBLC database for El Dorado Chemical Company (AR-0170) and Midwest Fertilizer Company LLC (IN-0324). The BACT limits contained in these permits are no more stringent than limits contained in permits that were reviewed as a part of the BACT analysis submitted with the KNO permit application.
- Urea Granulation (Units 35 and 36) – No new RBLC entries were identified in the database for urea granulation units.
- Package Boilers (Units 44, 48, and 49) – The current RBLC summary includes a number of new entries for sources with boilers or process heaters with a heat input above 100 mmBtu/hr but less than 250 mmBtu/hr. The BACT limits contained in these permits are no more stringent than limits contained in permits that were reviewed as a part of the BACT analysis submitted with the KNO permit application.
- Solar Turbine/Generator Sets (Units 55, 56, 57, 58, and 59) – New permit limits have been added to the RBLC database for Norfolk Naval Shipyard (RBLC VA-0333) and Sabine Pass LNG Terminal (LA-0375). The BACT limits contained in these permits are no more stringent than limits contained in permits that were reviewed as a part of the BACT analysis submitted with the KNO permit application.
- Urea Ship Loading (Unit 47) – No recent permits were identified with BACT emission limits for urea ship loading.
- Urea Material Handling Units (Unit 47A, 47B, 47C, and 47D) – One new permit limit has been added to the RBLC database for Pallas Nitrogen LLC (OH-0368) with BACT limits for urea transfer operations. The BACT limit contained in this permit is no more stringent than limits contained in permits that were reviewed as a part of the BACT analysis submitted with the KNO permit application.

Based on the summary of RBLC listings reviewed, no new permits have been issued since the date of the Construction Permit for KNO that contain BACT limits that are more stringent than those reviewed as a part of the BACT determination for KNO. An updated RBLC listing (with new entries denoted in red font) is provided as an attachment to this request.

Air Quality Impact Analysis

As a part of its PSD application, KNO provided an air quality impact analysis demonstrating that the project would not result in an ambient impact that exceeded permissible increments under PSD rules nor would the project cause an exceedance of National Ambient Air Quality Standards (NAAQS). Although EPA guidance does not indicate that the air quality impact analysis must be revisited as a part of a first request for an extension to a PSD permit, KNO has reevaluated air quality in the area of its site as a part of this request.

KNO reviewed the ADEC web site to identify Construction Permits for major sources that had been issued since the PSD permit was issued to KNO in March 2021. KNO identified no Title I Construction Permits that have been issued since the date of its permit in March 2021.

The region surrounding KNO has experienced little change in population since the PSD permit was issued in March 2021, nor have any significant plant expansions occurred in the area since this time. As a consequence of the fact that there has been no significant growth in the area over the past eighteen months, KNO believes that air quality data collected to characterize the area are still an accurate representation of background air quality.


Summary

As described in detail above, the extension request is being filed due to the fact that Agrium has not been able to secure necessary contracts to assure that natural gas will be available at the time the plant would wish to begin operations. Agrium requests that the date by which it must commence construction be extended by 18 months to allow Agrium to secure necessary contracts prior to commencing construction on modifications necessary. This would extend the date by which construction must commence from 26 September 2022 to 26 March 2024.

If you have any questions regarding this request, please contact Dave Jordan of ERM at (513) 830-9035.

Aaron Simpson
ADEC
KNO Construction Permit Extension
7 June 2022
Page 5

Sincerely,

A handwritten signature in black ink, appearing to read 'Fred Werth', with a stylized flourish at the end.

Fred Werth
Manager, Kenai Plant

cc: Ted Hartman, Nutrien
David Jordan, ERM

Enclosure: RBLC Update

Attachment – RBLC Update

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Cooling Tower" - All Results Included
Unit 40 - Cooling Tower

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
BIG RIVER STEEL LLC	AR-0168	3/17/2021	TPM	Contact Cooling Tower	0.0010	% DRIFT LOSS	Drift Eliminators Low TDS
BIG RIVER STEEL LLC	AR-0168	3/17/2021	TPM10	Contact Cooling Tower	0.0010	% DRIFT LOSS	Drift Eliminators Low TDS
BIG RIVER STEEL LLC	AR-0168	3/17/2021	TPM2.5	Contact Cooling Tower	0.0010	% DRIFT LOSS	Drift Eliminators Low TDS
BIG RIVER STEEL LLC	AR-0168	3/17/2021	Visible Emissions (VE)	Contact Cooling Tower	5.0000	%	Drift Eliminators Low TDS
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	FPM	SN-212 Cooling Tower	0.0005	% DRIFT LOSS	High efficiency Drift/mist eliminator
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	TPM10	SN-212 Cooling Tower	0.0005	% DRIFT LOSS	High efficiency Drift/mist eliminator
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	TPM2.5	SN-212 Cooling Tower	0.0005	% DRIFT LOSS	High efficiency Drift/mist eliminator
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM	Cooling Towers	0.0005	DRIFT LOSS	Drift Eliminators Low TDS
BIG RIVER STEEL LLC	AR-0173	1/31/2022	TPM10	Cooling Towers	0.0005	%	Drift Eliminators Low TDS
BIG RIVER STEEL LLC	AR-0173	1/31/2022	TPM2.5	Cooling Towers	0.0005	DRIFT LOSS	Drift Eliminators Low TDS
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Visible Emissions (VE)	Cooling Towers	5.0000	%	Drift Eliminators Low TDS
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	FPM	Mechanical Draft Auxiliary Cooling System	0.0005	% DRIFT RATE	Certified drift rate < 0.0005%
SHELL ROCK SOY PROCESSING	*IA-0117	3/17/2021	TPM	Cooling Tower	0.2600	LB/HR, PM, PM10 AND PM2.5	Drift Eliminator
SHELL ROCK SOY PROCESSING	*IA-0117	3/17/2021	TPM	Cooling Tower	0.0000	%, OPACITY	Drift Eliminator
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	TPM10	ten cell evaporative cooling tower EU-010	2000.0000	MG/L, AVERAGED ON A MONTHLY BASIS	shall be controlled by high efficiency drift eliminators; The cooling tower (EU-010) shall be designed to meet a 0.0005% drift
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	TPM2.5	ten cell evaporative cooling tower EU-010	2000.0000	MG/L, AVERAGED ON A MONTHLY BASIS	shall be controlled by high efficiency drift eliminators; The cooling tower (EU-010) shall be designed to meet a 0.0005% drift
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-01 - Melt Shop ICW Cooling Tower	0.3600	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-01 - Melt Shop ICW Cooling Tower	1.5600	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-01 - Melt Shop ICW Cooling Tower	0.2700	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-01 - Melt Shop ICW Cooling Tower	1.1600	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-01 - Melt Shop ICW Cooling Tower	0.0008	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-01 - Melt Shop ICW Cooling Tower	0.0035	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-02 - Melt Shop DCW Cooling Tower	0.0400	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-02 - Melt Shop DCW Cooling Tower	0.1900	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-02 - Melt Shop DCW Cooling Tower	0.0300	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-02 - Melt Shop DCW Cooling Tower	0.1400	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-02 - Melt Shop DCW Cooling Tower	0.0001	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-02 - Melt Shop DCW Cooling Tower	0.0004	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-03 - Rolling Mill ICW Cooling Tower	0.0600	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-03 - Rolling Mill ICW Cooling Tower	0.2500	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-03 - Rolling Mill ICW Cooling Tower	0.0400	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-03 - Rolling Mill ICW Cooling Tower	0.1900	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-03 - Rolling Mill ICW Cooling Tower	0.0001	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-03 - Rolling Mill ICW Cooling Tower	0.0006	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-04 - Rolling Mill DCW Cooling Tower	0.1700	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-04 - Rolling Mill DCW Cooling Tower	0.7500	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-04 - Rolling Mill DCW Cooling Tower	0.1200	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-04 - Rolling Mill DCW Cooling Tower	0.5100	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-04 - Rolling Mill DCW Cooling Tower	0.0004	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-04 - Rolling Mill DCW Cooling Tower	0.0016	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-05 - Rolling Mill Quench/ACC Cooling Tower	0.7800	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-05 - Rolling Mill Quench/ACC Cooling Tower	3.4100	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-05 - Rolling Mill Quench/ACC Cooling Tower	0.5400	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Cooling Tower" - All Results Included
Unit 40 - Cooling Tower

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-05 - Rolling Mill Quench/ACC Cooling Tower	2.3500	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-05 - Rolling Mill Quench/ACC Cooling Tower	0.0017	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-05 - Rolling Mill Quench/ACC Cooling Tower	0.0075	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-06 - Light Plate Quench DCW Cooling Tower	0.0600	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-06 - Light Plate Quench DCW Cooling Tower	0.2600	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-06 - Light Plate Quench DCW Cooling Tower	0.0400	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-06 - Light Plate Quench DCW Cooling Tower	0.1900	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-06 - Light Plate Quench DCW Cooling Tower	0.0001	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-06 - Light Plate Quench DCW Cooling Tower	0.0006	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-07 - Heavy Plate Quench DCW Cooling Tower	0.0200	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-07 - Heavy Plate Quench DCW Cooling Tower	0.1000	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-07 - Heavy Plate Quench DCW Cooling Tower	0.0200	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-07 - Heavy Plate Quench DCW Cooling Tower	0.0700	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-07 - Heavy Plate Quench DCW Cooling Tower	0.0001	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-07 - Heavy Plate Quench DCW Cooling Tower	0.0002	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-08 - Air Separation Plant Cooling Tower	0.1000	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	FPM	EP 09-08 - Air Separation Plant Cooling Tower	0.4600	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-08 - Air Separation Plant Cooling Tower	0.0800	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM10	EP 09-08 - Air Separation Plant Cooling Tower	0.3400	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-08 - Air Separation Plant Cooling Tower	0.0002	LB/HR	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
NUCOR STEEL BRANDENBURG	KY-0110	7/23/2020	TPM2.5	EP 09-08 - Air Separation Plant Cooling Tower	0.0010	TON/YR, 12-MONTH ROLLING	High Efficiency Mist Eliminator. The mist eliminator drift loss shall be maintained at 0.001% or less to total gpm.
WESTLAKE VINYL, INC. - PVC PLANT	KY-0112	11/13/2020	FPM	Cooling Tower [EU 31]	0.1250	LBS/HOUR, MONTHLY BASIS	1. State-of-the-art, high-efficiency drift eliminators with a drift rate specified at 0.0005% percent of the circulating water rate; 2. Monitoring and limiting total dissolved solids in the circulating water; and 3. Proper equipment operation, and maintenance. BACT: 1. Using non contact cooling water system; and 2. Monthly monitoring of vinyl chloride monomer (VCM) or VOC concentration in the cooling water
WESTLAKE VINYL, INC. - PVC PLANT	KY-0112	11/13/2020	TPM10	Cooling Tower [EU 31]	0.0790	LBS/HOUR, MONTHLY BASIS	1. State-of-the-art, high-efficiency drift eliminators with a drift rate specified at 0.0005% percent of the circulating water rate; 2. Monitoring and limiting total dissolved solids in the circulating water; and 3. Proper equipment operation, and maintenance. BACT: 1. Using non contact cooling water system; and 2. Monthly monitoring of vinyl chloride monomer (VCM) or VOC concentration in the cooling water
WESTLAKE VINYL, INC. - PVC PLANT	KY-0112	11/13/2020	TPM2.5	Cooling Tower [EU 31]	0.0003	LBS/HOUR, MONTHLY BASIS	1. State-of-the-art, high-efficiency drift eliminators with a drift rate specified at 0.0005% percent of the circulating water rate; 2. Monitoring and limiting total dissolved solids in the circulating water; and 3. Proper equipment operation, and maintenance. BACT: 1. Using non contact cooling water system; and 2. Monthly monitoring of vinyl chloride monomer (VCM) or VOC concentration in the cooling water
WESTLAKE VINYL, INC. - PVC PLANT	KY-0112	11/13/2020	VOC	Cooling Tower [EU 31]	3.9000	PPMV OF VOC, 12-MONTH ROLLING BASIS	1. State-of-the-art, high-efficiency drift eliminators with a drift rate specified at 0.0005% percent of the circulating water rate; 2. Monitoring and limiting total dissolved solids in the circulating water; and 3. Proper equipment operation, and maintenance
WESTLAKE VINYL, INC. - PVC PLANT	KY-0112	11/13/2020	VOC	Cooling Tower [EU 31]	50.0000	PPBW OF VCM, 12-MONTH ROLLING BASIS	1. State-of-the-art, high-efficiency drift eliminators with a drift rate specified at 0.0005% percent of the circulating water rate; 2. Monitoring and limiting total dissolved solids in the circulating water; and 3. Proper equipment operation, and maintenance
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Laminar Cooling Tower - Hot Mill Cells (EP 03-09)	0.2700	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Laminar Cooling Tower - Hot Mill Cells (EP 03-09)	1.1800	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Laminar Cooling Tower - Hot Mill Cells (EP 03-09)	0.1900	LB/HR	Mist Eliminator, 0.001% drift loss

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Cooling Tower" - All Results Included
Unit 40 - Cooling Tower

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Laminar Cooling Tower - Hot Mill Cells (EP 03-09)	0.8700	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Laminar Cooling Tower - Hot Mill Cells (EP 03-09)	0.0006	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Laminar Cooling Tower - Hot Mill Cells (EP 03-09)	0.0026	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Direct Cooling Tower-Caster & Roughing Mill Cells (EP 03-10)	0.1700	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Direct Cooling Tower-Caster & Roughing Mill Cells (EP 03-10)	0.7500	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Direct Cooling Tower-Caster & Roughing Mill Cells (EP 03-10)	0.1200	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Direct Cooling Tower-Caster & Roughing Mill Cells (EP 03-10)	0.5500	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Direct Cooling Tower-Caster & Roughing Mill Cells (EP 03-10)	0.0004	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Direct Cooling Tower-Caster & Roughing Mill Cells (EP 03-10)	0.0020	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Melt Shop #2 Cooling Tower (indirect) (EP 03-11)	0.3900	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Melt Shop #2 Cooling Tower (indirect) (EP 03-11)	1.7100	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Melt Shop #2 Cooling Tower (indirect) (EP 03-11)	0.2900	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Melt Shop #2 Cooling Tower (indirect) (EP 03-11)	1.2700	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Melt Shop #2 Cooling Tower (indirect) (EP 03-11)	0.0008	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Melt Shop #2 Cooling Tower (indirect) (EP 03-11)	0.0030	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Cold Mill Cooling Tower (EP 03-12)	0.1400	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Cold Mill Cooling Tower (EP 03-12)	0.6000	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Cold Mill Cooling Tower (EP 03-12)	0.0940	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Cold Mill Cooling Tower (EP 03-12)	0.4100	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Cold Mill Cooling Tower (EP 03-12)	0.0003	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Cold Mill Cooling Tower (EP 03-12)	0.0013	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Air Separation Plant Cooling Tower (EP 03-13)	0.0800	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	Air Separation Plant Cooling Tower (EP 03-13)	0.3700	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Air Separation Plant Cooling Tower (EP 03-13)	0.0700	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	Air Separation Plant Cooling Tower (EP 03-13)	0.3200	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Air Separation Plant Cooling Tower (EP 03-13)	0.0002	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	Air Separation Plant Cooling Tower (EP 03-13)	0.0008	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	DCW Auxiliary Cooling Tower (EP 03-14)	0.0600	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	FPM	DCW Auxiliary Cooling Tower (EP 03-14)	0.2700	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	DCW Auxiliary Cooling Tower (EP 03-14)	0.0500	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM10	DCW Auxiliary Cooling Tower (EP 03-14)	0.2100	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	DCW Auxiliary Cooling Tower (EP 03-14)	0.0001	LB/HR	Mist Eliminator, 0.001% drift loss
NUCOR STEEL GALLATIN, LLC	KY-0115	4/19/2021	TPM2.5	DCW Auxiliary Cooling Tower (EP 03-14)	0.0006	TON/YR, 12-MONTH ROLLING	Mist Eliminator, 0.001% drift loss
FG LA COMPLEX	LA-0364	1/6/2020	TPM10	Cooling Towers	0.0010	%	High efficiency drift eliminators and low TDS cooling water.
FG LA COMPLEX	LA-0364	1/6/2020	TPM2.5	Cooling Towers	0.0010	%	High efficiency drift eliminators and low TDS cooling water.
TITANIUM DIOXIDE PLANT	LA-0367	11/17/2020	TPM10	Cooling Tower	0.0005	%	High efficiency drift eliminators
TITANIUM DIOXIDE PLANT	LA-0367	11/17/2020	TPM2.5	Cooling Tower	0.0005	%	High efficiency drift eliminators
SHINTECH PLAQUEMINES PLANT 1	LA-0379	5/4/2021	TPM	C/A Cooling Tower	0.0800	LB/MM GAL	Good design, maintenance and mist eliminators.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Cooling Tower" - All Results Included
Unit 40 - Cooling Tower

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
SHINTECH PLAQUEMINES PLANT 1	LA-0379	5/4/2021	TPM10	C/A Cooling Tower	0.0800	LB/MM GAL	Good design, maintenance and mist eliminators.
GARYVILLE REFINERY	LA-0385	2/11/2021	TPM10	Cooling Towers	0.0000		High Efficiency Drift Eliminators
GARYVILLE REFINERY	LA-0385	2/11/2021	TPM2.5	Cooling Towers	0.0000		High Efficiency Drift Eliminators
GARYVILLE REFINERY	LA-0385	2/11/2021	VOC	Cooling Towers	0.0000		Periodic monitoring cooling water as specified by 40 CFR 63 Subpart CC (for EQT0213 and EQT0397)
GARYVILLE REFINERY	LA-0385	2/11/2021	Hydrogen Sulfide	Cooling Towers	0.0000		Periodic monitoring cooling water as specified by 40 CFR 63 Subpart CC (for EQT0213 and EQT0397)
PORT ARTHUR REFINERY	TX-0873	2/4/2020	VOC	COOLING TOWER	0.0000		NON CONTACT DESIGN
PORT ARTHUR REFINERY	TX-0873	2/4/2020	TPM	COOLING TOWER	0.0000		DRIFT ELIMINATORS
PORT ARTHUR REFINERY	TX-0873	2/4/2020	TPM10	COOLING TOWER	0.0000		DRIFT ELIMINATORS
PORT ARTHUR REFINERY	TX-0873	2/4/2020	TPM2.5	COOLING TOWER	0.0000		DRIFT ELIMINATORS
PORT ARTHUR ETHANE CRACKER UNIT	TX-0876	2/6/2020	VOC	COOLING TOWER	0.0800	PPMW	Non-contact design and sampling of strippable VOC
PORT ARTHUR ETHANE CRACKER UNIT	TX-0876	2/6/2020	FPM	COOLING TOWER	1200.0000	PPM, TDS	DRIFT ELIMINATORS
PORT ARTHUR ETHANE CRACKER UNIT	TX-0876	2/6/2020	TPM10	COOLING TOWER	1200.0000	PPM, TDS	DRIFT ELIMINATORS
PORT ARTHUR ETHANE CRACKER UNIT	TX-0876	2/6/2020	TPM2.5	COOLING TOWER	1200.0000	PPM, TDS	DRIFT ELIMINATORS
SWEENEY REFINERY	TX-0877	1/8/2020	VOC	COOLING TOWER	0.0800	PPMW	non-contact design; the VOC in water will be monitored monthly per Appendix P; and identified leaks will be repaired as soon as possible, but before next scheduled shutdown, or shutdown triggered by 0.08 ppmw cooling water VOC concentration. Circulation rate 32000 gal/min
EXXONMOBIL BEAUMONT REFINERY	TX-0881	1/10/2020	TPM10	COOLING TOWERS	0.0000		High efficiency drift eliminators to control drift to no more than 0.005%.
EXXONMOBIL BEAUMONT REFINERY	TX-0881	1/10/2020	TPM2.5	COOLING TOWERS	0.0000		High efficiency drift eliminators to control drift to no more than 0.005%.
MONT BELVIEU NGL FRACTIONATION UNIT	TX-0886	3/31/2020	VOC	COOLING TOWER	0.7000	LB/MMGAL, HOURLY	Monthly cooling water monitoring using air stripping
MONT BELVIEU NGL FRACTIONATION UNIT	TX-0886	3/31/2020	VOC	COOLING TOWER	0.3000	LB/MMGAL, ANNUAL	Monthly cooling water monitoring using air stripping
ORANGE POLYETHYLENE PLANT	TX-0888	4/23/2020	VOC	COOLING TOWERS	0.7000	LB/MMGAL	Use of a non-contact cooling tower design and monthly monitoring.
ORANGE POLYETHYLENE PLANT	TX-0888	4/23/2020	Carbon Dioxide Equivalent (CO2e)	COOLING TOWERS	0.0000		Use of a non-contact cooling tower design and monthly monitoring.
ORANGE POLYETHYLENE PLANT	TX-0888	4/23/2020	TPM	COOLING TOWERS	0.0000		DRIFT ELIMINATORS
ORANGE POLYETHYLENE PLANT	TX-0888	4/23/2020	TPM10	COOLING TOWERS	0.0000		DRIFT ELIMINATORS
ORANGE POLYETHYLENE PLANT	TX-0888	4/23/2020	TPM2.5	COOLING TOWERS	0.0000		DRIFT ELIMINATORS
SWEENEY OLD OCEAN FACILITIES	TX-0889	8/8/2020	Carbon Dioxide Equivalent (CO2e)	cooling tower	0.0000		Good operational practices, non-contact
CHEVRON PHILLIPS CHEMICAL SWEENEY COMPLEX	TX-0894	10/30/2020	VOC	Cooling Tower (EPN 81-05-9202)	0.0000		The cooling tower will have a non-contact design and will be monitored continuously for VOC equipment leaks in accordance with 30 TAC 115.764(a)(2) requirements. The leaks discovered from this monitoring shall be repaired as soon as possible, but no later than the next scheduled shutdown, or a shutdown triggered by a 0.08 ppmw cooling water VOC concentration.
MOTIVA POLYETHYLENE MANUFACTURING COMPLEX	TX-0904	9/9/2020	VOC	COOLING TOWER	0.0800	PPMW	Non-contact design and sampling of strippable VOC
MOTIVA POLYETHYLENE MANUFACTURING COMPLEX	TX-0904	9/9/2020	TPM	COOLING TOWER	1200.0000	PPMW	Non-contact design and DRIFT ELIMINATORS
MOTIVA POLYETHYLENE MANUFACTURING COMPLEX	TX-0904	9/9/2020	TPM10	COOLING TOWER	1200.0000	PPMW	Non-contact design and DRIFT ELIMINATORS
MOTIVA POLYETHYLENE MANUFACTURING COMPLEX	TX-0904	9/9/2020	TPM2.5	COOLING TOWER	0.0000		Non-contact design and DRIFT ELIMINATORS
DIAMOND GREEN DIESEL PORT ARTHUR FACILITY	TX-0905	9/16/2020	VOC	COOLING TOWER	0.0000		Non-contact design and sampling of strippable VOC
DIAMOND GREEN DIESEL PORT ARTHUR FACILITY	TX-0905	9/16/2020	TPM	COOLING TOWER	0.0000		DRIFT ELIMINATORS 0.001%
DIAMOND GREEN DIESEL PORT ARTHUR FACILITY	TX-0905	9/16/2020	TPM10	COOLING TOWER	0.0000		DRIFT ELIMINATORS 0.001%
DIAMOND GREEN DIESEL PORT ARTHUR FACILITY	TX-0905	9/16/2020	TPM2.5	COOLING TOWER	0.0000		DRIFT ELIMINATORS 0.001%
MONT BELVIEU FRACTIONATOR	TX-0912	2/5/2021	VOC	COOLING TOWER	0.0000		drift eliminators with 0.0005% maximum drift
UNIT 5	TX-0915	3/17/2021	TPM	COOLING TOWER	60000.0000	PPM, TDS	Drift eliminators - 0.0005%
UNIT 5	TX-0915	3/17/2021	TPM10	COOLING TOWER	60000.0000	PPM, TDS	Drift eliminators - 0.0005%
UNIT 5	TX-0915	3/17/2021	TPM2.5	COOLING TOWER	60000.0000	PPM, TDS	Drift eliminators - 0.0005%
FORMOSA POINT COMFORT PLANT	TX-0929	10/15/2021	VOC	COOLING TOWER	0.0000		This cooling tower is non-contact design. Monthly monitoring of VOC content of the cooling water in addition to a VOC leak detection system will be implemented.
CENTURION BROWNSVILLE	TX-0930	10/19/2021	VOC	Cooling Tower	3.1000	PPMVD	Monthly VOC monitoring required. Leak action level (for new sources) defined as a total strippable hydrocarbon concentration (as methane) in the stripping gas of 3.1 ppmv. Non-contact design.
CENTURION BROWNSVILLE	TX-0930	10/19/2021	TPM	Cooling Tower	0.0000		Drift eliminators required. Maximum drift 0.0005 percent. TDS limit of 3,500 ppmw in the cooling water. Daily sampling for TDS required, or weekly TDS sampling is allowed if conductivity is monitored daily and a TDS to conductivity ratio is established.
CENTURION BROWNSVILLE	TX-0930	10/19/2021	TPM10	Cooling Tower	0.0000		Drift eliminators required. Maximum drift 0.0005 percent. TDS limit of 3,500 ppmw in the cooling water. Daily sampling for TDS required, or weekly TDS sampling is allowed if conductivity is monitored daily and a TDS to conductivity ratio is established.
CENTURION BROWNSVILLE	TX-0930	10/19/2021	TPM2.5	Cooling Tower	0.0000		Drift eliminators required. Maximum drift 0.0005 percent. TDS limit of 3,500 ppmw in the cooling water. Daily sampling for TDS required, or weekly TDS sampling is allowed if conductivity is monitored daily and a TDS to conductivity ratio is established.
ROEHM AMERICA BAY CITY SITE	TX-0931	12/16/2021	VOC	Cooling Tower	0.0000		Non-contact design and sampling of strippable VOC
ROEHM AMERICA BAY CITY SITE	TX-0931	12/16/2021	TPM	Cooling Tower	0.0000		Drift eliminators with 0.001% drift
ROEHM AMERICA BAY CITY SITE	TX-0931	12/16/2021	TPM10	Cooling Tower	0.0000		Drift eliminators with 0.001% drift
ROEHM AMERICA BAY CITY SITE	TX-0931	12/16/2021	TPM2.5	Cooling Tower	0.0000		Drift eliminators with 0.001% drift
NACERO PENWELL FACILITY	TX-0933	11/17/2021	VOC	Cooling tower	0.0800	PPMW	Non-contact design and sampling of strippable VOC
NACERO PENWELL FACILITY	TX-0933	11/17/2021	TPM	Cooling tower	5000.0000	PPM	Drift eliminators with 0.001% drift
NACERO PENWELL FACILITY	TX-0933	11/17/2021	TPM10	Cooling tower	0.0000		Drift eliminators with 0.001% drift
NACERO PENWELL FACILITY	TX-0933	11/17/2021	TPM2.5	Cooling tower	0.0000		Drift eliminators with 0.001% drift

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Cooling Tower" - All Results Included
Unit 40 - Cooling Tower

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
MAIDSVILLE	*WV-0033	1/5/2022	TPM	Cooling Tower	2.1600	LB/HR	Drift Eliminator to 0.0005%
Nucor Steel Kankakee, Inc.	IL-0126	11/1/2018 updated 2/19/2019	TPM (PM, PM10 and PM2.5)	Cooling Tower	0.0010	Weight %	Drift Eliminator (BACT-PSD) 4500.00 gallons/minute throughput
Nucor Steel Kankakee, Inc.	IL-0126	11/1/2018 updated 2/19/2019	TPM (PM, PM10 and PM2.5)	Cooling Tower	4000	total dissolved solid	Drift Eliminator (BACT-PSD) 4500.00 gallons/minute throughput
Nucor Steel Kankakee, Inc.	IL-0126	11/1/2018 updated 2/19/2019	TPM (PM, PM10 and PM2.5)	Cooling Tower	0.79	tpy 12-month rolling basis	Permit Limit
Knauf Insulation, Inc. - Albion Facility	MI-0437	10/10/2018 updated 2/19/2019	FPM	EU-COOLTOWER (Cooling Tower)	0.39	tpy 12-month rolling basis	Drift Eliminator (99.0 % efficient) (BACT-PSD-SIP) 1500.00 gallons/minute throughput
Knauf Insulation, Inc. - Albion Facility	MI-0437	10/10/2018 updated 2/19/2019	TPM10	EU-COOLTOWER (Cooling Tower)	0.39	tpy 12-month rolling basis	Drift Eliminator (99.0 % efficient) (BACT-PSD-SIP)
Knauf Insulation, Inc. - Albion Facility	MI-0437	10/10/2018 updated 2/19/2019	TPM2.5	EU-COOLTOWER (Cooling Tower)	0.39	tpy 12-month rolling basis	Drift Eliminator (99.0 % efficient) (BACT-PSD-SIP)
Knauf Insulation, Inc. - Albion Facility	MI-0437	10/10/2018 updated 2/19/2019	FPM	EU-COOLTOWER (Cooling Tower)	2200	PPM by weight monthly	Drift Eliminator (99.0 % efficient) (BACT-PSD-SIP)
Knauf Insulation, Inc. - Albion Facility	MI-0437	10/10/2018 updated 2/19/2019	TPM10	EU-COOLTOWER (Cooling Tower)	2200	PPM by weight monthly	Drift Eliminator (99.0 % efficient) (BACT-PSD-SIP)
Knauf Insulation, Inc. - Albion Facility	MI-0437	10/10/2018 updated 2/19/2019	TPM2.5	EU-COOLTOWER (Cooling Tower)	2200	PPM by weight monthly	Drift Eliminator (99.0 % efficient) (BACT-PSD-SIP)
Knauf Insulation, Inc. - Albion Facility	MI-0437	10/10/2018 updated 2/19/2019	FPM	EU-COOLTOWER (Cooling Tower)	0.005	% drift rate or less	Drift Eliminator (99.0 % efficient) (BACT-PSD-SIP) Vendor certification of drift rate required
Knauf Insulation, Inc. - Albion Facility	MI-0437	10/10/2018 updated 2/19/2019	TPM10	EU-COOLTOWER (Cooling Tower)	0.005	% drift rate or less	Drift Eliminator (99.0 % efficient) (BACT-PSD-SIP) Vendor certification of drift rate required
Knauf Insulation, Inc. - Albion Facility	MI-0437	10/10/2018 updated 2/19/2019	TPM2.5	EU-COOLTOWER (Cooling Tower)	0.005	% drift rate or less	Drift Eliminator (99.0 % efficient) (BACT-PSD-SIP) Vendor certification of drift rate required
Premcor Refining Group - Valero Port Arthur Refinery	TX-0847 (draft)	9/16/2018 updated 2/14/2019	VOC	Cooling Tower/Heat Exchange System	0.08	PPMW	Noncontact (BACT-PSD)
Premcor Refining Group - Valero Port Arthur Refinery	TX-0847 (draft)	9/16/2018 updated 2/14/2019	TPM10	Cooling Tower/Heat Exchange System	0.001	% drift rate or less	Drift Eliminators (BACT-PSD)
Premcor Refining Group - Valero Port Arthur Refinery	TX-0847 (draft)	9/16/2018 updated 2/14/2019	TPM2.5	Cooling Tower/Heat Exchange System	0.001	% drift rate or less	Drift Eliminators (BACT-PSD)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018 updated 2/19/2019	FPM	EUCOOLINGTWR: Cooling Tower (14 cell wet mechanical draft cooling tower)	4.03	lb/hr hourly	High Efficiency Drift/Mist Eliminators (BACT-PSD)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018 updated 2/19/2019	FPM	EUCOOLINGTWR: Cooling Tower (14 cell wet mechanical draft cooling tower)	0.0005	% drift rate or less	High Efficiency Drift/Mist Eliminators (BACT-PSD) Vendor certification of drift rate required
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018 updated 2/19/2019	FPM	EUCOOLINGTWR: Cooling Tower (14 cell wet mechanical draft cooling tower)	3000	PPM TDS by weight monthly	Permit Limit
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018 updated 2/19/2019	TPM10	EUCOOLINGTWR: Cooling Tower (14 cell wet mechanical draft cooling tower)	0.48	lb/hr	High Efficiency Drift/Mist Eliminators (BACT-PSD)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018 updated 2/19/2019	TPM10	EUCOOLINGTWR: Cooling Tower (14 cell wet mechanical draft cooling tower)	0.0005	% drift rate or less	High Efficiency Drift/Mist Eliminators (BACT-PSD) Vendor certification of drift rate required
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018 updated 2/19/2019	TPM10	EUCOOLINGTWR: Cooling Tower (14 cell wet mechanical draft cooling tower)	3000	PPM TDS by weight monthly	Permit Limit
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018 updated 2/19/2019	TPM2.5	EUCOOLINGTWR: Cooling Tower (14 cell wet mechanical draft cooling tower)	0.48	lb/hr	High Efficiency Drift/Mist Eliminators (BACT-PSD)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018 updated 2/19/2019	TPM2.5	EUCOOLINGTWR: Cooling Tower (14 cell wet mechanical draft cooling tower)	0.0005	% drift rate or less	High Efficiency Drift/Mist Eliminators (BACT-PSD) Vendor certification of drift rate required
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018 updated 2/19/2019	TPM2.5	EUCOOLINGTWR: Cooling Tower (14 cell wet mechanical draft cooling tower)	3000	PPM TDS by weight monthly	Permit Limit
Dow Chemical - LHC-9	TX-0841	7/1/2018 updated 2/19/2019	FPM	Cooling Tower/Heat Exchange System	0.005	% efficiency	Drift Eliminators (BACT-PSD)
Dow Chemical - LHC-9	TX-0841	7/1/2018 updated 2/19/2019	TPM10	Cooling Tower/Heat Exchange System	0.005	% efficiency	Drift Eliminators (BACT-PSD)
Dow Chemical - LHC-9	TX-0841	7/1/2018 updated 2/19/2019	TPM2.5	Cooling Tower/Heat Exchange System	0.005	% efficiency	Drift Eliminators (BACT-PSD)
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	FPM	EUCOOLTOWER (North Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	5.59	tpy 12-month rolling basis	High Efficiency Drift/Mist Eliminators (BACT-PSD) (170,000 gal/min)
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	FPM	EUCOOLTOWER (North Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	0.0005	% drift rate or less	High Efficiency Drift/Mist Eliminators (BACT-PSD) Vendor certification of drift rate required

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Cooling Tower" - All Results Included
Unit 40 - Cooling Tower

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	FPM	EUCOOLTOWER (North Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	3000	PPM TDS by weight monthly	Permit Limit
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM10	EUCOOLTOWER (North Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	2.85	tpy 12-month rolling basis	High Efficiency Drift/Mist Eliminators (BACT-PSD) (170,000 gal/min)
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM10	EUCOOLTOWER (North Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	0.0005	% drift rate or less	High Efficiency Drift/Mist Eliminators (BACT-PSD) Vendor certification of drift rate required
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM10	EUCOOLTOWER (North Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	3000	PPM TDS by weight monthly	Permit Limit
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM2.5	EUCOOLTOWER (North Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	2.85	tpy 12-month rolling basis	High Efficiency Drift/Mist Eliminators (BACT-PSD) (170,000 gal/min)
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM2.5	EUCOOLTOWER (North Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	0.0005	% drift rate or less	High Efficiency Drift/Mist Eliminators (BACT-PSD) Vendor certification of drift rate required
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM2.5	EUCOOLTOWER (North Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	3000	PPM TDS by weight monthly	Permit Limit
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	FPM	EUCOOLTOWER (South Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	5.59	tpy 12-month rolling basis	High Efficiency Drift/Mist Eliminators (BACT-PSD) (170,000 gal/min)
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	FPM	EUCOOLTOWER (South Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	0.0005	% drift rate or less	High Efficiency Drift/Mist Eliminators (BACT-PSD) Vendor certification of drift rate required
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	FPM	EUCOOLTOWER (South Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	3000	PPM TDS by weight monthly	Permit Limit
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM10	EUCOOLTOWER (South Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	2.85	tpy 12-month rolling basis	High Efficiency Drift/Mist Eliminators (BACT-PSD) (170,000 gal/min)
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM10	EUCOOLTOWER (South Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	0.0005	% drift rate or less	High Efficiency Drift/Mist Eliminators (BACT-PSD) Vendor certification of drift rate required
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM10	EUCOOLTOWER (South Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	3000	PPM TDS by weight monthly	Permit Limit
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM2.5	EUCOOLTOWER (South Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	2.85	tpy 12-month rolling basis	High Efficiency Drift/Mist Eliminators (BACT-PSD) (170,000 gal/min)
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM2.5	EUCOOLTOWER (South Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	0.0005	% drift rate or less	High Efficiency Drift/Mist Eliminators (BACT-PSD) Vendor certification of drift rate required
Marshall Energy Center LLC MEC North, LLC and MEC South LLC	MI-0433	6/29/2018 updated 2/19/2019	TPM2.5	EUCOOLTOWER (South Plant): Cooling Tower (8 cell wet mechanical draft cooling tower)	3000	PPM TSD by weight monthly	High Efficiency Drift/Mist Eliminators (Permit) (170,000 gal/min)
Shintech Louisiana, LLC - Plaquemines Plant 1	LA-0328	5/2/2018 updated 2/19/2019	TPM10	Cooling Tower 2 (P-35)	0.0005	% drift rate or less	Drift Eliminator (BACT-PSD, OPERATING PERMIT) (26,000 gal/min)
Shintech Louisiana, LLC - Plaquemines Plant 1	LA-0328	5/2/2018 updated 2/19/2019	TPM2.5	Cooling Tower 2 (P-35)	0.0005	% drift rate or less	Drift Eliminator (BACT-PSD, OPERATING PERMIT) (26,000 gal/min)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018 updated 11/16/2018(draft)		Cooling Tower	6250	mg/l TSD - monthly water quality testing	This is pollution prevention measure. No Controls Feasible (SIP)
Entergy Texas Inc - Montgomery County Power Station	TX-0834	3/30/2018 updated 2/19/2019	TPM	Cooling Tower	0.005	% efficiency	Drift Eliminators (BACT-PSD)(9,864,000 gal/hr)
Entergy Texas Inc - Montgomery County Power Station	TX-0834	3/30/2018 updated 2/19/2019	TPM10	Cooling Tower	0.005	% efficiency	Drift Eliminators (BACT-PSD)(9,864,000 gal/hr)
Entergy Texas Inc - Montgomery County Power Station	TX-0834	3/30/2018 updated 2/19/2019	TPM2.5	Cooling Tower	0.005	% efficiency	Drift Eliminators (BACT-PSD)(9,864,000 gal/hr)
Exxonmobil Oil Corporation - Exxonmobile Beaumont Refinery	TX-0832	1/9/2018 updated 2/19/2019	TPM	Cooling Towers	0.005	% efficiency	Drift Eliminator (BACT-PSD, NSPS Ja, MACT CC)
Exxonmobil Oil Corporation - Exxonmobile Beaumont Refinery	TX-0832	1/9/2018 updated 2/19/2019	TPM10	Cooling Towers	0.005	% efficiency	Drift Eliminator (BACT-PSD, NSPS Ja, MACT CC)
Exxonmobil Oil Corporation - Exxonmobile Beaumont Refinery	TX-0832	1/9/2018 updated 2/19/2019	TPM2.5	Cooling Towers	0.005	% efficiency	Drift Eliminator (BACT-PSD, NSPS Ja, MACT CC)

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Cooling Tower" - All Results Included
Unit 40 - Cooling Tower

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017 updated 3/8/2018	FPM	EUCOOLTWR (Cooling Tower--Wet Mechanical Drift)	0.0006	% max drift rate (vendor certified)	BACT is to equip and maintain four-cell evaporative cooling tower in series with mechanical chilling to cool turbine inlet air with high efficiency drift eliminators.
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017 updated 3/8/2018	FPM	EUCOOLTWR (Cooling Tower--Wet Mechanical Drift)	7700	PPM TDS by weight	BACT is to equip and maintain four-cell evaporative cooling tower in series with mechanical chilling to cool turbine inlet air with high efficiency drift eliminators.
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017 updated 3/8/2018	TPM10	EUCOOLTWR (Cooling Tower--Wet Mechanical Drift)	0.0006	% max drift rate (vendor certified)	BACT is to equip and maintain four-cell evaporative cooling tower in series with mechanical chilling to cool turbine inlet air with high efficiency drift eliminators.
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017 updated 3/8/2018	TPM10	EUCOOLTWR (Cooling Tower--Wet Mechanical Drift)	7700	PPM TDS by weight	BACT is to equip and maintain four-cell evaporative cooling tower in series with mechanical chilling to cool turbine inlet air with high efficiency drift eliminators.
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017 updated 3/8/2018	TPM2.5	EUCOOLTWR (Cooling Tower--Wet Mechanical Drift)	0.0006	% max drift rate (vendor certified)	BACT is to equip and maintain four-cell evaporative cooling tower in series with mechanical chilling to cool turbine inlet air with high efficiency drift eliminators.
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017 updated 3/8/2018	TPM2.5	EUCOOLTWR (Cooling Tower--Wet Mechanical Drift)	7700	PPM TDS by weight	BACT is to equip and maintain four-cell evaporative cooling tower in series with mechanical chilling to cool turbine inlet air with high efficiency drift eliminators.
Kimberly-Clark Corporation - Mobile Operations - Kimberly-Clark Mobile	AL-0321	10/11/2017 updated 5/11/2018	FPM10	803 Cooling Tower	0.005	% drift elimination	No Controls Feasible
Kimberly-Clark Corporation - Mobile Operations - Kimberly-Clark Mobile	AL-0321	10/11/2017 updated 5/11/2018	FPM10	803 Cooling Tower	1000	mg/L TDS 12 month avg	No Controls Feasible
Kimberly-Clark Corporation - Mobile Operations - Kimberly-Clark Mobile	AL-0321	10/11/2017 updated 5/11/2018	FPM2.5	803 Cooling Tower	0.005	% drift elimination	No Controls Feasible
Kimberly-Clark Corporation - Mobile Operations - Kimberly-Clark Mobile	AL-0321	10/11/2017 updated 5/11/2018	FPM2.5	803 Cooling Tower	1000	mg/L TDS 12 month avg	No Controls Feasible
Knauf Insulation, Inc. - Inwood	WV-0027	9/15/2017 updated 5/1/2018	TPM	Cooling Tower 3 Cells	0.04	lb/hr 3-hour avg	0.005% drift eliminator - Restrict the make-up water to be provided from the local water company or have a TDS of less than 750 ppm by weight. 3 mechanical draft cooling towers.
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft)	PM	Eighteen Cell Cooling Tower (EU-010)	2000	mg/l avg on a monthly basis	High Efficiency Drift Eliminator
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft)	PM	Eighteen Cell Cooling Tower (EU-010)	0.0005	% Drift	High Efficiency Drift Eliminator
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft)	PM10	Eighteen Cell Cooling Tower (EU-010)	2000	mg/l avg on a monthly basis	High Efficiency Drift Eliminator
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft)	PM10	Eighteen Cell Cooling Tower (EU-010)	0.0005	% Drift	High Efficiency Drift Eliminator
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft)	PM2.5	Eighteen Cell Cooling Tower (EU-010)	2000	mg/l avg on a monthly basis	High Efficiency Drift Eliminator
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft)	PM2.5	Eighteen Cell Cooling Tower (EU-010)	0.0005	% Drift	High Efficiency Drift Eliminator
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	PM2.5	Cooling Tower CT-16-1 (EQI032)	0.001	lbs/hr	High Efficiency Drift Eliminator
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	PM2.5	Cooling Tower CT-16-1 (EQI032)	0.01	tons/year	High Efficiency Drift Eliminator
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	PM10	Cooling Towers	0.0005	% three one-hour test average	Drift Eliminators (Unit A = 241,843 gpm Unit B = 201,196 gpm Unit C = 72,531 gpm)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	PM2.5	Cooling Towers		% three one-hour test average	Drift Eliminators (Unit A = 241,843 gpm Unit B = 201,196 gpm Unit C = 72,531 gpm)
Lyondell Chemical Bayport Choate Plant	TX-0823 (draft)	6/7/17 draft, 8/7/17 update	VOC	Cooling Towers	4.05	tpy	VOC leak detection system to identify leaks into the cooling water (LAER) (products and byproducts throughput)
Total Petrochemicals & Refining USA, Inc.	TX-0815 (draft)	1/17/17 draft, 1/26/17 update	VOC	Cooling Towers	27.95	tpy	coolint water VOC concentration (non-contact) (MACT XX) (no additional notes)
Total Petrochemicals & Refining USA, Inc.	TX-0815 (draft)	1/17/17 draft, 1/26/17 update	PM10	Cooling Towers	No numerical limit	No numerical limit	Drift Eliminators (99.999% efficiency)
Methanex - Geismar Methanol Plant	LA-0317	12/22/16, 4/28/17 update	PM10	Cooling Towers (I-CT-621, II-CT-621)	0.001	% Drift Rate	Drift Eliminators (66000 gpm throughput)
Methanex - Geismar Methanol Plant	LA-0317	12/22/16, 4/28/17 update	PM2.5	Cooling Towers (I-CT-621, II-CT-621)	0.001	% Drift Rate	Drift Eliminators (66000 gpm throughput)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/16 draft, 7/31/17 update	TPM10	EUCOOLTWR (Cooling Tower--Wet Mechanical Draft)	2.37	tpy 12-month rolling time period	Mist/Drift Eliminators (SIP) (A three-cell wet mechanical draft cooling tower with plume abatement by a dry heat exchanger.)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/16 draft, 7/31/17 update	TPM10	EUCOOLTWR (Cooling Tower--Wet Mechanical Draft)	0.005	% Drift Rate	Mist/Drift Eliminators (SIP) (A three-cell wet mechanical draft cooling tower with plume abatement by a dry heat exchanger.)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/16 draft, 7/31/17 update	TPM2.5	EUCOOLTWR (Cooling Tower--Wet Mechanical Draft)	2.37	tpy 12-month rolling time period	Mist/Drift Eliminators (SIP) (A three-cell wet mechanical draft cooling tower with plume abatement by a dry heat exchanger.)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/16 draft, 7/31/17 update	TPM2.5	EUCOOLTWR (Cooling Tower--Wet Mechanical Draft)	0.005	% Drift Rate	Mist/Drift Eliminators (SIP) (A three-cell wet mechanical draft cooling tower with plume abatement by a dry heat exchanger.)
Nucor Steel	IN-0255	9/21/16, 10/11/16 update	FPM	Hot Mill Contact Cooling Tower	0.001	% Drift Rate	Drift Eliminators (25000 gpm throughput)
Nucor Steel	IN-0255	9/21/16, 10/11/16 update	FPM	Hot Mill Contact Cooling Tower	0.38	lb/hr	Drift Eliminators (25000 gpm throughput)
Nucor Steel	IN-0255	9/21/16, 10/11/16 update	TPM10	Hot Mill Contact Cooling Tower	0.001	% Drift Rate	Drift Eliminators (25000 gpm throughput)
Nucor Steel	IN-0255	9/21/16, 10/11/16 update	TPM10	Hot Mill Contact Cooling Tower	0.19	lb/hr	Drift Eliminators (25000 gpm throughput)
Nucor Steel	IN-0255	9/21/16, 10/11/16 update	TPM2.5	Hot Mill Contact Cooling Tower	0.001	% Drift Rate	Drift Eliminators (25000 gpm throughput)

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Cooling Tower" - All Results Included
Unit 40 - Cooling Tower

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Nucor Steel	IN-0255	9/21/16, 10/11/16 update	TPM2.5	Hot Mill Contact Cooling Tower	0.001	lb/hr	Drift Eliminators (25000 gpm throughput)
CPV Fairview Energy Center	PA-0310 (draft)	9/2/16 draft, 7/31/17 update	TPM	Cooling Tower	0.8	lb/hr	NSPS (12-cell mechanical draft wet cooling tower with high-efficiency drift eliminator. Permittee shall sample, analyze, and record the circulating water TDS on a monthly basis. TDS solids shall not exceed 1500 ppm.)
CPV Fairview Energy Center	PA-0310 (draft)	9/2/16 draft, 7/31/17 update	TPM	Cooling Tower	3.4	tpy 12-month rolling basis	NSPS (12-cell mechanical draft wet cooling tower with high-efficiency drift eliminator. Permittee shall sample, analyze, and record the circulating water TDS on a monthly basis. TDS solids shall not exceed 1500 ppm.)
CPV Fairview Energy Center	PA-0310 (draft)	9/2/16 draft, 7/31/17 update	TPM10	Cooling Tower	0.8	lb/hr	NSPS (12-cell mechanical draft wet cooling tower with high-efficiency drift eliminator. Permittee shall sample, analyze, and record the circulating water TDS on a monthly basis. TDS solids shall not exceed 1500 ppm.)
CPV Fairview Energy Center	PA-0310 (draft)	9/2/16 draft, 7/31/17 update	TPM10	Cooling Tower	3.4	tpy	NSPS (12-cell mechanical draft wet cooling tower with high-efficiency drift eliminator. Permittee shall sample, analyze, and record the circulating water TDS on a monthly basis. TDS solids shall not exceed 1500 ppm.)
CPV Fairview Energy Center	PA-0310 (draft)	9/2/16 draft, 7/31/17 update	TPM2.5	Cooling Tower	0.4	lb/hr	NSPS (12-cell mechanical draft wet cooling tower with high-efficiency drift eliminator. Permittee shall sample, analyze, and record the circulating water TDS on a monthly basis. TDS solids shall not exceed 1500 ppm.)
CPV Fairview Energy Center	PA-0310 (draft)	9/2/16 draft, 7/31/17 update	TPM2.5	Cooling Tower	1.8	tpy	NSPS (12-cell mechanical draft wet cooling tower with high-efficiency drift eliminator. Permittee shall sample, analyze, and record the circulating water TDS on a monthly basis. TDS solids shall not exceed 1500 ppm.)
Sasol Chemicals - Comonomer-1 Unit	LA-0277	9/1/16, 4/28/17 update	VOC	Cooling Tower Y12-800			NESHAP - Comply with requirements of 40 CFR 63.104 (15200 gpm)
Sasol Chemicals - Lake Charles Chemical Complex - Comonomer-1 Unit	LA-0319	9/1/16, 4/28/17 update	VOC	cooling tower y12-800			NESHAP - Comply with requirements of 40 CFR 63.104
Entergy Louisiana, LLC - St. Charles Power Station	LA-0313	8/31/16, 4/28/17 update	FPM10	SCPS Cooling Tower 1	1.24	lb/hr hourly maximum	High Efficiency Drift Eliminators (164400 gpm)
Entergy Louisiana, LLC - St. Charles Power Station	LA-0313	8/31/16, 4/28/17 update	FPM10	SCPS Cooling Tower 1	3.61	tpy annual maximum	High Efficiency Drift Eliminators (164400 gpm)
Entergy Louisiana, LLC - St. Charles Power Station	LA-0313	8/31/16, 4/28/17 update	FPM10	SCPS Cooling Tower 1	0.005	% Drift Rate	BACT - High Efficiency Drift Eliminators (164400 gpm)
Entergy Louisiana, LLC - St. Charles Power Station	LA-0313	8/31/16, 4/28/17 update	FPM2.5	SCPS Cooling Tower 1	1.24	lb/hr hourly maximum	High Efficiency Drift Eliminators (164400 gpm)
Entergy Louisiana, LLC - St. Charles Power Station	LA-0313	8/31/16, 4/28/17 update	FPM2.5	SCPS Cooling Tower 1	3.61	tpy annual maximum	High Efficiency Drift Eliminators (164400 gpm)
Entergy Louisiana, LLC - St. Charles Power Station	LA-0313	8/31/16, 4/28/17 update	FPM2.5	SCPS Cooling Tower 1	0.005	% Drift Rate	BACT - High Efficiency Drift Eliminators (164400 gpm)
Indorama Ventures Olefins, LLC - Indorama Lake Charles Facility	LA-0314	8/3/16, 4/28/17 update	TPM10	cooling towers - 007	0.005	% Drift Rate	Drift Eliminators (86500 gpm)
Indorama Ventures Olefins, LLC - Indorama Lake Charles Facility	LA-0314	8/3/16, 4/28/17 update	TPM10	cooling towers - 007	1400	PPM TDS	Drift Eliminators (86500 gpm)
Indorama Ventures Olefins, LLC - Indorama Lake Charles Facility	LA-0314	8/3/16, 4/28/17 update	TPM2.5	cooling towers - 007	0.005	% Drift Rate	Drift Eliminators (86500 gpm)
Indorama Ventures Olefins, LLC - Indorama Lake Charles Facility	LA-0314	8/3/16, 4/28/17 update	TPM2.5	cooling towers - 007	1400	PPM TDS	Drift Eliminators (86500 gpm)
Indorama Ventures Olefins, LLC - Indorama Lake Charles Facility	LA-0314	8/3/16, 4/28/17 update	VOC	cooling towers - 007	No numeric limit		NESHAP - monitored as required by 40 CFR 63 subpart XX (86500 gpm)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	FPM	Cooling Tower	0.685	lb/hr	BACT, NSPS - High Efficiency Drift Eliminators (One 8-cell, 124,800 gallon per minute (GPM) Mechanical Induced Draft Cooling Tower)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	FPM10	Cooling Tower	0.535	lb/hr	BACT - High Efficiency Drift Eliminators (One 8-cell, 124,800 gallon per minute (GPM) Mechanical Induced Draft Cooling Tower)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	FPM2.5	Cooling Tower	0.223	lb/hr	BACT - High Efficiency Drift Eliminators (One 8-cell, 124,800 gallon per minute (GPM) Mechanical Induced Draft Cooling Tower)
Equistar Chemicals, LP - Westlake Facility	LA-0295	7/12/16, 9/19/16 update	VOC	CGP Unit Cooling Tower (3-03, EQT 15)	0.13	lb/hr hourly maximum	BACT - Monthly hydrocarbon monitoring; maintain equipment to minimize fugitive emissions; repair faulty equipment at the earliest opportunity, but no later than the next scheduled unit shutdown (Annual VOC emissions from the CGP Unit Cooling Tower, along with VOC emissions from a number of other cooling towers not addressed in the PSD permit, are capped at 12.29 TPY (GRP 13). (3000 GPM)
Flint Hills Resources Houston Chemical LLC - PL Propylene Houston Olefins Plant	TX-0803 (draft)	7/12/16 draft, 8/31/16 update	TPM10	Cooling Tower	0.001	% Drift Rate	BACT - Drift Eliminators
Flint Hills Resources Houston Chemical LLC - PL Propylene Houston Olefins Plant	TX-0803 (draft)	7/12/16 draft, 8/31/16 update	TPM2.5	Cooling Tower	0.001	% Drift Rate	BACT - Drift Eliminators
Flint Hills Resources Houston Chemical LLC - PL Propylene Houston Olefins Plant	TX-0801 (draft)	6/24/16 draft, 7/20/16 update	CO2e	Cooling Tower	0.005	Drift	BACT - % drift design
Florida Power & Light - Okeechobee Clean Energy Center	FL-0356	03/09/2016	TPM	Mechanical draft cooling tower	0.0005	% Drift Rate	BACT (Must have certified drift rate no more than 0.0005%)
Commercial Metals Company - CMC Steel Oklahoma	OK-0173	1/19/16, 7/7/16 update	TPM10	Cooling Towers	0.001	% Drift Rate	BACT - Drift Eliminators (For this analysis, as a simplifying conservative assumption, all of the particulate resulting from the drift is considered to be PM10. Throughput Capacity/Size deemed "Confidential" by applicant.) (The only feasible option at this location is a wet cooling tower with high efficiency drift eliminators (0.001%). The emission rate is somewhat higher than many cooling towers, but the sizes proposed are very much smaller than the cooling towers that are installed at power plants, refineries, etc.)
Flopam, Inc. - Flopam Facility	LA-0318	1/7/16, 4/28/17 update	TPM10	Cooling Towers	No numeric limit		Integrated Drift Eliminators (PSD-LA-747 entered as LA-0240 and PSD-LA-747(M1) entered as LA-0251. LA-0318 is for PSD-747(M2), dated 7/5/12 (add dust collectors, cooling tower, and diesel engines), PSD-747(M3), dated 5/13/13 (no BACT changes), PSD-747(M4), dated 2/10/15 (add a cooling tower and diesel engines), and PSD-747(M5), dated 1/7/16 (add dust collectors))
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Cooling Towers	0.0005	% Drift	Drift Eliminator
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Cooling Tower	0.0005	% Drift	Drift Eliminator

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Cooling Tower" - All Results Included
Unit 40 - Cooling Tower

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Ohio Valley Resources, LLC	TBD	9/26/2013	PM	Cooling Towers	0.0005	% Drift	High Efficiency Drift Eliminator
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM	Cooling Tower	0.0005	% of total circ flow	Drift/Mist Eliminators
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM	Cooling Tower	1.5	lbs/hr	Drift/Mist Eliminators
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM	Cooling Tower	20%	Reduction	Drift/Mist Eliminators
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Cooling Towers	0.0005	% Drift	Drift Eliminator
Consolidated Environmental Management Inc. - Nucor Direct Reduction Iron Pl	LA-0248	1/27/2011	PM10	Process Water Cooling Tower	0.11	lbs/hr	BACT is a combination of less than or equal to 1000 milligrams per liter TDS concentration in the culling water and drift eliminators employing a drift maximum of 0.0005%
Consolidated Environmental Management Inc. - Nucor Direct Reduction Iron Pl	LA-0248	1/27/2011	PM10	Process Water Cooling Tower	0.4	tons/year	BACT is a combination of less than or equal to 1000 milligrams per liter TDS concentration in the culling water and drift eliminators employing a drift maximum of 0.0005%
Consolidated Environmental Management Inc. - Nucor Direct Reduction Iron Pl	LA-0248	1/27/2011	PM10	Clean Water Cooling Tower	0.07	lbs/hr	BACT is a combination of less than or equal to 1000 milligrams per liter TDS concentration in the culling water and drift eliminators employing a drift maximum of 0.0005%
Consolidated Environmental Management Inc. - Nucor Direct Reduction Iron Pl	LA-0248	1/27/2011	PM10	Clean Water Cooling Tower	0.29	tons/year	BACT is a combination of less than or equal to 1000 milligrams per liter TDS concentration in the culling water and drift eliminators employing a drift maximum of 0.0005%
Entergy Louisiana LLC Ninemile Point Electric Generating Plant	LA-0254	8/16/2011	PM10	Cooling Tower	0.0005	% Drift annual average	High Efficiency Mist Eliminator
Entergy Louisiana LLC Ninemile Point Electric Generating Plant	LA-0254	8/16/2011	PM10	Chiller Cooling Tower	0.001	% Drift annual average	High Efficiency Mist Eliminator
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Cooling Tower	0.0005	% Drift	Drift Eliminator
Koch Nitrogen Company Enid Nitrogen Plant	OK-0124	5/1/2008	PM10	Cooling Tower	No numeric limit		High Efficiency Drift Eliminator
Ohio Valley Resources, LLC	TBD	9/26/2013	PM10	Cooling Towers	0.0005	% Drift	High Efficiency Drift Eliminator
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM10	Cooling Tower	0.0005	% of total circ flow	Drift/Mist Eliminators
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM10	Cooling Tower	1.5	lbs/hr	Drift/Mist Eliminators
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Cooling Towers	0.0005	% Drift	Drift Eliminator
Entergy Louisiana LLC Ninemile Point Electric Generating Plant	LA-0254	8/16/2011	PM2.5	Cooling Tower	0.0005	% Drift annual average	High Efficiency Mist Eliminator
Entergy Louisiana LLC Ninemile Point Electric Generating Plant	LA-0254	8/16/2011	PM2.5	Chiller Cooling Tower	0.001	% Drift annual average	High Efficiency Mist Eliminator
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Cooling Tower	0.0005	% Drift	Drift Eliminator
Ohio Valley Resources, LLC	TBD	9/26/2013	PM2.5	Cooling Towers	0.0005	% Drift	High Efficiency Drift Eliminator
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	Visible Emission	Cooling Towers	0	%	Drift Eliminator
Iowa Fertilizer Company	IA-0105	10/26/2012	Visible Emission	Cooling Tower	0	% Opacity	Drift Eliminator
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Cooling Towers	No numeric limit		limit the amount of VOC in treatment chemicals and a drift eliminator

Notes:

Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times. Some facilities are not shown because they are not fertilizer production facilities. These units are not directly comparable because they do not flare common process gas.

Appendix B KNO Restart - RBLC Summary

KNO Restart

RBLC Search Summary

Search: "MDEA", "methyl", "urea", "42.009", "61.999" - All Results

UF-85 Tanks

No new entries

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Toyota Motors - Motor Vehicle Assembly Plant	TX-0846	9/23/2018(draft)	VOC	Storage Tanks - Very Low Vapor Pressure Non Gasoline Automotive Fluids - Gear Lube, Engine Oil, Diesel fuel, Urea, ATF Etc. <20,000 gal each	0		P2: White fixed roof storage tanks equipped with a submerged fill pipe. use of drain dry construction is required to minimize the emissions from tank entry and inspection.
Iowa Fertilizer Company	IA-0105	10/26/2012	VOC	MDEA Storage Tank	0.1	tons/year rolling 12 month total	Nitrogen Gas Blanket
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Urea uf-85 Storage Tank	0.046	lb/hr average of 3 stack tests	packed bed scrubber

Notes:

Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Reformer" - Fertilizer Plants only
Unit 12 - Primary Reformer

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
EL DORADO CHEMICAL COMPANY	AR-0170	12/2/2020	Methane	SN-49 Ammonia Plant Primary Reformer	0.0099	LB/MMBTU, 3 HR	Proper Catalyst Selection, Good Operating Practices
EL DORADO CHEMICAL COMPANY	AR-0170	12/2/2020	CO2e	SN-49 Ammonia Plant Primary Reformer	423800	TONS PER 12 ROLLING MONTHS	good combustion practices and proper design, shall combust natural gas and/or process off gas streams, shall be equipped with the following energy efficiency features: air inlet controls and flue gas heat recovery to pre-heat inlet fuel, inlet air and inlet steam flows, shall be designed to achieve a thermal efficiency of 80% (HHV).
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	Reformer Furnace EU-001	0.0024	LB/MMBTU	good combustion practices and proper design
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	Reformer Furnace EU-001	1.87	LB/HR	good combustion practices and proper design
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	Reformer Furnace EU-001	0.0024	LB/MMBTU	good combustion practices and proper design
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	Reformer Furnace EU-001	1.87	LB/HR	good combustion practices and proper design
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	Reformer Furnace EU-001	59.61	LB/MMCF	good combustion practices and proper design, shall combust natural gas and/or process off gas streams, shall be equipped with the following energy efficiency features: air inlet controls and flue gas heat recovery to pre-heat inlet fuel, inlet air and inlet steam flows, shall be designed to achieve a thermal efficiency of 80% (HHV).
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	Reformer Furnace EU-001	399317	TON/YR, TWELVE CONSECUTIVE MONTH PERIOD	good combustion practices and proper design, shall combust natural gas and/or process off gas streams, shall be equipped with the following energy efficiency features: air inlet controls and flue gas heat recovery to pre-heat inlet fuel, inlet air and inlet steam flows, shall be designed to achieve a thermal efficiency of 80% (HHV).
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	Reformer Furnace EU-001	0.0014	POUND PER MMBTU	good combustion practices and proper design, shall combust natural gas and/or process off gas streams.
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	Reformer Furnace EU-001	1.09	LB/HR	good combustion practices and proper design, shall combust natural gas and/or process off gas streams.
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	Reformer Furnace EU-001	0.0194	LB/MMBTU	good combustion practices and proper design, shall combust natural gas and/or off gas streams
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	Reformer Furnace EU-001	15.13	LB/HR	good combustion practices and proper design, shall combust natural gas and/or off gas streams
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	Reformer Furnace EU-001	9	PPMVD THIRTY-DAY ROLLING AVERAGE	selective catalytic reduction at all times the reformer is in operation, except during startup and shutdown when the catalyst is below its normal operating temperature.
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	CO2e	Primary Reformer Stack RS-16-1 (EQT029)	363287	tpy	Energy Efficiency Measure (note: 111.72 kg/MM BTU of CO2, 0.001 kg/MM BTU of CH4, and 0.0001 kg/MM BTU of N2O)
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	CO	Primary Reformer Stack RS-16-1 (EQT029)	33.26	lb/hr	Good Combustion Practices (Note: 0.0824 lb/MMBtu of natural gas)
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	CO	Primary Reformer Stack RS-16-1 (EQT029)	121.41	tpy	Good Combustion Practices (Note: 0.0824 lb/MMBtu of natural gas)
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	PM2.5	Primary Reformer Stack RS-16-1 (EQT029)	3.01	lb/hr	Good Combustion Practices (Note: 0.00745 lb/MMBtu of natural gas)
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	PM2.5	Primary Reformer Stack RS-16-1 (EQT029)	10.99	tpy	Good Combustion Practices (Note: 0.00745 lb/MMBtu of natural gas)
Agrium US, Inc	TX-0814	1/5/2017(draft)	CO2e	Reformer Furnace 101-B	564019	tpy	Good engineering practices (1100 MMBtu/hr)
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CH4	Primary Reformer	0.0023	lb/MMBtu average of 3 stack tests	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CH4	Primary Reformer	0.0023	lb/MMBtu average of 3 stack tests	Good Combustion Practices
CF Industries Inc. Donaldsonville Nitrogen Co	LA-0236	3/3/2009	CO	NO. 1,2,3,&4 Ammonia Plant Reformers	301.29	tons/year	Optimum combustion control and the use of natural gas as fuel
CF Industries Inc. Donaldsonville Nitrogen Co	LA-0236	3/3/2009	CO	NO. 1,2,3,&4 Ammonia Plant Reformers	303.47	lb/hr	Optimum combustion control and the use of natural gas as fuel
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Primary Reformer	0.0194	lb/MMBtu average of 3 stack tests	Good operating practices & use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Primary Reformer	90.3	tpy Rolling 12 month total	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CO	Primary Reformer	0.0194	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	CO	Primary Reformer	96.3	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Primary Reformer	43.45	lb/MMcf 3 hour average	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2	Primary Reformer	117	lb/MMBtu 30 day rolling average	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CO2	Primary Reformer	117	lb/MMBtu 30 day rolling average	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO2	Primary Reformer	59.61	tons/MMcf 3 hour average	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO2	Primary Reformer	515246	tons per 12 consecutive month period	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2e	Primary Reformer	545674	tpy Rolling 12 month total	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CO2e	Primary Reformer	596905	tpy Rolling 12 month total	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	N2O	Primary Reformer	0.0006	lb/MMBtu average of 3 stack tests	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	N2O	Primary Reformer	0.0006	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Altoona GTL LLC/Gilberton	PA-0285	1/16/2013	NH3	Convection Reformers	5	PPMVD @ 15%O2, 3 hr average, rolling by 1 hr	SCR
Air Products and Chemicals, Inc.	LA-0264	9/4/2012	NOx	Reformers	48.74	lb/hr hourly maximum	ULNB and SCR
Air Products and Chemicals, Inc.	LA-0264	9/4/2012	NOx	Reformers	0.015	lb/MMBtu annual average	ULNB and SCR
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Primary Reformer	9	ppmv 30 day rolling average	SCR
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Primary Reformer	56	tons/year rolling 12 month total	SCR
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Primary Reformer	9	ppmvd 30 day rolling average	SCR
Air Products and Chemicals, Inc.	LA-0264	9/4/2012	PM	Reformers	11.24	lb/hr hourly average	Proper equipment designs, good combustion practices, and gaseous fuel
Air Products and Chemicals, Inc.	LA-0264	9/4/2012	PM	Reformers	0.0075	lb/MMBtu	Proper equipment designs, good combustion practices, and gaseous fuel

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Reformer" - Fertilizer Plants only
Unit 12 - Primary Reformer

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Altoona GTL LLC/Gilberton	PA-0285	1/16/2013	PM	Convection Reformers	0.2	Grains/DSCF	Unknown
Altoona GTL LLC/Gilberton	PA-0285	1/16/2013	PM	Reformers	0.2	Grains/DSCF	Unknown
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Primary Reformer	0.0024	lb/MMBtu average of 3 stack tests	Good operating practices & use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Primary Reformer	11.2	tpy Rolling 12 month total	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Primary Reformer	0.0024	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Primary Reformer	11.9	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	PM	Primary Reformer	1.9	lb/MMcf 3 hour average	Good Combustion Practices
Air Products and Chemicals, Inc.	LA-0264	9/4/2012	PM10	Reformers	11.24	lb/hr hourly average	Proper equipment designs, good combustion practices, and gaseous fuel
Air Products and Chemicals, Inc.	LA-0264	9/4/2012	PM10	Reformers	0.0075	lb/MMBtu	Proper equipment designs, good combustion practices, and gaseous fuel
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Primary Reformer	0.0024	lb/MMBtu average of 3 stack tests	Good operating practices & use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Primary Reformer	11.2	tpy Rolling 12 month total	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Primary Reformer	0.0024	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Primary Reformer	11.9	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	PM10	Primary Reformer	7.6	lb/MMcf 3 hour average	Good Combustion Practices
Air Products and Chemicals, Inc.	LA-0264	9/4/2012	PM2.5	Reformers	11.24	lb/hr hourly average	Proper equipment designs, good combustion practices, and gaseous fuel
Air Products and Chemicals, Inc.	LA-0264	9/4/2012	PM2.5	Reformers	0.0075	lb/MMBtu	Proper equipment designs, good combustion practices, and gaseous fuel
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Primary Reformer	0.0024	lb/MMBtu average of 3 stack tests	Good operating practices & use of natural gas
Navajo Refining Company LLC Navajo Refini	NM-0050	12/14/2007	PM10	Steam Methane Reformer Heater	2.52	lbs/hr hourly	Gaseous Fuel Combustion Only
Navajo Refining Company LLC Navajo Refini	NM-0050	12/14/2007	SO2	Steam Methane Reformer Heater	2.16	tpy	Selective Catalytic Reduction
Navajo Refining Company LLC Navajo Refini	NM-0050	12/14/2007	SO2	Steam Methane Reformer Heater	0.494	lbs/hr	Selective Catalytic Reduction
Navajo Refining Company LLC Navajo Refini	NM-0050	12/14/2007	VOC	Steam Methane Reformer Heater	0.005	lb/MMBtu hourly	Gaseous Fuel Combustion Only
Navajo Refining Company LLC Navajo Refini	NM-0050	12/14/2007	VOC	Steam Methane Reformer Heater	1.69	lbs/hr hourly	Gaseous Fuel Combustion Only
Altoona GTL LLC/Gilberton	PA-0285	1/16/2013	SOx	Reformers	500	PPMVD expressed as SO2	Unknown
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	Visible Emissions	Primary Reformer	0	%	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	Visible Emissions	Primary Reformer	0	%	Good Operation Practices
Pryor Plant Chemical Company	OK-0134 OK-0135	2/23/2009	PM	Primary Reformer	1.68	lbs/hr	Unknown
Pryor Plant Chemical Company	OK-0134 OK-0135	2/23/2009	PM10	Primary Reformer	1.26	lbs/hr 24-hr	Unknown
Pryor Plant Chemical Company	OK-0134 OK-0135	2/23/2009	SO2	Primary Reformer	1.35	lb/hr	Natural Gas
Pryor Plant Chemical Company	OK-0134 OK-0135	2/23/2009	SO2	Primary Reformer	0.2	lb/MMBtu	Natural Gas
Pryor Plant Chemical Company	OK-0134 OK-0135	2/23/2009	VOC	Primary Reformer	1.21	lbs/hr	Unknown

Notes:

Some facilities are not shown because they are not fertilizer production facilities. These units are not directly comparable because they do not flare common process gas.
Some facilities are not shown because they are not fertilizer production facilities. These units are not directly comparable because they are not natural gas fired.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "CO2 Vent", "CO2 Stripper" - All Results Included
Unit 14 - CO₂ Vent

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
EL DORADO CHEMICAL COMPANY	AR-0170	12/2/2020	Methane	SN-51 Ammonia Plant CO2 Regenerator	0.106	LB/TON NH3, 3-HR	Proper Catalyst Selection, Good Operating Practices
EL DORADO CHEMICAL COMPANY	AR-0170	12/2/2020	Methane	SN-51 Ammonia Plant CO2 Regenerator	6.9	LB/HR, 3-HR	Proper Catalyst Selection, Good Operating Practices
EL DORADO CHEMICAL COMPANY	AR-0170	12/2/2020	CO2e	SN-51 Ammonia Plant CO2 Regenerator	711000	TON PER YEAR	Proper Catalyst Selection, Good Operating Practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	CO2 purification process EU 003	1.275	TON/AMMONIA PRODUCED, BASED ON 100% CO2 VENTING.	good operational procedures including the selection of an optimal process catalyst
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	CO2 purification process EU 003	831040	TON/YR, TWELVE CONSECUTIVE MONTH PERIOD	good operational procedures including the selection of an optimal process catalyst
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	CO2 purification process EU 003	0.106	LB/TON AMMONIA PRODUCED, BASED ON 100% CO2 VENTING.	shall be controlled by the use of good operational procedures including the selection of an optimal process catalyst
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	CO2 purification process EU 003	0.02	LB/TON AMMONIA PRODUCED, BASED ON 100% CO2 VENTING.	good operational procedures including the selection of an optimal process catalyst including the selection of an optimal process catalyst
Praxair Inc - Praxair Clear Lake Plant	TX-0830	10/19/2017	CO2e	HyCO CO2 Stripper MSS	0		No controls feasible.
Praxair Inc - Praxair Clear Lake Plant	TX-0830	10/19/2017	CO	HyCO CO2 Stripper MSS	3.3	tpy	No controls feasible.
Praxair Inc - Praxair Clear Lake Plant	TX-0827	10/19/2017	CO2e	HyCO CO2 Stripper MSS	0		No controls feasible. Emissions included in sitewide grouped limit
Praxair Inc - Praxair Clear Lake Plant	TX-0827	10/19/2017	CO	HyCO CO2 Stripper MSS	3.3	tpy	No controls feasible.
Agrium US, Inc	TX-0814	1/5/2017 (draft)	CO2e	CO2 Stripper Vent	843150	tpy	Good engineering practices to minimize CO2e emissions, with emissions limited to releasing to the atmosphere the CO2 with cannot be sold. (730,000 TPY Urea and 702,625 TPY Ammonia Greenhouse gas (GHG) will be controlled by using Carbon dioxide (CO2) as a raw material to produce urea. If the Urea Plant is not operating, the CO2 generated in the ammonia process will be vented to the atmosphere)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	CO	Acid Gas Removal Unit/CO2 Vent	No Numeric Limit	No Numeric Limit	Thermal Oxidizers
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	CO2e	Acid Gas Removal Unit/CO2 Vent	No Numeric Limit	No Numeric Limit	Thermal Oxidizers
Topchem Pollock, LLC	LA-0306	12/20/2016 (draft), 08/08/2017 update	CO2e	CO2 Stripper Column CO2SC-16-1 (EQT031)	162511	tpy	Use of pipeline quality natural gas and good combustion practices. 0.29 Ton CO2e/Metric Ton of NH3 produced.
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	Acetaldehyde ⁽¹⁾	Carbon Dioxide Regenerator	1,226,814	tpy rolling 12 month total	Good operational practices
CF Industries Inc. Donaldsonville Nitrogen Complex - Ammonia Plant	LA-0236	3/3/2009	CO	CO2 Vents	5.59	lbs/hr	Optimum Catalytic Conversion of CO to CO2 in the high and low shift converters, and continued use of an optimum liquid alkanol amine solution, or other solution to maximize the absorbing of CO2
CF Industries Inc. Donaldsonville Nitrogen Complex - Ammonia Plant	LA-0236	3/3/2009	CO	CO2 Vents	6.55	tons/year	Optimum Catalytic Conversion of CO to CO2 in the high and low shift converters, and continued use of an optimum liquid alkanol amine solution, or other solution to maximize the absorbing of CO2
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Carbon Dioxide Regenerator	0.02	lb/ton of NH3 average of 3 stack tests	Good operational practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Carbon Dioxide Regenerator	9.74	tpy rolling 12 month total	Good operational practices
Iowa Fertilizer company	IA-0105	10/26/2012	CO	CO2 Regenerator	0.02	lb/ton of NH3 average of 3 stack tests	Good operational practices
Iowa Fertilizer company	IA-0105	10/26/2012	CO	CO2 Regenerator	9.65	tpy rolling 12 month total	Good operational practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	CO2 purification process	0.0117	lb/ton of NH3 3 hour average	good operational practices and the use of a process catalyst
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	CO	Selexol AGR CO2 Vent	8.7	lbs/hr	Thermal Oxidizer (Cat-Ox)
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2	Carbon Dioxide Regenerator	1.26	lb/ton of NH3 30 day rollin g average ⁽²⁾	Good operational practices
Iowa Fertilizer company	IA-0105	10/26/2012	CO2	CO2 Regenerator	1.26	Tons/ton of NH3 rolling 30 day average	Good operational practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO2	CO2 purification process	1.275	ton/ton of NH3 3 hour average	Good Operational Practices
Pryor Plant Chemical Company	OK-0135	2/23/2009	CO2	Carbon dioxide vent	3.65	lbs/hr 1 hour/8 hour	good operation practices
Iowa Fertilizer company	IA-0105	10/26/2012	CO2e	CO2 Regenerator	1,211,847	tpy rolling 12 month total	Good operational practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	NOx	Selexol AGR CO2 Vent	0.9	lbs/hr	Thermal Oxidizer (Cat-Ox)
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Carbon Dioxide Regenerator	0.106	lb/ton of NH3 average of 3 stack tests	Good operational practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Carbon Dioxide Regenerator	51.60	tpy rolling 12 month total	Good operational practices
Iowa Fertilizer company	IA-0105	10/26/2012	VOC	CO2 Regenerator	0.106	lb/ton of NH3 average of 3 stack tests	Good operational practices
Iowa Fertilizer company	IA-0105	10/26/2012	VOC	CO2 Regenerator	51.2	tpy rolling 12 month total	Good operational practices
Ohio Valley Resources, LLC	TBD	9/25/2013	VOC	CO2 purification process	0.0558	lb/ton of NH3 3 hour average	low VOC catalyst

⁽¹⁾ This is not correct according to Chris Roling for the Iowa DNR, most likely CO2e

⁽²⁾ The units may be incorrect. It might be tons/ton of NH3

Notes:

Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Flare" - Fertilizer Plants only
Unit 22 - Plants 4 and 5 Small Flare
Unit 23 - Plants 4 and 5 Emergency Flare

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	ammonia storage flare EU-016	0.0075	LB/MMBTU	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	ammonia storage flare EU-016	168	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	ammonia storage flare EU-016	168	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	ammonia storage flare EU-016	0.0075	LB/MMBTU	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	ammonia storage flare EU-016	168	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	ammonia storage flare EU-016	0.068	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	ammonia storage flare EU-016	168	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	ammonia storage flare EU-016	0.37	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	ammonia storage flare EU-016	168	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	ammonia storage flare EU-016	0.0054	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	ammonia storage flare EU-016	563	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	ammonia storage flare EU-016	168	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	Front End Flare EU 017	0.0075	LB/MMBTU	The pilot and purge gas fuels used shall be natural gas, Flares shall be designed for and operated with no visible emissions, except for periods not to exceed 5 minutes during any two consecutive hours, Flares shall be operated with a flame present at all times, Flares shall be continuously monitored to assure the presence of a pilot flame with a thermocouple, infrared monitor, or other approved device
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	Front End Flare EU 017	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels used shall be natural gas, Flares shall be designed for and operated with no visible emissions, except for periods not to exceed 5 minutes during any two consecutive hours, Flares shall be operated with a flame present at all times, Flares shall be continuously monitored to assure the presence of a pilot flame with a thermocouple, infrared monitor, or other approved device
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	Front End Flare EU 017	0.0075	LB/MMBTU	The pilot and purge gas fuels used shall be natural gas, Flares shall be designed for and operated with no visible emissions, except for periods not to exceed 5 minutes during any two consecutive hours, Flares shall be continuously monitored to assure the presence of a pilot flame with a thermocouple, infrared monitor, or other approved device
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	Front End Flare EU 017	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels used shall be natural gas, Flares shall be designed for and operated with no visible emissions, except for periods not to exceed 5 minutes during any two consecutive hours, Flares shall be operated with a flame present at all times, Flares shall be continuously monitored to assure the presence of a pilot flame with a thermocouple, infrared monitor, or other approved device
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	Front End Flare EU 017	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	Front End Flare EU 017	0.068	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	Front End Flare EU 017	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	Front End Flare EU 017	0.37	LB/MMBTU	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	Front End Flare EU 017	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	Front End Flare EU 017	0.0054	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	Front End Flare EU 017	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	Front End Flare EU 017	116.89	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	Back End Flare EU-018	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	Back End Flare EU-018	0.0075	LB/MMBTU	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	Back End Flare EU-018	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	Back End Flare EU-018	0.0075	LB/MMBTU	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	Back End Flare EU-018	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	Back End Flare EU-018	0.068	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	Back End Flare EU-018	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	Back End Flare EU-018	0.37	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	Back End Flare EU-018	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	Back End Flare EU-018	0.0054	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	Back End Flare EU-018	336	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	Back End Flare EU-018	116.89	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	Discontinuous Urea Flare EU-DUF	240	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	Discontinuous Urea Flare EU-DUF	0.0075	LB/MMBTU	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	Discontinuous Urea Flare EU-DUF	240	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	Discontinuous Urea Flare EU-DUF	0.0075	LB/MMBTU	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	Discontinuous Urea Flare EU-DUF	240	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	Discontinuous Urea Flare EU-DUF	0.068	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	Discontinuous Urea Flare EU-DUF	240	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	Discontinuous Urea Flare EU-DUF	0.37	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	Discontinuous Urea Flare EU-DUF	240	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	Discontinuous Urea Flare EU-DUF	0.0054	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	Discontinuous Urea Flare EU-DUF	240	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	Discontinuous Urea Flare EU-DUF	116.89	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM10	Emergency Urea Flare EU-EUF	0.0075	LB/MMBTU	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	PM2.5	Emergency Urea Flare EU-EUF	0.0075	LB/MMBTU	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	Emergency Urea Flare EU-EUF	0.068	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	Emergency Urea Flare EU-EUF	0.37	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	Emergency Urea Flare EU-EUF	0.0054	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	Emergency Urea Flare EU-EUF	116.89	LB/MMBTU, DURING NORMAL OPERATION	The pilot and purge gas fuels shall be natural gas
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	PM2.5	Process Flare FL-16-1 (EQT034)	0.01	lb/hr hourly maximum	Correct flare design and good combustion practices; Compliance with the Louisiana Non-NSPS Flare Requirements (2.17 MMBtu/hr)(Flare shall not operate more than 4 hours above normal firing rate in any 24 consecutive hours and 148 hours per year)
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	PM2.5	Process Flare FL-16-1 (EQT034)	0.02	tpy annual maximum	Correct flare design and good combustion practices; Compliance with the Louisiana Non-NSPS Flare Requirements (2.17 MMBtu/hr)(Flare shall not operate more than 4 hours above normal firing rate in any 24 consecutive hours and 148 hours per year)
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	CO	Process Flare FL-16-1 (EQT034)	0.87	lb/hr hourly maximum	Correct flare design and good combustion practices; Compliance with the Louisiana Non-NSPS Flare Requirements (2.17 MMBtu/hr)(Flare shall not operate more than 4 hours above normal firing rate in any 24 consecutive hours and 148 hours per year)
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	CO	Process Flare FL-16-1 (EQT034)	3.76	tpy annual maximum	Correct flare design and good combustion practices; Compliance with the Louisiana Non-NSPS Flare Requirements (2.17 MMBtu/hr)(Flare shall not operate more than 4 hours above normal firing rate in any 24 consecutive hours and 148 hours per year)
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	CO2e	Process Flare FL-16-1 (EQT034)	370	tpy annual maximum	Correct flare design and good combustion practices; Compliance with the Louisiana Non-NSPS Flare Requirements (2.17 MMBtu/hr)(Flare shall not operate more than 4 hours above normal firing rate in any 24 consecutive hours and 148 hours per year)
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	TPM	Back End Flare (EU-018)	0.0019	lb/MMBTU 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	TPM	Back End Flare (EU-018)	336	hours/12 consec month	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	TPM	Back End Flare (EU-018)	No Numeric Limit	No Numeric Limit	Pilot and purge gas shall be natural gas; and process flaring minimization practices; operated with a flame present at all times; continuously monitored

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Flare" - Fertilizer Plants only
Unit 22 - Plants 4 and 5 Small Flare
Unit 23 - Plants 4 and 5 Emergency Flare

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	PM10	Back End Flare (EU-018)	0.0075	lb/MMBtu 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	PM10	Back End Flare (EU-018)	336	hours/12 consec month venting	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	PM10	Back End Flare (EU-018)	No Numeric Limit	No Numeric Limit	Pilot and purge gas shall be natural gas; and process flaring minimization practices; operated with a flame present at all times; continuously monitored
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	PM2.5	Back End Flare (EU-018)	0.0075	lb/MMBtu 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	PM2.5	Back End Flare (EU-018)	336	hours/12 consec month venting	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	PM2.5	Back End Flare (EU-018)	No Numeric Limit	No Numeric Limit	Pilot and purge gas shall be natural gas; and process flaring minimization practices; operated with a flame present at all times; continuously monitored
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	NOx	Back End Flare (EU-018)	0.068	lb/MMBtu during normal operations 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	NOx	Back End Flare (EU-018)	624.94	lb/hour venting operations 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	NOx	Back End Flare (EU-018)	No Numeric Limit	No Numeric Limit	Pilot and purge gas shall be natural gas; and process flaring minimization practices; operated with a flame present at all times; continuously monitored
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	CO	Back End Flare (EU-018)	0.37	lb/MMBtu during normal operations 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	CO	Back End Flare (EU-018)	804.76	lb/hour venting operations 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	CO	Back End Flare (EU-018)	No Numeric Limit	No Numeric Limit	Pilot and purge gas shall be natural gas; and process flaring minimization practices; operated with a flame present at all times; continuously monitored
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	VOC	Back End Flare (EU-018)	0.0054	lb/MMBtu during normal operations 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	VOC	Back End Flare (EU-018)	11.73	lb/hour venting operations 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	VOC	Back End Flare (EU-018)	No Numeric Limit	No Numeric Limit	Pilot and purge gas shall be natural gas; and process flaring minimization practices; operated with a flame present at all times; continuously monitored
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	CO2	Back End Flare (EU-018)	116.89	lb/MMBtu during normal operations 3 hour average	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	CO2	Back End Flare (EU-018)	573	tons/12 consecutive months	
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft), updated 7/10/17	CO2	Back End Flare (EU-018)	No Numeric Limit	No Numeric Limit	Pilot and purge gas shall be natural gas; and process flaring minimization practices; operated with a flame present at all times; continuously monitored
Agrium US, Inc	TX-0814	1/5/2017(draft)	CO2e	Ammonia Emergency Flare	157	tpy	Good Engineering Practices (0.31 MMBtu/hr and 2715 MMBtu/year)
Agrium US, Inc	TX-0814	1/5/2017(draft)	CO2e	Urea Emergency Flare	1418	tpy	Good Engineering Practices (2.76 MMBtu/hr)
Agrium US, Inc	TX-0814	1/5/2017(draft)	CO2e	Urea Emergency Flare (maintenance)	5.9	tpy	Good Engineering Practices (2000 kg/event, 36 hrs/event, 4 events/yr)
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CH4	Flares	No Numeric Limit	No Numeric Limit	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CH4	Ammonia Flare	No Numeric Limit	No Numeric Limit	Work Practice/Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Flares	No Numeric Limit	No Numeric Limit	Good operating practices & use of natural gas
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Front End Process Flare	0.37	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Front End Process Flare	3240.16	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Back end ammonia process vent flare	0.37	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Back end ammonia process vent flare	804.76	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	CO	Process Flare	No Numeric Limit	No Numeric Limit	Good combustion practices. Meet 40 CFR 60.18
United Wisconsin Grain Producers UWGP - Fuel Grade Ethanol Plant	WI-0204	8/14/2003	CO	Bypass Flare, Biomethanator	2.4	lbs/hr	Operation Limit: No more than 5040 hr/yr
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Ammonia Flare	No Numeric Limit	No Numeric Limit	Work Practice/Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Front End Process Flare	0.068	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Front End Process Flare	595.47	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	Visible Emissions	Flares	No Numeric Limit	No Numeric Limit	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	Visible Emissions	Ammonia Flare	No Numeric Limit	No Numeric Limit	Work Practice/Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Flares	No Numeric Limit	No Numeric Limit	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	VOC	Ammonia Flare	No Numeric Limit	No Numeric Limit	Work Practice/Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	VOC	Front End Process Flare	0.0054	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	VOC	Front End Process Flare	47.26	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	CO	Flare, Steam Assisted	12.8	lbs/hr	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	CO	Flare, Steam Assisted	56.07	tons/year 365-day sum of daily emissions	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	NOx	Flare, Steam Assisted	15.23	lbs/hr	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	NOx	Flare, Steam Assisted	66.71	tons/year 365-day sum of daily emissions	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	PM10	Flare, Steam Assisted	1.16	lbs/hr	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	PM10	Flare, Steam Assisted	5.08	tons/year 365-day sum of daily emissions	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	SOx	Flare, Steam Assisted	4.2	lbs/hr	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	SOx	Flare, Steam Assisted	18.4	tons/year 365-day sum of daily emissions	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	Visible Emissions	Flare, Steam Assisted	0	% opacity no NE except for 5 min during any 2 hrs	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	VOC	Flare, Steam Assisted	3.68	tons/year 365-day sum of daily emissions	Unknown
Sunoco, Inc. Sun Company, Inc., Toledo Refinery	OH-0308	2/23/2009	VOC	Flare, Steam Assisted	0.84	lbs/hr	Unknown
Ohio Valley Resources, LLC	TBD	9/25/2013	VOC	Back end ammonia process vent flare	0.0054	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	VOC	Back end ammonia process vent flare	11.73	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
United Wisconsin Grain Producers UWGP - Fuel Grade Ethanol Plant	WI-0204	8/14/2003	VOC	Bypass Flare, Biomethanator	0.3	lbs/hr	Operation Limit: No more than 5040 hr/yr
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	CO	Flares, 3500 SCFM LFG (3)	17.3	lbs/hr	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	CO	Flares, 3500 SCFM LFG (3)	98%	Reduction	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	CO	Flares, 2500 SCFM LFG (2)	12.3	lbs/hr	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	CO	Flares, 2500 SCFM LFG (2)	98%	Reduction	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Flare" - Fertilizer Plants only
Unit 22 - Plants 4 and 5 Small Flare
Unit 23 - Plants 4 and 5 Emergency Flare

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	NOx	Flares, 2500 SCFM LFG (2)	3.6	lbs/hr	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	NOx	Flares, 3500 SCFM LFG (3)	5.1	lbs/hr	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	NOx	Flares, 3500 SCFM LFG (3)	98%	Reduction	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	NOx	Flares, 2500 SCFM LFG (2)	98%	Reduction	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	PM10	Flares, 2500 SCFM LFG (2)	1.6	lbs/hr	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	PM10	Flares, 2500 SCFM LFG (2)	98%	Reduction	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	PM10	Flares, 3500 SCFM LFG (3)	2.2	lbs/hr	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	PM10	Flares, 3500 SCFM LFG (3)	98%	Reduction	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	SO2	Flares, 2500 SCFM LFG (2)	1.4	lbs/hr	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	SO2	Flares, 3500 SCFM LFG (3)	1.9	lbs/hr	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	VOC	Flares, 2500 SCFM LFG (2)	1	lbs/hr nonmethane organic carbon	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	VOC	Flares, 2500 SCFM LFG (2)	98%	Reduction	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	VOC	Flares, 3500 SCFM LFG (3)	0.6	lbs/hr	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG
WM Atlantic Waste Disposal Inc. Atlantic Waste Disposal Landfill	VA-0294	2/5/2003	VOC	Flares, 3500 SCFM LFG (3)	1.4	lbs/hr nonmethane organic carbon	Proper maintenance of the flare, including monitoring for the presence of flame, LGF flow rate, 0% opacity, measuring % methane in LFG

Notes:
Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.
Some facilities are not shown because they are not fertilizer production facilities. These units are not directly comparable because they do not flare common process gas.

Appendix B KNO Restart - RBLC Summary

KNO Restart
 RBLC Search Summary
 Search: "MDEA", "methy!", "42.009", "61.999" - All Results
MDEA Storage Tank

No new entries

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
No New Results							
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Methyl-diethanol Amine (MDEA) Storage Tank	0.1 tons/year rolling 12 month total		Nitrogen Gas Blanket
Iowa Fertilizer Company	IA-0105	10/26/2012	VOC	MDEA Storage Tank	0.1 tons/year rolling 12 month total		Nitrogen Gas Blanket

Notes:
 Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu).

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Start up", "Start-up","Preheat" - All Results Included
Unit 13 - Startup Heater

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 PM10	Startup heater EU-002	200	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 PM10	Startup heater EU-002	0.249	LB/HR	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 PM2.5	Startup heater EU-002	200	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 PM2.5	Startup heater EU-002	0.249	LB/HR	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 CO2e	Startup heater EU-002	200	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 CO2e	Startup heater EU-002	3898	LB/HR	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 VOC	Startup heater EU-002	200	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 VOC	Startup heater EU-002	0.18	LB/HR	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 CO	Startup heater EU-002	200	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 CO	Startup heater EU-002	1.217	LB/HR	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 NOx	Startup heater EU-002	200	HR/YR, TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas, shall be controlled by good combustion practices
MIDWEST FERTILIZER COMPANY LLC	*IN-0324		44687 NOx	Startup heater EU-002	6.007	LB/HR	shall combust natural gas, shall be controlled by good combustion practices

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Start up", "Start-up","Preheat" - All Results Included
Unit 13 - Startup Heater

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
PORT ARTHUR REFINERY	TX-0873		43865 NOx	Heaters' SCR MSS and heater	0.1	LB/MMBTU, Hourly	
PORT ARTHUR REFINERY	TX-0873		43865 SO2	Heaters' SCR MSS and heater	162	PPMV H2S	
BIG RIVER STEEL LLC	AR-0173		44592 PM10	Vertical and Horizontal Ladl	0.0075	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 PM2.5	Vertical and Horizontal Ladl	0.0075	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 SOx	Vertical and Horizontal Ladl	0.0006	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 CO2e	Vertical and Horizontal Ladl	117	LB/MMBTU	Good operating practices
BIG RIVER STEEL LLC	AR-0173		44592 Visible Emissions (VE)	Vertical and Horizontal Ladl	5	%	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 VOC	Vertical and Horizontal Ladl	0.0054	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 CO	Vertical and Horizontal Ladl	0.0824	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 NOx	Vertical and Horizontal Ladl	0.095	LB/MMBTU	Low NOx burners Combustion of clean fuel Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 FPM	Vertical and Horizontal Ladl	0.0075	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 PM10	Tundish Preheaters/Dryout	0.0075	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 PM2.5	Tundish Preheaters/Dryout	0.0075	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 CO2e	Tundish Preheaters/Dryout	117	LB/MMBTU	Good operating practices
BIG RIVER STEEL LLC	AR-0173		44592 Visible Emissions (VE)	Tundish Preheaters/Dryout	5	%	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 VOC	Tundish Preheaters/Dryout	0.0054	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 CO	Tundish Preheaters/Dryout	0.0824	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 NOx	Tundish Preheaters/Dryout	0.097	LB/MMBTU	Low NOx burners Combustion of clean fuel Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 FPM	Tundish Preheaters/Dryout	0.0075	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173		44592 SO2	Tundish Preheaters/Dryout	0.0006	LB/MMBTU	Combustion of Natural gas and Good Combustion Practices
NUCOR STEEL KANKAKEE, INC.	*IL-0132		44221 PM10	Ladle Preheater	0.0076	LB/MMBTU	Good combustion practice
NUCOR STEEL KANKAKEE, INC.	*IL-0132		44221 VOC	Ladle Preheater	0.0055	LB/MMBTU	Good combustion practice
NUCOR STEEL KANKAKEE, INC.	*IL-0132		44221 CO	Ladle Preheater	0.084	LB/MMBTU	Good combustion practice
NUCOR STEEL KANKAKEE, INC.	*IL-0132		44221 NOx	Ladle Preheater	0.1	LB/MMBTU	Good combustion practice
NUCOR STEEL KANKAKEE, INC.	*IL-0132		44221 FPM	Ladle Preheater	0.0019	LB/MMBTU	Good combustion practice
NUCOR STEEL KANKAKEE, INC.	*IL-0132		44221 SO2	Ladle Preheater	0.0006	LB/MMBTU	Good combustion practice
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 TPM	Galvanizing Line #2 Preheat	7.6	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 TPM	Galvanizing Line #2 Preheat	3.07	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 PM2.5	Galvanizing Line #2 Preheat	7.6	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 PM2.5	Galvanizing Line #2 Preheat	3.07	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 Ammonia (NH3)	Galvanizing Line #2 Preheat	10	PPM, CONTINUOUSLY MONITORED	
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 CO2e	Galvanizing Line #2 Preheat	48725	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan and implement various design and operational efficiency requirements.
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 VOC	Galvanizing Line #2 Preheat	5.5	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 VOC	Galvanizing Line #2 Preheat	2.22	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 CO	Galvanizing Line #2 Preheat	84	LB/MMSCF, 3-HR AVERAGE	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 CO	Galvanizing Line #2 Preheat	33.91	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 NOx	Galvanizing Line #2 Preheat	7.5	LB/MMSCF, 3-HR AVERAGE	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. This unit is also equipped with a SCR/SNCR system to control emissions. During a cold start, SCR does not reach operating temperature for approximately 30 minutes. During this time, only low-NOx burners are controlling emissions of NOx. NSG estimates the unit may undergo 1 cold start every two (2) weeks.
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 NOx	Galvanizing Line #2 Preheat	3.03	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. This unit is also equipped with a SCR/SNCR system to control emissions. During a cold start, SCR does not reach operating temperature for approximately 30 minutes. During this time, only low-NOx burners are controlling emissions of NOx. NSG estimates the unit may undergo 1 cold start every two (2) weeks.
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 Lead (Pb) / Lead Compounds	Galvanizing Line #2 Preheat	0.0005	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 Lead (Pb) / Lead Compounds	Galvanizing Line #2 Preheat	0.0002	TON/YR, 12-MONTH ROLLING	

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Start up", "Start-up", "Preheat" - All Results Included
Unit 13 - Startup Heater

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 FPM	Galvanizing Line #2 Preheat	1.9	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 FPM	Galvanizing Line #2 Preheat	0.77	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 SO2	Galvanizing Line #2 Preheat	0.6	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 SO2	Galvanizing Line #2 Preheat	0.24	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 PM10	Galvanizing Line #2 Zinc Pot	7.6	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 PM10	Galvanizing Line #2 Zinc Pot	0.0019	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 PM2.5	Galvanizing Line #2 Zinc Pot	7.6	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 PM2.5	Galvanizing Line #2 Zinc Pot	0.0019	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 CO2e	Galvanizing Line #2 Zinc Pot	30	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan and implement various design and operational efficiency requirements.
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 VOC	Galvanizing Line #2 Zinc Pot	5.5	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 VOC	Galvanizing Line #2 Zinc Pot	0.0013	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 CO	Galvanizing Line #2 Zinc Pot	84	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 CO	Galvanizing Line #2 Zinc Pot	0.021	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 NOx	Galvanizing Line #2 Zinc Pot	70	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. This unit is equipped with a low-NOx burner.
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 NOx	Galvanizing Line #2 Zinc Pot	0.017	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. This unit is equipped with a low-NOx burner.
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 Lead (Pb) / Lead Compounds	Galvanizing Line #2 Zinc Pot	0.0005	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 FPM	Galvanizing Line #2 Zinc Pot	1.9	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 FPM	Galvanizing Line #2 Zinc Pot	0.0005	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 SO2	Galvanizing Line #2 Zinc Pot	0.6	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115		44305 SO2	Galvanizing Line #2 Zinc Pot	0.0001	TON/YR, 12-MONTH ROLLING	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
PETMIN USA INCORPORATED	OH-0383		44029 CO	Ladle Preheaters (P002, P003)	0.521	LB/H	Good combustion practices and the use of natural gas
PETMIN USA INCORPORATED	OH-0383		44029 CO	Ladle Preheaters (P002, P003)	2.26	T/YR, PER ROLLING 12 MONTH PERIOD	Good combustion practices and the use of natural gas
PETMIN USA INCORPORATED	OH-0383		44029 CO	Ladle Preheaters (P002, P003)	0.0344	LB/MMBTU	Good combustion practices and the use of natural gas
STEEL MANUFACTURING FACILITY	TX-0867		43832 VOC	MELT SHOP LADLE PREHEAT	0		GOOD COMBUSTION PRACTICES
STEEL MANUFACTURING FACILITY	TX-0867		43832 CO	MELT SHOP LADLE PREHEAT	0		GOOD COMBUSTION PRACTICES
STEEL MANUFACTURING FACILITY	TX-0867		43832 NOx	MELT SHOP LADLE PREHEAT	0		GOOD COMBUSTION PRACTICES
STEEL MANUFACTURING FACILITY	TX-0867		43832 SO2	MELT SHOP LADLE PREHEAT	0		CLEAN FUEL AND SCRAP
SDSW STEEL MILL	TX-0882		43847 TPM	LADLE DRYERS AND PREHEAT	0.0075	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 PM10	LADLE DRYERS AND PREHEAT	0.0075	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 PM2.5	LADLE DRYERS AND PREHEAT	0.0075	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 CO2e	LADLE DRYERS AND PREHEAT	117.1	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 VOC	LADLE DRYERS AND PREHEAT	0.0054	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 CO	LADLE DRYERS AND PREHEAT	0.082	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 NOx	LADLE DRYERS AND PREHEAT	0.1	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 SO2	LADLE DRYERS AND PREHEAT	0.0006	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 TPM	Tundish Dryer and Tundish	0.0075	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 PM10	Tundish Dryer and Tundish	0.0075	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 PM2.5	Tundish Dryer and Tundish	0.0075	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 CO2e	Tundish Dryer and Tundish	117.1	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 VOC	Tundish Dryer and Tundish	0.0054	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 CO	Tundish Dryer and Tundish	0.082	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 NOx	Tundish Dryer and Tundish	0.1	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL
SDSW STEEL MILL	TX-0882		43847 SO2	Tundish Dryer and Tundish	0.0006	LB/MMBTU	GOOD COMBUSTION PRACTICES, CLEAN FUEL

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Start up", "Start-up","Preheat" - All Results Included
Unit 13 - Startup Heater

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
CHAPARRAL STEEL MILL	TX-0932		44575 SO2	Melt Shop - Electric Arc Furn	0		Sweet NG, Scrap Best Mgmt Practices
Gerdau Macsteel Inc. - Gerdau Macsteel Monroe	MI-0438	10/29/2018, updated 2/19/2019	PM10	mmbtu/hr burner)	0.0076	lb/MMBtu Hourly	Use of NG fuel and good combustion practices
Gerdau Macsteel Inc. - Gerdau Macsteel Monroe	MI-0438	10/29/2018, updated 2/19/2019	PM2.5	mmbtu/hr burner)	0.0076	lb/MMBtu Hourly	Use of NG fuel and good combustion practices
Gerdau Macsteel Inc. - Gerdau Macsteel Monroe	MI-0438	10/29/2018, updated 2/19/2019	NOx	Ladle Preheater (30 mmbtu/hr burner)	0.08	lb/MMBtu Hourly	LAER - Low NOx burners, use of NG fuel, and good combustion practices. NOx subject to LAER due to non-attainment for ozone, also subject to NOx BACT in NOx attainment area.
Gerdau Macsteel Inc. - Gerdau Macsteel Monroe	MI-0438	10/29/2018, updated 2/19/2019	CO	Ladle Preheater (30 mmbtu/hr burner)	0.084	lb/MMBtu Hourly	Use of NG fuel and good combustion practices
Gerdau Macsteel Inc. - Gerdau Macsteel Monroe	MI-0438	10/29/2018, updated 2/19/2019	SO2	Ladle Preheater (30 mmbtu/hr burner)	0.0006	lb/MMBtu Hourly	Use of NG fuel and good combustion practices
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	PM2.5	Ammonia Converter Start-up Heater Stack SUH-16-1 (EQT030)	0.18	lb/hr hourly maximum	Use of pipeline quality natural gas and good combustion practices
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	PM2.5	Ammonia Converter Start-up Heater Stack SUH-16-1 (EQT030)	0.01	tpy annual maximum	Use of pipeline quality natural gas and good combustion practices
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	CO	Ammonia Converter Start-up Heater Stack SUH-16-1 (EQT030)	1.96	lb/hr hourly maximum	Use of pipeline quality natural gas and good combustion practices
Topchem Pollock, LLC	LA-0306	12/20/2016, updated 8/8/17	CO	Ammonia Converter Start-up Heater Stack SUH-16-1 (EQT030)	0.12	tpy annual maximum	Use of pipeline quality natural gas and good combustion practices
Topchem Pollock, LLC	IN-0263 (draft)	12/20/2016, updated 8/8/17	CO2e	Ammonia Converter Start-up Heater Stack SUH-16-1 (EQT030)	169	tpy annual maximum	Use of pipeline quality natural gas and good combustion practices
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	FPM	Startup Heater EU-002	0.13	lb/hr 3 hour average	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	FPM	Startup Heater EU-002	200	hours/year	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	PM10	Startup Heater EU-002	0.522	lb/hr 3 hour average	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	PM10	Startup Heater EU-002	200	hours/year	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	PM2.5	Startup Heater EU-002	0.522	lb/hr 3 hour average	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	PM2.5	Startup Heater EU-002	200	hours/year	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	NOx	Startup Heater EU-002	12.611	lb/hr 3 hour average	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	NOx	Startup Heater EU-002	200	hours/year	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	CO	Startup Heater EU-002	2.556	lb/hr 3 hour average	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	CO	Startup Heater EU-002	200	hours/year	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	VOC	Startup Heater EU-002	0.378	lb/hr 3 hour average	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	VOC	Startup Heater EU-002	200	hours/year	Good Combustion Practices & use of natural gas (70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	CO2	Startup Heater EU-002	8184	lb/hr 3 hour average	Good Combustion Practices & use of inlet air control sensors that limit excess air(70 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	CO2	Startup Heater EU-002	200	hours/year	Good Combustion Practices & use of inlet air control sensors that limit excess air(70 MMBtu/hr)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	PM10	Gasifier Start-up Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering practices, good combustion technology, and use of clean fuels (23 MMBtu/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	PM2.5	Gasifier Start-up Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering practices, good combustion technology, and use of clean fuels (23 MMBtu/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	SO2	Gasifier Start-up Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering practices, good combustion technology, and use of clean fuels (23 MMBtu/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	NOx	Gasifier Start-up Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering practices, good combustion technology, and use of clean fuels (23 MMBtu/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	CO	Gasifier Start-up Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering practices, good combustion technology, and use of clean fuels (23 MMBtu/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	CO2e	Gasifier Start-up Preheat Burners	No Numeric Limit	No Numeric Limit	Good equipment design and good combustion practices (23 MMBtu/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	PM10	WSA Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering design and practices and use of clean fuels (no size listed)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	PM2.5	WSA Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering design and practices and use of clean fuels(no size listed)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	SO2	WSA Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering design and practices and use of clean fuels (no size listed)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	NOx	WSA Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering design and practices and use of clean fuels(no size listed)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	CO	WSA Preheat Burners	No Numeric Limit	No Numeric Limit	Good engineering design and practices and use of clean fuels (no size listed)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	CO2e	WSA Preheat Burners	No Numeric Limit	No Numeric Limit	Good equipment design and good combustion practices (no size listed)

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Start up", "Start-up","Preheat" - All Results Included
Unit 13 - Startup Heater

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	CO	FGFUELHTR (Two fuel pre-heaters identified as EUFUELHTR1 & EUFUELHTR2)	2.22	lb/hr hourly; each unit	SIP - Good combustion practices (27 MMBtu/hr each)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	NOx	FGFUELHTR (Two fuel pre-heaters identified as EUFUELHTR1 & EUFUELHTR2)	2.65	lb/hr hourly; each unit	SIP - Good combustion practices (27 MMBtu/hr each)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	FPM	FGFUELHTR (Two fuel pre-heaters identified as EUFUELHTR1 & EUFUELHTR2)	0.002	lb/MMBtu Test Protocol will Specify Avg Time	Good combustion practices (27 MMBtu/hr each)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	TPM10	FGFUELHTR (Two fuel pre-heaters identified as EUFUELHTR1 & EUFUELHTR2)	0.2	lb/hr hourly; each fuel heater	SIP - Good combustion practices (27 MMBtu/hr each)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	TPM2.5	FGFUELHTR (Two fuel pre-heaters identified as EUFUELHTR1 & EUFUELHTR2)	0.2	lb/hr hourly; each fuel heater	SIP - Good combustion practices (27 MMBtu/hr each)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	VOC	FGFUELHTR (Two fuel pre-heaters identified as EUFUELHTR1 & EUFUELHTR2)	0.15	lb/hr hourly; each fuel heater	Good combustion practices (27 MMBtu/hr each)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	SO2	FGFUELHTR (Two fuel pre-heaters identified as EUFUELHTR1 & EUFUELHTR2)	2000	gr/MMscf Based upon Fuel Receipt Records	SIP - Good combustion practices and the use of pipeline quality natural gas (The limit is 2,000 grains of sulfur per MMscf. The natural gas material limit of 2000 grains of sulfur per MMscf is what the emission factor is based upon.) (27 MMBtu/hr each)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	CO2e	FGFUELHTR (Two fuel pre-heaters identified as EUFUELHTR1 & EUFUELHTR2)	13848	tpy combined 12-month rolling time period	Energy efficiency measures and the use of a low carbon fuel (pipeline quality natural gas) (27 MMBtu/hr each)
Holland Board of Public Works - East 5th Street	MI-0424 (draft) (update of MI-0412)	12/5/2016, 7/31/17 update	CO	EUFUELHTR (Fuel pre-heater)	0.41	lb/hr Test Protocol will Specify Avg Time	SIP - Good combustion practices (3.7 MMBtu/hr each)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	NOx	EUFUELHTR (Fuel pre-heater)	0.55	lb/hr Test Protocol will Specify Avg Time	SIP - Good combustion practices (3.7 MMBtu/hr each)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	FPM	EUFUELHTR (Fuel pre-heater)	0.007	lb/MMBtu Test Protocol will Specify Avg Time	Good combustion practices (3.7 MMBtu/hr each)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	TPM10	EUFUELHTR (Fuel pre-heater)	0.0075	lb/MMBtu Test Protocol will Specify Avg Time	SIP - Good combustion practices (3.7 MMBtu/hr each)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	TPM2.5	EUFUELHTR (Fuel pre-heater)	0.0075	lb/MMBtu Test Protocol will Specify Avg Time	SIP - Good combustion practices (3.7 MMBtu/hr each)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	VOC	EUFUELHTR (Fuel pre-heater)	0.03	lb/hr Test Protocol will Specify Avg Time	Good combustion practices (3.7 MMBtu/hr each)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	SO2	EUFUELHTR (Fuel pre-heater)	2000	gr/MMscf Based upon Fuel Receipt Records	SIP - Good combustion practices and the use of pipeline quality natural gas (The limit is 2,000 grains of sulfur per MMscf. The natural gas material limit of 2000 grains of sulfur per MMscf is what the emission factor is based upon.) (3.7 MMBtu/hr each)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	CO2e	EUFUELHTR (Fuel pre-heater)	1934	tpy combined 12-month rolling time period	Good combustion practices (3.7 MMBtu/hr each)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	NOx	Dew Point Heater 13.8	0.011	lb/MMBtu	NSPS (12.8 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	CO	Dew Point Heater 13.8	0.08	lb/MMBtu	NSPS (12.8 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	CO	Dew Point Heater 3.2	0.08	lb/MMBtu	NSPS (3.2 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	NOx	Dew Point Heater 3.2	0.035	lb/MMBtu	NSPS (3.2 MMBtu/hr)
Mid-Kansas Electric Company, LLC - Rubart Station	KS-0030 (draft)	3/31/16, 7/19/17 update	NOx	Indirect Fuel-Gas Heater	0.2	lb/hr excludes SSM	(One (1) indirect fuel-gas heater, rated at 2 mMBtu/hr heat input, which shall only burn natural gas, for the purpose of heating the natural gas fuel prior to combustion in the Caterpillar 4SLB RICE)
Mid-Kansas Electric Company, LLC - Rubart Station	KS-0030 (draft)	3/31/16, 7/19/17 update	CO	Indirect Fuel-Gas Heater	0.16	lb/hr excludes SSM	(One (1) indirect fuel-gas heater, rated at 2 mMBtu/hr heat input, which shall only burn natural gas, for the purpose of heating the natural gas fuel prior to combustion in the Caterpillar 4SLB RICE)
Mid-Kansas Electric Company, LLC - Rubart Station	KS-0030 (draft)	3/31/16, 7/19/17 update	VOC	Indirect Fuel-Gas Heater	0.011	lb/hr excludes SSM	(One (1) indirect fuel-gas heater, rated at 2 mMBtu/hr heat input, which shall only burn natural gas, for the purpose of heating the natural gas fuel prior to combustion in the Caterpillar 4SLB RICE)
Mid-Kansas Electric Company, LLC - Rubart Station	KS-0030 (draft)	3/31/16, 7/19/17 update	TPM	Indirect Fuel-Gas Heater	0.015	lb/hr excludes SSM	(One (1) indirect fuel-gas heater, rated at 2 mMBtu/hr heat input, which shall only burn natural gas, for the purpose of heating the natural gas fuel prior to combustion in the Caterpillar 4SLB RICE)

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Start up", "Start-up","Preheat" - All Results Included
Unit 13 - Startup Heater

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Mid-Kansas Electric Company, LLC - Rubart Stati	KS-0030 (draft)	3/31/16, 7/19/17 update	TPM10	Indirect Fuel-Gas Heater	0.015	lb/hr excludes SSM	(One (1) indirect fuel-gas heater, rated at 2 mmBtu/hr heat input, which shall only burn natural gas, for the purpose of heating the natural gas fuel prior to combustion in the Caterpillar 4SLB RICE)
Mid-Kansas Electric Company, LLC - Rubart Stati	KS-0030 (draft)	3/31/16, 7/19/17 update	TPM2.5	Indirect Fuel-Gas Heater	0.015	lb/hr excludes SSM	(One (1) indirect fuel-gas heater, rated at 2 mmBtu/hr heat input, which shall only burn natural gas, for the purpose of heating the natural gas fuel prior to combustion in the Caterpillar 4SLB RICE)
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CH4	Startup Heater	0.0023	lb/MMBtu average of 3 stack tests	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CH4	Startup Heater	0.0023	lb/MMBtu average of 3 stack tests	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Startup Heater	0.0194	lb/MMBtu average of 3 stack tests	good operating practices & use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Startup Heater	0.057	tons/year rolling 12 month total	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CO	Startup Heater	0.0194	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	CO	Startup Heater	0.1	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Ammonia catalyst startup heater	37.23	lb/MMcf 3 hour average	good heater design and good combustion practices
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	CO	Heaters	0.01	lb/MMBtu	Unknown
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	CO	Heaters, Reboiler	0.01	lb/MMBtu	Unknown
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	CO	Heater, CCR Reactor	0.01	lb/MMBtu	Unknown
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2	Startup Heater	117	lb/MMBtu average of 3 stack tests	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CO2	Startup Heater	117	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO2	Ammonia catalyst startup heater	59.61	ton/MMcf 3 hour average	good heater design and good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2e	Startup Heater	345	tons/year rolling 12 month total	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CO2e	Startup Heater	638	tons/year rolling 12 month total	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	N2O	Startup Heater	0.0006	lb/MMBtu average of 3 stack tests	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	N2O	Startup Heater	0.0006	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Startup Heater	0.119	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Startup Heater	0.63	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Ammonia catalyst startup heater	183.7	lb/MMcf 3 hour average	good heater design and good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Startup Heater	0.0024	lb/MMBtu average of 3 stack tests	good operating practices & use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Startup Heater	0.007	tons/year rolling 12 month total	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Startup Heater	0.0024	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Startup Heater	0.01	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	PM	Ammonia catalyst startup heater	1.9	lb/MMcf 3 hour average	good heater design and good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Startup Heater	0.0024	lb/MMBtu average of 3 stack tests	good operating practices & use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Startup Heater	0.007	tons/year rolling 12 month total	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Startup Heater	0.0024	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Startup Heater	0.01	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	PM10	Ammonia catalyst startup heater	7.6	lb/MMcf 3 hour average	good heater design and good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Startup Heater	0.0024	lb/MMBtu average of 3 stack tests	good operating practices & use of natural gas

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Start up", "Start-up", "Preheat" - All Results Included
Unit 13 - Startup Heater

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Startup Heater	0.007	tons/year rolling 12 month total	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Startup Heater	0.0024	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Startup Heater	0.01	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	PM2.5	Ammonia catalyst startup heater	7.6	lb/MMcf 3 hour average	good heater design and good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	Visible Emissions	Startup Heater	0	%	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	Visible Emissions	Startup Heater	0	% Opacity	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Startup Heater	0.0014	lb/MMBtu average of 3 stack tests	good operating practices & use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Startup Heater	0.004	tons/year rolling 12 month total	good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	VOC	Startup Heater	0.0014	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	VOC	Startup Heater	0.01	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	VOC	Ammonia catalyst startup heater	5.5	lb/MMcf 3 hour average	good heater design and good combustion practices

Notes:

Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times. Some facilities are not shown because they are not fertilizer production facilities. These units are not directly comparable because they are not used for startup.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Urea" - All Results Included
Unit 35 - Urea Granulators A/B
Unit 36 - Urea Granulators C/D

No new entries

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft)	PM	Urea Granulation Unit (EU-008)	0.163	lb/ton 3 hour average	Wet Scrubber
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft)	PM	Urea Granulation Unit (EU-008)	368040	tons/12 consecutive mos	Wet Scrubber
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft)	PM10	Urea Granulation Unit (EU-008)	0.163	lb/ton 3 hour average	Wet Scrubber
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft)	PM10	Urea Granulation Unit (EU-008)	368040	tons/12 consecutive mos	Wet Scrubber
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft)	PM2.5	Urea Granulation Unit (EU-008)	0.163	lb/ton 3 hour average	Wet Scrubber
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft)	PM2.5	Urea Granulation Unit (EU-008)	368040	tons/12 consecutive mos	Wet Scrubber
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CH4	Urea Granulator	0.0023	lb/MMBtu average of 3 stack tests	good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Urea Granulator	0.0194	lb/MMBtu average of 3 stack tests	good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Urea Granulator	5.5	tpy rolling 12 month total	good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2	Urea Granulator	117	lb/MMBtu average of 3 stack tests	good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2e	Urea Granulator	33469	tpy rolling 12 month total	good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	N2O	Urea Granulator	0.0006	lb/MMBtu average of 3 stack tests	good combustion practices
Agrium U.S. Incorporated Kennewick Fertilizer Operations	WA-0318	7/11/2008	PM	Granular Urea Ammonium Nitrate Production	0.096	gr/dscf 24 hour average	Wet Scrubber, Mist Eliminator, and Product Hardener
Agrium U.S. Incorporated Kennewick Fertilizer Operations	WA-0318	7/11/2008	PM	Granular Urea Ammonium Nitrate Production	99.6	tons/year 12 month rolling average	Wet Scrubber, Mist Eliminator, and Product Hardener
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Urea Granulator	0.11	lb/ton of urea average of 3 stack tests	good combustion practices along with a wet scrubber
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Urea Granulator	85.7	tpy rolling 12 month total	good combustion practices along with a wet scrubber
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Urea Granulator	0.1	kg/metric ton average of 3 stack tests	Wet Scrubber
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Urea Granulator	60.4	tons/year rolling 12 month total	Wet Scrubber
Pryor Plant Chemical Company	OK-0135	2/23/2009	PM	Granulator Scrubbers	0.7	lbs/hr 24-hour	Good operating practices
Pryor Plant Chemical Company	OK-0135	2/23/2009	PM	Granulator Scrubbers	80%	Reduction	Good operating practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM	Urea Granulation Vent	0.011	lb/ton	Wet Scrubber
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM	Urea Granulation Vent	20.5	lbs/hr	Wet Scrubber
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM	Urea Granulation Vent	20%	Reduction	Wet Scrubber
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Urea Granulator	0.11	lb/ton of urea average of 3 stack tests	good combustion practices along with a wet scrubber
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Urea Granulator	85.7	tpy rolling 12 month total	good combustion practices along with a wet scrubber
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Urea Granulator	0.1	kg/metric ton average of 3 stack tests	Wet Scrubber
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Urea Granulator	60.4	tons/year rolling 12 month total	Wet Scrubber
Koch Nitrogen Company Enid Nitrogen Plant	OK-0124	5/1/2008	PM10	Urea Granulators	6.6	lbs/hr per granulator	Wet Scrubber
Pryor Plant Chemical Company	OK-0135	2/23/2009	PM10	Granulator Scrubbers	0.7	lbs/hr 24-hour	Good operating practices
Pryor Plant Chemical Company	OK-0135	2/23/2009	PM10	Granulator Scrubbers	80%	Reduction	Good operating practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM10	Urea Granulation Vent	0.005	lb/ton	Wet Scrubber
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM10	Urea Granulation Vent	9	lbs/hr	Wet Scrubber
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Urea Granulator	0.108	lb/ton of urea average of 3 stack tests	good combustion practices along with a wet scrubber
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Urea Granulator	85.7	tpy rolling 12 month total	good combustion practices along with a wet scrubber
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Urea Granulator	0.025	kg/metric ton average of 3 stack tests	Wet Scrubber
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Urea Granulator	15.1	tons/year rolling 12 month total	Wet Scrubber
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	Visible Emission	Urea Granulator	0	%	good combustion practices and wet scrubber
Iowa Fertilizer Company	IA-0105	10/26/2012	Visible Emission	Urea Granulator	0	% opacity	Wet Scrubber
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Urea Granulator	0.05	lb/ton of urea average of 3 stack tests	good combustion practices and wet scrubber
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Urea Granulator	38.9	tpy rolling 12 month total	good combustion practices and wet scrubber

Notes:
Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers and heaters >100 MMBtu/hr Included. (Process Type 12.31 (>100 MMBtu) and 11.31 (>250 MMBtu))
 Unit 44 - Package Boiler
 Unit 48 - Package Boiler
 Unit 49 - Package Boiler

Process Code	Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	TPM10	natural gas-fired auxiliary boilers EU 012A and EU 012B	7.6	LB/MMCF	shall combust natural gas
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	TPM10	natural gas-fired auxiliary boilers EU 012A and EU 012B	1877.39	MMCF TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	TPM2.5	natural gas-fired auxiliary boilers EU 012A and EU 012B	7.6	LB/MMCF	shall combust natural gas
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	TPM2.5	natural gas-fired auxiliary boilers EU 012A and EU 012B	1877.39	MMCF TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	natural gas-fired auxiliary boilers EU 012A and EU 012B	59.61	TON/MMCF	The natural gas-fired auxiliary boilers shall combust natural gas; shall be designed to achieve a minimum 80% thermal efficiency (HHV); shall be equipped with the following energy efficient design features: air inlet controls, heat recovery, condensate recovery, and blow down heat recovery.
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO2e	natural gas-fired auxiliary boilers EU 012A and EU 012B	1877.39	MMCF TWELVE CONSECUTIVE MONTH PERIOD	The natural gas-fired auxiliary boilers shall combust natural gas; shall be designed to achieve a minimum 80% thermal efficiency (HHV); shall be equipped with the following energy efficient design features: air inlet controls, heat recovery, condensate recovery, and blow down heat recovery.
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	natural gas-fired auxiliary boilers EU 012A and EU 012B	5.5	LB/MMCF, THREE-HOUR AVERAGE	shall combust natural gas
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	VOC	natural gas-fired auxiliary boilers EU 012A and EU 012B	1877.39	MMCF TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	natural gas-fired auxiliary boilers EU 012A and EU 012B	37.22	LB/MMCF, THREE-HOUR AVERAGE	shall combust natural gas
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	CO	natural gas-fired auxiliary boilers EU 012A and EU 012B	1877.39	MMCF TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	natural gas-fired auxiliary boilers EU 012A and EU 012B	20.4	LB/MMCF	shall combust natural gas
12.31	MIDWEST FERTILIZER COMPANY LLC	*IN-0324	5/6/2022	NOx	natural gas-fired auxiliary boilers EU 012A and EU 012B	1877.39	MMCF TWELVE CONSECUTIVE MONTH PERIOD	shall combust natural gas
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	TPM10	FCCU Charge Heater (EQT0163)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	TPM2.5	FCCU Charge Heater (EQT0163)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	CO2e	FCCU Charge Heater (EQT0163)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	VOC	FCCU Charge Heater (EQT0163)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	H2S	FCCU Charge Heater (EQT0163)	0		Comply with 40 CFR 60 Subpart J Fuel gas H2S <=162 ppmv (3-hour rolling average) Fuel gas H2S <=60 ppmv (365-day rolling average)
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	CO	FCCU Charge Heater (EQT0163)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	NOx	FCCU Charge Heater (EQT0163)	0.06	LB/MM BTU ANNUAL AVERAGE	LNB
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	SO2	FCCU Charge Heater (EQT0163)	0		Comply with 40 CFR 60 Subpart J Fuel gas H2S <=162 ppmv (3-hour rolling average) Fuel gas H2S <=60 ppmv (365-day rolling average)
12.31	GARYVILLE REFINERY	LA-0385	2/11/2021	TPM10	Reboilers/Heaters (EQT0164, EQT0181, EQT0376)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
12.31	GARYVILLE REFINERY	LA-0385	2/11/2021	TPM2.5	Reboilers/Heaters (EQT0164, EQT0181, EQT0376)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
12.31	GARYVILLE REFINERY	LA-0385	2/11/2021	CO2e	Reboilers/Heaters (EQT0164, EQT0181, EQT0376)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
12.31	GARYVILLE REFINERY	LA-0385	2/11/2021	VOC	Reboilers/Heaters (EQT0164, EQT0181, EQT0376)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers and heaters >100 MMBtu/hr Included. (Process Type 12.31 (>100 MMBtu) and 11.31 (>250 MMBtu))
 Unit 44 - Package Boiler
 Unit 48 - Package Boiler
 Unit 49 - Package Boiler

Process Code	Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
12.31	GARYVILLE REFINERY	LA-0385	2/11/2021	H2S	Reboilers/Heaters (EQT0164, EQT0181, EQT0376)	0		Comply with 40 CFR 60 Subpart J Fuel gas H2S <=162 ppmv (3-hour rolling average) Fuel gas H2S <=60 ppmv (365-day rolling average)
12.31	GARYVILLE REFINERY	LA-0385	2/11/2021	CO	Reboilers/Heaters (EQT0164, EQT0181, EQT0376)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
12.31	GARYVILLE REFINERY	LA-0385	2/11/2021	NOx	Reboilers/Heaters (EQT0164, EQT0181, EQT0376)	0.04	LB/MM BTU ANNUAL AVERAGE	LNB
12.31	GARYVILLE REFINERY	LA-0385	2/11/2021	SO2	Reboilers/Heaters (EQT0164, EQT0181, EQT0376)	0		Comply with 40 CFR 60 Subpart J Fuel gas H2S <=162 ppmv (3-hour rolling average) Fuel gas H2S <=60 ppmv (365-day rolling average)
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	TPM10	Crude Heaters (EQT0292)	0.0075	LB/MM BTU ANNUAL AVERAGE	Proper design and good engineering practices Fueled by refinery fuel gas and natural gas
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	CO2e	Crude Heaters (EQT0292)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	VOC	Crude Heaters (EQT0292)	0.0015	LB/MM BTU ANNUAL AVERAGE	Proper design and good engineering practices Fueled by refinery fuel gas and natural gas
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	H2S	Crude Heaters (EQT0292)	0		Total Sulfur in fuel gas <= 40 ppmv and H2S in fuel gas <= 25 ppmv (annual average) based on monthly fuel gas sampling for sulfur plus CEMS weekly H2S average
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	CO	Crude Heaters (EQT0292)	0.02	LB/MM BTU ANNUAL AVERAGE	Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	NOx	Crude Heaters (EQT0292)	0.0125	LB/MM BTU ANNUAL AVERAGE	LNB + SCR
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	SO2	Crude Heaters (EQT0292)	0		Fueled by natural gas and/or refinery fuel gas Total Sulfur in fuel gas <= 40 ppmv and H2S in fuel gas <= 25 ppmv (annual average) based on monthly fuel gas sampling for sulfur plus CEMS weekly H2S average
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	TPM10	Charge Heaters (EQT0377, EQT0378)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	TPM2.5	Charge Heaters (EQT0377, EQT0378)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	CO2e	Charge Heaters (EQT0377, EQT0378)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	VOC	Charge Heaters (EQT0377, EQT0378)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	H2S	Charge Heaters (EQT0377, EQT0378)	0		Total Sulfur in fuel gas <= 40 ppmv and H2S in fuel gas <= 25 ppmv (annual average) based on monthly fuel gas sampling for sulfur plus CEMS weekly H2S average
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	CO	Charge Heaters (EQT0377, EQT0378)	0		Comply with work practice standards of 40 CFR 63 Subpart DDDDD
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	NOx	Charge Heaters (EQT0377, EQT0378)	0.06	LB/MM BTU ANNUAL AVERAGE	LNB
11.31	GARYVILLE REFINERY	LA-0385	2/11/2021	SO2	Charge Heaters (EQT0377, EQT0378)	0		Total Sulfur in fuel gas <= 40 ppmv and H2S in fuel gas <= 25 ppmv (annual average) based on monthly fuel gas sampling for sulfur plus CEMS weekly H2S average
12.31	PETMIN USA INCORPORATED	OH-0383	7/17/2020	CO2e	Process gas heater (P001)	70203	LB/H	Good combustion practices and the use of natural gas
12.31	PETMIN USA INCORPORATED	OH-0383	7/17/2020	CO2e	Process gas heater (P001)	307490	T/YR PER ROLLING 12 MONTH PERIOD	Good combustion practices and the use of natural gas
12.31	PETMIN USA INCORPORATED	OH-0383	7/17/2020	CO	Process gas heater (P001)	11.17	LB/H	Good combustion practices and the use of natural gas
12.31	PETMIN USA INCORPORATED	OH-0383	7/17/2020	CO	Process gas heater (P001)	48.92	T/YR PER ROLLING 12 MONTH PERIOD	Good combustion practices and the use of natural gas
12.31	PETMIN USA INCORPORATED	OH-0383	7/17/2020	NOx	Process gas heater (P001)	18.88	LB/H	Low NOX burners, use of natural gas and good combustion practices
12.31	PETMIN USA INCORPORATED	OH-0383	7/17/2020	NOx	Process gas heater (P001)	82.71	T/YR PER ROLLING 12 MONTH PERIOD	Low NOX burners, use of natural gas and good combustion practices
12.31	MONT BELVIEU NGL FRACTIONATION UNIT	TX-0886	3/31/2020	VOC	HOT OIL HEATERS	0.002	LB/MMBTU	clean fuel, good combustion practices
12.31	MONT BELVIEU NGL FRACTIONATION UNIT	TX-0886	3/31/2020	NOx	HOT OIL HEATERS	0.01	LB/MMBTU, HOURLY	Low-NOx burners and selective catalytic reduction (SCR)

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers and heaters >100 MMBtu/hr Included. (Process Type 12.31 (>100 MMBtu) and 11.31 (>250 MMBtu))
 Unit 44 - Package Boiler
 Unit 48 - Package Boiler
 Unit 49 - Package Boiler

Process Code	Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
12.31	MONT BELVIEU NGL FRACTIONATION UNIT	TX-0886	3/31/2020	NOx	HOT OIL HEATERS	0.006	LB/MMBTU ANNUAL	Low-NOx burners and selective catalytic reduction (SCR)
12.31	MONT BELVIEU NGL FRACTIONATION UNIT	TX-0886	3/31/2020	NOx	HOT OIL HEATERS MSS	0.05	LB/MMBTU	LIMITED MSS OPERATIONS
12.31	TEXAS CITY CHEMICAL PLANT	*TX-0913	9/27/2021	CO2e	BOILERS	0		Good combustion practices, natural gas
12.31	TEXAS CITY CHEMICAL PLANT	*TX-0913	9/27/2021	CO	BOILERS	50	PPMV, 3% O2	Good combustion practices, natural gas
12.31	TEXAS CITY CHEMICAL PLANT	*TX-0913	9/27/2021	FPM2.5	BOILERS	1.38	LB/HR/BOILER	Good combustion practices, natural gas
	Venture Global Calcasieu Pass, LLC - Calcasieu Pass LNG Project	LA-0331 (draft)	9/21/2018, updated 2/19/2019	NOx	Hot Oil Heaters (HOH1 to HOH6) (115 MMBtu/hr)	0.038	lb/MMBtu 3-hr average	Ultra Low NOx Burners and Good Combustion Practices (BACT-PSD NSPS)
	Venture Global Calcasieu Pass, LLC - Calcasieu Pass LNG Project	LA-0331 (draft)	9/21/2018, updated 2/19/2019	CO	Hot Oil Heaters (HOH1 to HOH6) (115 MMBtu/hr)	0.082	lb/MMBtu 3-hr average	Exclusive Combustion of Fuel Gas and Good Combustion Practices (BACT-PSD NSPS)
	Venture Global Calcasieu Pass, LLC - Calcasieu Pass LNG Project	LA-0331 (draft)	9/21/2018, updated 2/19/2019	TPM10	Hot Oil Heaters (HOH1 to HOH6) (115 MMBtu/hr)	0.0075	lb/MMBtu 3-hr average	Exclusive Combustion of Fuel Gas and Good Combustion Practices (BACT-PSD NSPS)
	Venture Global Calcasieu Pass, LLC - Calcasieu Pass LNG Project	LA-0331 (draft)	9/21/2018, updated 2/19/2019	TPM2.5	Hot Oil Heaters (HOH1 to HOH6) (115 MMBtu/hr)	0.0075	lb/MMBtu 3-hr average	Exclusive Combustion of Fuel Gas and Good Combustion Practices (BACT-PSD NSPS)
	Venture Global Calcasieu Pass, LLC - Calcasieu Pass LNG Project	LA-0331 (draft)	9/21/2018, updated 2/19/2019	SO2	Hot Oil Heaters (HOH1 to HOH6) (115 MMBtu/hr)	0.0006	lb/MMBtu 3-hr average	Exclusive Use of Low Sulfur Fuel Gas and Proper Engineering Practices (BACT-PSD NSPS)
	Venture Global Calcasieu Pass, LLC - Calcasieu Pass LNG Project	LA-0331 (draft)	9/21/2018, updated 2/19/2019	VOC	Hot Oil Heaters (HOH1 to HOH6) (115 MMBtu/hr)	0.0054	lb/MMBtu 3-hr average	Proper Equipment Design and Operation, Good Combustion Practices, and Exclusive Combustion of Fuel Gas (BACT-PSD NSPS)
	Venture Global Calcasieu Pass, LLC - Calcasieu Pass LNG Project	LA-0331 (draft)	9/21/2018, updated 2/19/2019	CO2e	Hot Oil Heaters (HOH1 to HOH6) (115 MMBtu/hr)	354456	tons/year	Exclusive Use of Low Carbon Fuel Gas, Good Combustion Practices, Good Operation and Maintenance Practices and Insulation (BACT Limit based on Annual Total for 6 Heaters. 40 CFR Subpart Dc) (BACT-PSD NSPS)
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	TPM (all PM is assumed to be PM2.5 or less)	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	0.008	lbs/MMBtu	Good combustion practices, use of natural gas.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	TPM (all PM is assumed to be PM2.5 or less)	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	0.87	lb/hr	Good combustion practices, use of natural gas.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	TPM (all PM is assumed to be PM2.5 or less)	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	1.99	tons/year	Good combustion practices at all times boilers are in operation, use of natural gas. Annual emissions are based on 512,140 mmBtu/yr.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	Sulfuric Acid	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	0.0001	lbs/MMBtu	Use of natural gas.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	Sulfuric Acid	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	0.02	lb/hr	Use of natural gas.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	Sulfuric Acid	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	0.03	tons/year	Use of natural gas. Annual emissions are based on 512,140 mmBtu/yr.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	NOx	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	0.011	lb/MMBtu	Low NOx burners and good combustion practices. Annual emissions are based on 512,140 mmBtu/yr.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	NOx	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	1.23	lb/hour	Low NOx burners and good combustion practices.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	NOx	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	2.82	tons/year	Low NOx burners and good combustion practices.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	CO	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	0.037	lb/MMBtu	Good combustion practices at all times boilers are in operation, must only combust natural gas. Annual emissions are based on 512,140 mmBtu/yr.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	CO	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	4.14	lb/hour	Good combustion practices.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	CO	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	9.47	tons/year	Good combustion practices, use of natural gas. Annual emissions are based on 512,140 mmBtu/yr.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	VOC	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	0.008	lb/MMBtu	Good combustion practices, use of natural gas.
	ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	VOC	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	0.9	lb/hour	Good combustion practices, use of natural gas.

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart
RBLC Search Summary

Search: "boiler","heater" - All Results for boilers and heaters >100 MMBtu/hr Included. (Process Type 12.31 (>100 MMBtu) and 11.31 (>250 MMBtu))

Unit 44 - Package Boiler

Unit 48 - Package Boiler

Unit 49 - Package Boiler

Process
Code

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	VOC	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	2.05	tons/year	Good combustion practices, use of natural gas. Annual emissions are based on 512,140 mmBtu/yr.
ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	CO2e	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	14768	lb/hour	Use of natural gas.
ESC Brooke County Power I, LLC	WV-0032 (draft)	9/18/2018 (draft) updated 1/2/2019	CO2e	Auxiliary Boiler (111.90 MMBtu/hr - Natural Gas/Ethane)	33790	tons/year	Use of natural gas. Annual emissions are based on 512,140 mmBtu/yr.
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	NOx	Auxiliary Boiler (902 mmcf/year)	0.011	lb/MMBtu corrected to 3% O2	Low NOx Burners (Annual limit of 5.1 tons/yr on a 12-month rolling total. Compliance based on stack test and annual fuel throughput) (BACT-PSD NSPS SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	NOx	Auxiliary Boiler (902 mmcf/year)	1.2	lb/hr	Low NOx Burners (Annual limit of 5.1 tons/yr on a 12-month rolling total. Compliance based on stack test and annual fuel throughput) (BACT-PSD NSPS SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	CO	Auxiliary Boiler (902 mmcf/year)	0.037	lb/MMBtu	Good Combustion Practices and Clean Fuel (Compliance based on stack test. Annual limit 17.1 tons/year base on fuel throughput.)(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	CO	Auxiliary Boiler (902 mmcf/year)	3.9	lb/hr	Good Combustion Practices and Clean Fuel (Compliance based on stack test. Annual limit 17.1 tons/year base on fuel throughput.)(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	TPM10	Auxiliary Boiler (902 mmcf/year)	0.8	lb/hr	Good Combustion Practices and the Use of Pipeline Quality Natural Gas with a Maximum Sulfur Content of 0.4 gr/100 scf on a 12-month rolling avg.(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	TPM10	Auxiliary Boiler (902 mmcf/year)	3.3	tons/year 12-month rolling total	Good Combustion Practices and the Use of Pipeline Quality Natural Gas with a Maximum Sulfur Content of 0.4 gr/100 scf on a 12-month rolling avg.(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	TPM2.5	Auxiliary Boiler (902 mmcf/year)	0.8	lb/hr	Good Combustion Practices and the Use of Pipeline Quality Natural Gas with a Maximum Sulfur Content of 0.4 gr/100 scf on a 12-month rolling avg.(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	TPM2.5	Auxiliary Boiler (902 mmcf/year)	3.3	tons/year 12-month rolling total	Good Combustion Practices and the Use of Pipeline Quality Natural Gas with a Maximum Sulfur Content of 0.4 gr/100 scf on a 12-month rolling avg.(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	SO2	Auxiliary Boiler (902 mmcf/year)	0.0012	lb/MMBtu	The Use of Pipeline Quality Natural Gas with a Maximum Sulfur Content of 0.4 gr/100 scf on a 12-month rolling avg. (Compliance based on compliance with the fuel sulfur limit)(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	SO2	Auxiliary Boiler (902 mmcf/year)	0.6	tons/year 12-month rolling avg	The Use of Pipeline Quality Natural Gas with a Maximum Sulfur Content of 0.4 gr/100 scf on a 12-month rolling avg. (Compliance based on compliance with the fuel sulfur limit)(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	Sulfuric Acid (mist, vapors, etc)	Auxiliary Boiler (902 mmcf/year)			The Use of Pipeline Quality Natural Gas with a Maximum Sulfur Content of 0.4 gr/100 scf on a 12-month rolling avg. (Compliance based on compliance with the fuel sulfur content)(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	VOC	Auxiliary Boiler (902 mmcf/year)	0.005	lb/MMBtu	Good Combustion Practices(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	VOC	Auxiliary Boiler (902 mmcf/year)	2.3	tons/year 12-month rolling avg	Good Combustion Practices(BACT-PSD SIP)
Novi Energy - C4GT, LLC	VA-0328 (draft)	4/26/2018, updated 11/16/2018	CO2e	Auxiliary Boiler (902 mmcf/year)	53863	tons/year 12-month rolling total	Use of Natural Gas and High Efficiency Design and Operation(BACT-PSD SIP)

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart
RBLC Search Summary

Search: "boiler","heater" - All Results for boilers and heaters >100 MMBtu/hr Included. (Process Type 12.31 (>100 MMBtu) and 11.31 (>250 MMBtu))

Unit 44 - Package Boiler

Unit 48 - Package Boiler

Unit 49 - Package Boiler

Process
Code

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Targa - Channel View Terminal	TX-0835	4/13/2018, updated 2/19/2019	VOC	Crude Process Heaters (100 MMBtu/hr)	0.0013	lb/MMBtu	Good Combustion (Note: Process Type says Refinery Flares) (LAER NSPS)
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017, updated 3/8/2018	CO	EUAUXBOILER (Auxiliary Boiler) (182 MMBtu/hr)	0.04	lb/MMBtu	Good Combustion Practices (Catalytic Reduction not economically feasible)(BACT-PSD SIP)
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017, updated 3/8/2018	NOx	EUAUXBOILER (Auxiliary Boiler) (182 MMBtu/hr)	0.04	lb/MMBtu 30 day rolling avg	LNB that incorporate intern (within the burner) FGR and Good Combustion Practices (70% control efficiency) (SCR not economically feasible)(BACT-PSD SIP)
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017, updated 3/8/2018	FPM	EUAUXBOILER (Auxiliary Boiler) (182 MMBtu/hr)	0.005	lb/MMBtu	Good Combustion Practices (Add-on controls not economically feasible)(BACT-PSD)
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017, updated 3/8/2018	TPM10	EUAUXBOILER (Auxiliary Boiler) (182 MMBtu/hr)	0.0075	lb/MMBtu	Good Combustion Practices (Add-on controls not economically feasible)(BACT-PSD)
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017, updated 3/8/2018	TPM2.5	EUAUXBOILER (Auxiliary Boiler) (182 MMBtu/hr)	0.0075	lb/MMBtu	Good Combustion Practices (Add-on controls not economically feasible)(BACT-PSD)
Filer City Station Limited Partnership - Filer City Station	MI-0427	11/17/2017, updated 3/8/2018	CO2e	EUAUXBOILER (Auxiliary Boiler) (182 MMBtu/hr)	93346	tons/year 12-month roll time period	Good Combustion Practices (Add-on controls not economically feasible)(BACT-PSD)
Praxair Inc. - Praxair Clear Lake	TX-0830	10/20/2017, updated 2/19/2019	CO	HyCO Heater (180 MMBtu/hr)	50	PPMVD@3% O2	The Use of gaseous fuel and good combustion practices (BACT-PSD NSPS)
Praxair Inc. - Praxair Clear Lake	TX-0830	10/20/2017, updated 2/19/2019	CO2e	HyCO Heater (180 MMBtu/hr)	1148305	tons/year	Annual tune ups. Emissions are based on a plantwide grouped limit(BACT-PSD NSPS)
Praxair Inc. - Praxair Clear Lake Plant	TX-0827	10/19/2017, updated 11/2/2017	CO	HyCO Heater (180 MMBtu/hr)	50	PPMVD@3% O2	The Use of gaseous fuel and good combustion practices(BACT-PSD NSPS)
Praxair Inc. - Praxair Clear Lake Plant	TX-0827	10/19/2017, updated 11/2/2017	CO2e	HyCO Heater (180 MMBtu/hr)	1148305	tons/year	Annual tune ups. Emissions are based on a plantwide grouped limit(BACT-PSD NSPS)
Agrium US, Inc	TX-0814	1/5/2017 (draft)	CO2e	Package Boiler 1 (240 MMBtu/hr)	123059	tpy	Good Engineering Practices
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	TPM	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	1.9	lb/MMcf 3 hour average	Proper design and good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	TPM	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	1877.39	MMcf per 12 consecutive months	Proper design and good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	PM10	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	7.6	lb/MMcf 3 hour average	Proper design and good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	PM10	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	1877.39	MMcf per 12 consecutive months	Proper design and good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	PM2.5	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	7.6	lb/MMcf 3 hour average	Proper design and good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	PM2.5	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	1877.39	MMcf per 12 consecutive months	Proper design and good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	NOx	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	20.4	lb/MMcf 3 hour average	Low NOx burners with flue gas recirculation and good combustion practices, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	NOx	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	1877.39	MMcf per 12 consecutive months	Low NOx burners with flue gas recirculation and good combustion practices, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	CO	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	37.22	lb/MMcf 3 hour average	Good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers and heaters >100 MMBtu/hr Included. (Process Type 12.31 (>100 MMBtu) and 11.31 (>250 MMBtu))
 Unit 44 - Package Boiler
 Unit 48 - Package Boiler
 Unit 49 - Package Boiler

Process
Code

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	CO	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	1877.39	MMcf per 12 consecutive months	Good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	VOC	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	5.5	lb/MMcf 3 hour average	Good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	VOC	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	1877.39	MMcf per 12 consecutive months	Good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	CO2	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	59.61	ton/MMcf 3 hour average	Good combustion practices at all times boilers are in operation, must only combust natural gas (218.6 MMBtu/hr)
Midwest Fertilizer Company LLC	IN-0263 (draft)	3/23/17 (draft), updated 7/10/17	CO2	Natural Gas Auxiliary Boilers (EU-012A, EU-012B, EU-012C)	1877.39	MMcf per 12 consecutive months	Good combustion practices at all times boilers are in operation, must only combust natural gas, shall be designed to achieve a minimum 80% thermal efficiency limit, each shall be equipped with the energy efficiency design features (1) air inlet controls, (2) heat recovery, (3) condensate recovery, (4) blow down heat recovery (218.6 MMBtu/hr)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	CO	EUAUXBOILER (Auxiliary Boiler)	0.04	lb/MMBtu Test protocol will specify avg time	SIP - Good combustion practices (182 MMBtu/hr)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	NOx	EUAUXBOILER (Auxiliary Boiler)	0.04	lb/MMBtu 30-day rolling avg time period	NSPS, SIP - Low NOx burners/Flue gas recirculation and good combustion practices. (182 MMBtu/hr)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	FPM	EUAUXBOILER (Auxiliary Boiler)	0.005	lb/MMBtu Test protocol will specify avg time	Good combustion practices (182 MMBtu/hr)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	TPM10	EUAUXBOILER (Auxiliary Boiler)	1.36	lb/hr hourly, test protocol	SIP - Good combustion practices (182 MMBtu/hr)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	TPM2.5	EUAUXBOILER (Auxiliary Boiler)	1.36	lb/hr hourly, test protocol	Good combustion practices (182 MMBtu/hr)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	VOC	EUAUXBOILER (Auxiliary Boiler)	0.004	lb/MMBtu Test protocol will specify avg time	Good combustion practices (182 MMBtu/hr)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	SO2	EUAUXBOILER (Auxiliary Boiler)	0.6	lb/MMscf Based on Fuel Receipt Records	Good combustion practices and the use of pipeline quality natural gas (182 MMBtu/hr)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	SO2	EUAUXBOILER (Auxiliary Boiler)	2000	gr/MMscf Based upon Fuel Receipts	NSPS, SIP - Good combustion practices and the use of pipeline quality natural gas.(2,000 grains of sulfur per MMscf. The natural gas material limit of 2,000 grains of sulfur per MMscf is what the emission factor is based upon) (182 MMBtu/hr)
Indeck Niles, LLC	MI-0423 (draft)	1/4/2017, 7/25/17 update	CO2e	EUAUXBOILER (Auxiliary Boiler)	93346	tpy 12-month rolling time period	Energy efficiency measures and the use of a low carbon fuel (pipeline quality natural gas). (182 MMBtu/hr)
Rextac, LLC - Odessa Petrochemical Plant	TX-0813 (draft)	11/22/2016, 12/1/16 update	VOC	Boilers	0.0005	lb/MMBtu	NSPS Db - Best combustion practices (2 boilers - 223 Mmbtu/hr)
Rextac, LLC - Odessa Petrochemical Plant	TX-0813 (draft)	11/22/2016, 12/1/16 update	CO2e	Boilers	63796	tpy	MACT DDDDD - Minimul thermal design efficiency of 75%
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	PM10	Auxiliary Boilers and Superheaters	No Numeric Limit	No Numeric Limit	Good engineering design and proper operation (Supplement fuel: fuel gas Boilers: 225 MM BTU/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	PM2.5	Auxiliary Boilers and Superheaters	No Numeric Limit	No Numeric Limit	Good engineering design and proper operation (Supplement fuel: fuel gas Boilers: 225 MM BTU/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	SO2	Auxiliary Boilers and Superheaters	No Numeric Limit	No Numeric Limit	Fuel gases and/or pipeline quality natural gas (Supplement fuel: fuel gas Boilers: 225 MM BTU/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	NOx	Auxiliary Boilers and Superheaters	0.015	lbs/MMBtu 30 rolling avg, except SCR, SU or Maint	SCR (Supplement fuel: fuel gas Boilers: 225 MM BTU/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	CO	Auxiliary Boilers and Superheaters	No Numeric Limit	No Numeric Limit	Good engineering design and good combustion practices (Supplement fuel: fuel gas Boilers: 225 MM BTU/hr each)
Lake Charles Methanol, LLC	LA-0305	6/30/16, 4/26/17 update	CO2e	Auxiliary Boilers and Superheaters	No Numeric Limit	No Numeric Limit	Good equipment design and good combustion practices (Supplement fuel: fuel gas Boilers: 225 MM BTU/hr each)

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart
RBLC Search Summary

Search: "boiler","heater" - All Results for boilers and heaters >100 MMBtu/hr Included. (Process Type 12.31 (>100 MMBtu) and 11.31 (>250 MMBtu))

Unit 44 - Package Boiler

Unit 48 - Package Boiler

Unit 49 - Package Boiler

Process
Code

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Magnolia LNG Facility	LA-0307	3/21/16, 4/28/17 update	CO2e	Auxiliary Boilers	No Numeric Limit	No Numeric Limit	Good combustion/operating/maintenance practices and fueled by natural gas (171 MMBtu/hr)
Magnolia LNG Facility	LA-0307	3/21/16, 4/28/17 update	TPM10	Auxiliary Boilers	No Numeric Limit	No Numeric Limit	Good combustion practices (171 MMBtu/hr)
Magnolia LNG Facility	LA-0307	3/21/16, 4/28/17 update	TPM2.5	Auxiliary Boilers	No Numeric Limit	No Numeric Limit	Good combustion practices (171 MMBtu/hr)
Magnolia LNG Facility	LA-0307	3/21/16, 4/28/17 update	NOx	Auxiliary Boilers	No Numeric Limit	No Numeric Limit	Low NOx Burners (171 MMBtu/hr)
Magnolia LNG Facility	LA-0307	3/21/16, 4/28/17 update	CO	Auxiliary Boilers	No Numeric Limit	No Numeric Limit	Good combustion practices (171 MMBtu/hr)
Magnolia LNG Facility	LA-0307	3/21/16, 4/28/17 update	VOC	Auxiliary Boilers	No Numeric Limit	No Numeric Limit	Good combustion practices (171 MMBtu/hr)
Tennessee Valley Authority	TN-0162 (draft)	4/19/16, 5/19/16 update	TPM	Two Natural Gas-Fired Auxiliary Boilers	0.008	lb/MMBtu	Good combustion design and practices (450 MMBtu/hr each)
Tenaska PA Partners LLC - Tenaska PA Partners/Westmoreland Gen Fac	PA-0306 (draft)	2/12/16, 7/12/17 update	TPM2.5	245 MMBtu natural gas fired Auxiliary boiler	0.0075	lb/MMBtu 3 hr avg	NSPS - Good combustion practices. Total fuel usage of the auxiliary boiler shall not exceed 1052 MMsch/yr on a 12-month rolling basis.
Tenaska PA Partners LLC - Tenaska PA Partners/Westmoreland Gen Fac	PA-0306 (draft)	2/12/16, 7/12/17 update	TPM2.5	245 MMBtu natural gas fired Auxiliary boiler	4	tpy	NSPS - Good combustion practices. Total fuel usage of the auxiliary boiler shall not exceed 1052 MMsch/yr on a 12-month rolling basis.
Tenaska PA Partners LLC - Tenaska PA Partners/Westmoreland Gen Fac	PA-0306 (draft)	2/12/16, 7/12/17 update	Sulfuric Acid (mist, vapors, etc)	245 MMBtu natural gas fired Auxiliary boiler	0.0049	tpy	NSPS - Good combustion practices. Total fuel usage of the auxiliary boiler shall not exceed 1052 MMsch/yr on a 12-month rolling basis.
Tenaska PA Partners LLC - Tenaska PA Partners/Westmoreland Gen Fac	PA-0306 (draft)	2/12/16, 7/12/17 update	VOC	245 MMBtu natural gas fired Auxiliary boiler	0.0054	lb/MMBtu	Good combustion practices. Total fuel usage of the auxiliary boiler shall not exceed 1052 MMsch/yr on a 12-month rolling basis.
Tenaska PA Partners LLC - Tenaska PA Partners/Westmoreland Gen Fac	PA-0306 (draft)	2/12/16, 7/12/17 update	VOC	245 MMBtu natural gas fired Auxiliary boiler	2.89	tpy	Good combustion practices. Total fuel usage of the auxiliary boiler shall not exceed 1052 MMsch/yr on a 12-month rolling basis.
American Municipal Power Generating Station	OH-0310	10/8/2009	CO	Auxiliary Boiler	12.6	lbs/hr	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	CO	Auxiliary Boiler	5.52	tons/year per rolling 12 months	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	NOx	Auxiliary Boiler	21	lbs/hr	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	NOx	Auxiliary Boiler	9.2	tons/year per rolling 12 months	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	PM10	Auxiliary Boiler	1.14	lbs/hr	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	PM10	Auxiliary Boiler	0.5	tons/year per rolling 12 months	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	SO2	Auxiliary Boiler	0.09	lbs/hr	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	SO2	Auxiliary Boiler	0.04	tons/year per rolling 12 months	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	Visible Emission	Auxiliary Boiler	10	% opacity as a 6 minute average	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	VOC	Auxiliary Boiler	0.83	lbs/hr	Unknown
American Municipal Power Generating Station	OH-0310	10/8/2009	VOC	Auxiliary Boiler	0.36	tons/year per rolling 12 months	Unknown
Calpine Construction Finance Co. LP Amella Energy Center	TX-0386	3/26/2002	CO	Auxiliary Boiler	13.9	lbs/hr	Unknown
Calpine Construction Finance Co. LP Amella Energy Center	TX-0386	3/26/2002	CO	Auxiliary Boiler	0.08	lb/MMBtu	Unknown
Calpine Construction Finance Co. LP Amella Energy Center	TX-0386	3/26/2002	H2SO4	Auxiliary Boiler	0.129	lbs/hr	Unknown
Calpine Turner Energy Center, LLC	OR-0046	1/6/2005	PM10	Auxiliary Boiler	No numeric limit	No numeric limit	use of natural gas
Calpine Turner Energy Center, LLC	OR-0046	1/6/2005	VOC	Auxiliary Boiler	0.0044	lb/MMBtu 3-hr block	Oxidation Catalyst
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CH4	Boilers	0.0023	lb/MMBtu average of 3 stack tests	proper operation and use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CH4	Auxiliary Boiler	0.0023	lb/MMBtu average of 3 stack tests	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Boilers	0.0013	lb/MMBtu average of 3 stack tests	oxidation catalyst
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO	Boilers	2.6	tpy rolling 12 month total	oxidation catalyst
Iowa Fertilizer Company	IA-0105	10/26/2012	CO	Auxiliary Boiler	0.0013	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	CO	Auxiliary Boiler	0.57	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/26/2013	CO	Natural gas fired boilers	37.22	lb/MMcf 3 hour average	proper burning design, good combustion practices
Rocky Mountain Energy Center, LLC	CO-0052	8/11/2002	CO	Auxiliary Boiler	0.039	lb/MMBtu	Good combustion control practices
Rocky Mountain Energy Center, LLC	CO-0052	8/11/2002	CO	Auxiliary Boiler	70%	Reduction	Good combustion control practices
Southeast Idaho Energy, LLC Power County Advanced Energy C	ID-0017	2/10/2009	CO	250 MMBTU/H package boiler	0.074	lb/MMBtu	Good combustion practices
Southeast Idaho Energy, LLC Power County Advanced Energy C	ID-0017	2/10/2009	CO	250 MMBTU/H package boiler	18.5	lb/hr	Good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2	Boilers	117	lb/MMBtu average of 3 stack tests	proper operation and use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	CO2	Auxiliary Boiler	117	lb/MMBtu rolling 30 day average	Good Combustion Practices

Appendix B
KNO Restart - RBLC Summary

KNO Restart

RBLC Search Summary

Search: "boiler","heater" - All Results for boilers and heaters >100 MMBtu/hr Included. (Process Type 12.31 (>100 MMBtu) and 11.31 (>250 MMBtu))

Unit 44 - Package Boiler

Unit 48 - Package Boiler

Unit 49 - Package Boiler

Process
Code

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Ohio Valley Resources, LLC	TBD	9/26/2013	CO2	Natural gas fired boilers	59.61	ton/MMcf 3 hour average	proper burning design, good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2e	Boilers	234168	tpy rolling 12 month total	proper operation and use of natural gas
Forsyth Energy Projects, LLC Forsyth Energy Plant	NC-0101	9/29/2005	CO	Auxiliary Boiler	9.08	lbs/hr based on 3-hr average	Low-NOx Burners, good combustion control and clean bu
Forsyth Energy Projects, LLC Forsyth Energy Plant	NC-0101	9/29/2005	NOx	Auxiliary Boiler	15.13	lbs/hr based on 3-hr average	Low-NOx Burners, good combustion control and clean bu
Forsyth Energy Projects, LLC Forsyth Energy Plant	NC-0101	9/29/2005	PM10	Auxiliary Boiler	0.82	lbs/hr based on 3-hr average	Low-NOx Burners, good combustion control and clean bu
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Auxiliary Boiler	0.0125	lb/MMBtu rolling 30 day average	LNB and FGR
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Auxiliary Boiler	5.52	tons/year rolling 12 month total	LNB and FGR
Ohio Valley Resources, LLC	TBD	9/26/2013	NOx	Natural gas fired boilers	20.4	lb/MMcf 24 hour average	Ultra Low NOx Burners and Flue Gas Recirculation
Rocky Mountain Energy Center, LLC.	CO-0052	8/11/2002	NOx	Auxiliary Boiler	0.038	lb/MMBtu	Operation is limited to 1900 hr/yr. Low NOx combustion system.
Rocky Mountain Energy Center, LLC.	CO-0052	8/11/2002	NOx	Auxiliary Boiler	80%	Reduction	Operation is limited to 1900 hr/yr. Low NOx combustion system.
Southeast Idaho Energy, LLC Power County Advanced Energy C	ID-0017	2/10/2009	NOx	250 MMBTU/H package boiler	0.02	lb/MMBtu	Low-NOx Burners and FGR
Southeast Idaho Energy, LLC Power County Advanced Energy C	ID-0017	2/10/2009	NOx	250 MMBTU/H package boiler	5	lb/hr	Low-NOx Burners and FGR
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Boilers	0.0024	lb/MMBtu average of 3 stack tests	proper operation and use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Boilers	4.79	tpy rolling 12 month total	proper operation and use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Auxiliary Boiler	0.0024	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Auxiliary Boiler	1.06	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/26/2013	PM	Natural gas fired boilers	1.9	lb/MMcf 3 hour average	proper burning design, good combustion practices
Southeast Idaho Energy, LLC Power County Advanced Energy C	ID-0017	2/10/2009	PM	250 MMBTU/H package boiler	0.0052	lb/MMBtu	Good Combustion Practices
Southeast Idaho Energy, LLC Power County Advanced Energy C	ID-0017	2/10/2009	PM	250 MMBTU/H package boiler	1.3	lbs/hr	Good Combustion Practices
Liberty Generating Station	NJ-0043	3/28/2002	CO	Auxiliary Boiler	100	ppmvd @ 7% O2	CO catalyst
Liberty Generating Station	NJ-0043	3/28/2002	CO	Auxiliary Boiler	17.4	lb/hr	CO catalyst
Liberty Generating Station	NJ-0043	3/28/2002	NOx	Auxiliary Boiler	0.2	lb/MMBtu	SCR
Liberty Generating Station	NJ-0043	3/28/2002	NOx	Auxiliary Boiler	7.2	lbs/hr	SCR
Liberty Generating Station	NJ-0043	3/28/2002	PM	Auxiliary Boiler	1.6	lb/hr	unknown
Liberty Generating Station	NJ-0043	3/28/2002	PM	Auxiliary Boiler	0.008	lb/MMBtu	Unknown
Liberty Generating Station	NJ-0043	3/28/2002	PM10	Auxiliary Boiler	1.6	lb/hr	unknown
Liberty Generating Station	NJ-0043	3/28/2002	PM10	Auxiliary Boiler	0.008	lb/MMBtu	Unknown
Liberty Generating Station	NJ-0043	3/28/2002	SO2	Auxiliary Boiler	0.004	lb/MMBtu	None
Liberty Generating Station	NJ-0043	3/28/2002	SO2	Auxiliary Boiler	0.8	lbs/hr	None
Liberty Generating Station	NJ-0043	3/28/2002	VOC	Auxiliary Boiler	50	ppmvd @7% O2	CO catalyst
Liberty Generating Station	NJ-0043	3/28/2002	VOC	Auxiliary Boiler	1.6	lbs/hr	CO catalyst
Southeast Idaho Energy, LLC Power County Advanced Energy C	ID-0017	2/10/2009	PM	250 MMBTU/H package boiler	20%	Reduction	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Boilers	0.0024	lb/MMBtu average of 3 stack tests	proper operation and use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Boilers	4.79	tpy rolling 12 month total	proper operation and use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Auxiliary Boiler	0.0024	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Some facilities are not shown because they are not fertilizer prod	IA-0105	10/26/2012	PM10	Auxiliary Boiler	1.06	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/26/2013	PM10	Natural gas fired boilers	7.6	lb/MMcf 3 hour average	proper burning design, good combustion practices
Southeast Idaho Energy, LLC Power County Advanced Energy C	ID-0017	2/10/2009	PM10	250 MMBTU/H package boiler	0.0052	lb/MMBtu	Good Combustion Practices
Southeast Idaho Energy, LLC Power County Advanced Energy C	ID-0017	2/10/2009	PM10	250 MMBTU/H package boiler	1.3	lbs/hr	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Boilers	0.0024	lb/MMBtu average of 3 stack tests	proper operation and use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Boilers	4.79	tpy rolling 12 month total	proper operation and use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Auxiliary Boiler	0.0024	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Auxiliary Boiler	1.06	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/26/2013	PM2.5	Natural gas fired boilers	7.6	lb/MMcf 3 hour average	proper burning design, good combustion practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	Visible Emission	Boilers	0	%	proper operation and use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	Visible Emission	Auxiliary Boiler	0	% opacity	Good Combustion Practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Boilers	0.0014	lb/MMBtu average of 3 stack tests	proper operation and use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	VOC	Boilers	2.8	tpy rolling 12 month total	proper operation and use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	VOC	Auxiliary Boiler	0.0014	lb/MMBtu average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	VOC	Auxiliary Boiler	0.62	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/26/2013	VOC	Natural gas fired boilers	5.5	lb/MMcf 3 hour average	proper burning design, good combustion practices
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	NOx	WCR Heater	0.03	lb/MMBtu	Unknown
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	PM	Heaters	0.005	lb/MMBtu	Unknown
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	PM	Heater, Reboiler	0.005	lb/MMBtu	Unknown
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	PM	WCR Heater	0.005	lb/MMBtu	Unknown
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	PM	CCR Reactor	0.005	lb/MMBtu	Unknown

Appendix B
KNO Restart - RBLC Summary

KNO Restart

RBLC Search Summary

Search: "boiler","heater" - All Results for boilers and heaters >100 MMBtu/hr Included. (Process Type 12.31 (>100 MMBtu) and 11.31 (>250 MMBtu))

Unit 44 - Package Boiler

Unit 48 - Package Boiler

Unit 49 - Package Boiler

Process
Code

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
---------------	---------	-------------------	-----------	--------------	----------------	----------------------	--------------------

Notes:

Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.

Some facilities are not shown because they are not fertilizer production facilities. These units are not directly comparable because they are not natural gas fired.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "Flare" - Fertilizer Plants only
Unit 11 - Ammonia Tank Flare

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Front End Process Flare	0.37	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Front End Process Flare	3240.16	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Back end ammonia process vent flare	0.37	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Back end ammonia process vent flare	804.76	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	CO	Process Flare	No Numeric Limit	No Numeric Limit	Good combustion practices. Meet 40 CFR 60.18
United Wisconsin Grain Producers UWGP - Fuel Grade Ethanol Plant	WI-0204	8/14/2003	CO	Bypass Flare, Biomethanator	2.4	lbs/hr	Operation Limit: No more than 5040 hr/yr
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Ammonia Storage Flare	0.37	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	CO	Ammonia Storage Flare	No Numeric Limit	No Numeric Limit	Good combustion practices. Meet 40 CFR 60.18
Iowa Fertilizer Company	IA-0105	10/26/2012	CO2	Ammonia Flare	No Numeric Limit	No Numeric Limit	Work Practice/Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO2	Front End Process Flare	511.8	ton/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO2	Front End Process Flare	116.89	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO2	Back end ammonia process vent flare	116.89	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO2	Ammonia Storage Flare	52.02	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2e	Flares	No Numeric Limit	No Numeric Limit	Good operating practices & use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	CO2e	Flares	No Numeric Limit	No Numeric Limit	Good operating practices & use of natural gas
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	N2O	Flares	No Numeric Limit	No Numeric Limit	Good operating practices & use of natural gas
Iowa Fertilizer Company	IA-0105	10/26/2012	N2O	Ammonia Flare	No Numeric Limit	No Numeric Limit	Work Practice/Good Combustion Practices
Degussa Engineered Carbons Inc. Borger Carbon Black Plant	TX-0436	10/3/2002	NOx	Dryers, Boilers, Flare	0.1	lb/MMBtu	Good combustion practices and design
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Ammonia Flare	No Numeric Limit	No Numeric Limit	Work Practice/Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Front End Process Flare	0.068	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Front End Process Flare	595.47	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Back end ammonia process vent flare	0.068	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Back end ammonia process vent flare	624.94	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	NOx	Process Flare	No Numeric Limit	No Numeric Limit	Good combustion practices. Meet 40 CFR 60.19
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Ammonia Storage Flare	0.068	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Ammonia Storage Flare	125	lb/hr 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	NOx	Ammonia Storage Flare	No Numeric Limit	No Numeric Limit	Good combustion practices. Meet 40 CFR 60.19
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Flares	No Numeric Limit	No Numeric Limit	Good operating practices & use of natural gas
Ohio Valley Resources, LLC	TBD	9/25/2013	PM	Ammonia Storage Flare	0.0019	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM	Ammonia Storage Flare	No Numeric Limit	No Numeric Limit	Smokeless flare. Air or steam-assist only if unassisted flare produces smoke. Good combustion practices. Meet 40 CFR 60.21
Ohio Valley Resources, LLC	TBD	9/25/2013	PM10	Ammonia Storage Flare	0.0075	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Southeast Idaho Energy, LLC Power County Advanced Energy Center	ID-0017	2/10/2009	PM10	Ammonia Storage Flare	No Numeric Limit	No Numeric Limit	Smokeless flare. Air or steam-assist only if unassisted flare produces smoke. Good combustion practices. Meet 40 CFR 60.21
Ohio Valley Resources, LLC	TBD	9/25/2013	PM2.5	Ammonia Storage Flare	0.0075	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices
Iowa Fertilizer Company	IA-0105	10/26/2012	Visible Emissions	Ammonia Flare	0	%	Work Practice/Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	VOC	Ammonia Storage Flare	0.0054	lb/MMBtu 3 hour average	Proper flare design and good combustion practices; and process flaring minimization practices

Notes:
Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.

Appendix B KNO Restart - RBLC Summary

KNO Restart

RBLC Search Summary

Search: "Urea" - All Results Included

Unit 47 - Urea Loading

Unit 47a - Urea Transfer

Unit 47b - Urea Transfer

Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
PALLAS NITROGEN LLC	OH-0368	04/19/2017	Filterable PM	Granulated Urea Transfer Points with bin vents (P901)	0.005	GR/DSCF	Bin Vent Filter
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft)	PM	Truck and Rail Loading Operation (EU-021A)	0.15	lb/hr 3 hour average	Baghouse (4800 metric ton/day)
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft)	PM10	Truck and Rail Loading Operation (EU-021A)	0.15	lb/hr 3 hour average	Baghouse (4800 metric ton/day)
Midwest Fertilizer Company LLC	IN-0263	3/23/17 (draft)	PM2.5	Truck and Rail Loading Operation (EU-021A)	0.15	lb/hr 3 hour average	Baghouse (4800 metric ton/day)

CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Urea Loading	0.003	lb/ton average of 3 stack tests	Bin Vent Filter
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM	Urea Loading	5.48	tpy rolling 12 month total	Bin Vent Filter
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Granulated Urea Transfer	0.005	gr/dscf average of 3 stack tests	Bin Vent Filter
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Urea Loading	0.0011	lb/ton average of 3 stack tests	Bin Vent Filter
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM10	Urea Loading	2.01	tpy rolling 12 month total	Bin Vent Filter
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Granulated Urea Transfer	0.005	gr/dscf average of 3 stack tests	Bin Vent Filter
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Urea Loading	0.0011	lb/ton average of 3 stack tests	Bin Vent Filter
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	PM2.5	Urea Loading	1.97	tpy rolling 12 month total	Bin Vent Filter
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Granulated Urea Transfer	0.0013	gr/dscf average of 3 stack tests	Bin Vent Filter
CF Industries Nitrogen, LLC	IA-0106	7/12/2013	Visible Emissions	Urea Loading	0	%	Bin Vent Filter
Iowa Fertilizer Company	IA-0105	10/26/2012	Visible Emissions	Granulated Urea Transfer	0	% opacity	Bin Vent Filter

Notes:

Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "16.210 - combined cycle & cogen <25 MW" - All Results
Unit 55-Solar Turbines
Unit 56-Solar Turbines
Unit 57-Solar Turbines
Unit 58-Solar Turbines
Unit 59-Solar Turbines
Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
NORFOLK NAVAL SHIPYARD	VA-0333	12/9/2020	CO2e	Two (2) turbines - HRSG	117.1	lb/MMBtu	use of low carbon fuel and efficient power generation.
NORFOLK NAVAL SHIPYARD	VA-0333	12/9/2020	TPM10	Two (2) turbines - HRSG	0.011	lb/MMBtu	
NORFOLK NAVAL SHIPYARD	VA-0333	12/9/2020	TPM2.5	Two (2) turbines - HRSG	0.011	lb/MMBtu	
SABINE PASS LNG TERMINAL	LA-0375	9/17/2020	CO	Generator Turbines	25	ppm @ 15%O2 AT ALL LOAD	Good combustion practices and use od clean natural gas
SABINE PASS LNG TERMINAL	LA-0375	9/17/2020	NOx	Generator Turbines	150	ppm @ 15%O2 AND < 75% LOAD	Dry Low NOx and good combustion practices
Equistar Chemicals, LP - Westlake Facility	LA-0295	7/12/2016	NOx	Solar Titan 130 Gas Turbine with Unfired HRSG (3-08, EQT 323)	14.25	lb/hr hourly maximum	Dry low NOx combustor (SoLoNOx) and good combustion practices, including good equipment design, use of gaseous fuels for good mixing, and proper combustion techniques (159.46 MM BTU/HR) (Output power at generator: 14.117 MW) Turbine is subject to 40 CFR 60 Subpart KKKK. Good combustion practices shall include monitoring of the flue gas oxygen content, combustion air flow, fuel consumption, and flue gas temperature. These parameters shall be maintained within the manufacturer's recommended operating guidelines or within a range that is otherwise indicative of proper operation of the emissions unit.
Equistar Chemicals, LP - Westlake Facility	LA-0295	7/12/2016	NOx	Solar Titan 130 Gas Turbine with Unfired HRSG (3-08, EQT 323)	15	ppmv @ 15% O2 Annual Average	Dry low NOx combustor (SoLoNOx) and good combustion practices, including good equipment design, use of gaseous fuels for good mixing, and proper combustion techniques (159.46 MM BTU/HR) (Output power at generator: 14.117 MW) Turbine is subject to 40 CFR 60 Subpart KKKK. Good combustion practices shall include monitoring of the flue gas oxygen content, combustion air flow, fuel consumption, and flue gas temperature. These parameters shall be maintained within the manufacturer's recommended operating guidelines or within a range that is otherwise indicative of proper operation of the emissions unit.
Equistar Chemicals, LP - Westlake Facility	LA-0295	7/12/2016	VOC	Solar Titan 130 Gas Turbine with Unfired HRSG (3-08, EQT 323)	1.64	lb/hr hourly maximum	Good combustion practices, including good equipment design, use of gaseous fuels for good mixing, and proper combustion techniques consistent with the manufacturer's recommendations to maximize fuel efficiency and minize emissions. (159.46 MM BTU/HR) (Output power at generator: 14.117 MW) Turbine is subject to 40 CFR 60 Subpart KKKK. Good combustion practices shall include monitoring of the flue gas oxygen content, combustion air flow, fuel consumption, and flue gas temperature. These parameters shall be maintained within the manufacturer's recommended operating guidelines or within a range that is otherwise indicative of proper operation of the emissions unit. PSD permit requires an annual stack test for VOC. If VOC < 75% of the permit limit, the frequency of the testing may be reduced to once every 2 years. If result of any subsequent test exceeds 75% of the permit limit, resume annual testing.
Equistar Chemicals, LP - Westlake Facility	LA-0295	7/12/2016	VOC	Solar Titan 130 Gas Turbine with Unfired HRSG (3-08, EQT 323)	2.5	ppmv @ 15% O2 Annual Average	Good combustion practices, including good equipment design, use of gaseous fuels for good mixing, and proper combustion techniques consistent with the manufacturer's recommendations to maximize fuel efficiency and minize emissions. (159.46 MM BTU/HR) (Output power at generator: 14.117 MW) Turbine is subject to 40 CFR 60 Subpart KKKK. Good combustion practices shall include monitoring of the flue gas oxygen content, combustion air flow, fuel consumption, and flue gas temperature. These parameters shall be maintained within the manufacturer's recommended operating guidelines or within a range that is otherwise indicative of proper operation of the emissions unit. PSD permit requires an annual stack test for VOC. If VOC < 75% of the permit limit, the frequency of the testing may be reduced to once every 2 years. If result of any subsequent test exceeds 75% of the permit limit, resume annual testing.
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	NOx	Combustion Turbine with Duct Burner		ppmv @ 15% O2 1-hour block avg/excluding SS - ng firing	NSPS and SIP - Dry Low NOx Combustor & Selective Catalytic Reduction (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). NOx limits are determined as BACT under 310 CMR 7.02(8). NOx(firing NG): ≤0.0074 lb/MMBtu, ≤1.21 lb/hr(no duct firing), ≤1.51 lb/hr(with duct firing); during start-ups (≤3 hrs): ≤36.2 lb per event, during shutdowns (≤1 hr): ≤11.2 lb per event.
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	CO	Combustion Turbine with Duct Burner		ppmv @ 15% O2 1-hour block avg/excluding SS - ng firing	SIP - Oxidation Catalyst (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). CO limits are determined as BACT under 310 CMR 7.02(8). CO(firing NG): ≤0.0045 lb/MMBtu, ≤0.74 lb/hr(no duct firing), ≤0.92 lb/hr(with duct firing); during start-ups (≤3 hrs): ≤153.7 lb per event, during shutdowns (≤1 hr): ≤41.6 lb per event.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "16.210 - combined cycle & cogen <25 MW" - All Results
Unit 55-Solar Turbines
Unit 56-Solar Turbines
Unit 57-Solar Turbines
Unit 58-Solar Turbines
Unit 59-Solar Turbines
Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	VOC	Combustion Turbine with Duct Burner		ppmv @ 15% O2 1-hour block avg/excluding SS - ng firing 1.7	SIP - Oxidation Catalyst (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). VOC limits are determined as BACT under 310 CMR 7.02(8). VOC as CH4(firing NG): ≤0.0022 lb/MMBtu, ≤0.36 lb/hr(no duct firing), ≤0.45 lb/hr(with duct firing); during start-ups (≤3 hrs): ≤11.4 lb per event, during shutdowns (≤1 hr): ≤3.3 lb per event VOC as CH4.
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	SO2	Combustion Turbine with Duct Burner		ppmv @ 15% O2 1-hour block avg/excluding SS - ng firing 0.6	NSPS and SIP - clean fuels - using natural gas as primary fuel (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil as backup)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). SO2 limits are determined as BACT under 310 CMR 7.02(8). SO2(firing NG): ≤0.0029 lb/MMBtu, ≤0.48 lb/hr(no duct firing), ≤0.58 lb/hr(with duct firing); during start-ups (≤3 hrs): ≤1.8 lb per event, during shutdowns (≤1 hr): ≤0.6 lb per event.
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	Sulfuric Acid (mist)	Combustion Turbine with Duct Burner		ppmv @ 15% O2 1-hour block avg/excluding SS - ng firing 0.4	SIP - clean fuels - using natural gas as primary fuel (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil as backup)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). H2SO4 limits are determined as BACT under 310 CMR 7.02(8). H2SO4(firing NG): ≤0.0029lb/MMBtu, ≤0.47 lb/hr(no duct firing), ≤0.58 lb/hr(with duct firing); during start-ups (≤3 hrs): ≤1.8 lb per event, during shutdowns (≤1 hr): ≤0.6 lb per event.
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	Ammonia (NH3)	Combustion Turbine with Duct Burner		ppmv @ 15% O2 1-hour block avg/excluding SS - ng firing 2	SIP - no controls listed (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil as backup)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). NH3 limits are determined as BACT under 310 CMR 7.02(8). NH3(firing NG): ≤0.44 lb/hr(no duct firing), ≤0.55 lb/hr(with duct firing); NH3(turbine firing ULSD): ≤0.0029 lb/MMBtu, ≤0.46 lb/hr(no duct firing), ≤0.57 lb/hr(with duct firing).
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	Ammonia (NH3)	Combustion Turbine with Duct Burner		0.0027 lb/MMBtu 1-hour block avg/excluding SS - ng firing	SIP - no controls listed (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil as backup)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). NH3 limits are determined as BACT under 310 CMR 7.02(8). NH3(firing NG): ≤0.44 lb/hr(no duct firing), ≤0.55 lb/hr(with duct firing); NH3(turbine firing ULSD): ≤0.0029 lb/MMBtu, ≤0.46 lb/hr(no duct firing), ≤0.57 lb/hr(with duct firing).
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	TPM10	Combustion Turbine with Duct Burner		0.02 lb/MMBtu 1-hour block avg/excluding SS - ng firing	SIP - no controls listed (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil as backup)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). PM10(firing NG): ≤3.29 lb/hr(no duct firing), ≤4.07 lb/hr(with duct firing); during start-ups (≤3 hrs): ≤12.2 lb per event, during shutdowns (≤1 hr): ≤4.1 lb per event.
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	TPM2.5	Combustion Turbine with Duct Burner		0.02 lb/MMBtu 1-hour block avg/excluding SS - ng firing	SIP - no controls listed (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil as backup)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). PM2.5(firing NG): ≤3.29 lb/hr(no duct firing), ≤4.07 lb/hr(with duct firing); during start-ups (≤3 hrs): ≤12.2 lb per event, during shutdowns (≤1 hr): ≤4.1 lb per event.
Matem Limited Partnership - Medical Area Total Energy Plan	MA-0041	7/1/16, 4/28/17 update	CO2e	Combustion Turbine with Duct Burner		119 lb/MMBtu 1-hour block avg/excluding SS - ng firing	SIP - no controls listed (a nominal 14.4 Megawatt (MW) Solar Titan 130 Combustion Turbine Generator (164.6MMBtu/hr for NG firing(also permitted to burn fuel oil as backup)) with Heat Recovery Steam Generator including a Duct Burner) (38.8MMBtu/hr NG firing only). CO2e(firing NG): ≤19,584 lb/hr(no duct firing), ≤24,200 lb/hr(with duct firing).
Wesleyan University	CT-0155	8/27/2008	CO	2.4 MW natural gas fired cogeneration facility	0.48	G/B-HP-H short term emission limit	oxidation catalyst
Wesleyan University	CT-0155	8/27/2008	CO	2.4 MW natural gas fired cogeneration facility	15.51	tpy annual emission limit	oxidation catalyst
Geisinger Medical Center	PA-0289	6/18/2010	CO	Combined heat and power combustion turbine	25	ppm @ 15% O2 in solonox mode	Unknown
Geisinger Medical Center	PA-0289	6/18/2010	CO	Combined heat and power combustion turbine	100	ppm @ 15% O2 in non solonox mode	Unknown
Geisinger Medical Center	PA-0289	6/18/2010	Formaldehyde	Combined heat and power combustion turbine	0.0029	lb/MMBtu	Unknown
Wesleyan University	CT-0155	8/27/2008	NOx	2.4 MW natural gas fired cogeneration facility	0.18	G/B-HP-H short term emission limit	Steuler Eco2pro SCR
Wesleyan University	CT-0155	8/27/2008	NOx	2.4 MW natural gas fired cogeneration facility	5.82	tpy annual emission limit	Steuler Eco2pro SCR
Cutrale Citrus Juices USA Auburndale citrus facility	FL-0313	6/12/2008	NOx	Cogen System Turbine NO.1 W/existing duct Burner #1	25	PPMVD hr average/corrected to 25%O2	dry low NOx burners
Cutrale Citrus Juices USA Leesburg citrus facility	FL-0314	6/2/2008	NOx	Cogen System Turbine & existing steam generator	25	PPMVD hr average/corrected to 25%O2	dry low NOx burners
Geisinger Medical Center	PA-0289	6/18/2010	NOx	Combined heat and power combustion turbine	15	ppm @ 15% O2 in solonox mode	SoLoNOx combustor
Geisinger Medical Center	PA-0289	6/18/2010	NOx	Combined heat and power combustion turbine	42	ppm @ 15% O2 in non solonox mode	SoLoNOx combustor

Appendix B
KNO Restart - RBLC Summary

KNO Restart
 RBLC Search Summary
 Search: "16.210 - combined cycle & cogen <25 MW" - All Results
 Unit 55-Solar Turbines
 Unit 56-Solar Turbines
 Unit 57-Solar Turbines
 Unit 58-Solar Turbines
 Unit 59-Solar Turbines
 Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Cornell university Cornell combined heat & power project	NY-0101	3/12/2008	PM	Combustion Turbines 1, 2, 3	6.5	lb/hr above 1 hour average	sulfur in gas assigned max 1.2 gr/100scf; work practices to minimize NHZ slip
Cornell university Cornell combined heat & power project	NY-0101	3/12/2008	PM	Combustion Turbines 1, 2, 3	0.022	lb/MMBtu above 1 hour average w/ duct firing	sulfur in gas assigned max 1.2 gr/100scf; work practices to minimize NHZ slip
Cornell university Cornell combined heat & power project	NY-0101	3/12/2008	PM10	Combustion Turbines 1, 2, 3	6.7	lb/hr above/below 1 hour average	sulfur in gas assigned max 1.2 gr/100scf; work practices to minimize NHZ slip
Cornell university Cornell combined heat & power project	NY-0101	3/12/2008	PM10	Combustion Turbines 1, 2, 3	0.023	lb/MMBtu above/below 1 hour average w/ duct firing	sulfur in gas assigned max 1.2 gr/100scf; work practices to minimize NHZ slip
Cornell university Cornell combined heat & power project	NY-0101	3/12/2008	PM2.5	Combustion Turbines 1, 2, 3	6.7	lb/hr above/below 1 hour average	sulfur in gas assigned max 1.2 gr/100scf; work practices to minimize NHZ slip
Cornell university Cornell combined heat & power project	NY-0101	3/12/2008	PM2.5	Combustion Turbines 1, 2, 3	0.023	lb/MMBtu above/below 1 hour average w/ duct firing	sulfur in gas assigned max 1.2 gr/100scf; work practices to minimize NHZ slip
Geisinger Medical Center	PA-0289	6/18/2010	VOC	Combined heat and power combustion turbine	0.6	lb/hr in solonox mode	unknown
Geisinger Medical Center	PA-0289	6/18/2010	VOC	Combined heat and power combustion turbine	11.9	lb/hr sub-zero in non-solonox mode	unknown

Notes:
 Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup
 Unit 50- Waste Heat Boiler
 Unit 51- Waste Heat Boiler
 Unit 52- Waste Heat Boiler
 Unit 53- Waste Heat Boiler
 Unit 54- Waste Heat Boiler
 Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
BIG RIVER STEEL LLC	AR-0173	1/31/2022	CO2e	Pickle Line Boiler	117	LB/MMBTU	Good operating practices Minimum Boiler Efficiency
BIG RIVER STEEL LLC	AR-0173	1/31/2022	CO	Pickle Line Boiler	0.0824	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	NOx	Pickle Line Boiler	0.035	LB/MMBTU	Low NOx burners Combustion of clean fuel Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM	Pickle Line Boiler	0.0019	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM10	Pickle Line Boiler	0.0019	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM2.5	Pickle Line Boiler	0.0019	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	SO2	Pickle Line Boiler	0.0006	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	visible emissions	Pickle Line Boiler	0.05	percent opacity	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	VOC	Pickle Line Boiler	0.0054	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	CO2e	Galvanizing Line Boilers #1 and #2	117	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	CO	Galvanizing Line Boilers #1 and #2	0.0824	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	NOx	Galvanizing Line Boilers #1 and #2	0.035	LB/MMBTU	Low NOx burners Combustion of clean fuel Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM	Galvanizing Line Boilers #1 and #2	0.0007	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM10	Galvanizing Line Boilers #1 and #2	0.0007	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM2.5	Galvanizing Line Boilers #1 and #2	0.0007	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	SO2	Galvanizing Line Boilers #1 and #2	0.0006	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	visible emissions	Galvanizing Line Boilers #1 and #2	0.05	percent opacity	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	VOC	Galvanizing Line Boilers #1 and #2	0.0054	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	CO2e	Pickle Galvanizing Line Boiler	117	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	CO	Pickle Galvanizing Line Boiler	0.0824	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	NOx	Pickle Galvanizing Line Boiler	0.035	LB/MMBTU	Low NOx burners Combustion of clean fuel Good Combustion Practices
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM	Pickle Galvanizing Line Boiler	0.0012	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM10	Pickle Galvanizing Line Boiler	0.0012	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	FPM2.5	Pickle Galvanizing Line Boiler	0.0012	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	SO2	Pickle Galvanizing Line Boiler	0.0006	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	visible emissions	Pickle Galvanizing Line Boiler	0.05	percent opacity	Combustion of Natural gas and Good Combustion Practice
BIG RIVER STEEL LLC	AR-0173	1/31/2022	VOC	Pickle Galvanizing Line Boiler	0.0054	LB/MMBTU	Combustion of Natural gas and Good Combustion Practice
JUPITER BROWNSVILLE, LLC CENTURION BROWNSVILLE	TX-0930	10/19/2021	CO2e	Heaters and Boiler with Firing Rates Less than 100 MMBtu/hr	No Numeric Limit		Use of natural pipeline gas or refinery fuel gas. Good combustion practices, including maintaining proper air-to-fuel ratio and necessary residence time, temperature, and turbulence.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup

Unit 50- Waste Heat Boiler

Unit 51- Waste Heat Boiler

Unit 52- Waste Heat Boiler

Unit 53- Waste Heat Boiler

Unit 54- Waste Heat Boiler

Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
JUPITER BROWNSVILLE, LLC CENTURION BROWNSVILLE	TX-0930	10/19/2021	CO	Heaters and Boiler with Firing Rates Less than 100 MMBtu/hr	50	PPMVD	Use of natural pipeline gas or refinery fuel gas. Good combustion practices, including maintaining proper air-to-fuel ratio and necessary residence time, temperature, and turbulence.
JUPITER BROWNSVILLE, LLC CENTURION BROWNSVILLE	TX-0930	10/19/2021	NOx	Heaters and Boiler with Firing Rates Less than 100 MMBtu/hr	0.015	lb/MMBtu	LOW NOX BURNERS
JUPITER BROWNSVILLE, LLC CENTURION BROWNSVILLE	TX-0930	10/19/2021	FPM	Heaters and Boiler with Firing Rates Less than 100 MMBtu/hr	0.0089	lb/MMBtu	Use of natural pipeline gas or refinery fuel gas. Opacity not to exceed 5 percent over six minutes.
JUPITER BROWNSVILLE, LLC CENTURION BROWNSVILLE	TX-0930	10/19/2021	FPM10	Heaters and Boiler with Firing Rates Less than 100 MMBtu/hr	0.0089	lb/MMBtu	Use of natural pipeline gas or refinery fuel gas. Opacity not to exceed 5 percent over six minutes.
JUPITER BROWNSVILLE, LLC CENTURION BROWNSVILLE	TX-0930	10/19/2021	FPM2.5	Heaters and Boiler with Firing Rates Less than 100 MMBtu/hr	0.0089	lb/MMBtu	Use of natural pipeline gas or refinery fuel gas. Opacity not to exceed 5 percent over six minutes.
JUPITER BROWNSVILLE, LLC CENTURION BROWNSVILLE	TX-0930	10/19/2021	SO2	Heaters and Boiler with Firing Rates Less than 100 MMBtu/hr	No Numeric Limit		Use of natural pipeline gas or refinery fuel gas with sulfur content not to exceed 0.20 grains per 100 dscf.
JUPITER BROWNSVILLE, LLC CENTURION BROWNSVILLE	TX-0930	10/19/2021	VOC	Heaters and Boiler with Firing Rates Less than 100 MMBtu/hr	0.0054	lb/MMBtu	Use of natural pipeline gas or refinery fuel gas. Good combustion practices, including maintaining proper air-to-fuel ratio and necessary residence time, temperature, and turbulence.
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	CO2e	SN-202, 203, 204 Pickle Line Boilers	121	lb/MMBtu	Good Combustion Practice
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	CO	SN-202, 203, 204 Pickle Line Boilers	0.084	lb/MMBtu	Good Combustion Practice
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	Lead (Pb) / Lead Co	SN-202, 203, 204 Pickle Line Boilers	No Numeric Limit		
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	NOx	SN-202, 203, 204 Pickle Line Boilers	0.035	lb/MMBtu	Low NOx burners
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	FPM	SN-202, 203, 204 Pickle Line Boilers	0.0019	lb/MMBtu	Good Combustion Practice
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	TPM10	SN-202, 203, 204 Pickle Line Boilers	0.0076	GR/DSCF	Good Combustion Practice
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	TPM2.5	SN-202, 203, 204 Pickle Line Boilers	0.0076	GR/DSCF	Good Combustion Practice
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	SO2	SN-202, 203, 204 Pickle Line Boilers	0.0006	lb/MMBtu	Low Sulfur fuels
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	visible emissions	SN-202, 203, 204 Pickle Line Boilers	5	percent	Good Combustion Practice
NUCOR STEEL ARKANSAS	AR-0172	9/1/2021	VOC	SN-202, 203, 204 Pickle Line Boilers	0.0055	lb/MMBtu	Good Combustion Practice
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	CO	60 MMBtu/hour Auxiliary Boiler	0.08	LB/MMBTU	Good combustion practices and low-NOx burners
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	NOx	60 MMBtu/hour Auxiliary Boiler	0.05	LB/MMBTU	Low-NOx burners
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	FPM	60 MMBtu/hour Auxiliary Boiler	1.4	GR. S/100 SCF NG	Clean Fuels
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	FPM	60 MMBtu/hour Auxiliary Boiler	20	% opacity	Clean Fuels
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	FPM10	60 MMBtu/hour Auxiliary Boiler	1.4	GR. S/100 SCF NG	Clean Fuels
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	FPM10	60 MMBtu/hour Auxiliary Boiler	20	% opacity	Clean Fuels
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	FPM2.5	60 MMBtu/hour Auxiliary Boiler	1.4	GR. S/100 SCF NG	Clean Fuels
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	FPM2.5	60 MMBtu/hour Auxiliary Boiler	20	% opacity	Clean Fuels
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	SO2	60 MMBtu/hour Auxiliary Boiler	1.4	GR. S/100 SCF NG	Limited sulfur content in fuel
SHADY HILLS COMBINED CYCLE FACILITY	FL-0371	6/7/2021	Sulfuric Acid (mist, v	60 MMBtu/hour Auxiliary Boiler	1.4	GR. S/100 SCF NG	Limited sulfur content in fuel
NUCOR STEEL GALLATIN, LLC	KY-0115	04/19/2021	CO2e	Vacuum Degasser Boiler (EP 20-13)	26125	ton/yr	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan and implement various design and operational efficiency requirements.
NUCOR STEEL GALLATIN, LLC	KY-0115	04/19/2021	CO	Vacuum Degasser Boiler (EP 20-13)	61	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan
NUCOR STEEL GALLATIN, LLC	KY-0115	04/19/2021	Lead (Pb) / Lead Co	Vacuum Degasser Boiler (EP 20-13)	0.0005	LB/MMSCF	
NUCOR STEEL GALLATIN, LLC	KY-0115	04/19/2021	NOx	Vacuum Degasser Boiler (EP 20-13)	35	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. Also equipped with low-NOx burners.
NUCOR STEEL GALLATIN, LLC	KY-0115	04/19/2021	FPM	Vacuum Degasser Boiler (EP 20-13)	1.9	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. Also equipped with low-NOx burners.
NUCOR STEEL GALLATIN, LLC	KY-0115	04/19/2021	TPM10	Vacuum Degasser Boiler (EP 20-13)	7.6	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. Also equipped with low-NOx burners.
NUCOR STEEL GALLATIN, LLC	KY-0115	04/19/2021	TPM2.5	Vacuum Degasser Boiler (EP 20-13)	7.6	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. Also equipped with low-NOx burners.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup
 Unit 50- Waste Heat Boiler
 Unit 51- Waste Heat Boiler
 Unit 52- Waste Heat Boiler
 Unit 53- Waste Heat Boiler
 Unit 54- Waste Heat Boiler
 Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
NUCOR STEEL GALLATIN, LLC	KY-0115	04/19/2021	SO2	Vacuum Degasser Boiler (EP 20-13)	0.6	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. Also equipped with low-NOx burners.
NUCOR STEEL GALLATIN, LLC	KY-0115	04/19/2021	VOC	Vacuum Degasser Boiler (EP 20-13)	5.5	LB/MMSCF	The permittee must develop a Good Combustion and Operating Practices (GCOP) Plan. Also equipped with low-NOx burners.
SHELL ROCK SOY PROCESSING	IA-0117	03/17/2021	TPM	Natural Gas Boiler A and B	0.026	lb/Hr, each	Low NOx Burner and Flue Gas Recirculation
LBWL--ERICKSON STATION	MI-0447	01/07/2021	CO2e	EUAUXBOILER--nat gas fired auxiliary boiler	25644	ton/yr	Low carbon fuel (pipeline quality natural gas), good combustion practices, and energy efficiency measures.
LBWL--ERICKSON STATION	MI-0447	01/07/2021	CO	EUAUXBOILER--nat gas fired auxiliary boiler	50	PPM	Good combustion practices.
LBWL--ERICKSON STATION	MI-0447	01/07/2021	NOx	EUAUXBOILER--nat gas fired auxiliary boiler	30	PPM	Low NOx burners (LNB) or flue gas recirculation (FGR) along with good combustion practices.
LBWL--ERICKSON STATION	MI-0447	01/07/2021	TPM10	EUAUXBOILER--nat gas fired auxiliary boiler	0.74	lb/Hr	Good combustion practices.
LBWL--ERICKSON STATION	MI-0447	01/07/2021	TPM2.5	EUAUXBOILER--nat gas fired auxiliary boiler	0.4	lb/Hr	Good combustion practices.
LBWL--ERICKSON STATION	MI-0447	01/07/2021	VOC	EUAUXBOILER--nat gas fired auxiliary boiler	0.3	lb/Hr	Good combustion practices.
US NAVY NORFOLK NAVAL SHIPYARD	VA-0333	12/09/2020	CO2e	Three (3) boilers	117.1	LB/MMBTU	
US NAVY NORFOLK NAVAL SHIPYARD	VA-0333	12/09/2020	TPM10	Three (3) boilers	0.0078	LB/MMBTU	
US NAVY NORFOLK NAVAL SHIPYARD	VA-0333	12/09/2020	TPM2.5	Three (3) boilers	0.0078	LB/MMBTU	
LION OIL COMPANY	AR-0167	12/01/2020	NOx	SN-803 - #4 Pre-Flash Column Reboiler	1.9	lb/hr	Ultra-low NOx burners and good combustion practice
LION OIL COMPANY	AR-0167	12/01/2020	NOx	SN-805 - #4 Pre-Flash Reboiler	3.5	lb/hr	Ultra-low NOx burners and good combustion practice
LION OIL COMPANY	AR-0167	12/01/2020	NOx	SN-810 - #9 Hydrotreater Furnace/Reboiler	12.7	lb/hr	
PLANT BARRY, ALABAMA POWER COMPANY	AL-0328	11/09/2020	CO2e	90.5 MMBtu/hr Aux Boiler	46416	ton/yr	
PLANT BARRY, ALABAMA POWER COMPANY	AL-0328	11/09/2020	CO	90.5 MMBtu/hr Aux Boiler	0.037	LB/MMBTU	
PLANT BARRY, ALABAMA POWER COMPANY	AL-0328	11/09/2020	NOx	90.5 MMBtu/hr Aux Boiler	0.011	LB/MMBTU	
PLANT BARRY, ALABAMA POWER COMPANY	AL-0328	11/09/2020	FPM10	90.5 MMBtu/hr Aux Boiler	0.0075	LB/MMBTU	
PLANT BARRY, ALABAMA POWER COMPANY	AL-0328	11/09/2020	FPM2.5	90.5 MMBtu/hr Aux Boiler	0.0075	LB/MMBTU	
PLANT BARRY, ALABAMA POWER COMPANY	AL-0328	11/09/2020	SO2	90.5 MMBtu/hr Aux Boiler	0.002	LB/MMBTU	
PLANT BARRY, ALABAMA POWER COMPANY	AL-0328	11/09/2020	VOC	90.5 MMBtu/hr Aux Boiler	0.004	LB/MMBTU	
FG LA COMPLEX	LA-0364	01/06/2020	CO2e	PR Waste Heat Boiler	455475	ton/yr	Use of natural gas or fuel gas as fuel, energy-efficient design options, and operational/maintenance practices.
FG LA COMPLEX	LA-0364	01/06/2020	CO	PR Waste Heat Boiler	26.21	lb/hr	Good combustion practices and oxidation catalyst.
FG LA COMPLEX	LA-0364	01/06/2020	NOx	PR Waste Heat Boiler	14.41	lb/hr	SCR and LNB
FG LA COMPLEX	LA-0364	01/06/2020	TPM10	PR Waste Heat Boiler	0.61	lb/hr	Use of pipeline quality natural gas or fuel gas and good combustion practices.
FG LA COMPLEX	LA-0364	01/06/2020	TPM2.5	PR Waste Heat Boiler	0.61	lb/hr	Use of pipeline quality natural gas or fuel gas and good combustion practices.
FG LA COMPLEX	LA-0364	01/06/2020	SO2	PR Waste Heat Boiler	8.03	lb/hr	Use of pipeline quality natural gas or fuel gas.
FG LA COMPLEX	LA-0364	01/06/2020	VOC	PR Waste Heat Boiler	13.37	lb/hr	Good combustion practices and oxidation catalyst
Nucor Steel Kankakee, Inc.	IL-0126	11/1/2018, updated 2/19/2019	CO2e	Gas-Fired Space Heaters (25 MMBtu/hr)	10197	ton/year	Good combustion practices (Compliance with limit in accordance with provisions of 40 CFR Part 98)
Nucor Steel Kankakee, Inc.	IL-0126	11/1/2018, updated 2/19/2019	TPM10	Gas-Fired Space Heaters (25 MMBtu/hr)	0.0075	lb/MMBTU Individual Units	(Test methods EPA/OAR Mthd 201 and OTM 28) (BACT-PSD)
Nucor Steel Kankakee, Inc.	IL-0126	11/1/2018, updated 2/19/2019	TPM2.5	Gas-Fired Space Heaters (25 MMBtu/hr)	0.0075	lb/MMBTU Individual Units	(BACT-PSD)

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup
 Unit 50- Waste Heat Boiler
 Unit 51- Waste Heat Boiler
 Unit 52- Waste Heat Boiler
 Unit 53- Waste Heat Boiler
 Unit 54- Waste Heat Boiler
 Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Green Bay Packaging, Inc. - Shipping Container Division	WI-0266	9/6/2018, updated 2/19/2019	VOC	Natural gas-fired boiler (Boiler B01) (35 MMBtu/hr)	0.0055	lb/MMBtu	Good combustion practices, use only natural gas, equip boiler with Low NOx burners and flue gas recirculation
Green Bay Packaging, Inc. - Shipping Container Division	WI-0266	9/6/2018, updated 2/19/2019	CO2e	Natural gas-fired boiler (Boiler B01) (35 MMBtu/hr)	160	lb CO2e/1000 lb steam	Good combustion practices, use only natural gas, equip boiler with Low NOx burners and flue gas recirculation
Green Bay Packaging, Inc. - Shipping Container Division	WI-0266	9/6/2018, updated 2/19/2019	VOC	Space heaters (process P53) (40 MMBtu/hr)	0.0055	lb/MMBtu	Good combustion practices, use only natural gas, equip with Low NOx burners
Green Bay Packaging, Inc. - Shipping Container Division	WI-0266	9/6/2018, updated 2/19/2019	CO2e	Space heaters (process P53) (40 MMBtu/hr)	no numerical limit		Good combustion practices, use only natural gas, equip with Low NOx burners minimum design annual fuel utilization efficiency of 90%
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	NOx	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	0.011	lb/MMBtu 3-hr avg	Ultra-low NOx burners and flue gas recirculation, air preheater, automated combustion management system with O2 trim system and automated water blowdown, and good combustion practices (LAER)
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	NOx	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	1.1	lb/hr	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	NOx	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	2.2	ton/year	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	CO	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	0.037	lb/MMBtu 3-hr avg	Good Combustion Practices(BACT-PSD)
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	CO	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	3.6	lb/hr	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	CO	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	7.2	ton/year	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	TPM (PM, PM10 and PM2.5)	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	0.0075	no units listed	Good Combustion Practices(BACT-PSD)
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	TPM (PM, PM10 and PM2.5)	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	0.72	lb/hr	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	TPM (PM, PM10 and PM2.5)	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	1.44	ton/year	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	Sulfuric Acid (mist, vapors, etc)	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	0.1	lb/hr	Good Combustion Practices(BACT-PSD)
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	Sulfuric Acid (mist, vapors, etc)	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	0.2	ton/year	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	CO2e	Auxiliary Boiler (96 MMBtu/hr) (used on an intermittent basis (up to 4000 hrs/yr)	22500	ton/year 12-month rolling avg	Good Combustion Practices(BACT-PSD)
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	NOx	Fuel Heater (12.80 MMBtu/hr)	0.011	lb/MMBtu	LAER NSPS - Low NOx burners

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup
 Unit 50- Waste Heat Boiler
 Unit 51- Waste Heat Boiler
 Unit 52- Waste Heat Boiler
 Unit 53- Waste Heat Boiler
 Unit 54- Waste Heat Boiler
 Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	NOx	Fuel Heater (12.80 MMBtu/hr)	0.45	lb/hr	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	NOx	Fuel Heater (12.80 MMBtu/hr)	2.0	ton/year	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	CO	Fuel Heater (12.80 MMBtu/hr)	0.08	lb/hr	Good Combustion Practices(BACT-PSD)
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	CO	Fuel Heater (12.80 MMBtu/hr)	1.02	lb/hr	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	CO	Fuel Heater (12.80 MMBtu/hr)	4.5	ton/year	Permit Limit
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	TPM (PM, PM10 and PM2.5)	Fuel Heater (12.80 MMBtu/hr)	0.0075	lb/MMBtu	Good Combustion Practices(BACT-PSD)
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	Sulfuric Acid (mist, vapors, etc)	Fuel Heater (12.80 MMBtu/hr)	0.014	lb/hr	Good Combustion Practices(BACT-PSD)
CPV Three Rivers, LLC - Energy Center	IL-0129	7/30/2018, updated 2/19/2019	CO2e	Fuel Heater (12.80 MMBtu/hr)	6600	ton/year 12-month rolling avg	Good Combustion Practices(BACT-PSD)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	CO	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.007	lb/mmbtu hourly	Good Combustion Practices, Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	CO	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.7	lb/hr hourly	Good Combustion Practices, Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	NOx	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.036	lb/mmbtu hourly	Low NOx Burners/Flue Gas Recirculation (SCR not cost effective) (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	NOx	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	3.6	lb/hr hourly	Low NOx Burners/Flue Gas Recirculation (SCR not cost effective) (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	FPM	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.007	lb/mmbtu hourly	Good Combustion Practices, Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	FPM	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.7	lb/hr hourly	Good Combustion Practices, Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	TPM10	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.007	lb/mmbtu hourly	Good Combustion Practices, Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	TPM10	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.7	lb/hr hourly	Good Combustion Practices, Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	TPM2.5	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.075	lb/mmbtu hourly	Good Combustion Practices (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	TPM2.5	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	7.49	lb/hr hourly	Good Combustion Practices (BACT-PSD SIP)

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart

RBLC Search Summary

Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup

Unit 50- Waste Heat Boiler

Unit 51- Waste Heat Boiler

Unit 52- Waste Heat Boiler

Unit 53- Waste Heat Boiler

Unit 54- Waste Heat Boiler

Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	VOC	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.008	lb/mmbtu hourly	Good Combustion Controls (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	VOC	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.8	lb/hr hourly	Good Combustion Controls (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	Sulfuric Acid (mist, vapors, etc)	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	0.34	gr s/100 scf Fuel supplier records	Good Combustion Practices, Low Sulfur Fuel (BACT-PSD NSPS SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	CO2e	EUAUXBOILER: Auxiliary Boiler (99.9 MMBtu/hr)	25623	ton/year 12-month rolling time period	Energy Efficiency Measures, Use of Natural Gas (BACT-PSD)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	CO	EUFUELHTR1: Natural gas fired fuel heater (20.80 MMBtu/hr)	0.77	lb/hr hourly	Good Combustion Controls (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	NOx	EUFUELHTR1: Natural gas fired fuel heater (20.80 MMBtu/hr)	0.75	lb/hr hourly	Low NOx Burners (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	FPM	EUFUELHTR1: Natural gas fired fuel heater (20.80 MMBtu/hr)	0.15	lb/hr hourly	Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	TPM10	EUFUELHTR1: Natural gas fired fuel heater (20.80 MMBtu/hr)	0.15	lb/hr hourly	Low Sulfur Fuel (Oxidation catalyst is not economically feasible) (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	TPM2.5	EUFUELHTR1: Natural gas fired fuel heater (20.80 MMBtu/hr)	0.15	lb/hr hourly	Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	VOC	EUFUELHTR1: Natural gas fired fuel heater (20.80 MMBtu/hr)	0.17	lb/hr hourly	Good Combustion Controls (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	Sulfuric Acid (mist, vapors, etc)	EUFUELHTR1: Natural gas fired fuel heater (20.80 MMBtu/hr)	0.34	gr s/100 scf Fuel supplier records	Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	CO2e	EUFUELHTR1: Natural gas fired fuel heater (20.80 MMBtu/hr)	6310	ton/year 12-month rolling time period (combined EUFUELHTR1 and EUFUELHTR2)	Natural Gas Fuel (BACT-PSD)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	CO	EUFUELHTR2: Natural gas fired fuel heater (3.80 MMBtu/hr)	0.14	lb/hr hourly	Good Combustion Controls (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	NOx	EUFUELHTR2: Natural gas fired fuel heater (3.80 MMBtu/hr)	0.14	lb/hr hourly	Low NOx Burners (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	FPM	EUFUELHTR2: Natural gas fired fuel heater (3.80 MMBtu/hr)	0.03	lb/hr hourly	Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	TPM10	EUFUELHTR2: Natural gas fired fuel heater (3.80 MMBtu/hr)	0.03	lb/hr hourly	Low Sulfur Fuel (oxidation catalyst not economically feasible) (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	TPM2.5	EUFUELHTR2: Natural gas fired fuel heater (3.80 MMBtu/hr)	0.03	lb/hr hourly	BACT PSD SIP Low Sulfur Fuel (BACT-PSD SIP)

**Appendix B
KNO Restart - RBLC Summary**

KNO Restart

RBLC Search Summary

Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup

Unit 50- Waste Heat Boiler

Unit 51- Waste Heat Boiler

Unit 52- Waste Heat Boiler

Unit 53- Waste Heat Boiler

Unit 54- Waste Heat Boiler

Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	VOC	EUFUELHTR2: Natural gas fired fuel heater (3.80 MMBtu/hr)	0.03	lb/hr hourly	Good Combustion Controls (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	Sulfuric Acid (mist, vapors, etc)	EUFUELHTR2: Natural gas fired fuel heater (3.80 MMBtu/hr)	0.34	gr s/100 scf Fuel supplier records	Low Sulfur Fuel (BACT-PSD SIP)
DTE Electric Company - Belle River Combined Cycle Power Plant	MI-0435	7/16/2018, updated 2/19/2019	CO2e	EUFUELHTR2: Natural gas fired fuel heater (3.80 MMBtu/hr)	6310	ton/year 12-month rolling time period (combined EUFUELHTR1 and EUFUELHTR2)	Natural Gas Fuel (BACT-PSD)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	CO	EUAUXBOILER (North Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.08	lb/MMBtu hourly	Good Combustion Practices (oxidation catalyst not economically feasible) (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	NOx	EUAUXBOILER (North Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.04	lb/MMBtu 30-day rolling avg time period	Low NOx Burners/flue gas recirculation and good combustion practices (SCR not economically feasible) (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	FPM	EUAUXBOILER (North Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.005	lb/MMBtu hourly	Good Combustion Practices (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	TPM10	EUAUXBOILER (North Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.46	lb/hr hourly	Good Combustion Practices (no control equipment economically feasible) (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	TPM2.5	EUAUXBOILER (North Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.46	lb/hr hourly	Good Combustion Practices (no control equipment economically feasible) (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	VOC	EUAUXBOILER (North Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.004	lb/MMBtu hourly	Good Combustion Practices (oxidation catalysts not economically feasible) (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	SO2	EUAUXBOILER (North Plant): Auxiliary Boiler (61.5 MMBtu/hr)	1.8	lb/MMscf monthly	Good Combustion Practices and use of pipeline quality natural gas (BACT-PSD NSPS SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	SO2	EUAUXBOILER (North Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.6	gr s/100 scf Fuel supplier records	Good Combustion Practices and use of pipeline quality natural gas (emission factor based on natural gas material limit of 2,000 grains of sulfur per MMSCF) (BACT-PSD NSPS SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	CO2e	EUAUXBOILER (North Plant): Auxiliary Boiler (61.5 MMBtu/hr)	31540	ton/year 12-month rolling time period	Energy efficiency measures and the use of a low carbon fuel (pipeline quality natural gas) (BACT-PSD)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	CO	EUAUXBOILER (South Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.08	lb/MMBtu hourly	Good Combustion Practices (oxidation catalyst not economically feasible) (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	NOx	EUAUXBOILER (South Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.04	lb/MMBtu 30-day rolling avg time period	Low NOx Burners/flue gas recirculation and good combustion practices (SCR not economically feasible) (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	FPM	EUAUXBOILER (South Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.005	lb/MMBtu hourly	Good Combustion Practices (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	TPM10	EUAUXBOILER (South Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.46	lb/hr hourly	Good Combustion Practices (no control equipment economically feasible) (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	TPM2.5	EUAUXBOILER (South Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.46	lb/hr hourly	Good Combustion Practices (no control equipment economically feasible) (BACT-PSD SIP)

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary
Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup
Unit 50- Waste Heat Boiler
Unit 51- Waste Heat Boiler
Unit 52- Waste Heat Boiler
Unit 53- Waste Heat Boiler
Unit 54- Waste Heat Boiler
Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	VOC	EUAUXBOILER (South Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.004	lb/MMBtu hourly	Good Combustion Practices (oxidation catalysts not economically feasible) (BACT-PSD SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	SO2	EUAUXBOILER (South Plant): Auxiliary Boiler (61.5 MMBtu/hr)	1.8	lb/MMscf monthly	Good Combustion Practices and use of pipeline quality natural gas (BACT-PSD NSPS SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	SO2	EUAUXBOILER (South Plant): Auxiliary Boiler (61.5 MMBtu/hr)	0.6	gr s/100 scf Fuel supplier records	Good Combustion Practices and use of pipeline quality natural gas (emission factor based on natural gas material limit of 2,000 grains of sulfur per MMSCF) (BACT-PSD NSPS SIP)
Marshall Energy Center LLC - MEC North, LLC and MEC South, LLC	MI-0433	6/29/2018, updated 2/19/2019	CO2e	EUAUXBOILER (South Plant): Auxiliary Boiler (61.5 MMBtu/hr)	31540	ton/year 12-month rolling time period	Energy efficiency measures and the use of a low carbon fuel (pipeline quality natural gas) (BACT-PSD)
Dominion Energy Transmission, Inc. - Mockingbird Hill Compressor Station	WV-0031	6/14/2018, updated 9/24/2018	TPM2.5	WH-1 - Boiler (8.72 MMBtu/hr)	0.28	ton/year 12-month rolling	Limited to Natural Gas (Monitoring is limit to either fuel usage or tracking hours of operation) (BACT-PSD SIP)
Dominion Energy Transmission, Inc. - Mockingbird Hill Compressor Station	WV-0031	6/14/2018, updated 9/24/2018	TPM10	WH-1 - Boiler (8.72 MMBtu/hr)	0.28	ton/year 12-month rolling	Limited to Natural Gas (Monitoring is limit to either fuel usage or tracking hours of operation) (BACT-PSD SIP)
Dominion Energy Transmission, Inc. - Mockingbird Hill Compressor Station	WV-0031	6/14/2018, updated 9/24/2018	TPM	WH-1 - Boiler (8.72 MMBtu/hr)	0.28	ton/year 12-month rolling	Limited to Natural Gas (Monitoring is limit to either fuel usage or tracking hours of operation) (BACT-PSD SIP)
Dominion Energy Transmission, Inc. - Mockingbird Hill Compressor Station	WV-0031	6/14/2018, updated 9/24/2018	CO2e	WH-1 - Boiler (8.72 MMBtu/hr)	4468	ton/year 12-month rolling	Restricted to pipeline quality natural gas and tune-up the boiler once every five years (BACT-PSD)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	CO	Auxiliary Boiler (77.8 MMBtu/hr)	2.88	lb/hr	Good Combustion Practices (BACT-PSD)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	CO	Auxiliary Boiler (77.8 MMBtu/hr)	6.58	tons/year	Good Combustion Practices (BACT-PSD)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	CO	Auxiliary Boiler (77.8 MMBtu/hr)	0.037	lb/MMBtu	Good Combustion Practices (BACT-PSD)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	NOx	Auxiliary Boiler (77.8 MMBtu/hr)	0.86	lb/hr	Low NOx Burners/flue gas recirculation and good combustion practices (BACT-PSD)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	NOx	Auxiliary Boiler (77.8 MMBtu/hr)	1.96	tons/year	Low NOx Burners/flue gas recirculation and good combustion practices (BACT-PSD)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	NOx	Auxiliary Boiler (77.8 MMBtu/hr)	0.0011	lb/MMBtu	Low NOx Burners/flue gas recirculation and good combustion practices (BACT-PSD)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	TPM	Auxiliary Boiler (77.8 MMBtu/hr)	0.6	lb/hr	Low NOx Burners/flue gas recirculation and good combustion practices (BACT-PSD SIP)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	TPM	Auxiliary Boiler (77.8 MMBtu/hr)	1.38	tons/year	Low NOx Burners/flue gas recirculation and good combustion practices (BACT-PSD SIP)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	TPM	Auxiliary Boiler (77.8 MMBtu/hr)	0.008	lb/MMBtu	Low NOx Burners/flue gas recirculation and good combustion practices (BACT-PSD SIP)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	VOC	Auxiliary Boiler (77.8 MMBtu/hr)	0.62	lb/hr	Use of Natural Gas, Good Combustion Practices (BACT-PSD SIP)

Appendix B
KNO Restart - RBLC Summary

KNO Restart

RBLC Search Summary

Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup

Unit 50- Waste Heat Boiler

Unit 51- Waste Heat Boiler

Unit 52- Waste Heat Boiler

Unit 53- Waste Heat Boiler

Unit 54- Waste Heat Boiler

Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	VOC	Auxiliary Boiler (77.8 MMBtu/hr)	1.42	tons/year	Use of Natural Gas, Good Combustion Practices (BACT-PSD SIP)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	VOC	Auxiliary Boiler (77.8 MMBtu/hr)	0.008	lb/MMBtu	Use of Natural Gas, Good Combustion Practices (BACT-PSD SIP)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	Sulfuric Acid (mist, vapors, etc)	Auxiliary Boiler (77.8 MMBtu/hr)	0.0132	lb/hr	Use of Natural Gas (BACT-PSD SIP)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	Sulfuric Acid (mist, vapors, etc)	Auxiliary Boiler (77.8 MMBtu/hr)	0.03	tons/year	Use of Natural Gas (BACT-PSD SIP)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	Sulfuric Acid (mist, vapors, etc)	Auxiliary Boiler (77.8 MMBtu/hr)	0.0002	lb/MMBtu	Use of Natural Gas (BACT-PSD SIP)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	CO2e	Auxiliary Boiler (77.8 MMBtu/hr)	9107	lb/hr emission limit	Use of Natural Gas (BACT-PSD)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	CO2e	Auxiliary Boiler (77.8 MMBtu/hr)	20837	tons/year emission limit	Use of Natural Gas (BACT-PSD)
ESC Harrison County Power, LLC - Harrison County Power Plant	WV-0029	3/27/2018, updated 6/25/2018	CO2e	Auxiliary Boiler (77.8 MMBtu/hr)	9107	lb/hr standard emission	Use of Natural Gas (BACT-PSD)
Florida Power and Light Company - Dania Beach Energy Center	FL-0363 (draft)	12/4/2017, updated 4/11/2018	CO	99.8 MMBtu/hr Auxiliary Boiler	0.08	lb/MMBtu	Clean Fuel (Compliance by initial and annual stack test (EPA/OER mthd 10), or manufacturer guarantee. CO also serves as proxy for VOC.) (BACT-PSD)
Florida Power and Light Company - Dania Beach Energy Center	FL-0363 (draft)	12/4/2017, updated 4/11/2018	SO2	99.8 MMBtu/hr Auxiliary Boiler	no numeric limit		Clean Fuel (May only fire natural gas with sulfur content less than 2 grains per 100 scf. This limits SO2, SAM, PM, PM10, and PM2.5) (BACT-PSD NSPS)
Florida Power and Light Company - Dania Beach Energy Center	FL-0363 (draft)	12/4/2017, updated 4/11/2018	Sulfuric Acid (mist, vapors, etc)	99.8 MMBtu/hr Auxiliary Boiler	no numeric limit		Clean Fuel (May only fire natural gas with sulfur content less than 2 grains per 100 scf. This limits SO2, SAM, PM, PM10, and PM2.5) (BACT-PSD NSPS)
Florida Power and Light Company - Dania Beach Energy Center	FL-0363 (draft)	12/4/2017, updated 4/11/2018	FPM	99.8 MMBtu/hr Auxiliary Boiler	no numeric limit		Clean Fuel (May only fire natural gas with sulfur content less than 2 grains per 100 scf. This limits SO2, SAM, PM, PM10, and PM2.5) (BACT-PSD NSPS)
Florida Power and Light Company - Dania Beach Energy Center	FL-0363 (draft)	12/4/2017, updated 4/11/2018	TPM10	99.8 MMBtu/hr Auxiliary Boiler	no numeric limit		Clean Fuel (May only fire natural gas with sulfur content less than 2 grains per 100 scf. This limits SO2, SAM, PM, PM10, and PM2.5) (BACT-PSD)
Florida Power and Light Company - Dania Beach Energy Center	FL-0363 (draft)	12/4/2017, updated 4/11/2018	TPM2.5	99.8 MMBtu/hr Auxiliary Boiler	no numeric limit		Clean Fuel (May only fire natural gas with sulfur content less than 2 grains per 100 scf. This limits SO2, SAM, PM, PM10, and PM2.5) (BACT-PSD)
Holland Board of Public Works - East 5th Street	MI-0424 (draft) (update of MI-0412)	12/5/2016, 7/31/17 update	CO	EUAUXBOILER (Auxiliary Boiler)	0.077	lb/MMBtu Test protocol will specify avg time	SIP - Good combustion practices (83.5 MMBtu/hr)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	NOx	EUAUXBOILER (Auxiliary Boiler)	0.05	lb/MMBtu Test protocol will specify avg time	SIP - Low NOx burners/Internal flue gas recirculation and good combustion practices (83.5 MMBtu/hr)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	FPM	EUAUXBOILER (Auxiliary Boiler)	0.0018	lb/MMBtu Test protocol will specify avg time	Good combustion practices (83.5 MMBtu/hr)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	TPM10	EUAUXBOILER (Auxiliary Boiler)	0.007	lb/MMBtu Test protocol will specify avg time	SIP - Good combustion practices (83.5 MMBtu/hr)

Appendix B
KNO Restart - RBLC Summary

KNO Restart

RBLC Search Summary

Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup

Unit 50- Waste Heat Boiler

Unit 51- Waste Heat Boiler

Unit 52- Waste Heat Boiler

Unit 53- Waste Heat Boiler

Unit 54- Waste Heat Boiler

Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	TPM2.5	EU AUX BOILER (Auxiliary Boiler)	0.007	lb/MMBtu Test protocol will specify avg time	SIP - Good combustion practices (83.5 MMBtu/hr)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	VOC	EU AUX BOILER (Auxiliary Boiler)	0.008	lb/MMBtu Test protocol will specify avg time	Good combustion practices (83.5 MMBtu/hr)
Holland Board of Public Works - East 5th Street	MI-0424 (draft)	12/5/2016, 7/31/17 update	CO2e	EU AUX BOILER (Auxiliary Boiler)	43283	tpy 12-month rolling time period	Good combustion practices (83.5 MMBtu/hr)
Rextac, LLC - Odessa Petrochemical Plant	TX-0813 (draft)	11/22/2016, 12/1/16 update	VOC	Small Boiler	0.0005	MMBtu/hr	NSPS Dc - Best combustion practices (39.9 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	NOx	Auxiliary boiler	0.11	Lb/MMBtu Avg of 3 1-hr test runs	NSPS - Ultra low NOx burners, FGR, good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	NOx	Auxiliary boiler	2.03	tpy 12-month rolling basis	NSPS - Ultra low NOx burners, FGR, good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	CO	Auxiliary boiler	0.037	lb/MMBtu Avg of 3 1-hr test runs	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	CO	Auxiliary boiler	6.84	tpy 12-month rolling basis	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	TPM	Auxiliary boiler	0.007	lb/MMBtu	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	TPM	Auxiliary boiler	1.29	tpy 12-month rolling basis	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	TPM10	Auxiliary boiler	0.007	lb/MMBtu	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	TPM10	Auxiliary boiler	1.29	tpy 12-month rolling basis	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	TPM2.5	Auxiliary boiler	0.007	lb/MMBtu	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	TPM2.5	Auxiliary boiler	1.29	tpy 12-month rolling basis	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	VOC	Auxiliary boiler	0.004	lb/MMBtu Avg of 3 1-hr test runs	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)

Appendix B
KNO Restart - RBLC Summary

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup
 Unit 50- Waste Heat Boiler
 Unit 51- Waste Heat Boiler
 Unit 52- Waste Heat Boiler
 Unit 53- Waste Heat Boiler
 Unit 54- Waste Heat Boiler
 Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
CPV Fairview, LLC - CPV Fairview Energy Center	PA-0310	9/2/16, 7/31/17 update	VOC	Auxiliary boiler	0.74	typy 12-month rolling basis	NSPS - ULSD and good combustion practices (Operation of the auxiliary boiler shall not exceed 4000 hrs in any continuous 12-month period) (92.4 MMBtu/hr)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	NOx	Auxiliary boiler	0.975	lb/hr avg of three 1-hour initial stack test	NSPS - Low Nox burners and FGR and use of natural gas as a clean burning fuel (97.5 MMBtu/hr)(4000.00 H/YR)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	NOx	Auxiliary boiler	0.01	lb/MMBtu avg of three 1-hour initial stack test	NSPS - Low Nox burners and FGR and use of natural gas as a clean burning fuel (97.5 MMBtu/hr)(4000.00 H/YR)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	CO	Auxiliary boiler	3.6	lb/hr avg of three 1-hour initial stack test	Use of natural gas as a clean burning fuel and good combustion practices (97.5 MMBtu/hr)(4000.00 H/YR)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	VOC	Auxiliary boiler	0.488	lb/hr avg of three 1-hour initial stack tests initially	Use of natural gas as a clean burning fuel and good combustion practices (97.5 MMBtu/hr)(4000.00 H/YR)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	FPM	Auxiliary boiler	0.181	lb/hr avg of three 1-hour initial stack tests initially	Use of natural gas as a clean burning fuel and good combustion practices (97.5 MMBtu/hr)(4000.00 H/YR)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	TPM10	Auxiliary boiler	0.488	lb/hr avg of three 1-hour initial stack tests initially	Use of natural gas as a clean burning fuel and good combustion practices (97.5 MMBtu/hr)(4000.00 H/YR)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	TPM2.5	Auxiliary boiler	0.488	lb/hr avg of three 1-hour initial stack tests initially	Use of natural gas as a clean burning fuel and good combustion practices (97.5 MMBtu/hr)(4000.00 H/YR)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	SO2	Auxiliary boiler	0.128	lb/hr	Use of natural gas as a clean burning fuel low sulfur fuel (SUBJECT TO NJDEP STATE-OF-THE-ART REQUIREMENTS) (97.5 MMBtu/hr)(4000.00 H/YR)
Stonegate Power, LLC - Middlesex Energy Center, LLC	NJ-0085	7/19/16, 11/3/16 update	Sulfuric Acid (Mist, Vapors, etc)	Auxiliary boiler	0.01	lb/hr	Use of natural gas as a clean burning fuel low sulfur fuel (97.5 MMBtu/hr)(4000.00 H/YR)
DTE Gas Company - Milford Compressor Station	MI-0420	6/3/16, 4/27/17 update	NOx	FGAUXBOILERS	14	ppmv at 15% O2; Test Protocol (each boiler)	SIP - Ultra Low NOx Burners and good combustion practices (2 boilers at 6 MMBtu/hr each)
DTE Gas Company - Milford Compressor Station	MI-0420	6/3/16, 4/27/17 update	CO	FGAUXBOILERS	0.08	lb/MMBtu each; Test Protocol	SIP - Good combustion practices and clean burn fuel (pipeline quality natural gas) (2 boilers at 6 MMBtu/hr each)
DTE Gas Company - Milford Compressor Station	MI-0420	6/3/16, 4/27/17 update	TPM10	FGAUXBOILERS	0.0075	lb/MMBtu each; Test Protocol	SIP - Good combustion practices and low sulfur fuel (pipeline quality natural gas) (2 boilers at 6 MMBtu/hr each)
DTE Gas Company - Milford Compressor Station	MI-0420	6/3/16, 4/27/17 update	TPM2.5	FGAUXBOILERS	0.0075	lb/MMBtu each; Test Protocol	SIP - Good combustion practices and low sulfur fuel (pipeline quality natural gas) (2 boilers at 6 MMBtu/hr each)
DTE Gas Company - Milford Compressor Station	MI-0420	6/3/16, 4/27/17 update	CO2e	FGAUXBOILERS	6155	typy 12-month rolling time period	Use of pipeline quality natural gas and energy efficiency measures (2 boilers at 6 MMBtu/hr each)
PSEG Fossil LLC Sewaren Generating Station	NJ-0084	3/10/16, 7/25/16 update	NOx	Auxiliary Boiler firing natural gas	0.8	lb/hr avg of three 1-hour stack tests	NSPS - Low NOx burners and FGR (80 MMBtu/hr)
PSEG Fossil LLC Sewaren Generating Station	NJ-0084	3/10/16, 7/25/16 update	NOx	Auxiliary Boiler firing natural gas	0.01	lb/MMBtu avg of three 1-hour stack tests	NSPS - Low NOx burners and FGR (80 MMBtu/hr)
PSEG Fossil LLC Sewaren Generating Station	NJ-0084	3/10/16, 7/25/16 update	CO	Auxiliary Boiler firing natural gas	2.88	lb/hr avg of three 1-hour stack tests	Use of good combustion practices and use of natural gas a clean burning fuel (80 MMBtuhr)
PSEG Fossil LLC Sewaren Generating Station	NJ-0084	3/10/16, 7/25/16 update	VOC	Auxiliary Boiler firing natural gas	0.32	lb/hr avg of three 1-hour stack tests	Use of good combustion practices and use of natural gas a clean burning fuel (80 MMBtuhr)
PSEG Fossil LLC Sewaren Generating Station	NJ-0084	3/10/16, 7/25/16 update	FPM	Auxiliary Boiler firing natural gas	0.26	lb/hr avg of three 1-hour stack tests	Use of natural gas a clean burning fuel (80 MMBtuhr)
PSEG Fossil LLC Sewaren Generating Station	NJ-0084	3/10/16, 7/25/16 update	TPM10	Auxiliary Boiler firing natural gas	0.4	lb/hr avg of three 1-hour stack tests	Use of natural gas a clean burning fuel (80 MMBtuhr)
PSEG Fossil LLC Sewaren Generating Station	NJ-0084	3/10/16, 7/25/16 update	TPM2.5	Auxiliary Boiler firing natural gas	0.4	lb/hr avg of three 1-hour stack tests	Use of natural gas a clean burning fuel (80 MMBtuhr)

Appendix B
KNO Restart - RBLC Summary

KNO Restart

RBLC Search Summary

Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup

Unit 50- Waste Heat Boiler

Unit 51- Waste Heat Boiler

Unit 52- Waste Heat Boiler

Unit 53- Waste Heat Boiler

Unit 54- Waste Heat Boiler

Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
PSEG Fossil LLC Sewaren Generating Station	NJ-0084	3/10/16, 7/25/16 update	SO2	Auxiliary Boiler firing natural gas	0.12	lb/hr	Use of natural gas a low sulfur fuel (80 MMBtu/hr)
PSEG Fossil LLC Sewaren Generating Station	NJ-0084	3/10/16, 7/25/16 update	Sulfuric Acid (Mist, Vapors, etc)	Auxiliary Boiler firing natural gas	0.02	lb/hr	Use of natural gas a low sulfur fuel (80 MMBtu/hr)
Florida Power & Light - Okeechobee Clean Energy Center	FL-0356	3/9/16, 7/6/16 update	CO	Auxiliary Boiler, 99.8 MMBtu/hr	0.08	lb/MMBtu	Proper combustion prevents CO - only ng, limited to 2000 hours per year
Florida Power & Light - Okeechobee Clean Energy Center	FL-0356	3/9/16, 7/6/16 update	NOx	Auxiliary Boiler, 99.8 MMBtu/hr	0.05	lb/MMBtu	Low NOx burners - only ng, limited to 2000 hours per year
Florida Power & Light - Okeechobee Clean Energy Center	FL-0356	3/9/16, 7/6/16 update	TPM	Auxiliary Boiler, 99.8 MMBtu/hr	10	% Opacity	Use of natural gas with sulfur content less than 2 grains / 100 scf - only ng, limited to 2000 hours per year
Florida Power & Light - Okeechobee Clean Energy Center	FL-0356	3/9/16, 7/6/16 update	SO2	Auxiliary Boiler, 99.8 MMBtu/hr	2	gr s/100 scf gas	Use of low-sulfur gas - only ng, limited to 2000 hours per year
Florida Power & Light - Okeechobee Clean Energy Center	FL-0356	3/9/16, 7/6/16 update	CO2e	Auxiliary Boiler, 99.8 MMBtu/hr	No numeric limit	No numeric limit	Use of natural gas only - only ng, limited to 2000 hours per year
Florida Power & Light - Okeechobee Clean Energy Center	FL-0356	3/9/16, 7/6/16 update	NOx	Two Natural Gas Heaters	0.1	lb/MMBtu	Must have NOx emission design value less than 0.1 lb/MMBtu (fueled only with ng, may operate one at a time, 10 MMBtu/hr)
Florida Power & Light - Okeechobee Clean Energy Center	FL-0356	3/9/16, 7/6/16 update	SO2	Two Natural Gas Heaters	2	gr s/100 scf gas	Use of low-sulfur fuel (fueled only with ng, may operate one at a time, 10 MMBtu/hr)
Commercial Metals Company - CMC Steel Oklahoma	OK-0173	1/19/2016, 7/7/16 update	CO2e	Heaters (Gas-Fired)	120	lb/MMBtu	Natural Gas Fuel (Numerous gas-fired heaters will be installed. The application requested that the sizes all be kept confidential.)
Commercial Metals Company - CMC Steel Oklahoma	OK-0173	1/19/2016, 7/7/16 update	CO	Heaters (Gas-Fired)	0.084	lb/MMBtu	Natural Gas Fuel (Numerous gas-fired heaters will be installed. The application requested that the sizes all be kept confidential.)
Commercial Metals Company - CMC Steel Oklahoma	OK-0173	1/19/2016, 7/7/16 update	NOx	Heaters (Gas-Fired)	0.1	lb/MMBtu	Natural Gas Fuel (Numerous gas-fired heaters will be installed. The application requested that the sizes all be kept confidential.)
Commercial Metals Company - CMC Steel Oklahoma	OK-0173	1/19/2016, 7/7/16 update	TPM10	Heaters (Gas-Fired)	0.0076	lb/MMBtu	Natural Gas Fuel (Numerous gas-fired heaters will be installed. The application requested that the sizes all be kept confidential.)
Commercial Metals Company - CMC Steel Oklahoma	OK-0173	1/19/2016, 7/7/16 update	TPM2.5	Heaters (Gas-Fired)	0.0076	lb/MMBtu	Natural Gas Fuel (Numerous gas-fired heaters will be installed. The application requested that the sizes all be kept confidential.)
Commercial Metals Company - CMC Steel Oklahoma	OK-0173	1/19/2016, 7/7/16 update	VOC	Heaters (Gas-Fired)	0.0055	lb/MMBtu	Natural Gas Fuel (Numerous gas-fired heaters will be installed. The application requested that the sizes all be kept confidential.)
Equistar Chemicals, LP - Westlake Facility	LA-0295	7/12/16, 9/19/16 update	NOx	Firetube Boiler Nos. 1 and 2 (4-08, EQT 324 & 5-08, EQT 325)	2.75	lb/hr maximum	Flue gas recirculation and good combustion practices, including good equipment design, use of gaseous fuels for good mixing, and proper combustion techniques (63 MMBtu/hr - Natural Gas and Vent Gas). Aggregate NOx emissions from the boilers are capped at 10.05 TPY (GRP 11). Good combustion practices shall include monitoring of the flue gas oxygen content, combustion air flow, fuel consumption, and flue gas temperature. These parameters shall be maintained within the manufacturer's recommended operating guidelines or within a range that is otherwise indicative of proper operation of the emissions unit. The PSD permit also references the 30 ppmvd @ 3% O2 limit as a "three 1-hour testing average."

Appendix B
KNO Restart - RBLC Summary

KNO Restart
 RBLC Search Summary
 Search: "boiler","heater" - All Results for boilers <100 MMBtu/hr, not included in startup
 Unit 50- Waste Heat Boiler
 Unit 51- Waste Heat Boiler
 Unit 52- Waste Heat Boiler
 Unit 53- Waste Heat Boiler
 Unit 54- Waste Heat Boiler
 Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Equistar Chemicals, LP - Westlake Facility	LA-0295	7/12/16, 9/19/16 update	NOx	Firetube Boiler Nos. 1 and 2 (4-08, EQT 324 & 5-08, EQT 325)	30	ppmvd @ 3% O2 annual average	Flue gas recirculation and good combustion practices, including good equipment design, use of gaseous fuels for good mixing, and proper combustion techniques (63 MMBtu/hr - Natural Gas and Vent Gas). Aggregate NOx emissions from the boilers are capped at 10.05 TPY (GRP 11). Good combustion practices shall include monitoring of the flue gas oxygen content, combustion air flow, fuel consumption, and flue gas temperature. These parameters shall be maintained within the manufacturer's recommended operating guidelines or within a range that is otherwise indicative of proper operation of the emissions unit. The PSD permit also references the 30 ppmvd @ 3% O2 limit as a "three 1-hour testing average."
Equistar Chemicals, LP - Westlake Facility	LA-0295	7/12/16, 9/19/16 update	VOC	Firetube Boiler Nos. 1 and 2 (4-08, EQT 324 & 5-08, EQT 325)	0.21	lb/hr maximum	Oxidation catalyst and good combustion practices, including good equipment design, use of gaseous fuels for good mixing, and proper combustion techniques. (63 MMBtu/hr - Natural Gas and Vent Gas). Aggregate VOC emissions from the boilers are capped at 0.90 TPY (GRP 11). Good combustion practices shall include monitoring of the flue gas oxygen content, combustion air flow, fuel consumption, and flue gas temperature. These parameters shall be maintained within the manufacturer's recommended operating guidelines or within a range that is otherwise indicative of proper operation of the emissions unit. The PSD permit also references the 2.8 ppmvd @ 3% O2 limit as a "three 1-hour testing average."
Equistar Chemicals, LP - Westlake Facility	LA-0295	7/12/16, 9/19/16 update	VOC	Firetube Boiler Nos. 1 and 2 (4-08, EQT 324 & 5-08, EQT 325)	2.8	ppmvd @ 3% O2 annual average	Oxidation catalyst and good combustion practices, including good equipment design, use of gaseous fuels for good mixing, and proper combustion techniques. (63 MMBtu/hr - Natural Gas and Vent Gas). Aggregate VOC emissions from the boilers are capped at 0.90 TPY (GRP 11). Good combustion practices shall include monitoring of the flue gas oxygen content, combustion air flow, fuel consumption, and flue gas temperature. These parameters shall be maintained within the manufacturer's recommended operating guidelines or within a range that is otherwise indicative of proper operation of the emissions unit. The PSD permit also references the 2.8 ppmvd @ 3% O2 limit as a "three 1-hour testing average."
Flint Hills Resources Houson Chemical LLC - PL Propylene Houston Olefins Plant	TX-0803 (draft)	7/12/16, 8/31/16 update					Includes 5 turbines, 1 regen air heater, and one duct burner exhausting through one stack to provide regenerative hot air to catalyst beds
Subaru of Indiana Automotive, Inc.	IN-0239	2/18/16, 9/14/16 update	VOC	Boiler	0.005	lb/MMBtu	38 MMBtu/hr - Miscellaneous process heaters and boilers from (this is where the description ends...)
Pryor Plant Chemical Company	OK-0135	2/23/2009	CO	Boilers #1 and #2	6.6	lbs/hr 1 hour/8 hour	Good operating practices
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	CO	Boiler, NO. 9	0.09	lb/MMBtu	Unknown
Pryor Plant Chemical Company	OK-0135	2/23/2009	Formaldehyde	Boilers #1 and #2	0.1	lb/hr	unknown
Pryor Plant Chemical Company	OK-0135	2/23/2009	NOx	Boilers #1 and #2	4	lb/hr 3-H/168-H rolling d	Low NOx burners and good combustion practices
Pryor Plant Chemical Company	OK-0135	2/23/2009	NOx	Boilers #1 and #2	0.2	lb/MMBtu state limit	Low NOx burners and good combustion practices
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	NOx	Boiler, NO. 9	0.084	lb/MMBtu	Unknown
Pryor Plant Chemical Company	OK-0135	2/23/2009	PM	Boilers #1 and #2	0.6	lb/hr	Unknown

Appendix B
KNO Restart - RBLC Summary

KNO Restart

RBLC Search Summary

Search: "boiler", "heater" - All Results for boilers <100 MMBtu/hr, not included in startup

Unit 50- Waste Heat Boiler

Unit 51- Waste Heat Boiler

Unit 52- Waste Heat Boiler

Unit 53- Waste Heat Boiler

Unit 54- Waste Heat Boiler

Red = updated in 2022

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
Pryor Plant Chemical Company	OK-0135	2/23/2009	PM10	Boilers #1 and #2	0.5	lb/hr 24-hour	Unknown
Williams Refining & Marketing, L.L.C.	TN-0153	4/3/2002	PM10	Boiler, NO. 9	0.0075	lb/MMBtu	Unknown
Pryor Plant Chemical Company	OK-0135	2/23/2009	SO2	Boilers #1 and #2	0.2	lb/hr	Unknown
Pryor Plant Chemical Company	OK-0135	2/23/2009	SO2	Boilers #1 and #2	0.2	lb/MMBtu state limit	unknown
Pryor Plant Chemical Company	OK-0135	2/23/2009	VOC	Boilers #1 and #2	0.5	lb/hr	unknown

Notes:

Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.

Appendix B
KNO Restart - RBLC Summary

KNO Restart
RBLC Search Summary: Less than 500 HP Fire Pumps, 17.210 Fuel Oil

Unit 65 - Diesel Well Pump
Unit 66 - Gasoline Fire Pump
Did not update in 2017

Facility Name	RBLC ID	Permit Issue Date	Pollutant	Process Name	Emission Limit	Emission Limit Units	BACT Determination
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Carbon Dioxide Equivalent	Emergency Water Pumps	164	LB/MMBTU	Good Operating Practices
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Particulate matter, filterable	Emergency Water Pumps	1	G/BHP-HR	Good Operating Practices, limited hours of operation, Compliance with NSPS Subpart IIII
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Particulate matter, total	Emergency Water Pumps	1	G/BHP-HR	Good Operating Practices, limited hours of operation, Compliance with NSPS Subpart IIII
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Particulate matter, total	Emergency Water Pumps	1	G/BHP-HR	Good Operating Practices, limited hours of operation, Compliance with NSPS Subpart IIII
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Visible Emissions (VE)	Emergency Water Pumps	20	%	Good Operating Practices, limited hours of operation, Compliance with NSPS Subpart IIII
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Sulfur Dioxide (SO2)	Emergency Water Pumps	15	PPM SULFUR IN FUEL	Good Operating Practices, limited hours of operation, Compliance with NSPS Subpart IIII
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Volatile Organic Compounds	Emergency Water Pumps	1.12	G/BHP-HR	Good Operating Practices, limited hours of operation, Compliance with NSPS Subpart IIII
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Carbon Monoxide	Emergency Water Pumps	3.03	G/BHP-HR	Good Operating Practices, limited hours of operation, Compliance with NSPS Subpart IIII
BIG RIVER STEEL LLC	AR-0173	1/31/2022	Nitrogen Oxides (NOx)	Emergency Water Pumps	14.06	G/BHP-HR	Good Operating Practices, limited hours of operation, Compliance with NSPS Subpart IIII
LASALLE BIOENERGY LLC	LA-0386	5/5/2021	Particulate matter, total	Generators and Firewater Pumps Engines	0		Comply with 40 CFR 60 Subpart IIII
LASALLE BIOENERGY LLC	LA-0386	5/5/2021	Particulate matter, total	Generators and Firewater Pumps Engines	0		Comply with 40 CFR 60 Subpart IIII
LASALLE BIOENERGY LLC	LA-0386	5/5/2021	Volatile Organic Compounds	Generators and Firewater Pumps Engines	0		Comply with 40 CFR 60 Subpart IIII
LASALLE BIOENERGY LLC	LA-0386	5/5/2021	Carbon Monoxide	Generators and Firewater Pumps Engines	0		Comply with 40 CFR 60 Subpart IIII
LASALLE BIOENERGY LLC	LA-0386	5/5/2021	Carbon Dioxide Equivalent	Generators and Firewater Pumps Engines	0		Comply with 40 CFR 60 Subpart IIII
LASALLE BIOENERGY LLC	LA-0386	5/5/2021	Nitrogen Oxides (NOx)	Generators and Firewater Pumps Engines	0		Comply with 40 CFR 60 Subpart IIII
Iowa Fertilizer Company	IA-0105	10/26/2012	CH4	Fire Pump	0.0001	g/kw-hr average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	CO	Fire Pump	3.5	g/kw-hr average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	CO	Fire Pump	0.45	tons/year rolling 12 month total	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	CO2	Fire Pump	1.55	g/kw-hr average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	CO2e	Fire Pump	91	tpy rolling 12 month total	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Fire Pump	3.75	g/kw-hr average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	NOx	Fire Pump	0.49	tons/year rolling 12 month total	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Fire Pump	0.2	g/kw-hr average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM	Fire Pump	0.03	tons/year rolling 12 month total	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Fire Pump	0.2	g/kw-hr average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM10	Fire Pump	0.03	tons/year rolling 12 month total	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Fire Pump	0.2	g/kw-hr average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	PM2.5	Fire Pump	0.03	tons/year rolling 12 month total	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	Visible Emissions	Fire Pump	5	% 6 minute average	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	VOC	Fire Pump	0.25	g/kw-hr average of 3 stack tests	Good Combustion Practices
Iowa Fertilizer Company	IA-0105	10/26/2012	VOC	Fire Pump	0.03	tons/year rolling 12 month total	Good Combustion Practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO	Diesel-Fired Emergency Firewater Pump	2.6	g/hp-hr 3 hour average	good combustion practices
Ohio Valley Resources, LLC	TBD	9/25/2013	CO2	Diesel-Fired Emergency Firewater Pump	527.4	g/hp-hr 3 hour average	good combustion practices
Ohio Valley Resources, LLC	TBD	9/25/2013	NOx	Diesel-Fired Emergency Firewater Pump	2.86	g/hp-hr 3 hour average	good combustion practices
Ohio Valley Resources, LLC	TBD	9/25/2013	PM	Diesel-Fired Emergency Firewater Pump	0.15	g/hp-hr 3 hour average	good combustion practices
Ohio Valley Resources, LLC	TBD	9/25/2013	PM10	Diesel-Fired Emergency Firewater Pump	0.15	g/hp-hr 3 hour average	good combustion practices
Ohio Valley Resources, LLC	TBD	9/25/2013	PM2.5	Diesel-Fired Emergency Firewater Pump	0.15	g/hp-hr 3 hour average	good combustion practices
Ohio Valley Resources, LLC	TBD	9/25/2013	VOC	Diesel-Fired Emergency Firewater Pump	0.141	g/hp-hr 3 hour average	good combustion practices

Notes:
Highlighted fields represent the lowest limit in common units (e.g., lb/MMBtu). Other units may be shown; however, there is not enough information to convert to common units or averaging times.