

Table 1 - Private Well Analytical Results

| | | | Analyte | Perfluorooctane- sulfonic acid (PFOS) | Perfluorooctanoic acid (PFOA) | LHA Combined (PFOS + PFOA) |
|-------------|-------------|--|---------|--|----------------------------------|-------------------------------|
| | | EPA Lifetime Health Advisory (LHA) Level | | 70† | | 70† |
| Sample Name | Description | Depth | Date | ng/L | ng/L | |
| 536555-3 | | 228 feet (sub-permafrost) | 9/30/21 | 15 | 3.4 | 18 |
| 562637 | | Estimated 25 feet | 9/24/21 | 12 | 4.1 | 16 |
| 92924 | | 34 feet | 9/24/21 | 16 | 5.4 | 21 |
| 95443 | | Estimated less than 50 feet | 10/1/21 | 11 | 4.0 | 15 |

ng/L nanograms per liter, equivalent to parts per trillion (ppt)

EPA U.S. Environmental Protection Agency

LHA Lifetime Health Advisory

† EPA LHA level is 70 n/gL for PFOS and PFOA combined. Action Level for drinking water.