

**Table 3 - June 2022 Water Supply Well PFAS Analytical Results**

Analyte	EPA LHA	Units	ILI-001		ILI-013
			ILI-001	ILI-101	ILI-013
Perfluorohexanesulfonic acid (PFHxS)	N/A	ng/L	19	21	28
Perfluorohexanoic acid (PFHxA)	N/A	ng/L	5.3	5.2	4.8
Perfluoroheptanoic acid (PFHpA)	N/A	ng/L	0.53 J	0.52 J	0.60 J
Perfluorononanoic acid (PFNA)	N/A	ng/L	<1.9	<1.8	<1.9
Perfluorobutanesulfonic acid (PFBS)	N/A	ng/L	6.8	7.1	9.1
Perfluorodecanoic acid (PFDA)	N/A	ng/L	<1.9	<1.8	<1.9
Perfluoroundecanoic acid (PFUnA)	N/A	ng/L	<1.9	<1.8	<1.9
Perfluorododecanoic acid (PFDoA)	N/A	ng/L	<1.9	<1.8	<1.9
Perfluorotridecanoic acid (PFTTrDA)	N/A	ng/L	<1.9	<1.8	<1.9
Perfluorotetradecanoic acid (PFTeA)	N/A	ng/L	<1.9	<1.8	<1.9
N-Methyl perfluorooctane sulfonamidoacetic acid (N-MeFOSAA)	N/A	ng/L	<1.9	<1.8	<1.9
N-Ethyl perfluorooctane sulfonamidoacetic acid (N-EtFOSAA)	N/A	ng/L	<1.9	<1.8	<1.9
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	N/A	ng/L	<1.9	<1.8	<1.9
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	N/A	ng/L	<1.9	<1.8	<1.9
4,8-Dioxa-3H-perfluorononanoic acid (DONA)	N/A	ng/L	<1.9	<1.8	<1.9
Hexafluoropropylene oxide dimer acid (HFPO-DA)	N/A	ng/L	<1.9	<1.8	<1.9
Perfluorooctanesulfonic acid (PFOS)		ng/L	11	12	24
Perfluorooctanoic acid (PFOA)	70†	ng/L	0.77 J	0.65 J	1.1 J
LHA Combined (PFOS + PFOA)	70†	ng/L	12 J	13 J	25 J

Notes: Sample *ILI-101* is a field duplicate sample of *ILI-001*.

Results reported from Eurofins Environment Testing America work order 320-88822-1.

† EPA LHA level of 70 ppt for PFOS and PFOA combined is referenced.

N/A No applicable regulatory limit exists for the associated analyte.

< Analyte was not detected; reported as <Reporting Limit (RL).

J Estimated concentration, detected greater than the MDL and less than the RL. Flag applied by the laboratory.

EPA = United States Environmental Protection Agency; MDL = method detection limit; PFAS = per- and poly-fluoroalkyl substances; ng/L = nanograms per liter