

Alaska Department of Environmental Conservation

Underground Storage Tank Program

UST Public Record Program Information for Federal Fiscal Year 2008 (1 October 2007 to 30 September 2008)

General Information:

Posted Date: March 17, 2009

Total Number of UST Facilities: 511

Total Number of Active USTs: 1,198

Summary Information for On-Site Inspections:

Total Number of UST Facilities Inspected: 183

Inspection Period: 1 May 2008 to 30 Sept 2008

Percent Compliance: 55%

The number of tanks is the total number of tanks regulated under the definition of an Underground Storage Tank contained in 40 CFR 280.12 with the exception of those identified in 40 CFR 280.10(b) and 280.10(c) as excluded or deferred from current regulations. Percent compliance is the number of facilities that had no significant operational compliance issues for release detection or release prevention requirements. The most common issue is failure to maintain leak detection records.

Summary Information on releases

Number of confirmed Releases: 13

Release reporting period dates: 1 October 2007 to 30 Sept 2008

The below table provides summary information for release cause and the source:

SOURCE		CAUSES														
		SPILL		Overfill		Phys/Mech Problems		Corrosion		Install Problem		Other		Unknown		
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
TANK	7	54	0	0	1	14	0	0	3	43	0	0	0	0	3	43
PIPING	2	15	0	0	0	0	2	100	0	0	0	0	0	0	0	0
DISPENSER	2	15	0	0	0	0	2	100	0	0	0	0	0	0	0	0
*STP	1	8	0	0	0	0	0	0	0	0	0	0	1	100	0	0
DELIVERY PROBLEM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
OTHER	1	8	0	0	0	0	0	0	0	0	0	0	0	0	1	100
TOTALS	13	100	0	0	1	8	4	31	3	23	0	0	1	8	4	31

*Submersible Turbine Pump Area

Release, source and cause information is based on USTs regulated under Subtitle I that satisfies the definition of a UST in 40 CFR 280.12, except those USTs identified in 40 CFR 280.10(b) as excluded USTs. USTs deferred in 40 CFR 280.10(c) and those for emergency power generation deferred for release detection by 40 CFR 280.10(d) are included as part of this public record.

Information concerning Leaking Underground Storage Tank sites, specific spill information and all underground storage tank facilities can be accessed here:

http://www.dec.state.ak.us/spar/csp/db_search.htm