

**ALASKA DEPARTMENT OF ENVIRONMENTAL CONSERVATION**  
**Division of Spill Prevention and Response**  
**Prevention and Emergency Response Program**

**SITUATION REPORT**

**INCIDENT NAME:** H&H Contractors gasoline release                      **SITREP#:** 2 and final

**SPILL NUMBER:** 03309931601    **LEDGER CODE:** Not requested.

**TIME/DATE OF SPILL:** H&H Contractors estimated that the spill occurred on Wednesday, November 12, 2003 at 7:00 PM. The spill was reported to AST dispatch at approximately 7:30 AM on Thursday, November 13, 2003, who faxed the spill report to DEC that morning.

**TIME/DATE OF SITUATION REPORT:** 2:30 PM Thursday April 15, 2004

**TIME/DATE OF THE NEXT REPORT:** This is the final report.

**TYPE/AMOUNT OF PRODUCT SPILLED:** H&H contractors initially reported it as a spill greater than 55 gallons of gasoline. They then later revised the estimate of volume spilled as 2,400 gallons.

**LOCATION:** The spill occurred on Marion Drive in Fairbanks, AK. Marion Drive is a dead end street within an industrial area. Traffic in this area is generally limited to the H&H shop traffic.

**CAUSE OF SPILL:** A 5,000 gallon gasoline holding tank was pierced by a loader working the area.

**POTENTIAL RESPONSIBLE PARTY (PRP):** H&H Contractors, Inc.

**RESPONSE ACTION:** The area was cordoned off last winter after contaminated snow removal to limit traffic in the area. Visqueen was placed over the spill site to limit the amount of snow contacting the affected area.

This spring the snow was removed from atop the visqueen. A layer of soil that was on the surface of the asphalt lot was removed. An ADEC responder inspected the site on April 12, 2004 and verified that all contaminated material has been removed and that the site does not pose a threat to human health or the environment.

**SOURCE CONTROL:** The 5000 gallon tank was elevated on one side and braced with cribbing to keep the gasoline from pouring out of the puncture.

**RESOURCES AFFECTED:** A 100' by 50' area of snow/ice covered asphalt road. There are no water bodies in the vicinity that could be affected by the spill.

**FUTURE PLANS AND RECOMMENDATIONS:** DEC issued a "No Further Action" letter to H & H Contractors, Inc. on April 15, 2004.

**WEATHER:** Mostly cloudy, highs 45 – 50 with east winds to 10 mph.

**UNIFIED COMMAND AND PERSONNEL:**

Incident Commander .....	Tom Williams, H&H Contractors, Inc.
F.O.S.C.....	Matt Carr, EPA
S.O.S.C.....	Ed Meggert, ADEC
Field S.O.S.C.....	Amanda Leffel, ADEC

**FOR ADDITIONAL INFORMATION CONTACT:** Amanda Leffel, 451-2175

**AGENCY/STAKEHOLDER NOTIFICATION LIST**

Agency/Organization	Sent via	Additional Info	Telephone	FAX
ADNR	Fax		451-2724/ 451-2732	451-2751
ADF&G	Fax		459-7285 or 459-7279	456-3091
USEPA	Fax		271-5083 or (800) 424-9346	271-3424
<b>Legislature</b>				
Legislator (Senate E)	Fax	Fairbanks	465-3709	465-4714
Legislator (Senate D)	Fax	Fairbanks	465-2327	465-5241
Legislator (Senate F)	Fax	North Pole	465-4797 or (800) 860-4797	465-3884
Legislator (House 8)	Fax	Fairbanks	465-4457 or (800) 928-4457	465-3519
Legislator (House 9)	Fax	Fairbanks	465-3466	465-2937
Legislator (House 10)	Fax	Fairbanks	465-3004 or (877) 465-3004	465-2070
Legislator (House 11)	Fax	North Pole	465-3719 or (877) 465-3719	465-3258
Legislator (House 7)	Fax	Fairbanks	465-4976	465-3883
<b>Local Government:</b>				
Fairbanks North Star Borough	Fax	Mayor	459-1304	459-1102
City of Fairbanks	Fax	Mayor	459-6793	459-6710
City of Fairbanks	Fax	Chief (fire/police)	459-6500 x 6604	459-6804
City of Fairbanks	Fax	Deputy Chief (fire/police)	459-6500 x 6512	452-1588
City of North Pole	Fax	Mayor	488-2281	488-3002



Cleaned up spill site.  
Photo taken April 12, 2004