

**ALASKA DEPARTMENT OF ENVIRONMENTAL CONSERVATION
Division of Spill Prevention and Response
Prevention and Emergency Response Program**

SITUATION REPORT

INCIDENT NAME: Buckland KAE Diesel Fuel Spill **SITREP #:** 4

SPILL NUMBER: 08389909601 **LEDGER CODE:** 14257460

TIME/DATE OF SPILL: Kuskokwim Architect Engineers (KAE) discovered the spill on April 5, 2008 at approximately noon. KAE reported the spill to ADEC via the Alaska State Troopers on April 5, 2008 at 2:35 PM.

TIME/DATE OF SITUATION REPORT: 2:00 PM, April 17, 2008

TIME/DATE OF THE NEXT REPORT: As the situation warrants.

TYPE/AMOUNT OF PRODUCT SPILLED: On April 10, 2008 after further site assessment, tank gauging and reviewing fuel records, KAE and ADEC estimated that 7,750 gallons of No. 1 diesel fuel spilled.

LOCATION: Old Buckland Tank Farm, Buckland.

CAUSE OF SPILL: A fuel transfer pipe located under the pump shed cracked and spilled the fuel. The cause of the crack is under investigation by ADEC and KAE.

POTENTIAL RESPONSIBLE PARTY (PRP): Kuskokwim Architect Engineers (KAE)

RESPONSE ACTION: Responders have recovered pooled fuel from under ice as well as from a frozen wetland. Approximately 2600 gallons of fuel have been recovered so far.

Contaminated soil is being removed from the area affected by the spill. Contaminated soil will be placed in super-sacks until a disposal plan is developed. KAE and responders continued using a small loader, excavator, dozer, and hand tools to segregate clean snow from contaminated snow. One hundred and seventy cubic yards of contaminated snow removed previously has been melted and treated before it was discharged

One Alaska Chadux responder and one ADEC responder are on site supporting the response. Responders have begun working one 12-hour shift per day.

SOURCE CONTROL: KAE isolated the line and shut off the valves on the 40,000 gallon vertical fuel storage tank.

RESOURCES AFFECTED: KAE and ADEC estimate the diesel fuel impacted 5,850 square feet of a frozen wetland area. The area was covered by approximately three feet of snow at the time of the spill.

FUTURE PLANS AND RECOMMENDATIONS: On-scene responders developed a cleanup plan and are operating with a 12-hour operational period Incident Action Plan. Contaminated soil is being removed from the area affected by the spill. Contaminated soil will be placed in super-sacks when they arrive in Buckland.

WEATHER: Cloudy -0° F., calm conditions.

UNIFIED COMMAND AND PERSONNEL:

Incident Commander: Steve Markel (KEA)
F.O.S.C. :
S.O.S.C. : Ed Meggert (ADEC)
Field S.O.S.C.: Wesley Ghormley (ADEC)

FOR ADDITIONAL INFORMATION CONTACT: ADEC: Ed Meggert at 451-2124.

Photographs and other spill information are available for viewing at:

<http://www.state.ak.us/dec/spar/perp/index.htm>

AGENCY/STAKEHOLDER NOTIFICATION LIST

This sitrep has been distributed via email to the Governor's office, Senator Stevens' office, ADF&G, ADNR, SECC, USEPA, USDOJ, NMFS, USFWS, USFS and NOAA in addition to the following.

STATE AGENCY	NAME	SENT VIA	ADDITIONAL INFO	TELEPHONE	FAX
ADNR	Leon Lynch/ Gary Schultz/ Larry Byrne	Fax		451-2724/ 451-2732	451-2751/ 659-2965
ADNR (Habitat)	Al Ott/Jack Winters	Fax		459-7285/459-7279	459-7303
ADF&G	Todd Nichols	Fax		459-7363	459-7347
EPA	Matt Carr/Carl Lautenberger	Fax		271-5083/257-1342	271-3424
Attorney General Office	Cam Leonard/ Steve Mulder	Fax		451-2811/451-2914	451-2985/ 278-7022
Legislature					
Governor's Office (Fairbanks)	Palin/Parnell	Fax		451-2920	451-2858
Legislator (Senate T)	Donnie Olson (D)	Fax	Nome	465-3707	465-4821
Legislator (House 40)	Reggie Joule (D)	Fax	Kotzebue	465-4833/ (800) 782-4833	465-4586
Other Agencies:					
North West Arctic Borough	Siikauraq Martha Whiting	Fax	Mayor	442-2500	442-2930
Alaska Chadux Corp.	Bob Heavilin	Fax		348-2375	348-2330