

ALASKA DEPARTMENT OF ENVIRONMENTAL CONSERVATION
Division of Spill Prevention and Response
Prevention and Emergency Response Program

SITUATION REPORT

INCIDENT NAME: Unalakleet Power House Tank Overfill **SITREP #:** 2

SPILL NUMBER: 10389934701

LEDGER CODE: 14306960

TIME/DATE OF SPILL: 5:00PM, December 12, 2010.

TIME/DATE OF SITUATION REPORT: 3:30PM, December 16, 2010.

TIME/DATE OF THE NEXT REPORT: As the situation warrants.

TYPE/AMOUNT OF PRODUCT SPILLED: To determine the relative quantity released, the Unalakleet Valley Electric Cooperative reviewed fuel records and estimated the spilled amount to be 10,930 gallons of #2 diesel fuel.

LOCATION: Unalakleet, Alaska

CAUSE OF SPILL: Tank over-fill during fuel transfer operations.

POTENTIAL RESPONSIBLE PARTY (PRP): Unalakleet Valley Electric Cooperative

RESPONSE ACTION: Fuel recovery began with a pump set at the low point drain, transferring the free liquids to two 5,000 gallon tanks within the containment area. A volume of approximately 5890 gallons of fuel has been recovered as of noon today. Fuel may have migrated beneath the ice layer in the containment area, but the snow/ice coverage was reported as "light with some drifts." An ADEC responder is on-scene in Unalakleet to aid with the cleanup process. Snow is being removed from around the secondary containment for visual confirmation that the containment is not leaking.

SOURCE CONTROL: Source is controlled.

RESOURCES AFFECTED: None. The fuel spilled within the secondary containment.

FUTURE PLANS AND RECOMMENDATIONS: Continue the removal of free liquids from inside the containment area. Complete snow removal from around the outside of the containment area to ensure that containment is not leaking. A plan is under development to remove the contaminated snow and ice from the containment area, melt it, and recover the fuel that is separated from the water, which will be treated and discharged.

WEATHER: Temperatures between 0-15 below zero, wind will be 15 mph out of the East.

UNIFIED COMMAND AND PERSONNEL:

Incident Commander:

S.O.S.C.: Tom DeRuyter

Field S.O.S.C.: John Ebel

FOR ADDITIONAL INFORMATION CONTACT: Tom DeRuyter at 907-451-2145

AGENCY/STAKEHOLDER NOTIFICATION LIST

This sitrep has been distributed to the following agencies and stakeholders. The situation report was also distributed to the various agency staff listed on the standard distribution list. The receiving agencies listed in the standard distribution list includes: Governor's office, Senator Begich's office, ADF&G, ADNR, SECC, EPA, DOI, NMFS, and USFWS.

AGENCY/STAKEHOLDER	NAME	SENT VIA	ADDITIONAL INFO	TELEPHONE	FAX
Alaska State Troopers	Kotzebue	Fax		442-3222	442-3564
Alaska State Troopers	Nome	Fax		443-2835	443-5840
ADNR	Gary Schultz/ Melissa Head/ Sean Willison	Fax		451-2732/ 451-2719/ 451-2724	451-2751 or 659-2965
AF&G (Habitat)	Al Ott/Jack Winters	Fax		459-7285 or 459-7279	459-7303
EPA	Matt Carr/Robert Whittier	Fax		271-5083 or 271-3247	271-6340
Attorney General Office	Cam Leonard/ Steve Mulder	Fax		451-2811/451-2914	451-2985/ 278-7022
House/Anchorage		Fax	Anchorage/Fairbanks 5/16 – 1/09 Juneau 1/10 – 5/15		
Senate/Anchorage		Fax	Anchorage/Fairbanks 5/16 – 5/09 Juneau 1/10 – 5/15		
Governor's Office (Fairbanks)	Parnell/Treadwell	Fax		451-2920	451-2858
Lt. Governor's Office (Juneau)	Parnell/Treadwell	Fax			465-5400
Senator Murkowski's Washington DC Office	Chief of Staff	Fax		(202) 224-6665	(202) 224-5301
Senator Murkowski's Office in Fairbanks		Fax		456-0233	451-7146
Legislator (Senate T)	Donnie Olson (D)	Fax	Nome	465-3707	465-4821
Legislator (House 39)	Neal Foster (D)	Fax	Nome	465-3789 or (800) 478-3789	465-3242
Legislator (House 40)	Reggie Joule (D)	Fax	Kotzebue	465-4833 or (800) 782-4833	465-4586
North West Arctic Borough	Siikauraq Martha Whiting	Fax	Mayor	442-2500	442-2930

