

VSW Plan / Study / Report Review Status as of 9/1/2017

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date
Adak	Water & Sewer Downsizing Feasibility Study	Sep-04	Approved.
Adak	Water Treatment Plant PER	Jun-17	Approved. WTP siting, direct filtration, prefabricated building.
Akiachak	Piped Water and Sewer System PEP	Sep-04	Approved.
Alakanuk	Feasibility Study Water & Sewer for Service Area 7	Jan-02	Not approved.
Aleknagik	Water and Sewer Feasibility Study	Jun-07	Approved.
Ambler	Water, Sewer & Solid Waste Facilities MP Update	May-03	Phases 1-4 approved. Phase 5 not approved.
Ambler II	Sanitation Master Plan Update	Dec-11	Approved
Anchor Point	Sewer Feasibility Study	Apr-07	Approved
Anchor Point	WTP Deficiencies and Upgrade Evaluation	May-07	Approved
Angoon	Sanitation Facilities Master Plan	Apr-06	Phase 3 approved. Ph 1&2 to be revisited. Ph 4 disapproved.
Angoon	Aanya Street Sewer Main 65% PER	Aug-17	Critical Comments need to be addressed before review can be completed.
Anvik	Water and Sewer Feasibility Study	Jun-06	Approved
Arctic Village	Sanitation Water & Sewer Haul Feasibility Study	Sep-06	Approved
Atka	2008 Update to the 2001 Sanitation Feasibility Study	May-08	Items 4-6 approved. Items 7-12 not approved.
Atmautluak	Sanitation Facilities Master Plan	Jun-15	Not approved: piped water and pressure sewer system due to costs totaling ~\$33 million, a capital cost per home of approximately \$460,000.
Bethel	Water & Sewer Facilities Master Plan Update	Apr-05	Approved
Brevig Mission	Sanitation Facilities Master Plan	Oct-10	Approved, contingent upon proj submittal to SDS
Buckland	Landfill Preliminary Engineering Report Revision 2	Sep-16	Approved, being a solid waste project, it may not score highly enough for federal funding
Chalkyitsik	Water & Sewer Feasibility Study	Jun-01	Approved.
Chalkyitsik II	Water & Sewer Feasibility Study Update	Mar-15	Approved: Existing Systems Deficiencies. Not approved: biomass boiler and water self-haul with separating toilets (Kivalina/ANTHC's PASS).
Chenega Bay	Water and Sewer Feasibility Study	May-13	Approved: Phase I (sludge disposal site) and Phase II (sewer system repairs). Disapproved: Phase III (water and sewer service to future subdivision).
Chevak	Sanitation Facilities Master Plan	Mar-14	Approved
Chignik Bay	Water and Sewer Master Plan Update	May-07	Phases 1-4 approved. Phase 5 not approved.
Chignik Lake	Water & Sewer System Feasibility Study	Sep-00	Approved
Coffman Cove	Water & Sewer Feasibility Study	Sep-04	Phases 1-2 approved. Phases 3-8 not approved.
Coffman Cove	Luck Point Sewer Study Draft PER	Mar-17	Approved. However, project may not score highly enough for funds.
Crooked Creek	Water & Sewer Conceptual Design Report	Feb-12	Not approved.
Diomedea	Solid Waste Preliminary Engineering Report	Feb-04	Not approved.
Eagle Village	Sanitation Facilities Feasibility Study/Master Plan	May-01	Approved

VSW Plan / Study / Report Review Status as of 9/1/2017

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date
Eek	Water and Sewer Master Plan	Aug-04	Addendum/update approved
Eek	Water and Sewer Master Plan Update	Jul-08	Approved
Eek	Water and Sewer Project -- Master Plan Update	Nov-16	Approved. Originally sent June 2016 lacking info; attachment #6 added.
Ekwok	Wastewater System Preliminary Engineering Report	Jun-06	Approved
Elfin Cove	Water and Sewer Feasibility Study	Jan-13	Not approved (pop considerations, etc.)
Elim	Sanitation Facilities Master Plan	Jan-11	Phases 2, 3, 4, and 5 approved.
Elim II	Shelby Subdivision Master Plan Update	Aug-15	Approved. But must submit separate funding requests for each phase.
Emmonak	Water Distrib & Vacuum Sewage Collection Upgrade	May-08	Phase 1 & 2 approved. Phase 3 not approved.
False Pass	On-site Wastewater Systems PER	Mar-17	Approved. However, project may not score highly enough for funds.
Gambell	Water, Sewer, & Solid Waste Eng Feasibility Study	Dec-03	R&R + upgrade components approved.
Glennallen	Water Improvement Feasibil Study Addendum, Ph 1-	May-09	Approved
Golovin	Sanitation Facilities Master Plan Update	Dec-12	Upon review of additional estimates sent March 2016, the following was approved: pipes for upper village, rehabilitation of raw water intake, and sewage lagoon rehabilitation.
Grayling	Sanitation Facilities Project PER	Jun-17	Critical Comments need to be addressed before review can be completed.
Gulkana	Sanitation Master Plan/Feasibility Study	May-04	WTP only approved.
Hooper Bay	Water Treatment Study	Mar-01	Approved
Hoonah	Sanitation Facilities Master Plan Update – Final Repo	Mar-16	Approved: Phases 1, 2, and 3 after resubmitting with additional info requested. Originally submitted June 2016 but was not unclear what top priority project for Capital Improvement was.
Hughes	Eng Feasibility Study Update (as amended in 2006)	Jun-06	Approved
Hughes	Feasibility Engineering Study and Addendum	Feb-07	Approved
Huslia	Sanitation Facilities Improvement Plan	Dec-01	Approved
Huslia	W&S Connections for Homes Outside the Piped Area	Mar-17	Approved.
Iliamna	Sludge Disposal Preliminary Engineering Report	Feb-17	Not officially reviewed by SOA as EPA declined to fund project.
Kachemak Selo	Water System Feasibility Study	Dec-11	1st 3 priorities approved ONLY.
Karluk	Sanitation Facilities Master Plan	Sep-06	Approved
Karluk II	Sanitation Facilities Master Plan	Aug-15	Not approved. Capital cost of upgrades is extremely high.
Karluk III	Water Master Plan Addendum	Jun-17	Not approved.
Kasaan	Water & Sewer Master Plan + Update	Jan-07	Phase 1 only approved.
Kasaan	Water Distribution System PER	Mar-17	Not approved. Scope associated with O&M, not capital cost project.
Kiana	Sanitation Facilities Master Plan Update	Sep-11	Manhole repairs (\$50K), service line installations (\$80K), and Jackson service lines (\$50K) approved.

VSW Plan / Study / Report Review Status as of 9/1/2017

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date
Kiana II	Master Plan Update - Valley View Subdivision Ph 1	Dec-14	Approved: Revisions made to Phase 1 accomodating 5 new homes, specifically modifications to the gravity sewer collection main lines, lift station, water distribution main lines and number of homes served.
Kipnuk	Sanitation Facilities Master Plan	Apr-02	Not approved
Kipnuk II	Sanitation Facilities Master Plan Update	Dec-15	Approved following upgrades to existing facilities: Raise Raw Water Reservoir Berms and Raise Community Sewage Lagoon Berm. Disapproved: Piped system and 4 recommended upgrades.
Klukwan	Sewer Feasibility Study	Jun-06	Approved
Kobuk	Sanitation Facilites Plan	Apr-12	Approved except for new WST.
Kokhanok	Water and Wastewater Feasibility Study	Feb-11	Approved
Koliganek	Sanitation Facilities Master Plan	Oct-06	Approved
Koliganek II	New Koliganek Water Leak Study	Mar-13	Approved: replacement of pipes for supply and return. Not approved: replacement of entire main.
Kongiganak	Sanitation Facilities Master Plan Update	Aug-03	Approved
Kotzebue	Sanitation Utilities Development Plan	Jul-05	Approved
Koyuk	Koyuk Sanitation Facilities Improvement Plan	Aug-10	Approved except for Ph I (H ₂ O study) + II (new H ₂ O source)
Kwethluk	Water and Sewer Master Plan Update	Mar-11	Approved
Levelock	Wastewater Feasibil Study&Drainfield Failure Investi	Jan-13	Approved: replacement of 8 septic systems.
Lowell Point	Water and Sewer Feasibility Study	Nov-08	Approved
Lower Kalskag	Master Plan Capital Cost Update	May-08	Approved
Marshall	Marshall Lagoon Study	Jan-08	Approved
McGrath	Water & Sewer System Evaluation and Master Plan	Aug-03	Approved
McGrath	Wastewater Collection & Treatment PER	Aug-17	Approved on 8/4/2017
Metlakatla	Disinfection Byproduct Reduction & Pipe Corrosion	May-17	Approved, but requires two separate funding applications
Mountain Village	W&S Feasibility Study and Master Plan	Mar-11	More information requested.
Nanwalek	Water Source, Transmission and Distribution Report	Oct-06	Approved
Nanwalek	Masterplan Update	Sep-16	Only approved: Replace water distribution system (Sub-phases 1, 2, 3) and Solid Waste Landfill (though federal funds may not be available)
Nelson Lagoon	Water System Improvement Plan	Sep-02	Approved
Nenana	Sanitation Facilities Master Plan	Jul-05	Tasks 1-9 approved. Tasks 10-14 not approved.
Newhalen	Water and Wastewater Feasibility Study	Sep-06	Approved
Nightmute	Water & Sewer Improvement Feasibility Study	Aug-04	Approved
Nikolaevsk	Water Facilities Feasibility Study	Dec-06	Approved

VSW Plan / Study / Report Review Status as of 9/1/2017

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date
Nikolaevsk	Water System Improvements PER	Apr-17	WST Freeze Protection & Backup Water Source approved; Water Service to Unserved Residences not approved due to inadequate documentation.
Nikolai	Sanitation Facilities Master Plan	Jun-05	Approved
Nikolski	Utility Master Plan Update	Apr-07	Approved
Noatak	Water, Sewer & Solid Waste Facilities MP Update	May-03	Phases 1-4 & 8 approved. Ph 5, 6, 7, 9 & 10 disapproved.
Nondalton	Water & Sewer Engineering Feasibility Study	Aug-03	Approved
Noorvik	Sanitation Facilities Master Plan Update	Sep-04	Phases 1-3 approved. Phase 4 not approved.
Nulato	Water and Sewer Feasibility Study	May-07	Phases 1-3 approved
Nunapitchuk	Haul Lagoon Improvements Draft PER	Mar-17	Approved on 8/4/2017
Old Harbor	Water Distribution System PER	Feb-17	Not approved. Scope associated with O&M, not capital cost project.
Ouzinkie	Utilities Master Plan	Dec-00	Approved
Pelican	Water and Sewer Preliminary Engineering Report	Jun-05	Phases 1-2 approved. Phase 3 not approved
Perryville	Sanitation Feasibility Study	May-14	Not approved. Need for additional information: key elements needed in WTP, discussion and evaluation of various alternatives for WTP, realistic estimate of construction costs for a modular WTP.
Pilot Station	Landfill Relocation Feasibility Study	Sep-04	Approved
Pilot Station	Lagoon Relocation Feasibility Study	Jun-05	Approved
Port Graham	Outfall Consolidation Report	Jun-06	Approved.
Port Heiden	Sanitation Improvements Feasibility Study	May-04	Approved
Port Protection	Wastewater Engineering Study	Aug-04	Approved
Ruby	Sanitation Facilities Master Plan	Jun-01	Approved
Saint George	Water and Sewer Utility Plan Update	Apr-07	Approved
Saint George	Water Storage Preliminary Engineering Report	Jun-17	Approved. However, project may not score highly enough for funds.
Saint Mary's	Water & Wastewater Feasibility Study	May-06	Approved
Saint Paul	Ellerman Heights Sewer System Improv Feasibil Stud	Jul-05	Approved
Saxman	Water and Wastewater Facility Master Plan Update	May-07	Ph 1, 2 & 4 approved. Ph 3 approved for KGB connect. Ph 5 not approved.
Selawik	Water & Sewer Expansion Feasibility Study	Mar-05	Phase 1 approved. Phases 2-3 not approved.
Shageluk	Sanitation Facilities Master Plan Amendment	Aug-11	Approved for exploratory well drilling only at this time.
Shageluk	Preliminary Eng Report Water & Sewer System	Mar-16	Critical comments; pending ANTHC response.
Shaktoolik	Sanitation Master Plan	Jun-11	Approved
Shaktoolik	Sanitation Facilities Plan	Apr-13	Ph 1,2,& 3 approved. Fututre apps must be made incrementally.
Shishmaref	Sanitation Facilities Master Plan	Sep-10	Phases 1,2,4,5 & 6 approved. Phase 3 not approved.

VSW Plan / Study / Report Review Status as of 9/1/2017

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date
Shungnak	Sanitation Facilities Plan	Apr-12	Approved
Slana	Water & Sewer Feasibility Study	Apr-99	Approved
Sleetmute	Sanitation Facilities Improvement Plan 2002 Update	Sep-02	Approved
South Naknek	Wastewater Upgrades PER	Jun-17	Not approved.
Stebbins	Community Development Plan - Addendum	May-10	Not approved.
Tanacross	Sanitation Master Plan Update	Jan-06	Components 1-2 approved. Other components not approved.
Tanana	Water and Sewer Feasibility Study Update	Feb-06	Phases 1-3 approved. Phases 4-9 not approved
Teller	Sanitation Master Plan	May-14	Approved
Tetlin	Sanitation Facilities Master Plan Update	Mar-15	Not approved. Need for additional info listed in review letter.
Tetlin	Sewage Lagoon Upgrades PER	Feb-17	Approved. Repair wastewater lagoon for \$973,161.00
Thorne Bay	Water Treatment Plant Improvements PER	Jun-17	Approved. (Facility upgrades and Nanofiltration)
Tuluksak	Supplement to Preliminary Engineering Study	Mar-06	Approved
Tununak	Water Treatment Plant and Washeteria PER	Apr-17	Approved
Twin Hills	Sanitation Facilities Master Plan	May-07	Ph 1 & 4 approved. Ph 2, 3 & 5 not approved
Tyonek	Surface Water Source, Treatmnt & Distribut Study	Dec-04	Not approved
Unalakleet	Happy Valley Lift Station Project PER	Apr-17	Approved
Venetie	Sanitation Facilities Master Plan/Feasibility Study	Jan-05	Approved
Venetie	Sanitation Facilities Master Plan Update	Jan-17	Phase 1 (New WTP) and Phase 3 (Landfill upgrades) approved.
Venetie	Water Treatment Plant and Washeteria Facility PER	Jun-17	Approved (Modular Water Treatment Plant with Mechanical Reuse)
Wales	Sanitation Facilities Master Plan	Sep-02	Approved for washeteria and WTP
White Mtn	Sanitation Facilities Improvement Plan	Sep-04	Phases 1 and 2 approved. Phase 3 not approved.
Whittier	Water System Master Plan	Jun-05	Phase III approved
Yakutat	City and Borough Water & Sanitation Systems PER	Jun-17	5 projects approved. Not approved: Airport Service Area Wastewater Improvements

= Most recent reviews coordinate by Fátima

red font = Pending review from VSW