

Technical Analysis Report
For the terms and conditions of
Construction Permit AQ1524CPT01

Issued to Alaska Gasline Development Corporation
For the Gas Treatment Plant

Alaska Department of Environmental Conservation
Air Permits Program

Prepared by Dave Jones
Reviewed by Aaron Simpson

Preliminary – July 12, 2019

1. INTRODUCTION

This Technical Analysis Report (TAR) provides the Alaska Department of Environmental Conservation's (Department's) basis for issuing Construction Permit AQ1524CPT01 to the Alaska Gasline Development Corporation (AGDC) for the Gas Treatment Plant (GTP). The project triggers Prevention of Significant Deterioration (PSD) review under 18 AAC 50.306 for oxides of nitrogen (NO_x), sulfur dioxide (SO₂), carbon monoxide (CO), particulate matter (PM), particulate matter with an aerodynamic diameter not exceeding 10 microns (PM-10), particulate matter with an aerodynamic diameter not exceeding 2.5 microns (PM-2.5), volatile organic compounds (VOC), and greenhouse gases (GHG). The project is also classified under 18 AAC 50.316 as a major source of Hazardous Air Pollutants (HAPs) for formaldehyde.

1.1 Description of Source

GTP is a new stationary source located on Alaska's North Slope in the Prudhoe Bay Unit (PBU), approximately 8.5 miles north-northwest of Deadhorse. It is classified as a crude petroleum and natural gas facility under Standard Industrial Classification code 1311 and under North American Industrial Classification code 486210 for pipeline transportation of natural gas.

1.2 Application Description

AGDC submitted an initial application for this project on December 28, 2017. They retransmitted the application on February 14, 2018 due to missing/corrupted electronic files in the original submittal. They submitted several addenda through January 25, 2019. AGDC is requesting authorization to install and operate simple cycle and cogeneration gas-fired turbines, reciprocating internal combustion engines, heaters, flares, and fuel tanks to support the treatment of gas.

1.3 Project Description

GTP is part of one integrated liquefied natural gas (LNG) project to bring natural gas from Alaska's North Slope to international markets in the form of LNG, as well as for in-state deliveries in the form of natural gas. The GTP will take gas from the PBU and the Point Thomson Unit (PTU) and treat/process the gas, before it is sent 807 miles through a 42-inch diameter pipeline to a liquefaction facility in Nikiski on Alaska's Kenai Peninsula for export in foreign commerce.

The emissions units (EUs) at the stationary source will include cogeneration gas-fired turbines with supplemental firing duct burners for gas compression, simple cycle gas-fired turbines for power generation, gas-fired heaters for building and process heat, as well as flares for control of excess gas. In addition, the GTP will include a diesel-fired black start generator, several diesel-fired firewater pumps and emergency generators, and storage tanks for diesel and gasoline fuels.

Process Systems

The design of GTP would have an average stream day inlet natural gas treating capacity of 3.7 billion standard cubic feet per day (BSCF/D) and a 3.9 BSCF/D peak capacity,¹¹ and would be able to accommodate varying compositions of natural gas received from the PBU and PTU.

¹¹ Average stream day rate denotes the weighted 12-month average of monthly stream day rate values. Stream day rate represents the physical capacity of the facility at a particular ambient condition and does not account for planned or unplanned downtime (assume 100-percent uptime).

The design for GTP consists of three parallel treatment trains, each sized to process roughly 1.3 BSCF/D of sour feed gas. The process removes the majority of carbon dioxide (CO₂) and hydrogen sulfide (H₂S) from the sour feed gas to the specification of the Liquefaction Facility, and most of the water (to a dew point specification for the Mainline). The treated gas then would be compressed in stages and routed to a natural gas chilling unit. The chilling unit uses a refrigerant to cool the gas. After refrigeration, the natural gas would be delivered to the Mainline at pressures up to 2,075 psig.

GTP would include facilities in each treatment train to collect the CO₂ and H₂S removed from the natural gas. The CO₂/H₂S stream also would contain water and some hydrocarbons. The CO₂/H₂S stream from each train would be compressed and treated to remove water. The gaseous stream containing predominantly CO₂ and H₂S from each train would be combined into a single stream (GTP Byproduct) that would be sent to the PBU.

As discussed in the following sections, the water removed from both the natural gas and the Byproduct streams would be injected at the GTP site through Class 1 industrial wells located on the GTP Pad.

Inlet Facilities

The gas from the PBU would be metered for custody transfer at the PBU before entering the Prudhoe Bay Gas Transmissions Line (PBTL). Similarly, the feed gas from PTU would be custody transfer metered at the PTU before entering the Point Thomson Gas Transmissions Line (PTTL).

The PTU gas would be sent through an inlet knock-out drum to allow any liquids that may form in the PTTL to drop out of the natural gas stream before entering the processing trains. The natural gas from PBU would be combined with the natural gas flow from PTU and then sent to the process trains. The inlet facilities would be located on the northeast corner of the GTP Pad.

Acid Gas Removal Unit

There would be one acid gas removal unit (AGRU) per train. The AGRU would remove CO₂ and H₂S from the sour feed gas with the use of an amine solution and packed absorber tower commonly found in the natural gas treatment industry. The natural gas leaving the absorber tower would meet LNG specifications for CO₂ and H₂S but would also need to be treated by a gas dehydration unit to remove water to meet pipeline specification.

A regenerator, or second packed tower, would be used to release the CO₂ and H₂S from the amine solution. Once the CO₂ and H₂S are removed from the amine solution, the amine solution would be recirculated back to the absorber and the gaseous CO₂/H₂S stream would be compressed and dehydrated prior to return to PBU.

Treated Gas Dehydration Unit

There would be one treated gas dehydration unit system per train. The system would use glycol in a packed absorber tower to extract water from the natural gas stream. The dry natural gas stream would then flow to a treated gas compression system.

A regenerator, or second packed tower, would be used to release the water from the glycol solution using a stripping gas stream. Once the water has been removed, the glycol would be recirculated.

Treated Gas Compression

There would be one treated gas compression system per train. The purpose of the treated gas compression system would be to compress the dry natural gas to adequate pressure so that it enters the Mainline at the expected operating pressure. This would be done using natural gas turbine-driven compressors. GTP total treated gas compression power requirements would be approximately 298,000 ISO horsepower (combined for six units). The flue gas from the treated gas compression turbine drivers and from the CO₂ compression gas turbine drivers would be used to heat the process heat medium, as discussed below.

The treated natural gas would flow from the treated gas compression system in each train to common treated natural gas chillers prior to introduction into the Mainline. During winter periods when the air temperature is sufficiently cold, adequate cooling can be provided by the compressor discharge coolers, and the treated natural gas chilling and refrigeration system would not need to operate.

Treated Gas Chilling and Refrigeration

Treated natural gas from the three trains would be combined and then cooled to 30 °F upon entering the Mainline, using a propane refrigerant for chilling. The treated natural gas would flow from the chillers through a metering station and into the Mainline.

The refrigeration system would have two compressors (totaling approximately 27,000 brake horsepower) to provide flexibility between the summer months, when both compressors are expected to operate, and winter months when either one or none of the compressors would be operating. For initial fill and makeup, liquid propane would be transferred to the GTP from the PBU. The treated natural gas chillers and refrigeration system would be located on the northeast corner of the GTP pad.

CO₂ Compression and Dehydration

Each train would include one CO₂ compression and one dehydration system. The CO₂ compression system would compress the gaseous stream of predominately CO₂ (with some H₂S) released from the amine solution in four stages of compression. The first two stages would make up the low-pressure portion of the system and the last two stages would make up the high-pressure portion of the system. The low-pressure system would compress the gas to approximately 530 psig at which point the gas would be dehydrated by glycol in a contact tower. The process for dehydration would be similar to the treated gas dehydration unit described previously. Following dehydration, the CO₂ would flow to the high-pressure portion of the system where the gas would be boosted to approximately 4,000 psig for return to PBU. Following compression, the gas from each train would be combined into a single stream and then flow through a meter to the PBU. CO₂ compression at the GTP would be driven by natural gas turbines totaling approximately 205,000 ISO horsepower (combined for six units).

Building Heat Medium System

One building heat medium system would be located in the common utility area. The purpose of the building heat medium system would be to provide heat for freeze protection for process buildings, storage tanks, liquid drums, and air coolers as required to prevent equipment damage (during both normal and off-case operations) and to facilitate equipment maintenance. It would use a mixture of water and glycol in a closed loop system as the heat medium, which is heated by gas-fired heaters. This system would not heat the Operations Center buildings.

Cooling Medium Systems

Cooling medium systems would supply coolant to major GTP machinery (e.g., large compressors, etc.), pumps that require seal cooling, and some process heat exchangers. The cooling medium would be cooled using an air cooler. There would be one cooling medium system in each of the three trains. Additionally, air compressors, refrigeration compressors, and power generators would have their own cooling systems.

Process Heat Medium Systems

The purpose of the process heat medium systems would be to provide process heating to the AGRU reboilers. The system would use pressurized water as the heat medium, which is heated in the waste heat recovery units (WHRUs) by the exhaust from the gas turbines on the treated gas compressors and the CO₂ compressors in each train. Additional process heating requirements would be supplied by gas-fired duct burners (supplemental firing) within each of the WHRUs.

Electrical Power Generation System

The essential power generation for the GTP and GTP camp during construction would be supplied by a diesel generator located on the GTP Pad. An emergency diesel generator, located at the GTP Operations Center, would provide backup power for stairwell pressurization fans at the GTP Operations Center. Another emergency diesel generator would be provided at the Communications building to provide backup power.

The main power generation for the operation of the facility would be through six power generator natural gas turbines. The turbines would be located on the GTP Pad totaling approximately 267,000 to 299,000 horsepower. Emissions would be controlled using dry low emissions combustors.

Fuel Gas System

The fuel gas system supplies gas to the Operations Center via transfer line from the PBU Central Gas Facility. The fuel gas system would supply fuel gas to the gas turbines, supplemental firing for WHRUs, fired heaters, and flare system purges. Fuel gas would also be used as blanketing gas for a variety of equipment that either requires a higher pressure or a lower oxygen content than the nitrogen blanketing gas.

Flare System

Four flare systems would be provided for the GTP: high pressure (HP) hydrocarbon flare, low pressure (LP) hydrocarbon flare, HP CO₂ flare, and LP CO₂ flare. The flares are located to minimize radiant heat impacts on the facilities and to minimize downwind personnel exposure resulting from the prevailing wind direction.

Separate HP and LP hydrocarbon flares enable more efficient design by allowing low pressure gas to enter its own flare system with no interference from high pressure gas sources. HP and LP CO₂ systems would be segregated to keep water out of the high-pressure CO₂ system.

The design of the GTP facilities would not generate any continuous process or utility flow sources to flare or vent, except from limited pilot/purge streams. The flare system is for startup, emergency, pre-commissioning, commissioning, shutdown, or upset conditions. In general, protection systems would be designed to minimize potential flaring/venting flow rates to reduce impacts.

Diesel and Gasoline Fuel System

Arctic grade ultra-low sulfur diesel (ULSD) would be trucked to the GTP plant and stored for use on the GTP pad and Operations Center pad. The diesel fuel storage tank on the GTP pad would have a nominal capacity of 19,500 gallons and be sized to hold two weeks of diesel for the emergency and essential generators, diesel firewater pumps, and diesel fuel for service vehicles. The majority of this volume would be for vehicle usage. Usage by the emergency and essential diesel generators and firewater system would be for emergency and testing purposes.

The diesel-driven firewater pumps, communication tower, and the camp emergency generators would be located at the operations camp. Day tanks would be supplied directly via truck delivery to the operations camp.

Gasoline would be trucked to the GTP plant and stored for use at the GTP Operations Center. The gasoline storage tank would have a nominal capacity of approximately 10,000 gallons and would supply gasoline for service vehicles.

Chemical Storage

Storage for process chemicals would be provided on the GTP Pad. The chemical storage tanks would include storage for amine (130,000 gallons), triethylene glycol (26,500 gallons), and diesel (discussed previously). There would also be an additional empty tank with a capacity of 962,000 gallons to hold the amine from one train if it were to be taken out of service. A hydrocarbon holding tank would also be provided at the GTP Operations Center. The hydrocarbon holding tank is designed to hold recyclable waste diesel, glycol, solvents, miscellaneous fuels, and lubricants. This tank would be emptied using a vacuum truck as needed and either recycled or transported to an existing approved handling facility. Sizing for the hydrocarbon holding tank would be confirmed during later stages of the Project design.

2. CLASSIFICATION FINDINGS

Based on review of the application, the Department finds that:

1. This project is classified under 18 AAC 50.502(c)(1) for beginning actual construction of a new stationary source with the potential to emit greater than 40 tpy of NO_x, 15 tpy of PM-10, 10 tpy of PM-10, and 40 tpy of SO₂.
2. This project is also classified under 18 AAC 50.306(a) for beginning actual construction of a new stationary source that is PSD major for NO_x, CO, VOC, PM, PM-10, PM-2.5, SO₂, and GHG.
3. This project is also classified under 18 AAC 50.316 as a major source of HAPs for formaldehyde.

3. APPLICATION REVIEW FINDINGS

Based on review of the application, the Department finds that:

1. GTP is classified as a major stationary source under 40 C.F.R. 52.21(b)(1)(i)(b) because the stationary source has the potential to emit 250 tpy or more of a regulated air pollutant.
2. GTP has potential NO_x, CO, PM, PM-10, PM-2.5, SO₂, and VOC emissions that are PSD significant, per 40 C.F.R. 52.21(b)(23)(i). The GHG are subject to regulation per 40 C.F.R. 52.21(b)(49)(iv)(a). Therefore, the project requires a PSD permit under 18 AAC 50.306(a) for these pollutants.

3. AGDC did not model the secondary emissions occurring during the construction phase of the project. Instead, the Department is imposing a requirement to construct and maintain vertical, uncapped exhaust stacks on all temporary camp engines (Condition 9.1), a fugitive dust control plan (Condition 10.1), and a requirement to install and operate PM-10 and PM-2.5 ambient air monitoring stations (Condition 10.2) throughout the construction phase. For more information see the Modeling Report in Appendix D.
4. AGDC included a BACT analysis for all of the applicable emission unit types at the stationary source.
5. For compliance with the BACT emission limits the Department required initial source testing for larger units with add-on controls. BACT limits for EUs 1 through 6, 7 through 12, and 25 through 30, require source testing on two like kind units, and EUs 31 through 33 require source testing on one unit as representation for all of the units. Smaller units that are not likely to exceed the BACT limits are required to either submit to the Department a manufacturer's guarantee that the units will meet the BACT limits or source test the units to show they meet the numerical BACT emissions limits.
6. The cogeneration turbines EUs 1 through 12 and their associated waste heat recovery units (WHRU) EUs 13 through 24 were treated as one EU type for the BACT process, which is found in Appendix B, Section 3.0 of this TAR. The emission rates listed for these EUs in the permit and TAR account for both the turbine and their associated WHRU operating concurrently, and shall be measured after the WHRU. The WHRU have supplemental firing burners that use only exhaust air from the turbine for combustion and no supplemental air. The oxidation catalyst selected as BACT for controlling CO emissions for these EUs shall be installed after the WHRU so as to capture exhaust from both the turbine and the WHRU.
7. The PTE and BACT limits for all gas-fired EUs use a total sulfur content not to exceed 96 ppmv. This is a conservative assumption of the sulfur content considering that AGDC anticipates that once the first gas treatment train is operational, the total sulfur content will not exceed 16 ppmv.

4. EMISSIONS SUMMARY AND PERMIT APPLICABILITY

Table 11 shows the emissions summary and permit applicability with assessable emissions from the stationary source, listed in tons per year (tpy). Emission factors and detailed calculations are provided in Appendix A.

A summary of the potential to emit (PTE) and assessable PTE, as determined by the Department, is shown in Table 11 below.

Table 11: Emissions Summary and Permit Applicability

Parameter	Emissions (tpy)					
	NO _x	CO	VOC	PM-2.5	PM-10	SO ₂
PTE Authorized Under AQ15CPT01	3,321.7	9,020.4	13,094.0	903.4	903.4	1,076.3
18 AAC 50.502(c)(1) threshold	40	N/A	NA	10	15	40
18 AAC 50.502(c)(3) applicable?	Yes	NA	NA	Yes	Yes	Yes

Parameter	Emissions (tpy)					
	NO _x	CO	VOC	PM-2.5	PM-10	SO ₂
Title V Permit Thresholds	100	100	100	100	100	100
Title V Permit Required?	Yes	Yes	Yes	Yes	Yes	Yes
Assessable Emissions	3,322	9,020	13,094	903	903	1,076
	27,415					

Table Notes:

27,415 tons is a conservative estimate that includes flaring at maximum capacity for 500 hours per year. Without the inclusion of maximum flaring the total assessable emissions is 3,465 tons.

PM-10 emissions include PM-2.5 emissions. Therefore, PM-2.5 is not counted in total assessable emissions.

Fuel Gas Sulfur Content: 96 ppmv used for calculating SO₂ emissions from all gas-fired EUs.

Diesel Fuel Sulfur Content: 15 ppmv used for calculating SO₂ emissions from all diesel-fired EUs

Table 12: Major Source and PSD Review Applicability

Parameter	NO _x	CO	VOC	PM-2.5	PM-10	PM	SO ₂	CO ₂ e ¹
PTE for AQ1524CPT01 excluding fugitive emissions	3,321.7	9,020.4	13,094.0	903.4	903.4	903.4	1,076.3	7,278,238
PSD Major Source Threshold	250	250	250	250	250	250	250	N/A
Major Source Triggered?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	No
PSD Significant Emissions Rates	40	100	40 ³	10 ²	15	25	40	75,000
PSD Review Triggered?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

Table Notes:

¹ GHG are subject to regulation because the stationary source is major for a non-GHG pollutant and the carbon dioxide equivalent (CO₂e) is at least 75,000 tpy.

² PSD review for PM-2.5 can also be triggered by NO_x and SO₂ precursor emissions, as specified under 40 C.F.R. 52.21(b)(23)(i).

³ VOC acts as a surrogate for ozone (O₃). In addition to the VOC emissions trigger, PSD review for O₃ can also be triggered by NO_x emissions, as specified under 40 C.F.R. 52.21(b)(23)(i).

5. PERMIT CONDITIONS

The bases for the standard and general conditions imposed in Construction Permit AQ1524CPT01 are described below.

Section 1: Emissions Unit Inventory

The EUs authorized and/or restricted by this permit are listed in Table 1 of the permit. Unless otherwise noted in the permit, the information in Table 1 is for identification purposes only. Condition 1 is a general requirement to comply with AS 46.14 and 18 AAC 50 when installing a replacement EU.

Section 2: Fee Requirements

Condition 3, Administration Fees

18 AAC 50.306(d)(2) requires the Department to include a requirement to pay fees in accordance with 18 AAC 50.400 – 18 AAC 50.420 in each PSD permit issued under 18 AAC 50.306.

Conditions 4 and 5, Assessable Emissions

18 AAC 50.346(b)(1) requires the Department to include the Standard Permit Condition (SPC) I language for construction permits. However, for Construction Permit AQ1524CPT01 the Department modified the SPC I language to include a website address for submitting emission estimates through the Air Online Services (AOS) System. The Department also updated its mailing/delivery addresses.

As indicated by Footnote 3, if the stationary source has not commenced construction or operation on or before March 31, the Permittee is required to submit a transmittal letter certified by the responsible official under 18 AAC 50.205 indicating that the assessable emissions for the source are zero for the previous fiscal year.

Section 3: State Emission Standards

Condition 6, Visible Emissions

Visible emissions, excluding condensed water vapor, from an industrial process or fuel-burning equipment may not reduce visibility through the effluent by more than 20 percent averaged over six consecutive minutes, under 18 AAC 50.055(a)(1). Per 18 AAC 50.990(39), “fuel-burning equipment” does not include mobile internal combustion engines (e.g., NREs).

The Department is requiring an initial compliance demonstration within 60 days of startup of the new diesel-fired EUs 39 through 44. For the fuel gas-fired EUs 1 through 38, the Department is requiring a statement in each operating report that the EUs fired only fuel gas as fuel. For the flaring EUs 45 through 52 the Department is requiring an initial Method 9 observation during the first daylight flare event.

Condition 7, Particulate Matter (PM)

Particulate Matter emitted from an industrial process or fuel burning equipment may not exceed 0.05 grains per cubic foot of exhaust gas (gr/dscf), averaged over three hours, under 18 AAC 50.055(b).

Experience has shown there is a correlation between opacity and particulate matter. Twenty percent visible emissions would normally provide for compliance with the 0.05 gr/dscf emission limit. As such, compliance with opacity limits is included as a surrogate method of assuring compliance with the PM standards.

Condition 8, Sulfur Compound Emissions

Sulfur compound emissions from an industrial process or fuel burning equipment may not exceed 500 ppm averaged over a period of three hours, under 18 AAC 50.055(c).

Calculations show that fuel oil with sulfur content less than 0.74 percent by weight will comply with the state emissions standard. Calculations show that fuel gas with sulfur

content less than 4,000 parts per million by volume will comply with the state standards. The Permittee demonstrates compliance with Condition 8 by complying with the ambient air quality protection requirement Conditions 11.1 and 11.2, which require combusting only ULSD (0.0015 percent sulfur by weight) and firing only fuel gas with a sulfur content of no more than 96 ppmv.

Section 4: Ambient Air Quality Protection Requirements

Conditions 9 – 12

18 AAC 50.010 contains the ambient air quality standards, and the Department will include conditions to protect these standards when warranted. The Department determined that conditions are warranted to protect the 1-hour and annual NO₂; 24-hour PM-10; 24-hour and annual PM-2.5; 1-hour and 8-hour CO; and 1-hour, 3-hour, 24-hour, and annual SO₂ AAAQS for the reasons described in Appendix D of this TAR.

Section 5: Best Available Control Technology (BACT)

Conditions 13 – 19

The project triggers PSD review under 18 AAC 50.306 for NO_x, SO₂, CO, PM, PM-10, PM-2.5, VOCs, and GHGs. The Department performed a BACT analysis of all the available control options for equipment emitting the triggered pollutants listed above. The BACT evaluation process selects the best pollutant control option based on feasibility, economics, energy, and other impacts. The full BACT analysis is contained in Appendix B of this TAR and a summary of the BACT analysis is contained in Appendix C of this TAR.

Section 6: General Recordkeeping, Reporting, and Certification Requirements

Condition 20, Certification

18 AAC 50.205 requires the Permittee to certify any permit application, report, affirmation, or compliance certification submitted to the Department. This requirement is reiterated as a standard permit condition in 18 AAC 50.345(j). Construction Permit AQ1524CPT01 uses the standard condition language, but also expands it by allowing the Permittee to provide electronic signatures.

Condition 21, Submittals

Condition 21 clarifies where the Permittee should send their reports, certifications, and other submittals required by the permit. The Department included this condition from a practical perspective rather than a regulatory obligation.

Condition 22, Information Requests

AS 46.14.020(b) allows the Department to obtain a wide variety of emissions, design and operational information from the owner and operator of a stationary source. This statutory provision is reiterated as a standard permit condition in 18 AAC 50.345(i). The Department used the standard language in Construction Permit AQ1524CPT01.

Condition 23, Recordkeeping Requirements

The condition restates the regulatory requirements for recordkeeping, and supplements the recordkeeping defined for specific conditions in the permit. The records being kept provide an evidence of compliance with this requirement.

Condition 24, Excess Emission and Permit Deviation Reports

This condition reiterates the notification requirements in 18 AAC 50.235(a)(2) and 18 AAC 50.240 regarding unavoidable emergencies, malfunctions, and excess emissions. Also, the Permittee is required to notify the Department when emissions or operations deviate from the requirements of the permit. The Department used the Standard Condition III language, but with updated web-links.

Condition 25, Operating Reports

The Department mostly used the Standard Operating Permit Condition VII language for the operating report condition. However, the Department modified or eliminated the Title V only aspects in order to make the language applicable for a construction permit.

Condition 26, Air Pollution Prohibited

18 AAC 50.110 prohibits any emission which is injurious to human health or welfare, animal or plant life, or property, or which would unreasonably interfere with the enjoyment of life or property. Condition 26 reiterates this prohibition as a permit condition. The Department used the Standard Permit Condition II language for Construction Permit AQ1524CPT01.

Condition 27, Emission Inventory Reporting

18 AAC 50.346(b)(8) requires the Department to include the SPC XV emission inventory language for construction permits. 18 AAC 50.346(b)(9) requires the Department to include the SPC XVI Emission Inventory Form (Attachment 3) for construction permits. The Department used the language in SPC XV for the permit condition, but corrected the emissions threshold amount for Pb in Condition 27.2a, from 5 TPY to 0.5 TPY actual emissions. The Department has also added Conditions 27.4a, 27.4b, and updated the submittal requirements in the Emission Inventory Form to clarify the requirements for report submittal using the Department's Air Online Services (AOS) system, or using email, or mailing out a hard copy if the AOS system is not available.

27: Standard Permit Conditions

Conditions 28 – 33

As required under 18 AAC 50.345, the Department may include the standard permit conditions set out in subsections (c)(1) and (2), and (d) through (o), as applicable for a minor or construction permit. As required under 18 AAC 50.346, the Department will include the standard permit conditions set out in this subsection in each construction permit or Title V permit, unless the Department determines that emissions unit-specific or stationary source-specific conditions more adequately meet the requirements of this chapter, or that no comparable condition is appropriate for the stationary source or emissions unit.

The Department included all of the minor/construction permit-related standard conditions of 18 AAC 50.345 in Construction Permit AQ1524CPT01. The Department incorporated these standard conditions as follows:

- 18 AAC 50.345(c)(1) and (2) is incorporated as Condition 28 of 27 (Standard Permit Conditions);

- 18 AAC 50.345(d) through (h) is incorporated as Conditions 29 through 33, respectively, of 27 (Standard Permit Conditions);
- As previously discussed, 18 AAC 50.345(i) is incorporated as Condition 22 and 18 AAC 50.345(j) is incorporated as Condition 20 of Section 6 (Recordkeeping, Reporting, and Certification Requirements); and
- 18 AAC 50.345(k) is incorporated as Condition 34, and 18 AAC 50.345(l) through (o) is incorporated as Conditions 37 through 40, respectively, of Section 8 (General Source Testing Requirements). See the following discussion.

Section 8: General Source Test Requirements

Conditions 34 – 40

AS 46.14.180 states that monitoring requirements must be, “based on test methods, analytical procedures, and statistical conventions approved by the federal administrator or the department or otherwise generally accepted as scientifically competent.” The Department incorporated this requirement as follows:

- Condition 35 requires the Permittee to conduct their source tests under conditions that reflects the actual discharge to ambient air; and
- Condition 36 requires the Permittee to use specific EPA reference methods when conducting a source test.

Section 8 also includes the previously discussed standard conditions for source testing.

6. PERMIT ADMINISTRATION

Construction Permit AQ1524CPT01 is the initial permit for the Gas Treatment Plant. Alaska Gasline Development Corporation may therefore operate in accordance with Construction Permit AQ1524CPT01 upon issuance.

Appendix A: Emissions Calculations

Table 13 presents details of the EUs, their characteristics, and emissions. Potential emissions are estimated using maximum annual operation for all fuel burning equipment as defined in 18 AAC 50.990(39) subject to any operating limits.

Table 13: Detailed Permanent EU Inventory and Potential to Emit (tpy)

EU ID	Emissions Unit Description	Rating		Annual Operating Hours	NOx CO EF Units	NO _x		CO		VOC PM-2.5 PM-10 EF Units	VOC		PM ₁₀		PM _{2.5}		SO ₂ ¹
						EF	tpy	EF	tpy		EF	tpy	EF	tpy	EF	tpy	
1 ¹	Train 1a Treated Gas Compressor Turbine (includes SF WHR)	575	MMBtu/hr	8760	ppmv	17	105.24	5	18.84	lb/MMBtu	0.0022	4.85	0.0063	15.92	0.0063	15.92	37.84
2 ¹	Train 1b Treated Gas Compressor Turbine (includes SF WHR)	575	MMBtu/hr	8760	ppmv	17	105.24	5	18.84	lb/MMBtu	0.0022	4.85	0.0063	15.92	0.0063	15.92	37.84
3 ¹	Train 2a Treated Gas Compressor Turbine (includes SF WHR)	575	MMBtu/hr	8760	ppmv	17	105.24	5	18.84	lb/MMBtu	0.0022	4.85	0.0063	15.92	0.0063	15.92	37.84
4 ¹	Train 2b Treated Gas Compressor Turbine (includes SF WHR)	575	MMBtu/hr	8760	ppmv	17	105.24	5	18.84	lb/MMBtu	0.0022	4.85	0.0063	15.92	0.0063	15.92	37.84
5 ¹	Train 3a Treated Gas Compressor Turbine (includes SF WHR)	575	MMBtu/hr	8760	ppmv	17	105.24	5	18.84	lb/MMBtu	0.0022	4.85	0.0063	15.92	0.0063	15.92	37.84
6 ¹	Train3b Treated Gas Compressor Turbine (includes SF WHR)	575	MMBtu/hr	8760	ppmv	17	105.24	5	18.84	lb/MMBtu	0.0022	4.85	0.0063	15.92	0.0063	15.92	37.84
7 ¹	Train 1a CO2 Compressor Turbine (includes SF WHR)	433	MMBtu/hr	8760	ppmv	17	80.46	5	14.41	lb/MMBtu	0.0022	3.64	0.0063	11.99	0.0063	11.99	28.50
8 ¹	Train 1b CO2 Compressor Turbine (includes SF WHR)	433	MMBtu/hr	8760	ppmv	17	80.46	5	14.41	lb/MMBtu	0.0022	3.64	0.0063	11.99	0.0063	11.99	28.50
9 ¹	Train 2a CO2 Compressor Turbine (includes SF WHR)	433	MMBtu/hr	8760	ppmv	17	80.46	5	14.41	lb/MMBtu	0.0022	3.64	0.0063	11.99	0.0063	11.99	28.50
10 ¹	Train 2b CO2 Compressor Turbine (includes SF WHR)	433	MMBtu/hr	8760	ppmv	17	80.46	5	14.41	lb/MMBtu	0.0022	3.64	0.0063	11.99	0.0063	11.99	28.50
11 ¹	Train 3a CO2 Compressor Turbine (includes SF WHR)	433	MMBtu/hr	8760	ppmv	17	80.46	5	14.41	lb/MMBtu	0.0022	3.64	0.0063	11.99	0.0063	11.99	28.50
12 ¹	Train 3b CO2 Compressor Turbine (includes SF WHR)	433	MMBtu/hr	8760	ppmv	17	80.46	5	14.41	lb/MMBtu	0.0022	3.64	0.0063	11.99	0.0063	11.99	28.50
25 ²	Power Generation Turbines	40,465	kW	8760	ppmv	15	91.53	15	55.72	lb/MMBtu	0.0022	3.75	0.0070	11.78	0.0070	11.78	25.36
26 ²	Power Generation Turbines	40,465	kW	8760	ppmv	15	91.53	15	55.72	lb/MMBtu	0.0022	3.75	0.0070	11.78	0.0070	11.78	25.36
27 ²	Power Generation Turbines	40,465	kW	8760	ppmv	15	91.53	15	55.72	lb/MMBtu	0.0022	3.75	0.0070	11.78	0.0070	11.78	25.36
28 ²	Power Generation Turbines	40,465	kW	8760	ppmv	15	91.53	15	55.72	lb/MMBtu	0.0022	3.75	0.0070	11.78	0.0070	11.78	25.36
29 ²	Power Generation Turbines	40,465	kW	8760	ppmv	15	91.53	15	55.72	lb/MMBtu	0.0022	3.75	0.0070	11.78	0.0070	11.78	25.36
30 ²	Power Generation Turbines	40,465	kW	8760	ppmv	15	91.53	15	55.72	lb/MMBtu	0.0022	3.75	0.0070	11.78	0.0070	11.78	25.36

Alaska Gasline Development Corporation
Gas Treatment Plant

Technical Analysis Report Construction Permit AQ1524CPT01
Preliminary Date: July 12, 2019

31 ³	Building Heat Medium Heater	275	MMBtu/hr	8760	lb/MMBtu	0.036	43.32	0.007	8.42	lb/MMBtu	0.0057	6.85	0.0079	9.47	0.0079	9.47	18.07
32 ³	Building Heat Medium Heater	275	MMBtu/hr	8760	lb/MMBtu	0.036	43.32	0.007	8.42	lb/MMBtu	0.0057	6.85	0.0079	9.47	0.0079	9.47	18.07
33 ³	Building Heat Medium Heater (spare)	275	MMBtu/hr	0													
34	Buyback Gas Bath Heater Primary Heater (Standby)	0.15	MMBtu/hr	8760	lb/MMBtu	0.036	0.024	0.087	0.059	lb/MMBtu	0.0057	0.004	0.0079	0.005	0.0079	0.005	0.011
	Buyback Gas Bath Heater Primary Heater (Maximum)	25	MMBtu/hr	500	lb/MMBtu	0.036	0.23	0.087	0.55	lb/MMBtu	0.0057	0.036	0.0079	0.050	0.0079	0.050	0.10
35 ³	Buyback Gas Bath Heater Secondary Heater (Standby)	0.15	MMBtu/hr	8760	lb/MMBtu	0.036	0.024	0.087	0.059	lb/MMBtu	0.0057	0.004	0.0079	0.005	0.0079	0.005	0.011
	Buyback Gas Bath Heater Secondary Heater (Maximum)	21	MMBtu/hr	500	lb/MMBtu	0.036	0.19	0.087	0.45	lb/MMBtu	0.0057	0.030	0.0079	0.041	0.0079	0.041	0.079
36 ³	Operations Camp Heater	32	MMBtu/hr	8760	lb/MMBtu	0.036	5.03	0.087	12.14	lb/MMBtu	0.0057	0.79	0.0079	1.10	0.0079	1.10	2.12
37 ³	Operations Camp Heater	32	MMBtu/hr	8760	lb/MMBtu	0.036	5.03	0.087	12.14	lb/MMBtu	0.0057	0.79	0.0079	1.10	0.0079	1.10	2.12
38 ³	Operations Camp Heater (spare)	32	MMBtu/hr	0													
39 ⁴	Black Start Diesel Generator Engine	4,060	hp	500	g/hp-hr	3.25	7.27	0.33	0.73	g/hp-hr	0.18	0.39	0.045	0.10	0.045	0.10	0.010
40 ⁵	Main Diesel Firewater Pump Engine	250	hp	500	g/hp-hr	3.56	0.49	3.25	0.45	g/hp-hr	0.19	0.03	0.19	0.026	0.19	0.026	0.0008
41 ⁵	Main Diesel Firewater Pump Engine	250	hp	500	g/hp-hr	3.56	0.49	3.25	0.45	g/hp-hr	0.19	0.03	0.19	0.026	0.19	0.026	0.0008
42 ⁵	Main Diesel Firewater Pump Engine	250	hp	500	g/hp-hr	3.56	0.49	3.25	0.45	g/hp-hr	0.19	0.03	0.19	0.026	0.19	0.026	0.0008
43 ⁵	Dormitory Emergency Diesel Generator Engine	335	hp	500	g/hp-hr	3.56	0.66	3.25	0.60	g/hp-hr	0.19	0.03	0.19	0.035	0.19	0.035	0.0011
44 ⁵	Communications Tower Emergency Generator Engine	201	hp	500	g/hp-hr	3.56	0.39	3.25	0.36	g/hp-hr	0.19	0.02	0.19	0.021	0.19	0.021	0.0006
45 ⁶	HP Hydrocarbon Flare East (Pilot/Purge)	7.85	MMBtu/hr	8760	lb/MMBtu	0.068	2.34	0.37	12.72	lb/MMBtu	0.57	19.59	0.028	0.97	0.028	0.97	0.52
	HP Hydrocarbon Flare East (Maximum)	73,307	MMBtu/hr	500	lb/MMBtu	0.068	1,246.23	0.37	6,780.93	lb/MMBtu	0.57	10,446.3	0.028	517.19	0.028	517.19	309.28
46 ⁶	HP Hydrocarbon Flare West (Pilot/Purge)	7.85	MMBtu/hr	8760	lb/MMBtu	0.068	2.34	0.37	12.72	lb/MMBtu	0.57	19.59	0.028	0.97	0.028	0.97	0.52
47 ⁶	LP Hydrocarbon Flare East (Pilot/Purge)	1.44	MMBtu/hr	8760	lb/MMBtu	0.068	0.43	0.37	2.33	lb/MMBtu	0.57	3.59	0.028	0.18	0.028	0.18	0.09
	LP Hydrocarbon Flare East (Maximum)	4,497	MMBtu/hr	500	lb/MMBtu	0.068	76.44	0.37	415.93	lb/MMBtu	0.57	640.76	0.028	31.72	0.028	31.72	16.90
48 ⁶	LP Hydrocarbon Flare West (Pilot/Purge)	1.44	MMBtu/hr	8760	lb/MMBtu	0.068	0.43	0.37	2.33	lb/MMBtu	0.57	3.59	0.028	0.18	0.028	0.18	0.09
49 ⁶	HP CO2 Flare East (Pilot/Purge)	2.96	MMBtu/hr	8760	lb/MMBtu	0.068	0.88	0.37	4.80	lb/MMBtu	0.57	7.40	0.028	0.37	0.028	0.37	0.20
	HP CO2 Flare East (Maximum)	3,155	MMBtu/hr	500	lb/MMBtu	0.068	53.63	0.37	291.79	lb/MMBtu	0.57	449.52	0.028	22.26	0.028	22.26	38.70
50 ⁶	HP CO2 Flare West (Pilot/Purge)	2.96	MMBtu/hr	8760	lb/MMBtu	0.068	0.88	0.37	4.80	lb/MMBtu	0.57	7.40	0.028	0.37	0.028	0.37	0.20
51 ⁶	LP CO2 Flare East (Pilot/Purge) (3 Flares)	6.83	MMBtu/hr	8760	lb/MMBtu	0.068	2.03	0.37	11.07	lb/MMBtu	0.57	17.05	0.028	0.84	0.028	0.84	0.45

	LP CO2 Flare East (Maximum) (3 Flares)	9,630	MMBtu/hr	500	lb/MMBtu	0.068	163.71	0.37	890.78	lb/MMBtu	0.57	1,372.28	0.028	67.94	0.028	67.94	118.13
52 ⁶	LP CO2 Flare West (Pilot/Purge) (3 Flares)	6.83	MMBtu/hr	8760	lb/MMBtu	0.068	2.03	0.37	11.07	lb/MMBtu	0.57	17.05	0.028	0.84	0.028	0.84	0.45
53 – 61 ⁷	Diesel and Gasoline Storage Tanks	35,100	gal (total)	N/A	N/A							0.59					
Total Emissions (Without Maximum Flare)							1,781.7		640.9			185.2		264.3		264.3	593.3
Total Emissions (With Maximum Flare)							3,321.7		9,020.4			13,094.0		903.4		903.4	1,076.3

Table Notes:

Fuel Gas Heat Content (HHV): 1,077 Btu/scf

Fuel Gas Sulfur Content: 96 ppmv used for calculating SO₂ emissions from all gas-fired EUs.

Diesel Fuel Sulfur Content: 15 ppmw used for calculating SO₂ emissions from all diesel-fired EUs.

¹NO_x, CO, particulate matter, PM-10, PM-2.5, EFs provided by Permittee. PTE for NO_x and CO assumes no additional air for supplemental firing duct burners outside of turbine exhaust. VOC EF is Permittee's proposal for uncontrolled emissions with 70% reduction due to oxidation catalyst.

²NO_x and CO EFs provided by Permittee. Particulate matter, PM-10, and PM-2.5 EFs are the total particulate EF for gas turbines from AP-42 Table 3.1-2a. VOC EF from AP-42 Table 3.1-2a.

³NO_x, CO EF provided by Permittee. Particulate matter, PM-10, and PM-2.5 EFs are the total particulate EF for gas boilers from AP-42 Table 1.4-2. VOC EF from AP-42 Table 1.4-2. EUs 33 and 38 are spare units and do not have PTE. Condition 9.4 limits concurrent operations of these spare units with their counterparts.

⁴EFs are from EPA Tier 4 Final. NO_x, and VOC (NMHC) use a 25% not to exceed factor of safety. CO uses a 25% not to exceed factor of safety and 80% control from oxidation catalyst. Particulate matter, PM-10, and PM-2.5 use a 50% not to exceed factor of safety.

⁵NO_x, CO, VOC, particulate matter, PM-10, and PM-2.5 EFs are EPA Tier 3 with a 25% not to exceed factor of safety. NO_x is assumed to be 95% of NMHC + NO_x, and VOC is 5% of NMHC + NO_x.

⁶NO_x and CO EFs from AP-42 Table 13.5-1. Particulate matter, PM-10, and PM-2.5 EFs from AP-42 Table 13.5-1 for soot (lightly smoking flare). VOC EF from AP-42 Table 1.4-2 and converted to lb/MMBtu using fuel gas heat content of 1,077 Btu/scf.

⁷VOC PTE calculated using EPA's Tanks software.

Appendix B: Best Available Control Technology

1.0 INTRODUCTION

The Alaska Gasline Development Corporation's (AGDC's) Gas Treatment Plant (GTP) triggered Prevention of Significant Deterioration (PSD) requirements for carbon monoxide (CO), oxides of nitrogen (NO_x), sulfur dioxide (SO₂), particulate matter (PM), particulate matter with an aerodynamic diameter of 10 microns or less (PM-10), particulate matter with an aerodynamic diameter of 2.5 microns or less (PM-2.5), volatile organic compounds (VOC), and greenhouse gases (GHG). This appendix includes the Department of Environmental Conservation's (Department's) review of AGDC's Gas Treatment Plant's Best Available Control Technology (BACT) analysis for CO, NO_x, SO₂, PM, PM-10, PM-2.5 (the Department will refer to PM, PM-10, and PM-2.5 collectively as particulates in this BACT analysis), VOC, and GHG for its technical accuracy and adherence to accepted engineering cost estimation practices.

2.0 BACT EVALUATION

A BACT analysis is an evaluation of all available control options for equipment emitting the triggered pollutants and a process for selecting the best option based on feasibility, economics, energy, and other impacts. 40 C.F.R. 52.21(b)(12) defines BACT as a site-specific determination on a case-by-case basis. The Department's goal is to: identify BACT for the permanent emission units (EUs) at the GTP that emit CO, NO_x, SO₂, particulates, VOC, and GHG; establish emission limits which represent BACT; and assess the level of monitoring, recordkeeping, and reporting (MR&R) requirements necessary to ensure AGDC applies BACT for the EUs. The Department based the BACT review on the five-step top-down approach set forth in Federal Register Volume 61, Number 142, July 23, 1996 (Environmental Protection Agency). Table 2-1 presents the EUs subject to BACT review.

Table 2-1: EUs Subject to BACT Review

EUs	Description of EU
1 – 6	Treated Gas Compressor Turbines (Cogeneration)
7 – 12	CO ₂ Compressor Turbines (Cogeneration)
13 – 24	Waste Heat Recovery Units Supplemental Firing Burners
25 – 30	Power Generation Turbines (Simple Cycle)
31 – 38	Utility Heaters
39 – 44	Compression Ignition Engines
45 – 52	Vent Gas Disposal (Flares)
53 – 61	Fuel Tanks

Five-Step BACT Determinations

The following sections explain the steps used to determine BACT for CO, NO_x, SO₂, particulate matter (PM), PM-10, PM-2.5, VOCs, and GHGs for the applicable equipment.

Step 1 Identify All Potentially Available Control Options

The Department identifies all available control options for the EUs and the pollutant under consideration. This includes technologies used throughout the world or emission reductions through the application of available control techniques, changes in process design, and/or operational limitations. To assist in identifying available controls, the Department reviews available controls listed on the Reasonably Available Control Technology (RACT), BACT, and

Lowest Achievable Emission Rate (LAER) Clearinghouse (RBLC). The RBLC is an EPA database where permitting agencies nationwide post imposed BACT for PSD sources. It is usually the first stop for BACT research. In addition to the RBLC search, the Department used several search engines to look for emerging and tried technologies used to control NO_x, CO, SO₂, particulates, VOC, and GHG emissions from equipment similar to those listed in Table 2-1.

Step 2 Eliminate Technically Infeasible Control Options:

The Department evaluates the technical feasibility of each control option based on source specific factors in relation to each EU subject to BACT. Based on sound documentation and demonstration, the Department eliminates control options deemed technically infeasible due to physical, chemical, and engineering difficulties.

Step 3 Rank Remaining Control Technologies by Control Effectiveness

The Department ranks the remaining control options in order of control effectiveness with the most effective at the top.

Step 4 Evaluate the Most Effective Controls and Document the Results as Necessary

The Department reviews the detailed information in the permit application about the control efficiency, emission rate, emission reduction, cost, environmental, and energy impacts for each option to decide the final level of control. The applicant must present an objective evaluation of both the beneficial and adverse energy, environmental, and economic impacts. An applicant proposing to use the most effective option does not need to provide the detailed information for the less effective options. If cost is not an issue, a cost analysis is not required.

Cost effectiveness for a control option is defined as the total net annualized cost of control divided by the tons of pollutant removed per year. Annualized cost includes annualized equipment purchase, erection, electrical, piping, insulation, painting, site preparation, buildings, supervision, transportation, operation, maintenance, replacement parts, overhead, raw materials, utilities, engineering, start-up costs, financing costs, and other contingencies related to the control option.

Step 5 Select BACT

To complete the BACT process, the Department must establish enforceable emissions limits for each subject emission unit at the source for each pollutant subject to review. If technological or economic limitations in the application of a measurement methodology to a particulate emissions unit would make an emissions limit infeasible, a design, equipment, work practice, operational standard, or combination thereof may be prescribed. Also the technology upon which the BACT emissions limit is based should be specified so that they are specific to the individual emissions unit subject to BACT review.

The Department reviewed Gas Treatment Plant's BACT analysis and made BACT determinations for NO_x, CO, SO₂, PM, PM-10, PM-2.5, VOC, and GHG for various EUs based on the information submitted by AGDC in their application, information from vendors, suppliers, sub-contractors, RBLC, and a comprehensive internet search.

3.0 COMPRESSOR TURBINES

The GTP will contain six cogeneration natural gas-fired turbines (EUs 1 – 6) for treated gas compression and six cogeneration natural gas-fired turbines (EUs 7 – 12) for CO₂ byproduct compression. The 12 compressor turbines will include supplemental duct burners (EUs 13 through 24) in the exhaust firing natural gas. The duct burners will help increase the heat of the recovery system to cover needs of the process heat medium system. There will be 12 exhaust stacks for the 12 compressor turbines coupled with their respective exhaust duct burners. The emission rates in Section 3 include both the turbine and its accompanying duct burner.

Each of the treated gas compressor turbines EUs 1 – 6 are planned to have a nominal capacity of approximately 42 MW, for a total of 252 MW. The duct burners for EUs 1 – 6 have a high heating value input of approximately 190 MMBtu/hr for each burner. Each of the CO₂ compressor turbines EUs 7 – 12 are planned to have a nominal capacity of approximately 26 MW, for a total of 156 MW. The duct burners for EUs 7 – 12 have a high heating value input of approximately 140 MMBtu/hr for each burner. The compressor turbines will emit CO, NO_x, SO₂, PM, PM-10, PM-2.5, VOC, and GHG. The following sections provide the BACT review for each of these pollutants.

3.1 NO_x

Possible NO_x emission control technologies for turbines were obtained from the RBLIC. The RBLIC was searched for all determinations in the last 10 years under the process code 15.210: large combined cycle and cogeneration natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 3-1.

Table 3-1: NO_x Controls for Large Combined Cycle & Cogeneration Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (ppmv)
Selective Catalytic Reduction	67	2 – 9
Low NO _x Burners	3	5 – 25

Step 1 – Identify NO_x Control Technologies for Compressor Turbines

From research, the Department identified the following technologies as available for control of NO_x emissions from gas-fired combined cycle and cogeneration combustion turbines rated at 25 MW or greater:

(a) Selective Catalytic Reduction (SCR)

SCR is a post-combustion gas treatment technique for reducing nitric oxide (NO) and nitrogen dioxide (NO₂) in the turbine exhaust stream to molecular nitrogen (N₂), water, and oxygen (O₂). In the SCR process, aqueous or anhydrous ammonia (NH₃) is injected into the flue gas upstream of a catalyst bed. The catalyst lowers the activation energy of the NO_x decomposition reaction. NO_x and NH₃ combine at the catalyst surface forming an ammonium salt intermediate, which subsequently decomposes to produce elemental N₂ and water. The operating temperature of conventional SCR systems ranges from 400 degrees Fahrenheit (°F) to 800°F. High temperature SCR relies on special material reaction grids and can operate at higher temperature ranges between 700°F to 1,075°F. High temperature SCR is most frequently installed on simple cycle turbines. Depending

on the overall NH_3 -to- NO_x ratio, removal efficiencies are generally 80 to 90 percent. In the Department's search of the RBLC database, the majority of large combined cycle and cogeneration natural gas-fired combustion turbines used SCR as the primary control method for NO_x emissions and contained a BACT limit of 2 ppmv. Hence, the Department considers SCR a technically feasible control technology for the large cogeneration gas-fired turbines.

(b) Dry Low NO_x (DLN)

DLN combustors (marketed under many similar names such as SoLo NO_x or DLE) utilize multistage premix combustors where the air and fuel is mixed at a lean (high oxygen) fuel-to-air ratio. The excess air in the lean mixture acts as a heat sink, which lowers peak combustion temperatures and also ensures a more homogeneous mixture avoiding localized "hot spots", both resulting in greatly reduced NO_x formation rates. DLN combustors have the potential to reduce NO_x emissions by 40 to 60%. Note that DLN is designed for natural gas-fired or dual-fuel fired units and is not effective in controlling NO_x emissions from fuel oil-fired units. The Department considers DLN a technically feasible control technology for the large cogeneration gas-fired turbines.

(c) Water/Steam Injection

Water/steam injection involves the introduction of water or steam into the combustion zone. The injected fluid provides a heat sink which absorbs some of the heat of reaction, causing a lower flame temperature. The lower flame temperature results in lower thermal NO_x formation. Both steam and water injections are capable of obtaining the same level of control. The process requires approximately 0.8 to 1.0 pound of water or steam per pound of fuel burned. The main technical consideration is the required purity of the water or steam, which is required to protect the equipment from dissolved solids. Obtaining water or steam of sufficient purity requires the installation of rigorous water treatment and deionization systems, incurring additional costs. Water/steam injection also increases CO emissions as it lowers the combustion temperature. Depending on baseline uncontrolled NO_x levels, water or steam injection can reduce NO_x by 60% or more.

Water/steam injection is a proven technology for NO_x emissions reduction from turbines. However, the arctic environment presents significant challenges to water/steam injection due to cost of water treatment, freezing potential due to cold ambient temperatures, and increased maintenance problems due to accelerated wear in the hot sections of the turbines. Generally speaking the Department considers water/steam injection a technically feasible control technology for the large cogeneration gas-fired turbines.

However, the base model turbine selected by ADGC already comes equipped with DLN technology which is not compatible with water/steam injection, and has lower NO_x emission rates than water/steam injection. Additionally, the Department's research did not identify water/steam injection as a technology used to control NO_x emissions from large combined cycle or cogeneration turbines installed at any facility in the RBLC database. Hence the Department considers water/steam injection as a technically infeasible control technology for the large cogeneration gas-fired turbines.

(d) Selective Non-Catalytic Reduction (SNCR)

SNCR involves the non-catalytic decomposition of NO_x in the flue gas to N₂ and water using reducing agents such as urea or NH₃. The process utilizes a gas phase homogeneous reaction between NO_x and the reducing agent within a specific temperature window. The reducing agent must be injected into the flue gas at a location in the unit that provides the optimum reaction temperature and residence time. The NH₃ process (trade name-Thermal DeNO_x) requires a reaction temperature window of 1,600°F to 2,200°F. In the urea process (trade name–NO_xOUT), the optimum temperature ranges between 1,600 °F and 2,100 °F. Because the temperature of combined cycle and cogeneration turbines exhaust gas normally ranges from 800°F to 1,000°F, achieving the required reaction temperature is the main difficulty for application of SNCR to turbines. The Department’s research did not identify SNCR as a technology used to control NO_x emissions from turbines installed at any facility. Hence the Department considers SNCR as a technically infeasible control technology for the large cogeneration gas-fired turbines.

(e) Non-Selective Catalytic Reduction (NSCR)

NSCR simultaneously reduces NO_x and oxidizes CO and hydrocarbons in the exhaust gas to N₂, carbon dioxide (CO₂), and water. The catalyst, usually a noble metal, causes the reducing gases in the exhaust stream (hydrogen, methane, and CO) to reduce both NO and NO₂ to N₂ at a temperature between 800°F and 1,200°F. NSCR requires a low excess O₂ concentration in the exhaust gas stream to be effective because the O₂ must be depleted before the reduction chemistry can proceed. NSCR is only effective with rich-burn gas-fired units that operate at all times with an air/fuel ratio controller at or close to stoichiometric conditions. Turbines operate under conditions far more fuel-lean than required to support NSCR. The Department’s research did not identify NSCR as a control technology used to control NO_x emissions from turbines installed at any facility. Hence the Department considers NSCR as a technically infeasible control technology for the large cogeneration gas-fired turbines.

(f) SCONOX™

SCONOX™ is a new catalytic absorption technology developed by Goal Line Environmental Technologies, Inc. to treat exhaust gas with a potassium carbonate coated catalyst, reducing NO_x to N₂. The catalyst also oxidizes CO to CO₂, and NO and NO₂ to potassium nitrates (KNO₃). The catalyst is regenerated by passing dilute H₂ over it which converts the KNO₂ and KNO₃ to K₂CO₃, water, and N₂. One disadvantage of SCONOX™ is that the catalyst is very sensitive to sulfur in the fuel. For fuel gas sulfur content exceeding 30 ppmv, a sulfur adsorption catalyst must be installed upstream of the SCONOX™ catalyst to remove sulfur. No known installations exist in low ambient temperature settings or on turbine arrangements in industrial settings. The Department’s research did not identify facilities using SCONOX™ to control NO_x for turbines. Therefore, the Department considers this technology technically infeasible for the large cogeneration gas-fired turbines.

(g) XONON™

XONON™ is a catalytic technology developed by Catalytica Energy Systems, Inc. and now owned by Kawasaki. XONON™ uses flameless fuel combustion to lower NO_x emissions. The combustion chamber of a gas turbine completely contains the XONON™ system. XONON™ completely combusts fuel to produce a high-temperature mixture typically about 2,400 °F. Dilution air is added to shape the temperature profile required at the turbine inlet. General Electric and Solar Turbines are testing this new catalyst technology, and the Department's research did not identify facilities using XONON™. The Department considers XONON™ a technically infeasible control technology for the large cogeneration gas-fired turbines because it is not commercially available.

Step 2 – Eliminate Technically Infeasible NO_x Control Options for Compressor Turbines

As explained in Step 1, water/steam injection, SNCR, NSCR, SCONOX™, and XONON™ are not feasible technically technologies to control NO_x emissions from the cogeneration gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining NO_x Control Options for Compressor Turbines

The following control technologies have been identified and ranked for control of NO_x from the compressor turbines:

- | | |
|---------|---------------------|
| (a) SCR | (70% - 90% Control) |
| (b) DLN | (40% - 60% Control) |

Step 4 – Evaluate the Most Effective Controls

SCR is the most common and effective NO_x control for large combined cycle and cogeneration turbines. No unusual energy impacts were identified with the addition of SCR to the turbines. Environmental impacts include the disposal of the spent SCR catalyst when replacement becomes necessary, as well as ammonia slip from the SCR system. Neither the ammonia slip nor the waste disposal of the catalyst would preclude the use of SCR as a potential NO_x control device.

RBLC Review

A review of similar units in the RBLC indicates that SCR is the principle NO_x control technology installed on large combined cycle and cogeneration gas-fired turbines (just under 96% in the RBLC database).

Applicant Proposal

AGDC provided economic analyses of installing SCR on the compressor turbines to demonstrate that it is not economically feasible on these units. A summary of the analyses are shown in Table 3-2 and Table 3-3 for the treated gas and CO₂ compressor turbines respectively.

Table 3-2: AGDC Economic Analysis for Technically Feasible NOx Controls (EUs 1 – 6)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR with DLN	56.8	136.6	\$7,165,039	\$1,729,067	\$12,661
Capital Recovery Factor = 0.0858 (7% interest rate for a 25 year equipment life)					

Table 3-3: AGDC Economic Analysis for Technically Feasible NOx Controls (EUs 7 – 12)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR with DLN	40.5	101.1	\$5,760,011	\$1,330,569	\$13,162
Capital Recovery Factor = 0.0858 (7% interest rate for a 25 year equipment life)					

AGDC contends that the economic analysis indicates the level of NOx reduction from SCR does not justify the use of SCR for the large cogeneration gas-fired turbines based on the excessive cost per ton of NOx removed per year.

AGDC proposes the following as BACT for NOx emissions from the large cogeneration gas-fired turbines:

- (a) NOx emissions from the operation of the large cogeneration gas-fired turbines will be controlled with the use of DLN combustors; and
- (b) NOx emissions from the large cogeneration gas-fired turbines (turbine + supplemental firing burner) will not exceed 17ppmv at 15 percent oxygen (@ 15% O₂).

Department Evaluation of BACT for NOx Emissions from Cogeneration Gas Turbines

The Department revised the emissions tables to reflect the current bank prime interest rate of 5.5%, to account for differences in PTE, and greater reduction efficiency achievable with SCR. A summary of the analyses for the treated gas compressor turbines is shown in Table 3-4, and the CO₂ compressor turbines in Table 3-5.

Table 3-4: Department Economic Analysis for Technically Feasible NOx Controls (EUs 1–6)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR with DLN	15.5	113.8	\$7,165,039	\$1,473,919	\$12,958
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 3-5: Department Economic Analysis for Technically Feasible NO_x Controls (EUs 7–12)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR with DLN	11.1	81.3	\$5,760,011	\$1,105,042	\$13,592
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of NO_x reduction does not justify the use of SCR as BACT for the large cogeneration gas-fired combustion turbines at the Gas Treatment Plant.

Step 5 – Selection of NO_x BACT for Compressor Turbines

The Department's finding is that BACT for NO_x emissions from the cogeneration gas-fired combustion turbines greater than 25 MW is as follows:

- NO_x emissions from EUs 1 – 12 shall be controlled by operating and maintaining DLN combustors and good combustion practices at all times the units are in operation;
- NO_x emissions from EUs 1 – 12 shall not exceed 17 ppmv @ 15% O₂ averaged over a 3-hour period; and
- Initial compliance with the proposed NO_x emission limit will be demonstrated by conducting a performance test to obtain an emission rate.

3.2 CO

Possible CO emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.210: large combined cycle and cogeneration natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 3-6.

Table 3-6: CO Control for Large Combined Cycle & Cogeneration Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (ppmv)
Oxidation Catalyst	78	0.9 – 15
Good Combustion & Clean Fuel	17	2 – 50

Step 1 – Identify CO Control Technologies for Compressor Turbines

From research, the Department identified the following technologies as available for CO control of large combined cycle and cogeneration natural gas-fired combustion turbines rated at greater than 25 MW:

- CO Oxidation Catalyst**
Catalytic oxidation is a flue gas control that oxidizes CO and hydrocarbon compounds to carbon dioxide and water vapor in the presence of a noble metal catalyst; no reaction reagent is necessary. The reaction is spontaneous and no reactants are required. Catalytic oxidizers can provide oxidation efficiencies of up to 90% at temperatures between 750°F and 1,000°F; the efficiency of the oxidation temperature quickly deteriorates as the

temperature decreases. The temperature of the turbine is expected to exhaust at approximately 1,000°F or less, remaining within the temperature range for CO oxidation catalysts. In the Department's search of the RBLC database, the majority of large combined cycle and cogeneration natural gas-fired combustion turbines used an oxidation catalyst as the primary control method for CO emissions and contained a BACT limit between 1.5 - 3 ppmv. Therefore, the Department considers oxidation catalysts a technically feasible control technology for the large cogeneration gas-fired turbines.

(b) Good Combustion Practices (GCP) and Clean Fuel

GCP typically include the following elements:

1. Sufficient residence time to complete combustion;
2. Providing and maintaining proper air/fuel ratio;
3. High temperatures and low oxygen levels in the primary combustion zone;
4. High enough overall excess oxygen levels to complete combustion and maximize thermal efficiency;
5. Proper fuel gas supply system designed to minimize effects of contaminants or fluctuations in pressure and flow on the fuel gas delivered.

Combustion efficiency is dependent on the gas residence time, the combustion temperature, and the amount of mixing in the combustion zone. GCP is accomplished primarily through combustion chamber design as it relates to residence time, combustion temperature, air-to-fuel mixing, and excess oxygen levels. The Department considers GCP and clean fuels a technically feasible control technology for the large cogeneration gas-fired turbines.

(c) SCONOX™

As discussed in detail in the NO_x BACT Section 3.1, SCONOX™ reduces CO emissions by oxidizing the CO to CO₂. This technology combines catalytic conversion of CO with an absorption and regeneration process without using ammonia reagent. SCONOX™ catalyst must operate in a temperature range of 300°F to 700°F, and therefore, turbine exhaust temperature must be reduced through the installation of a cooling system prior to entry to the SCONOX™ system. The Department's research did not identify facilities using SCONOX™ to control CO for turbines. Therefore, the Department considers this technology technically infeasible for the large cogeneration gas-fired turbines.

(d) Non-Selective Catalytic Reduction (NSCR)

NSCR uses a catalyst reaction to reduce CO to CO₂. The catalyst is usually a noble metal. The operating temperature for NSCR system ranges from about 700°F to 1,500°F, depending on the catalyst. NSCR requires a low excess oxygen concentration in the exhaust gas stream (typically less than 1%) to be effective because the oxygen must be depleted before the reduction chemistry can proceed. As such, NSCR is only effective with rich-burn gas-fired units that operate at all times with an air-to-fuel (A/F) ratio controller at or close to stoichiometric conditions. The Department's research did not identify NSCR as a control technology used to control CO emissions from turbines installed at any facility in the RBLC database. Therefore, the Department considers NSCR a technically infeasible control technology for the large cogeneration gas-fired turbines.

Step 2 – Eliminate Technically Infeasible CO Control Options for Compressor Turbines

As explained in Step 1, NSCR and SCONOX™ are not feasible technologies to control CO emissions from cogeneration gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining CO Control Options for Compressor Turbines

The following control technologies have been identified and ranked for control of CO from the compressor turbines:

- | | |
|------------------------|-------------------------|
| (a) Oxidation Catalyst | (90% Control) |
| (b) GCP & Clean Fuels | (Less than 90% Control) |

Step 4 – Evaluate the Most Effective Controls

An oxidation catalyst will reduce CO emissions from EUs 1 - 12 while having minimal energy and environmental impacts. This system requires no consumables and does not produce waste effluents or by-products aside from catalyst replacement and recycling as necessary. Turbine efficiency will be minimally impacted by the oxidation catalyst.

RBLC Review

A review of similar units in the RBLC indicates that an oxidation catalyst and good combustion practices are the principle CO control technologies used for combined cycle and cogeneration gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC proposed to install an oxidation catalyst and maintain good combustion practices for the compressor turbines EUs 1 – 12 as BACT for reducing CO emissions. CO emissions from EUs 1 – 12 will not exceed 5 ppmv @ 15% O₂.

Step 5 – Selection of CO BACT for Compressor Turbines

The Department's finding is that BACT for CO emissions from the cogeneration gas-fired combustion turbines greater than 25 MW is as follows:

- (a) CO emissions from EUs 1 – 12 shall be controlled by operating and maintaining an oxidation catalyst and following good combustion practices at all times the units are in operation;
- (b) CO emissions from EUs 1 – 12 shall not exceed 5 ppmv @ 15% O₂ averaged over a 3-hour period; and
- (c) Initial compliance with the proposed CO emission limit will be demonstrated by conducting a performance test to obtain an emission rate.

3.3 Particulates

Possible particulate emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.210: large combined cycle and cogeneration natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 3-9.

Table 3-9: Particulate Control for Large Combined Cycle & Cogeneration Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Good Combustion & Clean Fuel	70	0.0025 – 0.044

Step 1 – Identify Particulate Control Technologies for Power Generation Turbines

From research, the Department identified the following technologies as available for particulate control of large combined cycle and cogeneration natural gas-fired combustion turbines rated at greater than 25 MW:

(a) Fuel Specifications

Natural gas combustion turbines are among the cleanest fossil-fuel fired power generation equipment commercially available. Particulate emissions from combustion turbines fired with low sulfur natural gas are relatively insignificant and marginally significant using a liquid fuel. Particulate matter in the exhaust of liquid or gas-fired turbines are directly related to the levels of ash and metallic additives in fuel. As such, fuel specifications are the primary method of particulate matter control and are a feasible control technology for the large cogeneration gas-fired turbines.

(b) Good Combustion Practices

As discussed in detail in the CO BACT Section 3.2, Proper management of the combustion process will result in a reduction of particulates. Therefore good combustion practices is a feasible control option for the large cogeneration gas-fired turbines.

Step 2 – Eliminate Technically Infeasible Particulate Controls for Compressor Turbines

All control technologies identified are technically feasible for cogeneration gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining Particulate Control Options for Compressor Turbines

The following control technologies have been identified and ranked for control of particulates from the power generation turbines:

- (a) Good Combustion Practices & Clean Fuels (Less than 40% Control)

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for particulates for EUs 1 – 12. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the only particulate control technologies installed on combined cycle and cogeneration gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC proposed to use clean fuel and good combustion practices for the compressor turbines EUs 1 – 12 as BACT for reducing particulate emissions. Particulate emissions from EUs 1 – 12 will not exceed 0.0063 lb/MMBtu.

Step 5 – Selection of Particulate BACT for Compressor Turbines

The Department's finding is that BACT for particulate emissions from the cogeneration gas-fired combustion turbines greater than 25 MW is as follows:

- (a) Particulate emissions from EUs 1 – 12 shall be minimized by maintaining good combustion practices and burning clean fuels at all times the units are in operation;
- (b) Particulate emissions from EUs 1 – 12 shall not exceed 0.0063 lb/MMBtu averaged over a 3-hour period; and
- (c) Initial compliance with the proposed particulate emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EUs will comply with the BACT limit.

3.4 SO₂

Possible SO₂ emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.210: large combined cycle and cogeneration natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 3-10.

Table 3-10: SO₂ Control for Large Combined Cycle & Cogeneration Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (gr/100 dscf)
Good Combustion & Clean Fuel	10	0.75 – 5
No Control	1	2

Step 1 – Identify SO₂ Control Technologies for Compressor Turbines

From research, the Department identified the following technologies as available for SO₂ control of large combined cycle and cogeneration natural gas-fired combustion turbines rated at greater than 25 MW:

- (a) Good Combustion Practices and Clean Fuels
As discussed in detail in CO BACT Section 3.2, as well as the fuel specifications portion of particulate BACT Section 3.3, GCP and clean fuels is a common technique for controlling SO₂ emissions. SO₂ emissions in the exhaust of liquid or gas-fired turbines are directly related to the levels of sulfur in fuel. As such, fuel specifications are the primary method of SO₂ emissions control and are a feasible control technology for the combustion turbines.

Step 2 – Eliminate Technically Infeasible SO₂ Control Options for Compressor Turbines

All control technologies identified are technically feasible for cogeneration gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining SO₂ Control Options for Compressor Turbines

The following control technologies have been identified and ranked for control of SO₂ from the compressor turbines:

- (a) Good Combustion Practices & Clean Fuels (Less than 40% Control)

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for SO₂ emissions for EUs 1 – 12. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the only SO₂ emission control technologies installed on large combined cycle and cogeneration gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC proposed to use clean fuels and good combustion practices for the power generation turbines EUs 1 – 12 as BACT for reducing SO₂ emissions. AGDC will utilize natural gas in the compressor turbines EUs 1 – 12 with a total sulfur content not to exceed 96 ppmv.

Step 5 – Selection of SO₂ BACT for Compressor Turbines

The Department's finding is that BACT for SO₂ emissions from the cogeneration gas-fired combustion turbines greater than 25 MW is as follows:

- (a) SO₂ emissions from EUs 1 – 12 shall be minimized by maintaining good combustion practices and burning natural gas with a total sulfur content not to exceed 96 ppmv at all times the units are in operation; and
- (b) Compliance with the proposed fuel sulfur content limit will be demonstrated with fuel shipment receipts and/or fuel test results for total sulfur content.

3.5 VOC

Possible VOC emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.210: large combined cycle and cogeneration natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 3-11.

Table 3-11: VOC Control for Large Combined Cycle & Cogeneration Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (ppmv)
Good Combustion & Clean Fuel	11	0.3 – 4
Oxidation Catalyst	42	0.7 – 5
No Controls	6	1 – 4

Step 1 – Identify VOC Control Technologies for Compressor Turbines

From research, the Department identified the following technologies as available for VOC control of large combined cycle and cogeneration natural gas-fired combustion turbines rated at greater than 25 MW:

(a) Oxidation Catalyst

Oxidation catalyst can control VOC emissions in the exhaust gas with the proper selection of catalyst. The oxidation reaction is spontaneous and does not require addition reagents. Formaldehyde and other organic HAPs can see reductions of 85% to 90%. The Department considers oxidation catalysts a technically feasible control technology for the large cogeneration gas-fired turbines.

(b) Good Combustion Practices

VOC emissions in gas combustion turbines result from incomplete combustion. These VOCs can contain a wide variety of organic compounds, some of which are hazardous air pollutants. VOCs are discharged into the atmosphere when some of the fuel is un-combusted or only partially combusted. VOCs can be trace constituents of the fuel or products of pyrolysis of heavier hydrocarbons in the gas. In that complete combustion will reduce VOC emissions, good combustion practices are a feasible control method for the large cogeneration gas-fired turbines.

Step 2 – Eliminate Technically Infeasible VOC Control Options for Compressor Turbines

All control technologies identified are technically feasible for cogeneration gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining VOC Control Options for Compressor Turbines

The following control technologies have been identified and ranked for control of VOC from the Compressor turbines:

- (a) Oxidation Catalyst (85% to 90% Control)
- (b) Good Combustion Practices (Less than 85% Control)

Step 4 – Evaluate the Most Effective Controls

An oxidation catalyst will reduce VOC emissions from EUs 1 – 12 while having minimal energy and environmental impacts. This system requires no consumables and does not produce waste effluents or by-products aside from catalyst replacement and recycling as necessary. Turbine efficiency will be minimally impacted by the oxidation catalyst.

RBLC Review

A review of similar units in the RBLC indicates that an oxidation catalyst and good combustion practices are the principle VOC control technologies used on combined cycle and cogeneration gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC proposed to install an oxidation catalyst and maintain good combustion practices for the compressor turbines EUs 1 – 12 as BACT for reducing VOC emissions. VOC emissions from EUs 1 – 12 will not exceed 0.0074 lb/MMBtu.

Step 5 – Selection of VOC BACT for the Compressor Turbines

The Department's finding is that BACT for VOC emissions from the cogeneration gas-fired combustion turbines greater than 25 MW is as follows:

- (a) VOC emissions from EUs 1 – 12 shall be controlled by operating and maintaining an oxidation catalyst and good combustion practices at all times the units are in operation;
- (b) VOC emissions from EUs 1 – 12 shall not exceed 0.0022 lb/MMBtu averaged over a 3-hour period (applicant proposal with 70% VOC removal from oxidation catalyst); and
- (c) Initial compliance with the proposed VOC emission limit will be demonstrated by conducting a performance test to obtain an emission rate.

3.6 GHG

Possible GHG emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.210: large combined cycle and cogeneration natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 3-12.

Table 3-12: GHG Control for Large Combined Cycle & Cogeneration Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (lb/MWh)
Good Combustion & Clean Fuel	27	850 – 1800
No Control	5	774 – 1000

CO₂ and N₂O emissions are produced during natural gas combustion in gas turbines. Nearly all of the fuel carbon is converted to CO₂ during the combustion process, regardless of the firing configuration. CH₄ is also present in the exhaust gas and is thought to be unburned fuel in the case of natural gas.

Step 1 – Identify GHG Control Technologies for Power Generation Turbines

From research, the Department identified the following technologies as available for GHG control of large combined cycle and cogeneration natural gas-fired combustion turbines rated at greater than 25 MW:

- (a) Thermal Efficiency and the Utilization of Thermal Energy and Electricity
The EPA Guidance states that options that improve the overall efficiency of the source or modification must be evaluated in the BACT analysis. These options can include technologies, processes, and practices at the emitting unit that allows the plant to operate more efficiently. In general, an efficient process requires less fuel for process heat, and therefore reduces the amount of CO₂ produced. In addition to energy efficiency of the individual emitting units, process improvements that impact the facility's higher-energy-using equipment, processes or operations could lead to reductions in emissions. There are a number of cycle configurations of a turbine as well as turbine designs that improves the efficiency of the operation.

1. Simple Cycle Gas-Fired Turbine (Baseline)

In the baseline case, each turbine would operate in a simple cycle, which includes a single gas turbine to generate power. This configuration uses air as a diluent to reduce combustion flame temperatures. Fuel and air are pre-mixed in an initial stage resulting in a uniform, lean, unburned fuel/air mixture, which is then delivered to the combustor. The efficient combustion resulting from the process reduces the fuel consumption and CO₂ emissions.

2. Turbine with Waste Heat Recovery (Combined Cycle or Combined Heat and Power)

In a combined cycle turbine, waste heat recovery units are added to the exhausts of the turbines, and recover previously unused energy to drive a steam turbine generator (STG). In a Combined Heat and Power (also known as cogeneration) turbine, waste heat from the turbine exhaust is put to a productive use such as heating a building, or used for a process that requires heat inputs. Utilizing waste heat in turbines leads to a more energy efficient operation because the additional power produced by the STG and heat produced by the turbine does not require additional fuel consumption. Besides the STG, this configuration requires additional equipment such as condensers, deaerator, and boiler feed pump, which increases the footprint and the cost of the facility. Furthermore, the additional steam turbine generation in a fixed electrical demand application forces gas turbine load reductions, increasing the gas turbine heat rates, and offsetting CO₂ reduction benefits.

3. Aeroderivative Turbine

Aeroderivative turbines are similar to industrial turbines (also known as heavy duty or frame turbines) except their design is derived from aviation turbines, causing them to be lighter and generally smaller. Aeroderivative turbines have been used in gas compression and electrical power generation operations due to their ability to be shut down and handle load changes quickly. These turbines are also used in the marine industry due to their reduced weight. In addition to being lighter weight than traditional industrial turbines, these turbines are generally more efficient than industrial turbines of comparable size and capacity. This leads to less fuel consumption to achieve the same power output, resulting in a reduction of GHG emissions in the 4% to 12% range.

4. Organic Rankine Cycle (ORC)

ORC uses a refrigerant working fluid that is heated by engine exhaust gas from the natural gas fired turbines, and expands through a turbine connected to the engine shaft. The ORC system involves the same components as in a conventional steam power plant; however, instead of using water as a working fluid, ORC uses a refrigerant with a boiling point lower than that of water, and enables recovery of heat from lower-temperature heat sources. The ORC offers reduced equipment size compared to the steam cycle. This equipment is at their best in air-cooled applications where the heat source is below approximately 400°F. The heat source for this application is the gas turbine exhaust, and is approximately 800 to 1,000 °F, which would require an additional thermal fluid loop.

A disadvantage of the ORC is that, the configuration requires more fuel consumption compared to the steam cycle, and operation when ambient temperature is below 40°F (approximately 50% of the year) makes the system less efficient. Also, additional heat exchangers may be needed to preheat the ORC working fluid and the combustion air, which would increase the cost and complexity of the system. The Department does not consider ORC as a technically feasible technology for control of GHGs.

(b) Carbon Capture and Sequestration (CCS)

The EPA Guidance classifies CCS as “an add-on pollution control technology that is ‘available’ for facilities emitting CO₂ in large amounts.” AGDC has included a description of CCS, and a review of the technology in their permit application.

CCS is a broad term that includes a number of technologies that involves three general steps: 1) capturing the carbon dioxide directly at its source and compressing it, 2) transporting, and 3) storing it in non-atmospheric reservoirs. Capture, the most energy-intensive of all the processes, can be done either through pre-combustion methods or post-combustion methods. Pre-combustion requires the use of oxygen instead of air to combust the fuel. In general, pre-combustion reduces the energy required and the cost to remove CO₂ emissions from the combustion process. The concentration of CO₂ in the untreated gas stream is higher in pre-combustion capture, thereby requiring less and cheaper equipment. The other method is post-combustion, applied to conventional combustion techniques using air and carbon-containing fuels in order to isolate CO₂ from the combustion exhaust gases.

After capture, the CO₂ is compressed to a near-liquid state, and transported via pipeline to a designated storage area. These reservoirs are deep enough for the pressure of the earth to keep it in a liquidized form where it will be sequestered for thousands of years. Depleted oil and gas reservoirs are the most practical places for storing CO₂ emissions that would otherwise be emitted back into the atmosphere. Other options for storage include deep saline formations, un-mineable coal seams, and even offshore storage. The stored CO₂ is expected to remain underground for as long as thousands, even millions of years.

The Department’s research did not identify CCS as a control technology used to control GHG emissions from turbines or any other emission unit type installed at any facility in the RBLC database. Therefore, the Department considers this technology to be commercially unavailable in the United States and a technically infeasible control technology for the large cogeneration gas-fired turbines.

(c) Good Combustion Practices (GCP) and Clean Fuels

Discussed in detail in CO BACT Section 3.2, as well as the fuel specifications portion of particulate BACT Section 3.3. GCP and clean fuels is a common technique for controlling GHG emissions. GHG emissions in the exhaust of liquid or gas-fired turbines are directly related to the carbon content in the fuel. Natural gas has the lowest amount of GHG emissions per Btu of energy of any fossil fuel, and is considered a feasible control technology for the power generation turbines.

Step 2 – Eliminate Technically Infeasible GHG Control Options for Compressor Turbines

As explained in Step 1, ORC and CCS are not feasible technologies to control GHG emissions from cogeneration gas-fired turbines larger than 25 MW.

Aeroderivative turbine: the facility is currently designed to use 12 cogeneration turbines for the treated gas compression and CO₂ compression. Requiring the compressor turbines to be aeroderivative models would fundamentally redefine the source, and is therefore not considered as an option in the BACT analysis.

Step 3 – Rank Remaining GHG Control Options for Compressor Turbines

AGDC has accepted the only feasible control option. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for GHG emissions for EUs 1 – 12. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the only GHG emission control technologies currently installed on combined cycle or and cogeneration gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC proposed to use clean fuels (natural gas) and good combustion practices for the compressor turbines EUs 1 – 12 as BACT for reducing GHG emissions. GHG emissions from EUs 1 – 12 will not exceed 117.1 lb/MMBtu, which is the carbon dioxide equivalent (CO₂e) emissions rates for burning natural gas in 40 CFR Part 98: Mandatory Greenhouse Gas Reporting. The total CO₂e emissions rate is calculated with the equation CO₂(1) + CH₄(25) + N₂O(298).

Step 5 – Selection of GHG BACT for Compressor Turbines

The Department's finding is that BACT for GHG emissions from the cogeneration gas-fired combustion turbines greater than 25 MW is as follows:

- (a) GHG emissions from EUs 1 – 12 shall be minimized by maintaining good combustion practices and burning clean fuels at all times the units are in operation; and
- (a) GHG emissions from treated gas compressor turbines EUs 1 – 12 shall not exceed 117.1 lb/MMBtu averaged over a 3-hour period.

4.0 POWER GENERATION TURBINES

The GTP will use six simple cycle natural gas-fired turbines (EUs 25 – 30) to supply power to the facility. Each turbine is planned to have a nominal capacity of approximately 40 MW, for a total of 240 MW. The power generation turbines will emit CO, NO_x, SO₂, particulates, VOC, and GHG. The following sections provide the BACT review for each of these pollutants.

4.1 NO_x

Possible NO_x emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.110: large simple cycle natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 4-1.

Table 4-1: NO_x Controls for Large Simple Cycle Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (ppmv)
Selective Catalytic Reduction	11	2.5 – 5
Low NO _x Burners	38	9 – 25
Water Injection	5	20 – 25

Step 1 – Identify NO_x Control Technologies for Power Generation Turbines

From research, the Department identified the following technologies as available for control of NO_x emissions from gas-fired simple cycle combustion turbines rated at 25 MW or greater:

(a) Selective Catalytic Reduction (SCR)

SCR is a post-combustion gas treatment technique for reducing nitric oxide (NO) and nitrogen dioxide (NO₂) in the turbine exhaust stream to molecular nitrogen (N₂), water, and oxygen (O₂). In the SCR process, aqueous or anhydrous ammonia (NH₃) is injected into the flue gas upstream of a catalyst bed. The catalyst lowers the activation energy of the NO_x decomposition reaction. NO_x and NH₃ combine at the catalyst surface forming an ammonium salt intermediate, which subsequently decomposes to produce elemental N₂ and water. The operating temperature of conventional SCR systems ranges from 400 degrees Fahrenheit (°F) to 800°F. High temperature SCR relies on special material reaction grids and can operate at higher temperature ranges between 700°F to 1,075°F. High temperature SCR is most frequently installed on simple cycle turbines. Depending on the overall NH₃-to-NO_x ratio, removal efficiencies are generally 80 to 90 percent. The Department considers SCR a technically feasible control technology for large simple cycle gas-fired turbines.

(b) Dry Low NO_x (DLN)

DLN combustors (marketed under many similar names such as SoLoNO_x or DLE) utilize multistage premix combustors where the air and fuel is mixed at a lean (high oxygen) fuel-to-air ratio. The excess air in the lean mixture acts as a heat sink, which lowers peak combustion temperatures and also ensures a more homogeneous mixture avoiding localized “hot spots”, both resulting in greatly reduced NO_x formation rates. DLN combustors have the potential to reduce NO_x emissions by 40 to 60%. In the Department’s search of the RBLC database, the majority of large simple cycle natural gas-fired combustion turbines used DLN as the primary control method for NO_x emissions and contained a BACT limit of 9 parts per million by volume (ppmv). Note that DLN is designed for natural gas-fired or dual-fuel fired units and is not effective in controlling NO_x emissions from fuel oil-fired units. The Department considers DLN a technically feasible control technology for large simple cycle gas-fired turbines.

(c) Water/Steam Injection

Water/steam injection involves the introduction of water or steam into the combustion zone. The injected fluid provides a heat sink which absorbs some of the heat of reaction, causing a lower flame temperature. The lower flame temperature results in lower thermal NO_x formation. Both steam and water injections are capable of obtaining the same level of control. The process requires approximately 0.8 to 1.0 pound of water or steam per pound of fuel burned. The main technical consideration is the required purity of the water or steam, which is required to protect the equipment from dissolved solids. Obtaining water or steam of sufficient purity requires the installation of rigorous water treatment and deionization systems, incurring additional costs. Water/steam injection also increases CO emissions as it lowers the combustion temperature. Depending on baseline uncontrolled NO_x levels, water or steam injection can reduce NO_x by 60% or more. Water/steam injection is a proven technology for NO_x emissions reduction from turbines. However, the arctic environment presents significant challenges to water/steam injection due to cost of water treatment, freezing potential due to extreme cold ambient temperatures, and increased maintenance problems due to accelerated wear in the hot sections of the turbines. The Department considers water/steam injection a technically feasible control technology for large simple cycle gas-fired turbines.

(d) Selective Non-Catalytic Reduction (SNCR)

SNCR involves the non-catalytic decomposition of NO_x in the flue gas to N₂ and water using reducing agents such as urea or NH₃. The process utilizes a gas phase homogeneous reaction between NO_x and the reducing agent within a specific temperature window. The reducing agent must be injected into the flue gas at a location in the unit that provides the optimum reaction temperature and residence time. The NH₃ process (trade name-Thermal DeNO_x) requires a reaction temperature window of 1,600°F to 2,200°F. In the urea process (trade name-NO_xOUT), the optimum temperature ranges between 1,600 °F and 2,100 °F. Because the temperature of simple cycle turbines exhaust gas normally ranges from 800°F to 1,000°F, achieving the required reaction temperature is the main difficulty for application of SNCR to turbines. The Department's research did not identify SNCR as a technology used to control NO_x emissions from turbines installed at any facility. Hence the Department considers SNCR as a technically infeasible control technology for the large simple cycle gas-fired turbines.

(e) Non-Selective Catalytic Reduction (NSCR)

NSCR simultaneously reduces NO_x and oxidizes CO and hydrocarbons in the exhaust gas to N₂, carbon dioxide (CO₂), and water. The catalyst, usually a noble metal, causes the reducing gases in the exhaust stream (hydrogen, methane, and CO) to reduce both NO and NO₂ to N₂ at a temperature between 800°F and 1,200°F. NSCR requires a low excess O₂ concentration in the exhaust gas stream to be effective because the O₂ must be depleted before the reduction chemistry can proceed. NSCR is only effective with rich-burn gas-fired units that operate at all times with an air/fuel ratio controller at or close to stoichiometric conditions. Turbines operate under conditions far more fuel-lean than required to support NSCR. The Department's research did not identify NSCR as a control technology used to control NO_x emissions from turbines installed at any facility. Hence

the Department considers NSCR as a technically infeasible control technology for the large simple cycle gas-fired turbines.

(f) SCONOX™

SCONOX™ is a new catalytic absorption technology developed by Goal Line Environmental Technologies, Inc. to treat exhaust gas with a potassium carbonate coated catalyst, reducing NO_x to N₂. The catalyst also oxidizes CO to CO₂, and NO and NO₂ to potassium nitrates (KNO₃). The catalyst is regenerated by passing dilute H₂ over it which converts the KNO₂ and KNO₃ to K₂CO₃, water, and N₂. One disadvantage of SCONOX™ is that the catalyst is very sensitive to sulfur in the fuel. For fuel gas sulfur content exceeding 30 ppmv, a sulfur adsorption catalyst must be installed upstream of the SCONOX™ catalyst to remove sulfur. No known installations exist in low ambient temperature settings or on turbine arrangements in industrial settings. The Department's research did not identify facilities using SCONOX™ to control NO_x for turbines. Therefore, the Department considers this technology technically infeasible for the large simple cycle gas-fired turbines.

(g) XONON™

XONON™ is a catalytic technology developed by Catalytica Energy Systems, Inc. and now owned by Kawasaki. XONON™ uses flameless fuel combustion to lower NO_x emissions. The combustion chamber of a gas turbine completely contains the XONON™ system. XONON™ completely combusts fuel to produce a high-temperature mixture typically about 2,400 °F. Dilution air is added to shape the temperature profile required at the turbine inlet. General Electric and Solar Turbines are testing this new catalyst technology, and the Department's research did not identify facilities using XONON™. The Department considers XONON™ a technically infeasible control technology for the large simple cycle gas-fired turbines because it is not commercially available.

Step 2 – Eliminate Technically Infeasible NO_x Control Options for Power Generation Turbines

As explained in Step 1, SNCR, NSCR, SCONOX™, and XONON™ are not feasible technologies to control NO_x emissions from simple cycle gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining NO_x Control Options for Power Generation Turbines

The following control technologies have been identified and ranked for control of NO_x from the power generation turbines:

- | | |
|---------------------------|---------------------|
| (a) SCR | (70% - 90% Control) |
| (b) DLN | (40% - 60% Control) |
| (c) Water/Steam Injection | (20% - 40% Control) |

Step 4 – Evaluate the Most Effective Controls

SCR is the most effective NO_x control for large simple cycle turbines. No unusual energy impacts were identified with the addition of SCR to the turbines. Environmental impacts include the disposal of the spent SCR catalyst when replacement becomes necessary, as well as ammonia slip from the SCR system. Neither the ammonia slip nor the waste disposal of the catalyst would preclude the use of SCR as a potential NO_x control device.

RBLC Review

A review of similar units in the RBLC indicates that DLN is the principle NOx control technology, followed by SCR for large simple cycle gas-fired turbines.

Applicant Proposal

AGDC provided an economic analysis of the top most effective control technology SCR (DLN is already installed on the base model turbine) available for the power generation turbines to demonstrate that the use of the most effective control (SCR) is not economically feasible on these units. A summary of the analysis for power generation turbines is shown in Table 4-2:

Table 4-2: AGDC Economic Analysis for Technically Feasible NOx Controls (EUs 25 – 30)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR with DLN	33.5	67.2	\$5,112,188	\$1,049,846	\$15,631
Capital Recovery Factor = 0.0858 (7% interest rate for a 25 year equipment life)					

AGDC contends that the economic analysis indicates the level of NOx reduction from SCR does not justify the use of SCR for the large simple cycle gas-fired turbines based on the excessive cost per ton of NOx removed per year.

AGDC proposes the following as BACT for NOx emissions from the large simple cycle gas-fired turbines:

- (a) NOx emissions from the operation of the large simple cycle gas-fired turbines will be controlled with the use of DLN combustors; and
- (b) NOx emissions from the large simple cycle gas-fired turbines will not exceed 15ppmv @ 15% O₂.

Department Evaluation of BACT for NOx Emissions from Large Simple Cycle Gas-Fired Turbines

The Department revised the emissions table to reflect the current bank prime interest rate of 5.5%, to account for differences in PTE, and greater reduction efficiency achievable with SCR. A summary of the analyses is shown below:

Table 4-3: Department Economic Analysis for Technically Feasible NOx Controls (EUs 25-30)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR with DLN	13.1	85.7	\$5,112,188	\$1,048,699	\$12,235
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of NO_x reduction does not justify the use of SCR as BACT for the large simple cycle gas-fired combustion turbines at the Gas Treatment Plant.

Step 5 – Selection of NO_x BACT for Power Generation Turbines

The Department's finding is that BACT for NO_x emissions from the simple cycle gas-fired combustion turbines greater than 25 MW is as follows:

- (a) NO_x emissions from EUs 25 – 30 shall be controlled by operating and maintaining DLN combustors at all times the units are in operation;
- (b) NO_x emissions from EUs 25 – 30 shall not exceed 15ppmv @ 15% O₂ averaged over a 3-hour period; and
- (c) Initial compliance with the proposed NO_x emission limit will be demonstrated by conducting a performance test to obtain an emission rate.

4.2 CO

Possible CO emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.110: large simple cycle natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 4-4.

Table 4-4: CO Control for Large Simple Cycle Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (ppmv)
Oxidation Catalyst	10	1.5 – 10
Good Combustion & Clean Fuel	30	4 – 29
No Control	1	63

Step 1 – Identify CO Control Technologies for Power Generation Turbines

From research, the Department identified the following technologies as available for CO control of large simple cycle natural gas-fired combustion turbines rated at greater than 25 MW:

- (a) Oxidation Catalyst
Catalytic oxidation is a flue gas control that oxidizes CO and hydrocarbon compounds to carbon dioxide and water vapor in the presence of a noble metal catalyst; no reaction reagent is necessary. The reaction is spontaneous and no reactants are required. Catalytic oxidizers can provide oxidation efficiencies of up to 90% at temperatures between 750°F and 1,000°F; the efficiency of the oxidation temperature quickly deteriorates as the temperature decreases. The temperature of the turbine is expected to exhaust at approximately 1,000°F or less, remaining within the temperature range for CO oxidation catalysts. The Department considers oxidation catalysts a technically feasible control technology for large simple cycle gas-fired turbines.
- (b) Good Combustion Practices (GCP) and Clean Fuel
GCP typically include the following elements:
 - 1. Sufficient residence time to complete combustion;
 - 2. Providing and maintaining proper air/fuel ratio;

3. High temperatures and low oxygen levels in the primary combustion zone;
4. High enough overall excess oxygen levels to complete combustion and maximize thermal efficiency;
5. Proper fuel gas supply system designed to minimize effects of contaminants or fluctuations in pressure and flow on the fuel gas delivered.

Combustion efficiency is dependent on the gas residence time, the combustion temperature, and the amount of mixing in the combustion zone. GCP is accomplished primarily through combustion chamber design as it relates to residence time, combustion temperature, air-to-fuel mixing, and excess oxygen levels. In the Department's search of the RBLC database, the majority of large simple cycle natural gas-fired combustion turbines used GCP and clean fuels as the primary control method for CO emissions. Therefore, the Department considers GCP and clean fuels a technically feasible control technology for large simple cycle gas-fired turbines.

(c) SCONOX™

As discussed in detail in the NO_x BACT Section 4.1, SCONOX™ reduces CO emissions by oxidizing the CO to CO₂. This technology combines catalytic conversion of CO with an absorption and regeneration process without using ammonia reagent. SCONOX™ catalyst must operate in a temperature range of 300°F to 700°F, and therefore, turbine exhaust temperature must be reduced through the installation of a cooling system prior to entry to the SCONOX™ system. The Department's research did not identify facilities using SCONOX™ to control CO for turbines. Therefore, the Department considers this technology technically infeasible for the large simple cycle gas-fired turbines.

(d) Non-Selective Catalytic Reduction (NSCR)

NSCR uses a catalyst reaction to reduce CO to CO₂. The catalyst is usually a noble metal. The operating temperature for NSCR system ranges from about 700°F to 1,500°F, depending on the catalyst. NSCR requires a low excess oxygen concentration in the exhaust gas stream (typically less than 1%) to be effective because the oxygen must be depleted before the reduction chemistry can proceed. As such, NSCR is only effective with rich-burn gas-fired units that operate at all times with an air-to-fuel (A/F) ratio controller at or close to stoichiometric conditions. The Department's research did not identify NSCR as a control technology used to control CO emissions from turbines installed at any facility in the RBLC database. Therefore, the Department considers NSCR a technically infeasible control technology for the large simple cycle gas-fired turbines.

Step 2 – Eliminate Technically Infeasible CO Control Options for Power Generation Turbines

As explained in Step 1, NSCR and SCONOX™ are not feasible technologies to control CO emissions from simple cycle gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining CO Control Options for Power Generation Turbines

The following control technologies have been identified and ranked for control of CO from the power generation turbines:

- | | |
|------------------------|-------------------------|
| (a) Oxidation Catalyst | (90% Control) |
| (b) GCP & Clean Fuels | (Less than 90% Control) |

Step 4 – Evaluate the Most Effective Controls

An oxidation catalyst will reduce CO emissions from EUs 25 - 30 while having minimal energy and environmental impacts. This system requires no consumables and does not produce waste effluents or by-products aside from catalyst replacement and recycling as necessary. Turbine efficiency will be minimally impacted by the oxidation catalyst.

RBLC Review

A review of similar units in the RBLC indicates that an oxidation catalyst and good combustion practices are the principle CO control technologies used for simple cycle gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC provided an economic analysis of the top most effective control technology (oxidation catalyst) available for the power generation turbines to demonstrate that the use of the most effective control is not economically feasible for the power generation turbines EUs 25 – 30. A summary of the analysis for the power generation turbines is shown in Table 4-5.

Table 4-5: AGDC Economic Analysis for Technically Feasible CO Controls (EUs 25 – 30)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	19.0	38.0	\$3,812,520	\$864,117	\$22,740
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

AGDC contends that the economic analysis indicates the level of CO reduction from an oxidation catalyst does not justify the use of an oxidation catalyst for the power generation turbines EUs 25 – 30 based on the excessive cost per ton of CO removed per year.

AGDC proposes the following as BACT for CO emissions from the large simple cycle gas-fired turbines:

- CO emissions from the operation of the power generation turbines (EUs 25 – 30) will be controlled with the use of good combustion practices and clean fuel; and
- CO emissions from the power generation turbines (EUs 25 – 30) will not exceed 15 ppmv @ 15% O₂.

Department Evaluation of BACT for CO Emissions from Simple Cycle Gas-Fired Turbines

The Department revised the emissions tables to reflect the equipment life revised to a 25 year lifespan, adjusted the interest rate to the current bank prime interest rate of 5.5%, and revised the freight cost to 10% of the purchased equipment costs. A summary of the analyses is shown below:

Table 4-6: Department Economic Analysis for Technically Feasible CO Controls (EUs 25–30)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	19.0	38.0	\$2,797,498	\$464,890	\$12,234
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of CO reduction does not justify the use of an oxidation catalyst as BACT for the power generation turbines (EUs 25 – 30) at the GTP.

Step 5 – Selection of CO BACT for Power Generation Turbines

The Department's finding is that BACT for CO emissions from the simple cycle gas-fired combustion turbines greater than 25 MW is as follows:

- CO emissions from EUs 25 – 30 shall be controlled by maintaining good combustion control practices and burning clean fuel at all times the units are in operation;
- CO emissions from EUs 25 – 30 shall not exceed 15 ppmv @ 15% O₂ averaged over a 3-hour period; and
- Initial compliance with the proposed CO emission limit will be demonstrated by conducting a performance test to obtain an emission rate.

4.3 Particulates

Possible particulate emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.110: large simple cycle natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 4-7.

Table 4-7: Particulate Control for Large Simple Cycle Natural Gas Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Good Combustion & Clean Fuel	25	0.0033 – 0.013

Step 1 – Identify Particulate Control Technologies for Power Generation Turbines

From research, the Department identified the following technologies as available for particulate control of large simple cycle natural gas-fired combustion turbines rated at greater than 25 MW:

- Fuel Specifications**
Natural gas combustion turbines are among the cleanest fossil-fuel fired power generation equipment commercially available. Particulate emissions from combustion turbines fired with low sulfur natural gas are relatively insignificant and marginally significant using a liquid fuel. Particulate matter in the exhaust of liquid or gas-fired turbines are directly related to the levels of ash and metallic additives in fuel. As such, fuel specifications are the primary method of particulate matter control and are a feasible control technology for the large simple cycle gas-fired turbines.

(b) Good Combustion Practices

As discussed in detail in the CO BACT Section 4.2, Proper management of the combustion process will result in a reduction of particulates. Therefore good combustion practices is a feasible control option for the large simple cycle gas-fired turbines.

Step 2 – Eliminate Technically Infeasible PM Controls for Power Generation Turbines

All control technologies identified are technically feasible for simple cycle gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining Particulate Control Options for Power Generation Turbines

The following control technologies have been identified and ranked for control of particulates from the power generation turbines:

- (a) GCP & Clean Fuels (Less than 40% Control)

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for particulates for EUs 25 – 30. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the only particulate control technologies installed on simple cycle gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC proposed to use clean fuel and good combustion practices for the power generation turbines EUs 25 – 30 as BACT for reducing particulate emissions. Particulate emissions from EUs 25 – 30 will not exceed 0.0070 lb/MMBtu.

Step 5 – Selection of Particulate BACT for Power Generation Turbines

The Department's finding is that BACT for particulate emissions from the simple cycle gas-fired combustion turbines greater than 25 MW is as follows:

- (a) Particulate emissions from EUs 25 – 30 shall be minimized by maintaining good combustion practices and burning clean fuels at all times the units are in operation;
- (b) Particulate emissions from EUs 25 – 30 shall not exceed 0.0070 lb/MMBtu averaged over a 3-hour period (AP-42 Table 3.1-2a, particulate (total) emissions rate for gas-fired turbines); and
- (c) Initial compliance with the proposed particulate emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EUs will comply with the BACT limit.

4.4 SO₂

Possible SO₂ emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.110: large simple cycle natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 4-8.

Table 4-8: SO₂ Control for Large Simple Cycle Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (gr/100 dscf)
Good Combustion & Clean Fuel	8	1 – 2
No Control	2	1 – 2

Step 1 – Identify SO₂ Control Technologies for Power Generation Turbines

From research, the Department identified the following technologies as available for SO₂ control of large simple cycle natural gas-fired combustion turbines rated at greater than 25 MW:

(a) Good Combustion Practices and Clean Fuels

As discussed in detail in CO BACT Section 4.2, as well as the fuel specifications portion of particulate BACT Section 4.3, GCP and clean fuels is a common technique for controlling SO₂ emissions. SO₂ emissions in the exhaust of liquid or gas-fired turbines are directly related to the levels of sulfur in fuel. As such, fuel specifications are the primary method of SO₂ emissions control and are a feasible control technology for the combustion turbines.

Step 2 – Eliminate Technically Infeasible SO₂ Control Options for Power Generation Turbines

All control technologies identified are technically feasible for simple cycle gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining SO₂ Control Options for Power Generation Turbines

The following control technologies have been identified and ranked for control of SO₂ from the power generation Turbines:

(a) Good Combustion Practices and Clean Fuels (Less than 40% Control)

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for SO₂ emissions for EUs 25 – 30. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the only SO₂ emission control technologies installed on simple cycle gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC proposed to use clean fuels and good combustion practices for the power generation turbines EUs 25 – 30 as BACT for reducing SO₂ emissions. AGDC will utilize natural gas in the compressor turbines EUs 1 – 12 with a total sulfur content not to exceed 96 ppmv.

Step 5 – Selection of SO₂ BACT for Power Generation Turbines

The Department's finding is that BACT for SO₂ emissions from the simple cycle gas-fired combustion turbines greater than 25 MW is as follows:

- (a) SO₂ emissions from EUs 25 – 30 shall be minimized by maintaining good combustion practices and burning natural gas with a total sulfur content not to exceed 96 ppmv at all times the units are in operation; and
- (b) Compliance with the proposed fuel sulfur content limit will be demonstrated with fuel shipment receipts and/or fuel test results for total sulfur content.

4.5 VOC

Possible VOC emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.110: large simple cycle natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 4-9.

Table 4-9: VOC Control for Large Simple Cycle Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (ppmv)
Good Combustion & Clean Fuel	10	1.4 – 5
Oxidation Catalyst	7	2 – 3

Step 1 – Identify VOC Control Technologies for Power Generation Turbines

From research, the Department identified the following technologies as available for VOC control of large simple cycle natural gas-fired combustion turbines rated at greater than 25 MW:

- (a) Oxidation Catalyst
Oxidation catalyst can control VOC emissions in the exhaust gas with the proper selection of catalyst. The oxidation reaction is spontaneous and does not require addition reagents. Formaldehyde and other organic HAPs can see reductions of 85% to 90%. The Department considers oxidation catalysts a technically feasible control technology for large simple cycle gas-fired turbines.
- (b) Good Combustion Practices
VOC emissions in gas combustion turbines result from incomplete combustion. These VOCs can contain a wide variety of organic compounds, some of which are hazardous air pollutants. VOCs are discharged into the atmosphere when some of the fuel is un-combusted or only partially combusted. VOCs can be trace constituents of the fuel or products of pyrolysis of heavier hydrocarbons in the gas. In that complete combustion will reduce VOC emissions, good combustion practices are a feasible control method for large simple cycle gas-fired turbines.

Step 2 – Eliminate Technically Infeasible VOC Controls for Power Generation Turbines

All control technologies identified are technically feasible for simple cycle gas-fired turbines larger than 25 MW.

Step 3 – Rank Remaining VOC Control Options for Power Generation Turbines

The following control technologies have been identified and ranked for control of VOC from the power generation turbines:

- (a) Oxidation Catalyst (85% to 90% Control)
- (b) Good Combustion Practices (Less than 85% Control)

Step 4 – Evaluate the Most Effective Controls

An oxidation catalyst will reduce VOC emissions from EUs 25 - 30 while having minimal energy and environmental impacts. This system requires no consumables and does not produce waste effluents or by-products aside from catalyst replacement and recycling as necessary. Turbine efficiency will be minimally impacted by the oxidation catalyst.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and oxidation catalysts are the principle VOC control technologies used on simple cycle gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC proposed to use good combustion practices for the power generation turbines EUs 25 – 30 as BACT for reducing VOC emissions. VOC emissions from EUs 25 – 30 will not exceed 0.0022 lb/MMBtu.

Note that AGDC previously demonstrated that an oxidation catalyst is not economically feasible for reducing CO emissions, which have an emissions rate more than 10 times greater than VOC emissions for EUs 25 – 30. Therefore, an oxidation catalyst will not be economically feasible for reducing VOC emissions.

Step 5 – Selection of VOC BACT for Power Generation Turbines

The Department's finding is that BACT for VOC emissions from the simple cycle gas-fired combustion turbines greater than 25 MW is as follows:

- (a) VOC emissions from EUs 25 – 30 shall be controlled by maintaining good combustion practices at all times the units are in operation;
- (b) VOC emissions from EUs 25 – 30 shall not exceed 0.0022 lb/MMBtu averaged over a 3-hour period (AP-42 Table 3.1-2a, VOC emission rate for gas-fired turbines); and
- (c) Initial compliance with the proposed VOC emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EUs will comply with the BACT limit.

4.6 GHG

Possible GHG emission control technologies for turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.110:

large simple cycle natural gas-fired combustion turbines (>25 MW). The search results are summarized in Table 4-10.

Table 4-10: GHG Control for Large Simple Cycle Natural Gas-Fired Combustion Turbines

Control Technology	Number of Determinations	Emission Limits (lb/MWh)
Good Combustion & Clean Fuel	11	884 – 1707
No Control	10	1030 – 1461

CO₂ and N₂O emissions are produced during natural gas combustion in gas turbines. Nearly all of the fuel carbon is converted to CO₂ during the combustion process, regardless of the firing configuration. CH₄ is also present in the exhaust gas and is thought to be unburned fuel in the case of natural gas.

Step 1 – Identify GHG Control Technologies for Power Generation Turbines

From research, the Department identified the following technologies as available for GHG control of large simple cycle natural gas-fired combustion turbines rated at greater than 25 MW:

(a) Thermal Efficiency and the Utilization of Thermal Energy and Electricity

The EPA Guidance states that options that improve the overall efficiency of the source or modification must be evaluated in the BACT analysis. These options can include technologies, processes, and practices at the emitting unit that allows the plant to operate more efficiently. In general, an efficient process requires less fuel for process heat, and therefore reduces the amount of CO₂ produced. In addition to energy efficiency of the individual emitting units, process improvements that impact the facility's higher-energy-using equipment, processes or operations could lead to reductions in emissions. There are a number of cycle configurations of a turbine as well as turbine designs that improves the efficiency of the operation.

1. Simple Cycle Gas-Fired Turbine (Baseline)

In the baseline case, each turbine would operate in a simple cycle, which includes a single gas turbine to generate power. This configuration uses air as a diluent to reduce combustion flame temperatures. Fuel and air are pre-mixed in an initial stage resulting in a uniform, lean, unburned fuel/air mixture, which is then delivered to the combustor. The efficient combustion resulting from the process reduces the fuel consumption and CO₂ emissions.

2. Turbine with Waste Heat Recovery (Combined Cycle or Combined Heat and Power)

In a combined cycle turbine, waste heat recovery units are added to the exhausts of the turbines, and recover previously unused energy to drive a steam turbine generator (STG). In a Combined Heat and Power (also known as cogeneration) turbine, waste heat from the turbine exhaust is put to a productive use such as heating a building, or used for a process that requires heat inputs. Utilizing waste heat in turbines leads to a more energy efficient operation because the additional power produced by the STG and heat produced by the turbine does not require additional fuel consumption. Besides the STG, this configuration requires additional equipment such as condensers, deaerator, and boiler feed pump, which increases the footprint and the cost of the facility. Furthermore, the additional steam turbine generation in a fixed

electrical demand application forces gas turbine load reductions, increasing the gas turbine heat rates, and offsetting CO₂ reduction benefits.

3. Aeroderivative Turbine

Aeroderivative turbines are similar to industrial turbines (also known as heavy duty or frame turbines) except their design is derived from aviation turbines, causing them to be lighter and generally smaller. Aeroderivative turbines have been used in gas compression and electrical power generation operations due to their ability to be shut down and handle load changes quickly. These turbines are also used in the marine industry due to their reduced weight. In addition to being lighter weight than traditional industrial turbines, these turbines are generally more efficient than industrial turbines of comparable size and capacity. This leads to less fuel consumption to achieve the same power output, resulting in a reduction of GHG emissions in the 4% to 12% range.

4. Organic Rankine Cycle (ORC)

ORC uses a refrigerant working fluid that is heated by engine exhaust gas from the natural gas fired turbines, and expands through a turbine connected to the engine shaft. The ORC system involves the same components as in a conventional steam power plant; however, instead of using water as a working fluid, ORC uses a refrigerant with a boiling point lower than that of water, and enables recovery of heat from lower-temperature heat sources. The ORC offers reduced equipment size compared to the steam cycle. This equipment is at their best in air-cooled applications where the heat source is below approximately 400°F. The heat source for this application is the gas turbine exhaust, and is approximately 800 to 1,000 °F, which would require an additional thermal fluid loop.

A disadvantage of the ORC is that, the configuration requires more fuel consumption compared to the steam cycle, and operation when ambient temperature is below 40°F (approximately 50% of the year) makes the system less efficient. Also, additional heat exchangers may be needed to preheat the ORC working fluid and the combustion air, which would increase the cost and complexity of the system. The Department does not consider ORC as a technically feasible technology for control of GHGs.

(b) Carbon Capture and Sequestration

The EPA Guidance classifies CCS as “an add-on pollution control technology that is ‘available’ for facilities emitting CO₂ in large amounts.” AGDC has included a description of CCS, and a review of the technology in their permit application.

CCS is a broad term that includes a number of technologies that involves three general steps: 1) capturing the carbon dioxide directly at its source and compressing it, 2) transporting, and 3) storing it in non-atmospheric reservoirs. Capture, the most energy-intensive of all the processes, can be done either through pre-combustion methods or post-combustion methods. Pre-combustion requires the use of oxygen instead of air to combust the fuel. In general, pre-combustion reduces the energy required and the cost to remove CO₂ emissions from the combustion process. The concentration of CO₂ in the untreated gas stream is higher in pre-combustion capture, thereby requiring less and

cheaper equipment. The other method is post-combustion, applied to conventional combustion techniques using air and carbon-containing fuels in order to isolate CO₂ from the combustion exhaust gases.

After capture, the CO₂ is compressed to a near-liquid state, and transported via pipeline to a designated storage area. These reservoirs are deep enough for the pressure of the earth to keep it in a liquidized form where it will be sequestered for thousands of years. Depleted oil and gas reservoirs are the most practical places for storing CO₂ emissions that would otherwise be emitted back into the atmosphere. Other options for storage include deep saline formations, un-mineable coal seams, and even offshore storage. The stored CO₂ is expected to remain underground for as long as thousands, even millions of years.

The Department's research did not identify CCS as a control technology used to control GHG emissions from turbines or any other emission unit type installed at any facility in the RBLC database. Therefore, the Department considers this technology to be commercially unavailable in the United States and a technically infeasible control technology for the large simple cycle gas-fired turbines.

(c) Good Combustion Practices (GCP) and Clean Fuels

Discussed in detail in CO BACT Section 4.2, as well as the fuel specifications portion of particulate BACT Section 4.3. GCP and clean fuels is a common technique for controlling GHG emissions. GHG emissions in the exhaust of liquid or gas-fired turbines are directly related to the carbon content in the fuel. Natural gas has the lowest amount of GHG emissions per Btu of energy of any fossil fuel, and is considered a feasible control technology for the power generation turbines.

Step 2 – Eliminate Technically Infeasible GHG Controls for Power Generation Turbines

As explained in Step 1, ORC and CCS are not feasible technologies to control GHG emissions from simple cycle gas-fired turbines larger than 25 MW.

Turbine with Waste Heat Recovery (Combined Cycle or Combined Heat and Power): the facility is currently designed to use six simple cycle turbines to generate power for the GTP. These power generation turbines will be located approximately 1/3 mile away from the processing facility, and there is no additional demand for the recovered waste heat. The process heat needs for the facility are satisfied by separate cogeneration turbines (combined heat and power) used for treated gas compression (EUs 1 – 6) and CO₂ compression (EUs 7 – 12). Additionally, the operating power demand profile for the power generation turbines has more load variance than the mechanical drives, making the control of a WHR system technically difficult with frequent starts and stops or load changes to units which could result in freezing or sub-cooling issues. Therefore, requiring the power generation turbines to include a waste heat recovery system would fundamentally redefine the nature of the proposed stationary source, and is therefore not considered as an option in the BACT analysis.

Aeroderivative turbine: the facility is currently designed to use six simple cycle turbines rated at 40 MW each to supply power to the GTP. Requiring the compression turbines to be

aeroderivative models would fundamentally redefine the project, and is therefore not considered as an option in the BACT analysis.

Step 3 – Rank Remaining GHG Control Options for Power Generation Turbines

AGDC has accepted the only feasible control option. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for GHG emissions for EUs 25 – 30. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the only GHG emission control technologies currently installed on simple cycle gas-fired turbines larger than 25 MW.

Applicant Proposal

AGDC proposed to use clean fuels (natural gas) and good combustion practices for the power generation turbines EUs 25 – 30 as BACT for reducing GHG emissions. GHG emissions from EUs 25 – 30 will not exceed 117.1 lb/MMBtu, which is the CO₂e emissions rates for burning natural gas in 40 CFR Part 98: Mandatory Greenhouse Gas Reporting. The total CO₂e emissions rate is calculated with the equation CO₂(1) + CH₄(25) + N₂O(298).

Step 5 – Selection of GHG BACT for Power Generation Turbines

The Department's finding is that BACT for GHG emissions from the simple cycle gas-fired combustion turbines greater than 25 MW is as follows:

- (a) GHG emissions from EUs 25 – 30 shall be minimized by maintaining good combustion practices and burning clean fuels at all times the units are in operation; and
- (b) GHG emissions from EUs 25 – 30 shall not exceed 117.1 lb/MMBtu averaged over a 3-hour period.

5.0 BLACK START AND EMERGENCY DIESEL-FIRED ENGINES

AGDC will have several engines on site, including one 2,500 kW black start diesel generator (EU 39), three 190 kW diesel fire pump engines (EUs 40 - 42), and two emergency diesel generators (EUs 43 and 44) rated at 250 kW and 150 kW respectively. EUs 39 - 44 are all considered limited use diesel-fired engines. The black start, fire pump, and emergency generator engines will emit CO, NO_x, SO₂, particulates, VOC, and GHG. The following sections provide the BACT review for each of these pollutants.

5.1 NO_x

Possible NO_x emission control technologies for limited use diesel engines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 17:110 to 17:190: Large Internal Combustion Engines (>500 hp) and 17:210: Small Fuel Oil-Fired Internal Combustion Engines (<500 hp). The search results for the engines greater than 500 hp and smaller than 500 hp are contained in Tables 5-1 and 5-2 respectively.

Table 5-1: NO_x Controls for Large Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Selective Catalytic Reduction	3	0.5 - 0.7
Other Add-On Control	1	1.0
Federal Emission Standards	13	3.0 - 6.9
Good Combustion Practices	31	3.0 - 13.5
No Control Specified	60	2.8 - 14.1

Table 5-2: NO_x Controls for Small Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Federal Emission Standards	5	2.2 – 4.8
Good Combustion Practices	25	2.0 – 9.5
Limited Operation	4	3.0
No Control Specified	25	2.6 – 5.6

RBLC Review

A review of similar units in the RBLC indicates good combustion practices and Federal emissions standards are the principle NO_x control technologies installed on diesel-fired engines. The lowest emission rate listed in the RBLC is 0.5 g/hp-hr for large diesel engines and 2.0 g/hp-hr for small diesel engines.

Step 1 – Identify NO_x Control Technologies for Diesel-Fired Engines

From research, the Department identified the following technologies as available for NO_x control of diesel engines:

(a) Selective Catalytic Reduction

The theory of SCR was discussed in detail in the NO_x BACT Section 3.1 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department considers SCR a technically feasible control technology for both the large and small diesel-fired engines.

(b) Turbocharger and Aftercooler

Turbocharger technology involves the process of compressing intake air in a turbocharger upstream of the air/fuel injection. This process boosts the power output of the engine. The air compression increases the temperature of the intake air so an aftercooler is used to reduce the intake air temperature. Reducing the intake air temperature helps lower the peak flame temperature which reduces NO_x formation in the combustion chamber. Today, manufacturers typically design new diesel engines with a turbocharger and aftercooler technology as part of standard equipment. The Department considers turbocharger and aftercooler a technically feasible control technology for both the large and small diesel-fired engines.

(c) Fuel Injection Timing Retard (FITR)

FITR reduces NO_x emissions by the delay of the fuel injection in the engine from the time the compression chamber is at minimum volume to a time the compression chamber is expanding. Timing adjustments are relatively straightforward. The larger volume in the

compression chamber produces a lower peak flame temperature. With the use of FITR the engine becomes less fuel efficient, particulate matter emissions increase, and there is a limit with respect to the degree the timing may be retarded because an excessive timing delay can cause the engine to misfire. The timing retard is generally limited to no more than three degrees. Diesel engines may also produce more black smoke due to a decrease in exhaust temperature and incomplete combustion. FITR can achieve up to 50 percent NOx reduction. Due to the increase in particulate matter emissions resulting from FITR, this technology will not be carried forward.

(d) Ignition Timing Retard (ITR)

ITR lowers NOx emissions by moving the ignition event to later in the power stroke, after the piston has begun to move downward. Because the combustion chamber volume is not at a minimum, the peak flame temperature is not as high, which lowers combustion temperature and produces less thermal NOx. Use of ITR can cause an increase in fuel usage, an increase in particulate matter emissions, and engine misfiring. ITR can achieve between 20 to 30 percent NOx reduction. Due to the increase in the particulate matter emissions resulting from ITR, this technology will not be carried forward.

(e) Federal Emission Standards

RBLC NOx determinations for federal emission standards require the engines meet the requirements of 40 C.F.R. 60 Subpart IIII, 40 C.F.R 63 Subpart ZZZZ, or EPA tier certifications. Subpart IIII applies to stationary compression ignition internal combustion engines that are manufactured or reconstructed after July 11, 2005. The Department considers meeting the technology based New Source Performance Standards (NSPS) of Subpart IIII as a technically feasible control technology for both the large and small diesel-fired engines.

(f) Limited Operation

Limiting the operation of emissions units reduces the potential to emit of those units. As stated above in Section 5.0, all of the diesel-fired engines at the GTP are considered limited use engines. The Department considers limited operation a technically feasible control technology for both the large and small diesel-fired engines.

(g) Good Combustion Practices

The theory of GCPs was discussed in detail in the CO BACT Section 3.2 for the combined cycle natural gas-fired turbines and will not be repeated here. The Department considers GCPs a technically feasible control technology for both the large and small diesel-fired engines.

Step 2 – Eliminate Technically Infeasible NOx Control Options for Diesel-Fired Engines

As explained in Step 1, the Department does not consider fuel injection timing retard and ignition timing retard as technically feasible technologies to control NOx emissions from the diesel-fired engines.

Step 3 – Rank Remaining NOx Control Options for Diesel-Fired Engines

The following control technologies have been identified and ranked for control of NOx from the engines:

- | | |
|-----------------------------------|-------------------------|
| (a) Limited Operation | (94% Control) |
| (b) Selective Catalytic Reduction | (90% Control) |
| (c) Good Combustion Practices | (Less than 40% Control) |
| (d) Turbocharger and Aftercooler | (6% – 12% Control) |
| (e) Federal Emission Standards | (Baseline) |

Step 4 – Evaluate the Most Effective Controls

SCR is the most effective NOx control for diesel-fired engines. Environmental impacts include the SCR system increasing exhaust back pressure which decreases the engine's efficiency requiring additional fuel consumption, the disposal of the spent SCR catalyst when replacement becomes necessary, as well as ammonia slip from the SCR system.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices is the principle NOx control technology used on diesel-fired engines.

Applicant Proposal

AGDC provided economic analyses of the top most effective control technology SCR with limited operation of 500 hours per year assumed for each engine to demonstrate that the use of the most effective control (SCR) is not economically feasible for these limited use diesel engines. A summary of the analyses for the black start diesel generator EU 39 can be found in Table 5-3, the main firewater pumps (EUs 40 – 42) in Table 5-4, the dormitory emergency diesel generator EU 43 in Table 5-5, and the communications tower emergency diesel generator EU 44 in Table 5-6.

Table 5-3: AGDC Economic Analysis for Technically Feasible NOx Controls (EU 39)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.41	5.43	\$204,055	\$291,091	\$53,580
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

Table 5-4: AGDC Economic Analysis for Technically Feasible NOx Controls (EUs 40 – 42)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.03	0.37	\$67,474	\$42,114	\$115,309
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

Table 5-5: AGDC Economic Analysis for Technically Feasible NOx Controls (EU 43)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.04	0.49	\$67,474	\$47,096	\$96,775
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

Table 5-6: AGDC Economic Analysis for Technically Feasible NOx Controls (EU 44)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.02	0.29	\$67,474	\$39,242	\$134,393
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

AGDC contends that the economic analysis indicates the level of NOx reduction from SCR does not justify the use of SCR for the limited use diesel engines based on the excessive cost per ton of NOx removed per year.

AGDC proposes the following as BACT for NOx emissions from the diesel engines:

- NOx emissions from the operation of the diesel engines EUs 39 - 44 will be controlled through limited operation of 500 hours per 12-month rolling period per unit and by utilizing good combustion practices;
- NOx emissions from the black start diesel generator EU 39 will not exceed 3.26 g/hp-hr @ 15% O₂;
- NOx emissions from the diesel firewater pump engines EUs 40 – 42 will not exceed 3.56 g/hp-hr @ 15% O₂; and
- NOx emissions from the emergency diesel engines EUs 43 and 44 will not exceed 3.54 g/hp-hr @ 15% O₂.

Department Evaluation of BACT for NOx Emissions from Diesel-Fired Engines

The Department revised the emissions tables to reflect the equipment life revised to a 25 year lifespan, to account for differences in PTE, and adjusted the interest rate to the current bank prime interest rate of 5.5%. A summary of the analyses for the black start diesel generator EU 39 can be found in Table 5-7, the main firewater pumps (EUs 40 – 42) in Table 5-8, the dormitory emergency diesel generator EU 43 in Table 5-9, and the communications tower emergency diesel generator EU 44 in Table 5-10.

Table 5-7: Department Economic Analysis for Technically Feasible NOx Controls (EU 39)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.51	6.79	\$204,055	\$286,970	\$43,677
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 5-8: Department Economic Analysis for Technically Feasible NOx Controls (EUs 40-42)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.03	0.46	\$67,474	\$40,775	\$89,314
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 5-9: Department Economic Analysis for Technically Feasible NOx Controls (EU 43)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.05	0.61	\$67,474	\$45,758	\$75,219
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 5-10: Department Economic Analysis for Technically Feasible NOx Controls (EU 44)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.03	0.36	\$67,474	\$37,903	\$103,846
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of NOx reduction does not justify the use of SCR as BACT for any of the limited use diesel engines at the Gas Treatment Plant.

Step 5 – Selection of NOx BACT for Diesel-Fired Engines

The Department's finding is that BACT for NOx emissions from the limited use diesel engines is as follows:

- NOx emissions from the operation of the diesel engine EUs 39 - 44 shall be controlled by maintaining good combustion practices at all times the units are in operation;
- Limit operation of the diesel-fired engines EUs 39 – 44 to no more than 500 hours per 12-month rolling period per engine;

- (c) NO_x emissions from the black start diesel generator EU 39 will not exceed 3.3 g/hp-hr @ 15% O₂ (EPA Tier 4 Final, includes 25% not to exceed factor of safety);
- (d) NO_x emissions from the diesel firewater pump engines EUs 40 – 42 will not exceed 3.6 g/hp-hr @ 15% O₂ (95% of NMHC + NO_x from Table 4 of NSPS Subpart IIII, also equivalent to EPA Tier 3, includes 25% not to exceed factor of safety);
- (e) NO_x emissions from the emergency diesel engines EUs 43 and 44 will not exceed 3.6 g/hp-hr @ 15% O₂ (95% of NMHC + NO_x from EPA Tier 3, includes 25% not to exceed factor of safety); and
- (f) Initial compliance with the proposed NO_x emission limits will be demonstrated by purchasing engines certified to meet the appropriate EPA Tier emissions standards.

5.2 CO

Possible CO emission control technologies for limited use diesel engines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 17.110 to 17:190: Large Internal Combustion Engines (>500 hp) and 17.210: Small Fuel Oil-Fired Internal Combustion Engines (<500 hp). The search results for the diesel engines greater than 500 hp and smaller than 500 hp are contained in Tables 5-11 and 5-12 respectively.

Table 5-11: CO Controls for Large Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Oxidation Catalyst	1	0.13
Federal Emission Standards, Clean Fuel, & Good Combustion Practices	56	0.31 - 8.5
Operational Limit	1	2.6
No Control Specified	15	0.26 – 2.6

Table 5-12: CO Controls for Small Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Federal Emission Standards, Clean Fuel, & Good Combustion Practices	43	0.53 - 3.7
Operational Limit	2	2.6 - 4.1
Turbocharger & Intercooler	1	0.45
No Control Specified	16	0.5 - 3.1

Step 1 – Identify CO Control Technologies for Diesel-Fired Engines

From research, the Department identified the following technologies as available for CO control of diesel-fired engines:

(a) Oxidation Catalyst

The theory of oxidation catalysts were discussed in detail in the CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines. Oxidation catalysts oxidize CO and hydrocarbon compounds to carbon dioxide and water vapor. The reaction is spontaneous and no reactants are required. CO catalysts can achieve up to 90%

reduction in CO emissions. The Department considers oxidation catalysts to be a technically feasible control technology for both the large and small sized diesel engines.

(b) Good Combustion Practices (GCP) and clean fuel

The theory of GCPs and clean fuel was discussed in detail in CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that GCPs and clean fuel are commonly used to control CO emissions for diesel engines. Therefore, the Department considers GCPs and clean fuel to be a technically feasible control technology for both the large and small sized diesel engines.

(c) Limited Operation

Limiting the operation of emissions units reduces the potential to emit of those units. As stated above in Section 5.0, all of the diesel-fired engines at the GTP are considered limited use engines. The Department considers limited operation a technically feasible control technology for both the large and small diesel-fired engines.

(d) Federal Emission Standards

RBLC CO determinations for federal emission standards require the engines meet the requirements of 40 C.F.R. 60 Subpart IIII, 40 C.F.R 63 Subpart ZZZZ, or EPA tier certifications. Subpart IIII applies to stationary compression ignition internal combustion engines that are manufactured or reconstructed after July 11, 2005. The Department considers meeting the technology based New Source Performance Standards of Subpart IIII as a technically feasible control technology for both the large and small diesel-fired engines.

Step 2 – Eliminate Technically Infeasible CO Control Options for Diesel-Fired Engines

All of the control technologies identified are technically feasible for the diesel engines.

Step 3 – Rank Remaining CO Control Options for Diesel-Fired Engines

The following control technologies have been identified and ranked for control of CO from the diesel-fired engines:

- | | |
|--------------------------------|-------------------------|
| (a) Limited Operation | (94% Control) |
| (b) Oxidation Catalyst | (90% Control) |
| (c) Good Combustion Practices | (Less than 90% Control) |
| (d) Federal Emission Standards | (Baseline) |

Step 4 – Evaluate the Most Effective Controls

An oxidation catalyst will reduce CO emissions from EUs 39 - 44 while having minimal energy and environmental impacts. This system requires no consumables and does not produce waste effluents or by-products aside from catalyst replacement and recycling as necessary. Engine efficiency will be minimally impacted by the oxidation catalyst.

RBLC Review

A review of similar units in the RBLC indicates good combustion practices with clean fuel and following Federal emissions standards are the principle CO control for both large and small sized diesel engines.

Applicant Proposal

AGDC provided economic analyses of the most effective control technology - oxidation catalyst with limited operation of 500 hours per year assumed for each engine to demonstrate that the use of an oxidation catalyst is not economically feasible for these limited use diesel engines. A summary of the analyses for the black start diesel generator EU 39 can be found in Table 5-13, the main firewater pumps (EUs 40 – 42) in Table 5-14, the dormitory emergency diesel generator EU 43 in Table 5-15, and the communications tower emergency diesel generator EU 44 in Table 5-16.

Table 5-13: AGDC Economic Analysis for Technically Feasible CO Controls (EU 39)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	1.75	4.09	\$25,507	\$6,857	\$1,677
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

Table 5-14: AGDC Economic Analysis for Technically Feasible CO Controls (EUs 40 – 42)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.11	0.25	\$25,507	\$6,857	\$27,343
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

Table 5-15: AGDC Economic Analysis for Technically Feasible CO Controls (EU 43)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.14	0.34	\$25,507	\$6,857	\$20,237
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

Table 5-16: AGDC Economic Analysis for Technically Feasible CO Controls (EU 44)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.09	0.20	\$25,507	\$6,857	\$33,879
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

AGDC contends that the economic analysis indicates the level of CO reduction from an oxidation catalyst does not justify the use of an oxidation catalyst for the engine EUs 40 - 44 based on the excessive cost per ton of CO removed per year. For the black start diesel engine EU 39, AGDC contends that the installation of an oxidation catalyst may be cost effective, but that the only case of an oxidation catalyst found in the RBLC for the same diesel engine included SCR to address NOx control with the additional benefit of CO reduction associated with an integrated oxidation catalyst in the SCR control system. AGDC contends that this is not representative of the situation of their black start diesel generator and therefore recommends good combustion practices and clean fuels as BACT for all of their limited use diesel engines.

AGDC proposes the following as BACT for CO emissions from the diesel engines:

- CO emissions from the operation of the diesel engines EUs 39 - 44 shall be controlled through limited operation of 500 hours per 12-month rolling period per unit and by maintaining good combustion control practices at all times the units are in operation;
- CO emissions from the black start diesel generator EU 39 will not exceed 3.26 g/hp-hr @ 15% O₂;
- NOx emissions from the diesel firewater pump engines EUs 40 – 42 will not exceed 3.25 g/hp-hr @ 15% O₂; and
- NOx emissions from the emergency diesel engines EUs 43 and 44 will not exceed 3.26 g/hp-hr @ 15% O₂.

Department Evaluation of BACT for CO Emissions from Diesel-Fired Engines

The Department revised the emissions tables to reflect the equipment life revised to a 25 year lifespan, to account for differences in PTE and greater reduction efficiency achievable with catalytic oxidation, and adjusted the interest rate to the current bank prime interest rate of 5.5%. A summary of the analyses for the black start diesel generator EU 39 can be found in Table 5-17, the main firewater pumps (EUs 40 – 42) in Table 5-18, the dormitory emergency diesel generator EU 43 in Table 5-19, and the communications tower emergency diesel generator EU 44 in Table 5-20.

Table 5-17: Department Economic Analysis for Technically Feasible CO Controls (EU 39)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	1.46	5.84	\$25,507	\$6,351	\$1,087
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 5-18: Department Economic Analysis for Technically Feasible CO Controls (EUs 40-42)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.09	0.36	\$25,507	\$6,351	\$17,728
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 5-19: Department Economic Analysis for Technically Feasible CO Controls (EU 43)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.12	0.48	\$25,507	\$6,351	\$13,179
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 5-20: Department Economic Analysis for Technically Feasible CO Controls (EU 44)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.07	0.29	\$25,507	\$6,351	\$21,965
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of CO reduction does not justify the use of an oxidation catalyst as BACT for diesel engine EUs 40 - 44. However, the Department finds that the removal cost of \$1,087 per ton for the installation of an oxidation catalyst on the black start generator EU 39 is reasonable, and the RBLC does contain an example of a large diesel engine with oxidation catalyst used to control CO emissions.

Step 5 – Selection of CO BACT for Diesel-Fired Engines

The Department's finding is that BACT for CO emissions from the limited use diesel engines is as follows:

- CO emissions from the operation of the black start diesel engine EU 39 shall be controlled by operating and maintaining an oxidation catalyst at all times the unit is in operation;
- CO emissions from the operation of the diesel engines EUs 40 - 44 shall be controlled by maintaining good combustion practices at all times the units are in operation;
- Limit operation of the diesel-fired engines EUs 39 – 44 to no more than 500 hours per 12-month rolling period per engine;
- CO emissions from the black start diesel generator EU 39 will not exceed 3.3 g/hp-hr @ 15% O₂ (EPA Tier 4 Final, includes 25% not to exceed factor of safety);

- (e) CO emissions from the diesel firewater pump engines EUs 40 – 42 will not exceed 3.3 g/hp-hr @ 15% O₂ (Table 4 from NSPS Subpart IIII, also equivalent to EPA Tier 3, includes 25% not to exceed factor of safety);
- (f) CO emissions from the emergency diesel engines EUs 43 and 44 will not exceed 3.3 g/hp-hr @ 15% O₂ (EPA Tier 3, includes 25% not to exceed factor of safety);
- (g) For the black start diesel engine EU 39, initial compliance with the proposed CO emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EU will comply with the BACT limit; and
- (h) For EUs 40 – 44, Initial compliance with the proposed CO emission limits will be demonstrated by purchasing engines certified to meet the appropriate EPA Tier emissions standards.

5.3 Particulates

Possible particulate emission control technologies for limited use diesel engines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 17.110 to 17:190: Large Internal Combustion Engines (>500 hp) and 17.210: Small Fuel Oil-Fired Internal Combustion Engines (<500 hp). The search results for the diesel engines greater than 500 hp and smaller than 500 hp are contained in Tables 5-21 and 5-22 respectively.

Table 5-21: Particulate Control for Large Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Diesel Particulate Filter	2	0.15
Federal Emission Standards, Good Combustion Practices, & Clean Fuel	113	0.015 – 0.43
Operational Limit	2	0.15
No Control Specified	32	0.025 – 0.32

Table 5-22: Particulate Control for Small Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Diesel Particulate Filter	2	0.15
Federal Emission Standards, Good Combustion Practices, & Clean Fuel	89	0.075 – 0.40
Operational Limit	2	0.15
No Control Specified	32	0.11 – 1.0

Step 1 – Identify Particulate Control Technologies for Diesel-Fired Engines

From research, the Department identified the following technologies as available for particulate control of diesel engines:

(a) Diesel Particulate Filter (DPF)

DPFs are a control technology that are designed to physically filter particulate matter from the exhaust stream. Several designs exist which require cleaning and replacement of the filter media after soot has become caked onto the filter media. Regenerative filter designs are also available that burn the soot on a regular basis to regenerate the filter media. The Department considers DPF a technically feasible control technology for the diesel-fired engines.

(b) Diesel Oxidation Catalyst (DOC)

DOC can reportedly reduce PM-2.5 emissions by 30% and PM emissions by 50%. A DOC is a form of “bolt on” technology that uses a chemical process to reduce pollutants in the diesel exhaust into decreased concentrations. They replace mufflers on vehicles, and require no modifications. More specifically, this is a honeycomb type structure that has a large area coated with an active catalyst layer. As CO and other gaseous hydrocarbon particles travel along the catalyst, they are oxidized thus reducing pollution. The Department considers DOC a technically feasible control technology for the diesel-fired engines.

(c) Positive Crankcase Ventilation

Positive crankcase ventilation is the process of re-introducing the combustion air into the cylinder chamber for a second chance at combustion after the air has seeped into and collected in the crankcase during the downward stroke of the piston cycle. This process allows any unburned fuel to be subject to a second combustion opportunity. Any combustion products act as a heat sink during the second pass through the piston, which will lower the temperature of combustion and reduce the thermal NO_x formation. The Department considers positive crankcase ventilation a technically feasible control technology for the diesel-fired engines.

(d) Low Sulfur Fuel

Low sulfur fuel has been known to reduce particulate matter emissions. The Department considers low sulfur fuel as a feasible control technology for the diesel-fired engines.

(e) Low Ash Diesel

Residual fuels and crude oil are known to contain ash forming components, while refined fuels are low ash. Fuels containing ash can cause excessive wear to equipment and foul engine components. The Department considers low ash diesel a technically feasible control technology for the diesel-fired engines.

(f) Federal Emission Standards

RBLIC PM-2.5 determinations for federal emission standards require the engines meet the requirements of 40 C.F.R. 60 NSPS Subpart IIII, 40 C.F.R 63 Subpart ZZZZ, non-road engines (NREs), or EPA tier certifications. NSPS Subpart IIII applies to stationary compression ignition internal combustion engines that are manufactured or reconstructed after July 11, 2005. The Department considers NSPS Subpart IIII a technically feasible control technology for the diesel-fired engines.

(g) Limited Operation

Limiting the operation of emissions units reduces the potential to emit of those units. As stated above in Section 5.0, all of the diesel-fired engines at the GTP are considered limited use engines. The Department considers limited operation a technically feasible control technology for the diesel-fired engines.

(h) Good Combustion Practices

As discussed in detail in the CO BACT Section 4.2, Proper management of the combustion process will result in a reduction of particulates. The Department considers good combustion practices a technically feasible control technology for the diesel-fired engines.

Step 2 – Eliminate Technically Infeasible Particulate Control Options for Diesel-Fired Engines

All control technologies identified are technically feasible to control particulate emissions from the diesel engines.

Step 3 – Rank Remaining Particulate Control Options for Diesel-Fired Engines

The following control technologies have been identified and ranked for control of particulate emissions from the diesel engines.

(a) Limited Operation	(94% Control)
(b) Diesel Particulate Filters	(85% Control)
(c) Good Combustion Practices	(Less than 40% Control)
(d) Diesel Oxidation Catalyst	(30% Control)
(e) Low Ash Diesel	(25% Control)
(f) Positive Crankcase Ventilation	(10% Control)
(g) Federal Emission Standards	(Baseline)

Step 4 – Evaluate the Most Effective Controls

Limited operation and diesel particulate filters will reduce particulate emissions from EUs 39 - 44 while having minimal environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that Federal emission standards, good combustion practices, and burning of ULSD fuel are the principle particulate control technologies installed on diesel engines.

Applicant Proposal

AGDC provided economic analyses of the top most effective control technology DPF with limited operation of 500 hours per year assumed for each engine to demonstrate that the use of a DPF is not economically feasible for these limited use diesel engines. A summary of the analyses for the black start diesel generator EU 39 can be found in Table 5-23, the main firewater pumps (EUs 40 – 42) in Table 5-24, the dormitory emergency diesel generator EU 43 in Table 5-25, and the communications tower emergency diesel generator EU 44 in Table 5-26.

Table 5-23: AGDC Economic Analysis for Feasible Particulate Controls (EU 39)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
DPF	0.01	0.06	\$308,893	\$57,884	\$958,085
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

Table 5-24: AGDC Economic Analysis for Feasible Particulate Controls (EUs 40 – 42)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
DPF	<0.01	0.02	\$19,022	\$3,565	\$191,617
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

Table 5-25: AGDC Economic Analysis for Feasible Particulate Controls (EU 43)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
DPF	<0.01	0.02	\$25,489	\$4,776	\$192,903
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

Table 5-26: AGDC Economic Analysis for Feasible Particulate Controls (EU 44)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
DPF	<0.01	0.01	\$15,293	\$2,866	\$192,903
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

AGDC contends that the economic analysis indicates the level of particulate emissions reduction from a DPF does not justify the use of DPF for the limited use diesel engines based on the excessive cost per ton of particulate emissions removed per year.

AGDC proposes the following as BACT for particulate emissions from the diesel-fired engines:

- (a) Particulate emissions from the operation of the diesel engines EUs 39 - 44 shall be controlled through limited operation of 500 hours per 12-month rolling period per unit and by maintaining good combustion control practices;
- (b) Particulate emissions from the black start diesel generator EU 39 will not exceed 0.0375 g/hp-hr @ 15% O₂;

- (c) Particulate emissions from the diesel firewater pump engines EUs 40 – 42 will not exceed 0.188 g/hp-hr @ 15% O₂; and
- (d) Particulate emissions from the emergency diesel engines EUs 43 and 44 will not exceed 0.186 g/hp-hr @ 15% O₂.

Department Evaluation of BACT for Particulate Emissions from Diesel-Fired Engines

The Department revised the emissions tables to reflect the equipment life revised to a 25 year lifespan, to account for differences in PTE, and adjusted the interest rate to the current bank prime interest rate of 5.5%. A summary of the analyses for the black start diesel generator EU 39 can be found in Table 5-27, the main firewater pumps (EUs 40 – 42) in Table 5-28, the dormitory emergency diesel generator EU 43 in Table 5-29, and the communications tower emergency diesel generator EU 44 in Table 5-30.

Table 5-27: Department Economic Analysis for Feasible Particulate Controls (EU 39)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
DPF	0.01	0.09	\$308,893	\$51,755	\$571,087
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 5-28: Department Economic Analysis for Feasible Particulate Controls (EUs 40-42)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
DPF	<0.01	0.02	\$19,022	\$3,187	\$137,061
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 5-29: Department Economic Analysis for Feasible Particulate Controls (EU 43)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
DPF	<0.01	0.03	\$25,489	\$4,271	\$137,981
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 5-30: Department Economic Analysis for Feasible Particulate Controls (EU 44)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
DPF	<0.01	0.02	\$15,293	\$2,562	\$137,981
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of particulate emissions reduction does not justify the use of a DPF as BACT for any of the limited use diesel engines at the Gas Treatment Plant.

Step 5 – Selection of Particulate BACT for Diesel-Fired Engines

The Department's finding is that BACT for particulate emissions from the limited use diesel engines is as follows:

- (a) Particulate emissions from the operation of the diesel engine EUs 39 - 44 shall be controlled by maintaining good combustion practices and burning ULSD fuel at all times the units are in operation;
- (b) Limit operation of the diesel-fired engines EUs 39 – 44 to no more than 500 hours per 12-month rolling period per engine;
- (c) Particulate emissions from the black start diesel-fired generator EU 39 will not exceed 0.045 g/hp-hr @ 15% O₂ (EPA Tier 4 Final, includes 50% not to exceed factor of safety);
- (d) Particulate emissions from the diesel firewater pump engines EUs 40 – 42 will not exceed 0.19 g/hp-hr @ 15% O₂ (Table 4 of NSPS Subpart IIII, also equivalent to EPA Tier 3, includes 25% not to exceed factor of safety);
- (e) Particulate emissions from the emergency diesel engines EUs 43 and 44 will not exceed 0.19 g/hp-hr @ 15% O₂ (EPA Tier 3, includes 25% not to exceed factor of safety); and
- (f) Initial compliance with the proposed particulate emission limits will be demonstrated by purchasing engines certified to meet the appropriate EPA Tier emissions standards.

5.4 SO₂

Possible SO₂ emission control technologies for limited use diesel-fired engines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 17.110 to 17.190: Large Internal Combustion Engines (>500 hp) and 17.210: Small Fuel Oil-Fired Internal Combustion Engines (<500 hp). The search results for the diesel engines greater than 500 hp and smaller than 500 hp are contained in Tables 5-31 and 5-32 respectively.

Table 5-31: SO₂ Controls for Large Diesel Engines

Control Technology	Number of Determinations	Emission Limits (sulfur content in fuel, ppm)
Ultra-Low Sulfur Diesel, Limited Operations, and Good Combustion Practices	27	≤15 – 500

Table 5-32: SO₂ Controls for Small Diesel Engines

Control Technology	Number of Determinations	Emission Limits (sulfur content in fuel, ppm)
Ultra-Low Sulfur Diesel, Limited Operations, and Good Combustion Practices	21	≤15 – 500

Step 1 – Identify SO₂ Control Technologies for Diesel-Fired Engines

From research, the Department identified the following technologies as available for control of SO₂ emissions from diesel-fired engines:

- (a) Ultra-Low Sulfur Diesel (ULSD) and Federal Emission Standards
SO₂ emissions in the exhaust of fuel-fired engines are directly related to the levels of sulfur in fuel. As such, fuel specifications are the primary method of controlling SO₂ emissions in engines. ULSD has a maximum sulfur content of 15 ppm (0.0015 percent by weight). The federal emission standards require all diesel-fired engines subject to NSPS Subpart IIII with a displacement of less than 30 liters per cylinder to burn ULSD (40 C.F.R. 60.4207(b)). Therefore, the Department considers ULSD a technically feasible control technology for the diesel-fired engines.
- (b) Limited Operation
Limiting the operation of emission units reduces the potential to emit for those units. The Department considers limited operation a technically feasible control technology for the diesel-fired engines.
- (c) Good Combustion Practices
The theory of GCPs was discussed in detail in the CO BACT Section 4.2 for simple cycle turbines and will not be repeated here. Proper management of the combustion process will result in a reduction of SO₂ emissions. The Department considers GCPs a technically feasible control technology for the diesel-fired engines.

Step 2 – Eliminate Technically Infeasible SO₂ Control Technologies for the Diesel Engines

All identified control technologies identified are technically feasible for the diesel-fired engines.

Step 3 – Rank Remaining SO₂ Control Technologies for Diesel-Fired Engines

The following control technologies have been identified and ranked by efficiency for the control of SO₂ emissions from the diesel-fired engines.

- | | |
|--|-------------------------|
| (a) ULSD (including Federal Standards) | (99% Control) |
| (b) Limited Operation | (94% Control) |
| (c) Good Combustion Practices | (Less than 40% Control) |

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, ULSD and good combustion practices are the applicable controls for SO₂ emissions for the diesel engines EUs 39 – 44. Since these are not add-on controls, there are no additional environmental impacts.

Applicant Proposal

AGDC proposed to use ULSD, limit operations of each engine to 500 hours per 12-month rolling period per unit, and maintain good combustion control practices for the limited use diesel engines EUs 39 – 44 as BACT for reducing SO₂ emissions.

Step 5 – Selection of SO₂ BACT for Diesel-Fired Engines

The Department's finding is that BACT for SO₂ emissions from the limited use diesel-fired

engines is as follows:

- (a) SO₂ emissions from the operation of the diesel-fired engines EUs 39 – 44 shall be controlled by only combusting ULSD at all times the units are in operation;
- (b) Limit operation of the diesel-fired engines EUs 39 – 44 to no more than 500 hours per 12-month rolling period per engine;
- (c) Maintain good combustion practices by following the manufacturer’s maintenance procedures at all times of operation; and
- (d) Compliance with the proposed fuel sulfur content limit will be demonstrated with fuel shipment receipts and/or fuel test results for sulfur content.

5.5 VOC

Possible VOC emission control technologies for limited use diesel-fired engines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 17.110 to 17.190: Large Internal Combustion Engines (>500 hp) and 17.210: Small Fuel Oil-Fired Internal Combustion Engines (<500 hp). The search results for the diesel engines greater than 500 hp and smaller than 500 hp are contained in Tables 5-33 and 5-34 respectively.

Table 5-33: VOC Control for Large Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Oxidation Catalyst	1	0.21
NSPS IIII	12	0.03 – 0.3
Good Combustion Practices	17	0.015 – 1.0
No Control Specified	26	0.07 – 0.32

Table 5-34: VOC Control for Small Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Federal Emission Standards	9	0.15 – 0.37
Good Combustion Practices	13	0.05 - 1.6
No Control Specified	8	0.15 - 1.14

Step 1 – Identify VOC Control Technologies for Diesel-Fired Engines

From research, the Department identified the following technologies as available for VOC control of diesel-fired engines:

- (a) Oxidation Catalyst
The theory of oxidation catalysts were discussed in detail in the CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines. Oxidation catalysts oxidize CO and hydrocarbon compounds to carbon dioxide and water vapor. The reaction is spontaneous and no reactants are required. The Department considers oxidation catalysts to be a technically feasible control technology for both the large and small sized diesel engines.
- (b) Good Combustion Practices

The theory of GCPs was discussed in detail in CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that GCPs are commonly used to control VOC emissions for diesel engines. Therefore, the Department considers GCPs and clean fuel to be a technically feasible control technology for both the large and small sized diesel engines.

(c) Limited Operation

Limiting the operation of emissions units reduces the potential to emit of those units. As stated above in Section 5.0, all of the diesel-fired engines at the GTP are considered limited use engines. The Department considers limited operation a technically feasible control technology for both the large and small diesel-fired engines.

(d) Federal Emission Standards

RBLC VOC determinations for federal emission standards require the engines meet the requirements of 40 C.F.R. 60 Subpart IIII, 40 C.F.R 63 Subpart ZZZZ, or EPA tier certifications. Subpart IIII applies to stationary compression ignition internal combustion engines that are manufactured or reconstructed after July 11, 2005. The Department considers meeting the technology based New Source Performance Standards (NSPS) of Subpart IIII as a technically feasible control technology for both the large and small diesel-fired engines.

Step 2 – Eliminate Technically Infeasible VOC Control Options for Diesel-Fired Engines

All of the control technologies identified are technically feasible for the diesel engines.

Step 3 – Rank Remaining VOC Control Options for Diesel-Fired Engines

The following control technologies have been identified and ranked for control of VOCs from the diesel-fired engines:

- | | |
|---------------------------------|-------------------------|
| (a) Limited Operation | (94% Control) |
| (b) Oxidation Catalyst | (90% Control) |
| (c) Good Combustion Practices | (Less than 90% Control) |
| (d) Federal Emissions Standards | (Baseline) |

Step 4 – Evaluate the Most Effective Controls

A review of similar units in the RBLC indicates add-on control technology (oxidation catalyst) is not practical for limited use engines. Based on the small potential to emit associated with these units (less than 10% when compared to CO emissions for which a cost demonstration is made for oxidation catalysts), it is not a cost effective control technology for the limited use diesel-fired engines.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and following the federal emissions standards are the primary VOC control technologies for diesel-fired engines.

Applicant Proposal

AGDC proposed to use good combustion practices, limit operations of each engine to 500 hours per year, and install engines certified to meet NSPS Subpart IIII as BACT for VOC emissions. Assuming that 5% of the total NO_x plus NMHC (non-methane hydrocarbons) emissions are VOC emissions, this equates to the following emissions rates:

- (a) Limit non-emergency operation of the diesel-fired engines EUs 39 – 44 to no more than 500 hours per 12-month rolling period for each engine, for maintenance checks and readiness testing;
- (b) VOC emissions from the black start diesel generator EU 39 will not exceed 0.178 g/hp-hr @ 15% O₂;
- (c) VOC emissions from the diesel firewater pump engines EUs 40 – 42 will not exceed 0.188 g/hp-hr @ 15% O₂; and
- (d) VOC emissions from the emergency diesel engines EUs 43 and 44 will not exceed 0.186 g/hp-hr @ 15% O₂.

Step 5 – Selection of VOC BACT for Diesel-Fired Engines

The Department's finding is that BACT for VOC emissions from the limited use diesel-fired engines is as follows:

- (a) VOC emissions from the operation of the diesel-fired engines EUs 39 – 44 shall be controlled by maintaining good combustion practices at all times the units are in operation;
- (b) Limit operation of the diesel-fired engines EUs 39 – 44 to no more than 500 hours per 12-month rolling period per engine;
- (c) VOC emissions from the black start diesel-fired generator EU 39 will not exceed 0.18 g/hp-hr @ 15% O₂ (EPA Tier 4 Final, includes 25% not to exceed factor of safety);
- (d) VOC emissions from the diesel firewater pump engines EUs 40 – 42 will not exceed 0.19 g/hp-hr @ 15% O₂ (5% of NO_x + NMHC value from Table 4 from NSPS Subpart IIII, also equivalent to EPA Tier 3, includes 25% not to exceed factor of safety);
- (e) VOC emissions from the emergency diesel-fired engines EUs 43 and 44 will not exceed 0.19 g/hp-hr @ 15% O₂ (5% of NO_x + NMHC value from EPA Tier 3, includes 25% not to exceed factor of safety); and
- (f) Initial compliance with the proposed VOC emission limits will be demonstrated by purchasing engines certified to meet the appropriate EPA Tier emissions standards.

5.6 GHG

Possible GHG emission control technologies for limited use diesel-fired engines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 17.110 to 17.190: Large Internal Combustion Engines (>500 hp) and 17.210: Small Fuel Oil-Fired Internal Combustion Engines (<500 hp). The search results for the diesel engines greater than 500 hp and smaller than 500 hp are contained in Tables 5-35 and 5-36 respectively.

Table 5-35: GHG Control for Large Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (tpy)
Federal Emission Standards	6	37 - 432

Good Combustion Practices	21	72 – 1,299,630
No Control Specified	11	14 – 7,194

Table 5-36: GHG Control for Small Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (tpy)
Good Combustion Practices	26	0.29 – 3,083
NSPS IIII	3	10 – 72
Limited Operation	5	5 – 58
No Control Specified	4	91 – 516

Step 1 – Identify GHG Control Technologies for Diesel-Fired Engines

From research, the Department identified the following technologies as available for GHG control of diesel-fired engines:

(a) Carbon Capture and Storage

CCS was discussed in detail in the GHG BACT Section 4.6 for simple cycle turbines, and will not be repeated here. The Department’s research did not identify CCS as a control technology used to control GHG emissions from diesel-fired engines or any other emission unit type installed at any facility in the RBLC database. Therefore, the Department considers this technology to be commercially unavailable in the United States and a technically infeasible control technology for the diesel-fired engines.

(b) Good Combustion Practices

Discussed in detail in CO BACT Section 4.2, as well as the fuel specifications portion of particulate BACT Section 4.3. GCP and clean fuels is a common technique for controlling GHG emissions. GHG emissions in the exhaust of engines are directly related to the carbon content in the fuel. Good combustion practices are considered a feasible control technology for the diesel-fired engines.

Step 2 – Eliminate Technically Infeasible GHG Control Options for Diesel-Fired Engines

As explained in Step 1, CCS is not considered a technically feasible technology to control GHG emissions from diesel-fired engines.

Step 3 – Rank Remaining GHG Control Options for Diesel-Fired Engines

AGDC has accepted the only feasible control option. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, good combustion practices are the applicable controls for GHG emissions for EUs 39 – 44. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices is the principle control method for GHG from diesel-fired engines.

Applicant Proposal

AGDC proposed to use good combustion practices and limited operation of 500 hours per 12-month rolling period for each engine for EUs 39 - 44 as BACT for reducing GHG emissions. GHG emissions from EUs 39 – 44 will not exceed 163.6 lb/MMBtu, which is the CO_{2e} emissions rates for burning diesel fuel in 40 CFR Part 98: Mandatory Greenhouse Gas Reporting. The total CO_{2e} emissions rate is calculated with the equation CO₂(1) + CH₄(25) + N₂O(298).

Step 5 – Selection of GHG BACT for Diesel-Fired Engines

The Department’s finding is that BACT for GHG emissions from the diesel-fired engines is as follows:

- (a) GHG emissions from EUs 39– 44 shall be controlled by maintaining good combustion practices at all times the units are in operation;
- (b) Limit operation of the diesel-fired engines EUs 39 – 44 to no more than 500 hours per 12-month rolling period per engine; and
- (c) GHG emissions from EUs 39 – 44 shall not exceed 163.6 lb/MMBtu averaged over a 3-hour period.

6.0 LARGE UTILITY HEATERS

GTP will have three building heat medium heaters (EUs 31 – 33). These heaters are natural gas-fired process heaters that will supply heat to buildings and other miscellaneous users, such as tank heaters. Each of the large utility heaters is rated at approximately 275 MMBtu/hr, for a total of 825 MMBtu/hr. The large utility heaters will emit CO, NO_x, SO₂, particulates, VOC, and GHG. The following sections provide the BACT review for each of these pollutants.

6.1 NO_x

Possible NO_x emission control technologies for the large utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 11.310: Natural Gas-Fired Utility and Large Industrial-Size Boilers/Furnaces (>250 MMBtu/hr). The search results are summarized in Table 6-1.

Table 6-1: NO_x Controls for Large Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Selective Catalytic Reduction	23	0.0032 - 0.20
Low-NO _x Burners	24	0.011 - 0.25
No Control Specified	1	0.0125

Step 1 – Identify NO_x Control Technologies for Large Utility Heaters

From research, the Department identified the following technologies as available for NO_x control of gas-fired boilers and heaters rated at greater than 250 MMBtu/hr:

- (a) Selective Catalytic Reduction (SCR)
The theory of SCR was discussed in detail in the NO_x BACT Section 3.1 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department’s search of the RLBC database indicated that SCR is a common NO_x control device for gas-fired boilers rated at greater than 250 MMBtu/hr. Therefore, the

Department considers SCR to be a technically feasible control technology for the large utility heaters.

(b) Low-NO_x Burners (LNB)

Using LNBs can reduce formation of NO_x through careful control of the fuel-air mixture during combustion. Control techniques used in LNBs includes staged air, and staged fuel, as well as other methods that effectively lower the flame temperature. Experience suggests that significant reduction in NO_x emissions can be realized using LNBs. The U.S. EPA reports that LNBs have achieved reduction up to 80%, but actual reduction depends on the type of fuel and varies considerably from one installation to another. Typical reductions range from 40% - 60% but under certain conditions, higher reductions are possible. The Department considers LNBs a technically feasible control technology for the large utility heaters.

(c) Ultra-Low NO_x Burners

Ultra-low NO_x burners operate on the same principle as LNB described above, but have advanced designs for achieving higher NO_x destruction efficiencies. Designs that promote superior NO_x destruction efficiencies often have a higher investment cost than typical LNBs. Some manufacturers of smaller heaters/boilers do not offer ultra-low NO_x burners because the incremental emissions reduction is not cost effective as compared to standard LNBs. However, the Department's search of the RBLC database found several heaters/boilers greater than 250 MMBtu/hr using ultra-low NO_x burners to control NO_x emissions. Hence, the Department considers the use of ultra-low NO_x burners a technically feasible control technology for the large utility heaters.

(d) Flue Gas Recirculation (FGR)

FGR involves recycling a portion of the combustion gases from the stack to the boiler combustion air intake. The combustion products are low in oxygen, and when mixed with the combustion air, lower the overall excess oxygen concentration. This process acts as a heat sink to lower the peak flame temperature as well as the residence time at peak flame temperature. These effects work together to limit thermal NO_x formation. The typical NO_x removal efficiency using FGR is 20-25%. The Department considers FGR to be a technically feasible control technology for the large utility heaters.

(e) Good Combustion Practices (GCP) and Clean Fuel

The theory of GCPs and clean fuel was discussed in detail in CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that GCPs and clean fuel are used to control NO_x emissions for gas-fired boilers rated at greater than 250 MMBtu/hr. Therefore, the Department considers GCP and clean fuel to be a technically feasible control technology for the large utility heaters.

Step 2 – Eliminate Technically Infeasible NO_x Control Options for Large Utility Heaters

All control technologies identified are technically feasible for gas-fired boilers and heaters rated at greater than 250 MMBtu/hr.

Step 3 – Rank Remaining NO_x Control Options for Large Utility Heaters

The following control technologies have been identified and ranked for control of NO_x from the large utility heaters:

- (a) SCR (70% - 90% Control)
- (b) Ultra-Low NO_x Burner (80% Control)
- (c) Low NO_x Burner (60% Control)
- (d) Flue Gas Recirculation (20% - 25% Control)
- (e) Good Combustion Practices (Less than 40% Control)

Step 4 – Evaluate the Most Effective Controls

SCR is the most effective NO_x control for large utility heaters. No unusual energy impacts were identified with the addition of SCR to the heaters. Environmental impacts include the disposal of the spent SCR catalyst when replacement becomes necessary, as well as ammonia slip from the SCR system. Neither the ammonia slip nor the waste disposal of the catalyst would preclude the use of SCR as a potential NO_x control device.

RBLC Review

A review of similar units in the RBLC indicates that SCR and low NO_x / ultra-low NO_x burners are the principle NO_x control technologies installed on boilers and heaters rated at greater than 250 MMBtu/hr.

Applicant Proposal

AGDC stated that LNBs are already a part of the base model proposed for the large utility heaters at the GTP and provided an economic analysis of the top most effective control technology (SCR) to demonstrate that this control is not economically feasible for the EUs 31 – 33. A summary of the analysis for the large utility heaters is shown in Table 6-2.

Table 6-2: AGDC Economic Analysis for Technically Feasible NO_x Controls (EUs 31 – 33)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	7.4	36.0.	\$3,891,719	\$672,628	\$18,707
Capital Recovery Factor = 0.858 (7% interest rate for a 25 year equipment life)					

AGDC contends that the economic analysis indicates the level of NO_x reduction from SCR does not justify the use of SCR for the large gas-fired heaters based on the excessive cost per ton of NO_x removed per year.

AGDC proposes the following as BACT for NO_x emissions from the large gas-fired heaters:

- (a) NO_x emissions from the operation of the large gas-fired heaters EUs 31 – 33 will be controlled with the use of LNB combustors; and
- (b) NO_x emissions from EUs 31 – 33 will not exceed 0.036 lb/MMBtu.

Department Evaluation of BACT for NO_x Emissions from Large Gas-Fired Heaters

The Department revised the emissions tables to reflect the current bank prime interest rate of 5.5%. A summary of the analyses for the large utility heaters is shown in Table 6-3.

Table 6-3: Department Economic Analysis for Technically Feasible NO_x Controls (EUs 31–33)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	7.4	36.0	\$3,891,719	\$628,981	\$17,493
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of NO_x reduction justifies the use of LNB as BACT for the large gas-fired utility heaters at the Gas Treatment Plant.

Step 5 – Selection of NO_x BACT for Large Utility Heaters

The Department's finding is that BACT for NO_x emissions from the gas-fired utility heaters rated at greater than 250 MMBtu/hr is as follows:

- NO_x emissions from EUs 31 – 33 shall be controlled by operating and maintaining LNB and good combustion practices at all times the units are in operation;
- NO_x emissions from EUs 31 – 33 shall not exceed 0.036 lb/MMBtu averaged over a 3-hour period; and
- Initial compliance with the proposed NO_x emission limit will be demonstrated by conducting a performance test to obtain an emission rate.

6.2 CO

Possible CO emission control technologies for the large utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 11.310: Natural Gas-Fired Utility and Large Industrial-Size Boilers/Furnaces (>250 MMBtu/hr). The search results are summarized in Table 6-4.

Table 6-4. CO Control for Large Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Oxidation Catalyst	1	0.0013
Good Combustion Practices	33	0.0013 - 0.47
No Control Specified	7	0.015 – 0.47

Step 1 – Identify CO Control Technologies for Large Utility Heaters

From research, the Department identified the following technologies as available for CO control of gas-fired boilers and heaters rated at greater than 250 MMBtu/hr:

- Oxidation Catalyst
The theory of oxidation catalysts were discussed in detail in the CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that oxidation catalysts

have been used as a CO control device for gas-fired boilers rated at greater than 250 MMBtu/hr. Therefore, the Department considers oxidation catalysts to be a technically feasible control technology for the large utility heaters.

(b) Good Combustion Practices (GCP) and Clean Fuel

The theory of GCPs and clean fuel was discussed in detail in CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that GCPs and clean fuel are used to control CO emissions for gas-fired boilers rated at greater than 250 MMBtu/hr. Therefore, the Department considers GCPs and clean fuel to be a technically feasible control technology for the large utility heaters.

Step 2 – Eliminate Technically Infeasible CO Control Options for Large Utility Heaters

All control technologies identified are technically feasible for gas-fired boilers and heaters rated at greater than 250 MMBtu/hr.

Step 3 – Rank Remaining CO Control Options for Large Utility Heaters

The following control technologies have been identified and ranked for control of CO from the large utility heaters:

- | | |
|---|-------------------------|
| (a) Oxidation Catalyst | (90% Control) |
| (b) Good Combustion Practices and Clean Fuels | (Less than 90% Control) |

Step 4 – Evaluate the Most Effective Controls

An oxidation catalyst will reduce CO emissions from EUs 31 – 33 while having minimal energy and environmental impacts. This system requires no consumables and does not produce waste effluents or by-products aside from catalyst replacement and recycling as necessary. Heater efficiency will be minimally impacted by the oxidation catalyst.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the principle CO control technologies used on boilers and heaters rated at greater than 250 MMBtu/hr. However, an oxidation catalyst would provide the best control for the large utility heaters and there were two facilities identified in the RBLC database that are using oxidation catalysts to control CO emissions from heaters and boilers rated greater than 250 MMBtu/hr.

Applicant Proposal

AGDC provided an economic analysis of the installation of oxidation catalysts on the large utility heaters which demonstrated that the use of this control is economically feasible on these units. However, AGDC stated that no examples of CO catalysts controls in the RBLC were found for the same size heater and that it is considered unlikely that CO controls would be imposed given this past precedent. A summary of the analysis for the large utility heaters is shown in Table 6-5.

Table 6-5: AGDC Economic Analysis for Technically Feasible CO Controls (EUs 31 – 33)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	7.3	29.1	\$430,358	\$135,898	\$4,666
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

AGDC contends that although the cost per ton of CO removal using an oxidation catalyst is reasonable, the fact that no examples of an oxidation catalyst control in the RBLC were found for the same size heater make it unreasonable that this technology be imposed.

AGDC proposes the following as BACT for CO emissions from the large gas-fired heaters:

- (a) CO emissions from the operation of the large gas-fired heaters EUs 31 – 33 will be controlled through good combustion practices and clean fuel; and
- (b) CO emissions from EUs 31 – 33 will not exceed 0.037 lb/MMBtu.

Department Evaluation of BACT for CO Emissions from Large Gas-Fired Heaters

The Department revised the emissions tables to reflect the equipment life revised to a 25 year lifespan, adjusted the interest rate to the current bank prime interest rate of 5.5%, and revised the freight cost to 10% of the purchased equipment costs. A summary of the analyses for the large utility heaters is shown in Table 6-6.

Table 6-6: Department Economic Analysis for Technically Feasible CO Controls (EUs 31–33)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	7.3	29.1	\$318,365	\$93,879	\$3,223
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of CO reduction justifies the use of an oxidation catalyst as BACT for the large gas-fired utility heaters at the Gas Treatment Plant. The Department identified one facility in the RBLC database (RBLC ID No. IA-0106) that has a gas-fired boiler/heater rated at greater than 250 MMBtu/hr with an oxidation catalyst installed for CO emissions control.

Step 5 – Selection of CO BACT for Large Utility Heaters

The Department's finding is that BACT for CO emissions from the gas-fired utility heaters rated at greater than 250 MMBtu/hr is as follows:

- (a) CO emissions from EUs 31 – 33 shall be controlled by operating and maintaining an oxidation catalyst and good combustion practices at all times the units are in operation;
- (b) CO emissions from EUs 31 – 33 shall not exceed 0.007 lb/MMBtu; and

- (c) Initial compliance with the proposed CO emission limit will be demonstrated by conducting a performance test to obtain an emission rate.

6.3 Particulates

Possible particulate emission control technologies for the large utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 11.310: Natural Gas-Fired Utility and Large Industrial-Size Boilers/Furnaces (>250 MMBtu/hr). The search results are summarized in Table 6-7.

Table 6-7: Particulate Controls for Large Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
GCP & Clean Fuels	46	0.001 - 0.010
Baghouse	0	N/A
Wet Scrubber	0	N/A
No Control Specified	8	0.0019 - 0.0076

Step 1 – Identify Particulate Control Technologies for Large Utility Heaters

From research, the Department identified the following technologies as available for particulate control of gas-fired boilers and heaters rated at greater than 250 MMBtu/hr:

(a) Baghouse

Baghouses are comprised of an array of filter bags contained in housing. Air passes through the filter media from the “dirty” to the “clean” side of the bag. These devices undergo periodic bag cleaning based on the build-up of filtered material on the bag as measured by pressure drop across the device. The cleaning cycle is set to allow operation within a range of design pressure drop. Baghouses are characterized by the type of cleaning cycle - mechanical-shaker, pulse-jet, and reverse-air. Fabric filter systems have control efficiencies of 95% to 99.9% ¹² and are generally specified to meet a discharge concentration of filterable particulate (e.g., 0.01 grains per dry standard cubic feet). The only entry for baghouses in the RBLC was for furnaces at an iron ore concentrate pelletizing facility in Indiana. This process involves iron ore pellets being exposed to high temperatures in a furnace in order to harden the pellets, which emits hazardous air pollutants (HAPs). At the GTP, EUs 31 – 33 will be used for providing space heating and will burn natural gas, a much cleaner process. Due to the fact that the only large gas-fired boilers/heaters in the RBLC with baghouses used to control particulates are actually installed because of the iron ore pelletizing process, the Department does not consider a baghouse a technically feasible control technology for the large utility heaters located at the GTP.

(b) Wet Scrubber

Wet Scrubbers use a scrubbing solution to remove particulate matter from exhaust streams. The mechanism for particulate collection is impaction and interception by water droplets. Wet scrubbers are configured as counter-flow, cross-flow, or concurrent flow, but typically employ counter-flow where the scrubbing fluid flows in the opposite

¹² <https://www3.epa.gov/ttn/catc/dir1/ff-shaker.pdf>
<https://www3.epa.gov/ttn/catc/dir1/ff-pulse.pdf>
<https://www3.epa.gov/ttn/catc/dir1/ff-revar.pdf>

direction as the gas flow. The only entry for wet scrubbers in the RBLC was for furnaces at an iron ore concentrate pelletizing facility in Texas. This process involves iron ore pellets being exposed to high temperatures in a furnace in order to harden the pellets, which emits HAPs. At the GTP, EUs 31 – 33 will be used for providing space heating and will burn natural gas, a much cleaner process. Due to the fact that the only large gas-fired boilers/heaters in the RBLC with wet scrubbers used to control particulates are actually installed because of the iron ore pelletizing process, the Department does not consider the use of wet scrubbers a technically feasible control technology for the large utility heaters located at the GTP.

(c) Limited Operation

Limiting the operation of emission units reduces the potential to emit for those units. EUs 31 – 33 are the only EUs that will supply building heat for the GTP. Therefore, it is not appropriate to limit the operation of these units. The Department does not consider the use of limited operation a technically feasible control technology for the large utility heaters.

(d) Good Combustion Practices and Clean Fuels

The theory of GCP and clean fuels was discussed in detail in the CO BACT section 4.2, for the gas-fired simple cycle gas turbines and will not be repeated here. Proper management of the combustion process and burning clean fuels will result in a reduction of particulate emissions. The Department considers GCP and clean fuels a technically feasible control technology for the large utility heaters.

(e) Flue Gas Recirculation (FGR)

The theory behind FGR was discussed in detail in the NO_x BACT Section 6.1 and will not be repeated here. The Department's research did not identify facilities using FGR to control particulate emissions for large gas-fired boilers/heaters. Therefore, the Department considers this technology technically infeasible for the large utility heaters at GTP.

Step 2 – Eliminate Technically Infeasible Particulate Control Options for Large Utility Heaters

As explained in Step 1, FGR, baghouses, wet scrubbers, and limited operation are not feasible technologies to control particulate emissions from the large utility heaters.

Step 3 – Rank Remaining Particulate Control Options for Large Utility Heaters

AGDC has accepted the only technically feasible control options for the large utility heaters EUs 31 – 33. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

Use of clean low-sulfur fuel and good combustion practices are the most effective controls for particulates from natural gas fired boilers and heaters rated at greater than 250 MMBtu/hr. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that use of clean fuels and good combustion practices are the principle control methods for particulates from boilers firing natural gas rated at greater than 250 MMBtu/hr.

Applicant Proposal

AGDC proposed to use clean fuel and good combustion practices for the large utility heaters EUs 31 – 33 as BACT for reducing particulate emissions. Particulate emissions from EUs 31 – 33 will not exceed 0.0079 lb/MMBtu.

Step 5 – Selection of Particulate BACT for Large Utility Heaters

The Department's finding is that BACT for particulate emissions from the gas-fired utility heaters rated at greater than 250 MMBtu/hr is as follows:

- (a) Particulate emissions from EUs 31 – 33 shall be minimized by maintaining good combustion practices and burning clean fuels at all times the units are in operation;
- (b) Particulate emissions from EUs 31 – 33 shall not exceed 0.0079 lb/MMBtu averaged over a 3-hour period (AP-42 Table 1.4-2, particulate (total) emissions rate for natural gas combustion in external combustion sources); and
- (c) Initial compliance with the proposed particulate emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EUs will comply with the BACT limit.

6.4 SO₂

Possible SO₂ emission control technologies for the large utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 11.310: Natural Gas-Fired Utility and Large Industrial-Size Boilers/Furnaces (>250 MMBtu/hr). The search results are summarized in Table 6-8.

Table 6-8: SO₂ Control for Large Natural Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
GCP & Clean Fuel	6	0.0006 – 0.002
No Control	4	.0006 – .003

Step 1 – Identify SO₂ Control Technologies for Large Utility Heaters

From research, the Department identified the following technologies as available for SO₂ control of gas-fired boilers and heaters rated at greater than 250 MMBtu/hr:

- (a) Good Combustion Practices (GCP) and Clean Fuels
As discussed in detail in CO BACT Section 4.2, as well as the fuel specifications portion of particulate BACT Section 4.3, GCP and clean fuels is a common technique for controlling SO₂ emissions. SO₂ emissions in the exhaust of liquid or gas-fired boilers and heaters are directly related to the levels of sulfur in fuel. As such, fuel specifications are the primary method of SO₂ emissions control and are a feasible control technology for the large utility heaters.

Step 2 – Eliminate Technically Infeasible SO₂ Control Options for Large Utility Heaters

All control technologies identified are technically feasible for gas-fired boilers and heaters rated at greater than 250 MMBtu/hr.

Step 3 – Rank Remaining SO₂ Control Options for Large Utility Heaters

AGDC has accepted the only technically feasible control technology for the large gas-fired utility heaters. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for SO₂ emissions for EUs 31 – 33. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the only SO₂ emission control technologies installed on gas-fired heaters and boilers rated at greater than 250 MMBtu/hr.

Applicant Proposal

AGDC proposed to use clean fuels and good combustion practices for the large utility heaters EUs 31 – 33 as BACT for reducing SO₂ emissions. AGDC will utilize natural gas in the large utility heaters EUs 31 – 33 with a total sulfur content not to exceed 96 ppmv.

Step 5 – Selection of SO₂ BACT for Large Utility Heaters

The Department's finding is that BACT for SO₂ emissions from the gas-fired utility heaters rated at greater than 250 MMBtu/hr is as follows:

- (a) SO₂ emissions from EUs 31 – 33 shall be minimized by maintaining good combustion practices and burning natural gas with a total sulfur content not to exceed 96 ppmv at all times the units are in operation; and
- (b) Compliance with the proposed fuel sulfur content limit will be demonstrated with fuel shipment receipts and/or fuel test results for total sulfur content.

6.5 VOC

Possible VOC emission control technologies for the large utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 11.310: Natural Gas-Fired Utility and Large Industrial-Size Boilers/Furnaces (>250 MMBtu/hr). The search results are summarized in Table 6-9.

Table 6-9: VOC Control for Large Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Oxidation Catalyst	0	N/A
GCP & Clean Fuel	17	0.0014 – 0.054
No Control Specified	5	0.0053 – 0.0055

Step 1 – Identify VOC Control Technologies for Large Utility Heaters

From research, the Department identified the following technologies as available for VOC control of gas-fired boilers and heaters rated at greater than 250 MMBtu/hr:

- (a) Oxidation Catalyst

The theory of oxidation catalysts were discussed in detail in the CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that oxidation catalysts have been used as a VOC control device for gas-fired boilers rated at greater than 250 MMBtu/hr. Therefore, the Department considers oxidation catalysts to be a technically feasible control technology for the large utility heaters.

(b) Good Combustion Practices (GCPs) and clean fuel

The theory of GCPs and clean fuel was discussed in detail in CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that GCPs and clean fuel are the primary technique used to control VOC emissions for gas-fired boilers rated at greater than 250 MMBtu/hr. Therefore, the Department considers GCPs and clean fuel to be a technically feasible control technology for the large utility heaters.

Step 2 – Eliminate Technically Infeasible VOC Control Options for Large Utility Heaters

Both control technologies identified are technically feasible for gas-fired boilers and heaters rated at greater than 250 MMBtu/hr.

Step 3 – Rank Remaining VOC Control Options for Large Utility Heaters

The following control technologies have been identified and ranked for control of VOC from the boilers and heaters:

- (a) Oxidation Catalyst (90% Control)
- (b) Good Combustion Practices (Less than 90% Control)

Step 4 – Evaluate the Most Effective Controls

An oxidation catalyst would provide the best VOC control for gas-fired heaters and boilers rated at greater than 250 MMBtu/hr. Since these are not add-on controls, there are no additional environmental impacts. However, the only BACT determination in the RBLC using an oxidation catalyst is for a biomass/distillate oil/natural gas fired utility heater, which is not a similar unit to any of EUs 31 – 33, which only fire natural gas.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices is the principle control method for VOC from gas-fired heaters and boilers rated at greater than 250 MMBtu/hr.

Applicant Proposal

AGDC proposed to use good combustion practices and clean fuel for the large utility heaters EUs 31 - 33 as BACT for reducing VOC emissions. VOC emissions from EUs 31 – 33 will not exceed 0.0057 lb/MMBtu.

Step 5 – Selection of VOC BACT for Large Utility Heaters

The Department's finding is that BACT for VOC emissions from the large gas-fired utility heaters rated at greater than 250 MMBtu/hr is as follows:

- (a) VOC emissions from EUs 31 – 33 shall be controlled by maintaining good combustion practices at all times the units are in operation;
- (b) VOC emissions from EUs 31 – 33 shall not exceed 0.0057 lb/MMBtu averaged over a 3-hour period (AP-42, Table 1.4-2, VOC emission rate for natural gas combustion in external combustion sources); and
- (c) Initial compliance with the proposed VOC emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EUs will comply with the BACT limit.

6.6 GHG

Possible GHG emission control technologies for the large utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 11.310: Natural Gas-Fired Utility and Large Industrial-Size Boilers/Furnaces (>250 MMBtu/hr). The search results are summarized in Table 6-10.

Table 6-10: GHG Control for Large Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (tpy)
GCP & Clean Fuel	19	4,339 – 826,600
No Control	11	113,552 – 700,000

CO₂ and N₂O emissions are produced during natural gas combustion in gas-fired heaters. Nearly all of the fuel carbon is converted to CO₂ during the combustion process, regardless of the firing configuration. CH₄ is also present in the exhaust gas and is thought to be unburned fuel in the case of natural gas.

Step 1 – Identify GHG Control Technologies for Large Utility Heaters

From research, the Department identified the following technologies as available for VOC control of gas-fired boilers and heaters rated at greater than 250 MMBtu/hr:

- (a) Carbon Capture and Sequestration
CCS was discussed in detail in the GHG BACT Section 4.6 for simple cycle turbines, and will not be repeated here. The Department’s research did not identify CCS as a control technology used to control GHG emissions from heaters or any other emission unit type installed at any facility in the RBLC database. Therefore, the Department considers this technology to be commercially unavailable in the United States and a technically infeasible control technology for the large utility heaters.
- (b) Good Combustion Practices and Clean Fuels
Discussed in detail in CO BACT Section 4.2, as well as the fuel specifications portion of particulate BACT Section 4.3. GCP and clean fuels is a common technique for controlling GHG emissions. GHG emissions in the exhaust of liquid or gas-fired boilers and heaters are directly related to the carbon content in the fuel. Natural gas has the lowest amount of GHG emissions per Btu of energy of any fossil fuel, and is considered a feasible control technology for the large utility heaters.

Step 2 – Eliminate Technically Infeasible GHG Control Options for Large Utility Heaters

As explained in Step 1, CCS is not considered a technically feasible technology to control GHG emissions from gas-fired boilers and heaters rated at greater than 250 MMBtu/hr.

Step 3 – Rank Remaining GHG Control Options for Large Utility Heaters

AGDC has accepted the only feasible control option. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for GHG emissions for EUs 31 – 33. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the principle control method for GHG from gas-fired boilers and heaters rated at greater than 250 MMBtu/hr.

Applicant Proposal

AGDC proposed to use good combustion practices and clean fuels for the large utility heaters EUs 31 – 33 as BACT for reducing GHG emissions. GHG emissions from EUs 31 – 33 will not exceed 117.1 lb/MMBtu, which is the CO₂e emissions rates for burning natural gas in 40 CFR Part 98: Mandatory Greenhouse Gas Reporting. The total CO₂e emissions rate is calculated with the equation CO₂(1) + CH₄(25) + N₂O(298).

Step 5 – Selection of GHG BACT for Large Utility Heaters

The Department's finding is that BACT for GHG emissions from the gas-fired boilers and heaters rated at greater than 250 MMBtu/hr:

- (a) GHG emissions from EUs 31 – 33 shall be controlled by maintaining good combustion practices at all times the units are in operation; and
- (b) GHG emissions from EUs 31 – 33 shall not exceed 117.1 lb/MMBtu averaged over a 3-hour period.

7.0 SMALL UTILITY HEATERS

GTP will use two buyback gas bath heaters (EUs 34 – 35) and three operations camp heaters (EUs 36 – 38). The operations camps and the buyback gas bath heaters, are natural gas-fired process heaters that would supply space heating to the camp and condition raw inlet gas for use as temporary fuel when treated gas is not available. The three operations camp heaters each have a design duty of 32 MMBtu/hr. There would be two buyback gas bath heaters, one with a design duty of 25 MMBtu/hr and the other rated at 21 MMBtu/hr. The buyback gas bath heaters are anticipated to operate up to 500 hours/year each unit, whereas the Operations Camp heaters are expected to operate 8,760 hours/year. The small utility heaters will emit CO, NO_x, SO₂, particulates, VOC, and GHG. The following sections provide the BACT review for each of these pollutants.

7.1 NO_x

Possible NO_x emission control technologies for the utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 13.310: Natural Gas-Fired Boilers/Furnaces (<100 MMBtu/hr). The search results are summarized in Table 7-1.

Table 7-1: NO_x Controls for Small Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Selective Catalytic Reduction	2	0.009
Low NO _x Burners	64	0.0011 – 0.07
Good Combustion Practices	5	0.035 – 0.10
No Control Specified	10	0.013 – 0.10

RBLC Review

A review of similar units in the RBLC indicates good combustion practices, low NO_x burners, selective catalytic reduction, and selective non-catalytic reduction are the principle NO_x control technologies installed on gas-fired boilers. The lowest emission rate listed in the RBLC is 0.006 lb/MMBtu.

Step 1 – Identify NO_x Control Technologies for Small Utility Heaters

From research, the Department identified the following technologies as available for NO_x control of gas-fired boilers and heaters rated at less than 100 MMBtu/hr:

(a) **Selective Catalytic Reduction (SCR)**

The theory of SCR was discussed in detail in the NO_x BACT section 3.1 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that SCR is used as a NO_x control device for gas-fired boilers rated at less than 100 MMBtu/hr. Therefore, the Department considers SCR to be a technically feasible control technology for the small utility heaters.

(b) **Low-NO_x Burners (LNB)**

Using LNBs can reduce formation of NO_x through careful control of the fuel-air mixture during combustion. Control techniques used in LNBs includes staged air, and staged fuel, as well as other methods that effectively lower the flame temperature. Experience suggests that significant reduction in NO_x emissions can be realized using LNBs. The U.S. EPA reports that LNBs have achieved reduction up to 80%, but actual reduction depends on the type of fuel and varies considerably from one installation to another. Typical reductions range from 40% - 60% but under certain conditions, higher reductions are possible. The Department considers LNBs a technically feasible control technology for the small utility heaters.

(c) **Ultra-Low NO_x Burners**

Ultra-low NO_x burners operate on the same principle as LNB described above, but have advanced designs for achieving higher NO_x destruction efficiencies. Designs that promote superior NO_x destruction efficiencies often have a higher investment cost than typical LNBs. Some manufacturers of smaller heaters/boilers do not offer ultra-low NO_x burners because the incremental emissions reduction is not cost effective as compared to standard LNBs. However, the Department's search of the RBLC database found several

heaters/boilers less than 100 MMBtu/hr using ultra-low NO_x burners to control NO_x emissions. Hence, the Department considers the use of ultra-low NO_x burners a technically feasible control technology for the small utility heaters.

(d) Flue Gas Recirculation (FGR)

FGR involves recycling a portion of the combustion gases from the stack to the boiler combustion air intake. The combustion products are low in oxygen, and when mixed with the combustion air, lower the overall excess oxygen concentration. This process acts as a heat sink to lower the peak flame temperature as well as the residence time at peak flame temperature. These effects work together to limit thermal NO_x formation. The typical NO_x removal efficiency using FGR is 20-25%. The Department considers FGR to be a technically feasible control technology for the small utility heaters.

(e) Good Combustion Practices (GCP) and Clean Fuel

The theory of GCPs and clean fuel was discussed in detail in CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that GCPs and clean fuel are used to control NO_x emissions for gas-fired boilers rated at less than 100 MMBtu/hr. Therefore, the Department considers SCR to be a technically feasible control technology for the small utility heaters.

Step 2 – Eliminate Technically Infeasible NO_x Control Options for Small Utility Heaters

All control technologies identified are technically feasible for gas-fired boilers and heaters rated at less than 100 MMBtu/hr.

Step 3 – Rank Remaining NO_x Control Options for Small Utility Heaters

The following control technologies have been identified and ranked for control of NO_x from the small utility heaters:

- | | |
|--------------------------------------|---------------------|
| (a) SCR | (70% - 90% Control) |
| (b) Ultra-Low NO _x Burner | (80% Control) |
| (c) Low NO _x Burner | (60% Control) |
| (d) Flue Gas Recirculation | (20% - 25% Control) |
| (e) Good Combustion Practices | (<40% Control) |

Step 4 – Evaluate the Most Effective Controls

RBLC Review

SCR is the most effective NO_x control for small utility heaters. No unusual energy impacts were identified with the addition of SCR to the heaters. Environmental impacts include the disposal of the spent SCR catalyst when replacement becomes necessary, as well as ammonia slip from the SCR system. Neither the ammonia slip nor the waste disposal of the catalyst would preclude the use of SCR as a potential NO_x control device.

A review of similar units in the RBLC indicates that low NO_x / ultra-low NO_x burners are the principle NO_x control technologies installed on boilers and heaters rated at less than 100 MMBtu/hr.

Applicant Proposal

AGDC provided an economic analysis of the most effective control technology (SCR) to demonstrate that this control is not economically feasible for the small utility heaters. A summary of AGDC's analysis for the buyback gas bath heater EUs 34 and 35 are shown in Tables 7-2, and 7-3 respectively, and the analysis for the camp heaters EUs 36 through 38 are shown in Table 7-4. Note that the cost analysis in Table 7-4 is on a per heater basis.

Table 7-2: AGDC Economic Analysis for Technically Feasible NO_x Controls (EU 34)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.039	0.19	\$826,216	\$76,769	\$405,882
Capital Recovery Factor = 0.0858 (7% interest rate for a 25 year equipment life)					

Table 7-3: AGDC Economic Analysis for Technically Feasible NO_x Controls (EU 35)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.029	0.14	\$686,477	\$63,673	\$447,679
Capital Recovery Factor = 0.0858 (7% interest rate for a 25 year equipment life)					

Table 7-4: AGDC Economic Analysis for Technically Feasible NO_x Controls (EUs 36-38)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.85	4.17	\$959,490	\$125,115	\$29,997
Capital Recovery Factor = 0.0858 (7% interest rate for a 25 year equipment life)					

AGDC contends that the economic analysis indicates the level of NO_x reduction from SCR does not justify the use of SCR for the small gas-fired heaters based on the excessive cost per ton of NO_x removed per year.

AGDC proposes the following as BACT for NO_x emissions from the small gas-fired heaters:

- (a) NO_x emissions from the operation of the small gas-fired heaters EUs 34 – 38 will be controlled with the use of DLN combustors;
- (b) NO_x emissions from the operation of EUs 34 and 35 will be controlled through limited operation of 500 hours per 12-month rolling period per boiler; and
- (c) NO_x emissions from EUs 34 – 38 will not exceed 0.036 lb/MMBtu.

Department Evaluation of BACT for NO_x Emissions from Small Gas-Fired Heaters

The Department revised the emissions tables to reflect the current bank prime interest rate of 5.5% and a higher rated capacity for EU 35. A summary of the analyses for the buyback gas bath

heater EUs 34 and 35 are shown in Tables 7-5, and 7-6 respectively, and the analysis for the camp heaters EUs 36 through 38 are shown in Table 7-7. Note that the cost analysis in Table 7-7 is on a per heater basis.

Table 7-5: Department Economic Analysis for Technically Feasible NOx Controls (EU 34)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.039	0.19	\$826,216	\$67,477	\$356,758
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 7-6: Department Economic Analysis for Technically Feasible NOx Controls (EU 35)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.033	0.16	\$729,806	\$59,525	\$380,905
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 7-7: Department Economic Analysis for Technically Feasible NOx Controls (EUs 36-38)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR	0.85	4.17	\$959,490	\$114,326	\$27,410
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of NOx reduction does not justify the use of SCR as BACT for the small gas-fired utility heaters at the Gas Treatment Plant.

Step 5 – Selection of NOx BACT for Small Utility Heaters

The Department's finding is that BACT for NOx emissions from the gas-fired utility heaters rated at less than 100 MMBtu/hr is as follows:

- NOx emissions from EUs 34 – 38 shall be controlled by operating and maintaining LNBs at all times the units are in operation;
- Limit operation of EUs 34 and 35 to no more than 500 hours per 12-month rolling period per boiler;
- NOx emissions from EUs 34 – 38 shall not exceed 0.036 lb/MMBtu averaged over a 3-hour period; and
- Initial compliance with the proposed NOx emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EUs will comply with the BACT limit.

7.2 CO

Possible CO emission control technologies for the small utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 13.310: Natural Gas-Fired Boilers/Furnaces (<100 MMBtu/hr). The search results are summarized in Table 7-8.

Table 7-8: CO Controls for Small Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
GCP and Clean Fuels	67	0.0075 – 0.84
No Control Specified	10	0.037 – 0.11

Step 1 – Identify CO Control Technologies for Small Utility Heaters

From research, the Department identified the following technologies as available for CO control of gas-fired boilers and heaters rated at less than 100 MMBtu/hr:

(a) Oxidation Catalyst

The theory of oxidation catalysts were discussed in detail in the CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database did not identify any oxidation catalysts used as a CO control device for gas-fired boilers rated at less than 100 MMBtu/hr. Therefore, the Department does not consider oxidation catalysts to be a technically feasible control technology for the small utility heaters.

(b) Good Combustion Practices (GCP) and Clean Fuel

The theory of GCPs and clean fuel was discussed in detail in CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that GCPs and clean fuel are used to control CO emissions for gas-fired boilers rated at less than 100 MMBtu/hr. Therefore, the Department considers GCPs and clean fuel to be a technically feasible control technology for the small utility heaters.

Step 2 – Eliminate Technically Infeasible CO Control Options for Small Utility Heaters

As explained in Step 1, oxidation catalysts are not technically feasible for gas-fired boilers and heaters rated at less than 100 MMBtu/hr.

Step 3 – Rank Remaining CO Control Options for Small Utility Heaters

The following control technologies have been identified and ranked for control of CO from the small utility heaters:

- (a) Good Combustion Practices and Clean Fuels (Less than 90% Control)

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, good combustion practices and clean fuels are the applicable controls for CO emissions for EUs 34 – 38. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the only CO emission control technologies installed on gas-fired heaters and boilers rated at less than 100 MMBtu/hr.

Applicant Proposal

AGDC provided an economic analysis of the top most effective control technology (oxidation catalyst) to demonstrate that this control is not economically feasible for the buyback gas bath heaters EUs 34 and 35. Additionally, AGDC stated that although the cost removal per ton for the operations camp heaters EUs 36 through 38 may be considered economically feasible, the fact that no gas-fired heaters rated at less than 100 MMBtu/hr were found using an oxidation catalyst in the RBLC database indicates that this control technology should be eliminated from consideration. A summary of AGDC's analysis for the buyback gas bath heater EUs 34 and 35 are shown in Tables 7-9, and 7-10 respectively, and the analysis for the camp heaters EUs 36 through 38 are shown in Table 7-11. Note that the cost analysis in Table 7-11 is on a per heater basis.

Table 7-9: AGDC Economic Analysis for Technically Feasible CO Controls (EU 34)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.05	0.47	\$47,818	\$15,100	\$32,381
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

Table 7-10: AGDC Economic Analysis for Technically Feasible CO Controls (EU 35)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.04	0.39	\$40,167	\$12,684	\$32,381
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

Table 7-11: AGDC Economic Analysis for Technically Feasible CO Controls (EUs 36-38)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	1.04	10.46	\$61,206	\$19,328	\$1,848
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

AGDC contends that the economic analysis indicates the level of CO reduction from an oxidation catalyst does not justify the use of this control for the buyback bath gas heaters EUs 34 and 35 based on the excessive cost per ton of CO removed per year. AGDC also contends that although the cost per ton of CO removal using an oxidation catalyst is reasonable for the

operations camp heaters EUs 36 through 38, the fact that no examples of an oxidation catalyst control in the RBLC were found for the same size heater make it unreasonable that this technology be imposed.

AGDC proposes the following as BACT for CO emissions from the small gas-fired heaters:

- (a) CO emissions from the operation of the small gas-fired heaters EUs 34 – 38 will be controlled by good combustion practices and clean fuels;
- (b) CO emissions from the operation of EUs 34 and 35 will be controlled through limited operation of 500 hours per 12-month rolling period per boiler; and
- (c) CO emissions from EUs 34 – 38 will not exceed 0.087 lb/MMBtu.

Department Evaluation of BACT for CO Emissions from Small Gas-Fired Heaters

The Department revised the emissions tables to reflect the equipment life revised to a 25 year lifespan and adjusted the interest rate to the current bank prime interest rate of 5.5%. A summary of the analyses for the buyback gas bath heater EUs 34 and 35 are shown in Tables 7-12, and 7-13 respectively, and the analysis for the camp heaters EUs 36 through 38 are shown in Table 7-14. Note that the cost analysis in Table 7-14 is on a per heater basis.

Table 7-12: Department Economic Analysis for Technically Feasible CO Controls (EU 34)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.05	0.47	\$47,818	\$11,856	\$25,425
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 7-13: Department Economic Analysis for Technically Feasible NOx Controls (EU 35)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	0.04	0.39	\$40,167	\$9,959	\$25,425
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 7-14: Department Economic Analysis for Technically Feasible NOx Controls (EUs 36-38)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
Oxidation Catalyst	1.04	10.46	\$61,206	\$15,176	\$1,451
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of CO reduction does not justify the use of an oxidation catalyst as BACT for EUs 34 and 35. While the economic analysis indicates that

an oxidation catalyst would be cost effective for EUs 36 through 38, there were no instances of gas-fired heaters rated at less than 100 MMBtu/hr in the RBLC, and is therefore considered a technically infeasible control option.

Step 5 – Selection of CO BACT for Small Utility Heaters

The Department's finding is that BACT for CO emissions from the gas-fired utility heaters rated at less than 100 MMBtu/hr is as follows:

- (a) CO emissions from EUs 34 through 38 shall be controlled by maintaining good combustion practices at all times the units are in operation;
- (b) Limit operation of EUs 34 and 35 to no more than 500 hours per 12-month rolling period per boiler;
- (c) CO emissions from EUs 34 through 38 shall not exceed 0.087 lb/MMBtu averaged over a 3-hour period (AP-42 Table 1.4-1, CO emissions rate for natural gas combustion in external combustion sources; and
- (d) For EUs 34 – 38, initial compliance with the proposed CO emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EUs will comply with the BACT limits.

7.3 Particulates

Possible particulate emission control technologies for the small utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 13.310: Natural Gas-Fired Boilers/Furnaces (<100 MMBtu/hr). The search results are summarized in Table 7-15.

Table 7-15: Particulate Control for Small Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
GCP & Clean Fuels	102	0.0004 - 0.018
Limited Operation	1	0.0074
No Control Specified	20	0.005 - 0.008

Step 1 – Identify Particulate Control Technologies for Small Utility Heaters

From research, the Department identified the following technologies as available for particulate control of gas-fired boilers and heaters rated at less than 100 MMBtu/hr:

- (a) Good Combustion Practices and Clean Fuels
The theory of GCP and clean fuels was discussed in detail in the CO BACT section 4.2, for the gas-fired simple cycle gas turbines and will not be repeated here. Proper management of the combustion process and burning clean fuels will result in a reduction of particulate emissions. The Department considers GCP and clean fuels a technically feasible control technology for the small utility heaters.
- (b) Limited Operation
Limiting the operation of emission units reduces the potential to emit for those units. The buyback gas bath heaters EUs 34 and 35 will be used to condition raw inlet gas for use as temporary fuel when treated gas is not available, with each heater limited to 500 hours of

operation per year. The operations camps heaters EUs 36 through 38 will provide space heat at GTP's camps, and therefore cannot take limits to their amount operation in the arctic environment.

Step 2 – Eliminate Technically Infeasible Particulate Control Options for Small Utility Heaters

As explained in Step 1, limited operation is not a feasible technology for the operations camps heaters EUs 36 – 38 to control particulate emissions.

Step 3 – Rank Remaining Particulate Control Options for Small Utility Heaters

AGDC has accepted the only technically feasible control options for the small utility heaters EUs 34 – 38. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

Use of clean low-sulfur fuel and good combustion practices are the most effective controls for particulates from natural gas fired boilers and heaters rated at less than 100 MMBtu/hr. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that use of clean fuels and good combustion practices are the principle control methods for particulates from boilers firing natural gas rated at less than 1000 MMBtu/hr.

Applicant Proposal

AGDC proposed to use clean fuel and good combustion practices for the small utility heaters EUs 34 – 38 as BACT for reducing particulate emissions. Additionally, EUs 34 and 35 will be limited to 500 hours per 12-month rolling period per boiler. Particulate emissions from EUs 34 – 38 will not exceed 0.0079 lb/MMBtu.

Step 5 – Selection of Particulate BACT for Small Utility Heaters

The Department's finding is that BACT for particulate emissions from the gas-fired utility heaters rated at less than 100 MMBtu/hr is as follows:

- (a) Particulate emissions from EUs 34 – 38 shall be minimized by maintaining good combustion practices and burning clean fuels at all times the units are in operation;
- (b) Limit operation of EUs 34 and 35 to no more than 500 hours per 12-month rolling period per boiler;
- (c) Particulate emissions from EUs 34 – 38 shall not exceed 0.0079 lb/MMBtu averaged over a 3-hour period (AP-42 Table 1.4-2, particulate (total) emissions rate for natural gas combustion in external combustion sources); and
- (d) Initial compliance with the proposed particulate emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EUs will comply with the BACT limit.

7.4 SO₂

Possible SO₂ emission control technologies for the small utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process

code 13.310: Natural Gas-Fired Boilers/Furnaces (<100 MMBtu/hr). The search results are summarized in Table 7-16.

Table 7-16: SO₂ Control for Small Natural Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (gr/100 dscf sulfur in fuel)
GCP & Clean Fuel	10	0.6 – 5
No Control	1	2

Step 1 – Identify SO₂ Control Technologies for Small Utility Heaters

From research, the Department identified the following technologies as available for SO₂ control of gas-fired boilers and heaters rated at less than 100 MMBtu/hr:

(a) Good Combustion Practices (GCP) and Clean Fuels

As discussed in detail in CO BACT Section 4.2, as well as the fuel specifications portion of particulate BACT Section 4.3, GCP and clean fuels is a common technique for controlling SO₂ emissions. SO₂ emissions in the exhaust of liquid or gas-fired boilers and heaters are directly related to the levels of sulfur in fuel. As such, fuel specifications are the primary method of SO₂ emissions control and are a feasible control technology for the utility heaters.

Step 2 – Eliminate Technically Infeasible SO₂ Control Options for Small Utility Heaters

All control technologies identified are technically feasible for gas-fired boilers and heaters rated at less than 100 MMBtu/hr.

Step 3 – Rank Remaining SO₂ Control Options for Small Utility Heaters

AGDC has accepted the only technically feasible control technology for the gas-fired utility heaters. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for SO₂ emissions for EUs 34 – 38. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the only SO₂ emission control technologies installed on gas-fired heaters and boilers rated at less than 100 MMBtu/hr.

Applicant Proposal

AGDC proposed to use clean fuels and good combustion practices for the small utility heaters EUs 34 – 38 as BACT for reducing SO₂ emissions. Additionally, EUs 34 and 35 will be limited to 500 hours per 12-month rolling period per boiler. AGDC will utilize only natural gas in the small utility heaters EUs 34 – 38 with a total sulfur content not to exceed 96 ppmv.

Step 5 – Selection of SO₂ BACT for Small Utility Heaters

The Department's finding is that BACT for SO₂ emissions from the gas-fired utility heaters rated at less than 100 MMBtu/hr is as follows:

- (a) SO₂ emissions from EUs 34 – 38 shall be minimized by maintaining good combustion practices and burning natural gas with a total sulfur content not to exceed 96 ppmv at all times the units are in operation;
- (b) Limit operation of EUs 34 and 35 to no more than 500 hours per 12-month rolling period per boiler; and
- (c) Compliance with the proposed fuel sulfur content limit will be demonstrated with fuel shipment receipts and/or fuel test results for total sulfur content.

7.5 VOC

Possible VOC emission control technologies for the utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 13.310: Natural Gas-Fired Boilers/Furnaces (<100 MMBtu/hr). The search results are summarized in Table 7-17.

Table 7-17: VOC Control for Small Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Good Combustion Practices	40	0.0014 – 0.02
No Control Specified	6	0.0050 – 0.0054

Step 1 – Identify VOC Control Technologies for Small Utility Heaters

From research, the Department identified the following technologies as available for VOC control of gas-fired boilers and heaters rated at less than 100 MMBtu/hr:

- (a) Oxidation Catalyst
The theory of oxidation catalysts were discussed in detail in the CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database did not identify any oxidation catalysts used as a VOC control device for gas-fired boilers rated at less than 100 MMBtu/hr. Therefore, the Department does not consider oxidation catalysts to be a technically feasible control technology for the small utility heaters.
- (b) Good Combustion Practices (GCPs) and clean fuel
The theory of GCPs and clean fuel was discussed in detail in CO BACT section 3.2 for the large combined cycle natural gas-fired combustion turbines and will not be repeated here. The Department's search of the RLBC database indicated that GCPs and clean fuel are the primary technique used to control VOC emissions for gas-fired boilers rated at less than 100 MMBtu/hr. Therefore, the Department considers GCPs and clean fuel to be a technically feasible control technology for the small utility heaters.

Step 2 – Eliminate Technically Infeasible VOC Control Options for Small Utility Heaters

As explained in Step 1, oxidation catalysts are not technically feasible for gas-fired boilers and heaters rated at less than 100 MMBtu/hr.

Step 3 – Rank Remaining VOC Control Options for Small Utility Heaters

The following control technologies have been identified and ranked for control of VOC from the small boilers and heaters:

- (a) Good Combustion Practices (Less than 90% Control)

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, good combustion practices and clean fuels are the applicable controls for VOC emissions for EUs 34 – 38. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices is the principle control method for VOC from gas-fired heaters and boilers rated at less than 100 MMBtu/hr.

Applicant Proposal

AGDC proposed to use good combustion practices and clean fuel for the small utility heaters EUs 34 - 38 as BACT for reducing VOC emissions. Additionally, EUs 34 and 35 will be limited to 500 hours per 12-month rolling period per boiler. VOC emissions from EUs 34 – 38 will not exceed 0.0057 lb/MMBtu.

Step 5 – Selection of VOC BACT for Small Utility Heaters

The Department's finding is that BACT for VOC emissions from the gas-fired utility heaters rated at less than 100 MMBtu/hr is as follows:

- (a) VOC emissions from EUs 34 – 38 shall be controlled by maintaining good combustion practices at all times the units are in operation;
- (b) Limit operation of EUs 34 and 35 to no more than 500 hours per 12-month rolling period per boiler;
- (c) VOC emissions from EUs 34 – 38 shall not exceed 0.0057 lb/MMBtu averaged over a 3-hour period (AP-42, Table 1.4-2, VOC emission rate for natural gas combustion in external combustion sources); and
- (d) Initial compliance with the proposed VOC emission limit will be demonstrated by conducting a performance test to obtain an emission rate, or supplying the Department with a vendor verification that the EUs will comply with the BACT limit.

7.6 GHG

Possible GHG emission control technologies for the small utility heaters were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 13.310: Natural Gas-Fired Boilers/Furnaces (<100 MMBtu/hr). The search results are summarized in Table 7-18.

Table 7-18: GHG Control for Small Gas-Fired Boilers and Heaters

Control Technology	Number of Determinations	Emission Limits (tpy)
GCP & Clean Fuels	30	345 – 153,716
Limited Operation	1	187

No Control	16	625 – 131,405
------------	----	---------------

CO₂ and N₂O emissions are produced during natural gas combustion in gas-fired heaters. Nearly all of the fuel carbon is converted to CO₂ during the combustion process, regardless of the firing configuration. CH₄ is also present in the exhaust gas and is thought to be unburned fuel in the case of natural gas.

Step 1 – Identify GHG Control Technologies for Small Utility Heaters

From research, the Department identified the following technologies as available for VOC control of gas-fired boilers and heaters rated at less than 100 MMBtu/hr:

(a) Carbon Capture and Sequestration (CCS)

CCS was discussed in detail in the GHG BACT Section 4.6 for simple cycle turbines, and will not be repeated here. The Department’s research did not identify CCS as a control technology used to control GHG emissions from heaters or any other emission unit type installed at any facility in the RBLC database. Therefore, the Department considers this technology to be commercially unavailable in the United States and a technically infeasible control technology for the small utility heaters.

(b) Good Combustion Practices and Clean Fuels

Discussed in detail in CO BACT Section 4.2, as well as the fuel specifications portion of particulate BACT Section 4.3. GCP and clean fuels is a common technique for controlling GHG emissions. GHG emissions in the exhaust of liquid or gas-fired boilers and heaters are directly related to the carbon content in the fuel. Natural gas has the lowest amount of GHG emissions per Btu of energy of any fossil fuel, and is considered a feasible control technology for the small utility heaters.

Step 2 – Eliminate Technically Infeasible GHG Control Options for Small Utility Heaters

As explained in Step 1, CCS is not considered a technically feasible technology to control GHG emissions from gas-fired boilers and heaters rated at less than 100 MMBtu/hr.

Step 3 – Rank Remaining GHG Control Options for Small Utility Heaters

AGDC has accepted the only feasible control option. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

According to the RBLC, clean fuels and good combustion practices are the applicable controls for GHG emissions for EUs 34 – 38. Since these are not add-on controls, there are no additional environmental impacts.

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and clean fuels are the principle control method for GHG from gas-fired boilers and heaters rated at less than 100 MMBtu/hr.

Applicant Proposal

AGDC proposed to use good combustion practices and clean fuels for the small utility heaters EUs 34 – 38 as BACT for reducing GHG emissions. Additionally, EUs 34 and 35 will be limited to 500 hours per 12-month rolling period per boiler. GHG emissions from EUs 34 – 38 will not exceed 117.1 lb/MMBtu, which is the CO₂e emissions rates for burning natural gas in 40 CFR Part 98: Mandatory Greenhouse Gas Reporting. The total CO₂e emissions rate is calculated with the equation CO₂(1) + CH₄(25) + N₂O(298).

Step 5 – Selection of GHG BACT for Small Utility Heaters

The Department’s finding is that BACT for GHG emissions from the gas-fired boilers and heaters rated at less than 100 MMBtu/hr:

- (a) GHG emissions from EUs 34 – 38 shall be controlled by maintaining good combustion practices and burning natural gas at all times the units are in operation;
- (b) Limit operation of EUs 34 and 35 to no more than 500 hours per 12-month rolling period per boiler; and
- (c) GHG emissions from EUs 34 – 38 shall not exceed 117.1 lb/MMBtu averaged over a 3-hour period.

8.0 VENT GAS DISPOSAL (FLARES)

The GTP will utilize four sets of flares (EUs 45 – 52) to handle the relief and blowdown requirements of the facility. EUs 45 – 48 contain the low pressure and high pressure (LP and HP) hydrocarbon flares, and EUs 49 – 52 contain the LP and HP CO₂ byproduct flares. These flare systems prevent the direct relief to the atmosphere of vent gases that contain VOC and GHG (in the form of CH₄). The flares will emit CO, NO_x, SO₂, particulates, VOC, and GHG. The following sections provide the BACT review for each of these pollutants.

8.1 NO_x

Possible NO_x emission control technologies for the flares were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 19: Miscellaneous combustion (19:300 is specific to flares) and 50: Petroleum/Natural Gas Production and Refining. The search results were then filtered to include only emissions units with flares. The search results are summarized in Table 8-1.

Table 8-1: NO_x Controls for Flares

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Flare Work Practice Requirements	7	0.02 - 0.098
Flaring Minimization Plan	10	0.068
No Control Specified	8	0.05 - 0.068

Step 1 – Identify NO_x Control Technologies for the Flares

From research, the Department identified the following technologies as available for NO_x control of the flares:

- (a) Flare Work Practice Requirements
Flare work practice requirements can be found in 40 CFR 60.18 (c) through (f). Flare design and monitoring are key elements in emissions performance of flares. Flares must

be properly operated and maintained in order to achieve the anticipated emission rates guaranteed by the flare manufacturer. The Department considers proper flare design and good combustion practices as technically feasible control options for the flares.

(b) Flaring Minimization Plan

Flaring minimization plans define the procedures intended to reduce the frequency, magnitude, and duration of flaring events, without compromising plant operations or safety. By limiting the volume of gas going to the flare, all emissions types are minimized. The Department considers flaring minimization plans a technically feasible control options for the flares.

(c) Flare Gas Recovery

Flare gas recovery has been implemented at some facilities that produce and use internally generated fuel gas streams, such as petroleum refineries, to reduce gaseous emissions to the atmosphere by recovering waste gas to be reused in the production process. However, flare gas recovery is not part of the GTP flare system design, as there would be no routine and continuous venting of gas to the flare. Therefore, consideration of flare gas recovery is unnecessary as a potential control technology.

Step 2 – Eliminate Technically Infeasible NO_x Control Options for the Flares

As explained in Step 1, flare gas recovery is not feasible to control NO_x emissions from the flares.

Step 3 – Rank Remaining NO_x Control Technologies for the Flares

AGDC has accepted the remaining two technically feasible control options for the flares EUs 45 – 52. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

RBLC Review

A review of similar units in the RBLC indicates that use of flare work practice requirements (including proper flare design and good combustion practices) as well as a flaring minimization plan are the principle control methods for NO_x emissions from flares. Since these are not add-on controls, there are no additional environmental impacts.

Applicant Proposal

AGDC proposed to use good combustion practices, proper flare design, and create a flaring minimization plan for the flares EUs 45 – 52 as BACT for reducing NO_x emissions. Additionally, EUs 45 – 52 will be limited to 500 hours of flaring per 12-month rolling period per flare. NO_x emissions from EUs 45 – 52 will not exceed 0.068 lb/MMBtu.

Step 5 – Selection of NO_x BACT for the Flares

The Department's finding is that BACT for NO_x emissions from the flares is as follows:

- (a) NO_x emissions from EUs 45 – 52 shall be minimized by proper flare work practice requirements and establishing a flaring minimization plan;

- (b) Limit the number of hours EUs 45 through 52 flare during startup, shutdown, and maintenance events, to no more than 500 hours per 12 consecutive month period per flare;¹³ and
- (c) NOx emissions from EUs 45 – 52 shall not exceed 0.068 lb/MMBtu averaged over a 3-hour period (AP-42 Table 13.5-1, NOx emissions rate for flare operations).

8.2 CO

Possible CO emission control technologies for the flares were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 19: Miscellaneous combustion (19:300 is specific to flares) and 50: Petroleum/Natural Gas Production and Refining. The search results were then filtered to include only emissions units with flares. The search results are summarized in Table 8-2.

Table 8-2. CO Controls for Flares

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Flare Work Practice Requirements	7	0.08 - 0.37
Flaring Minimization Plan	12	0.31 – 0.37
No Control Specified	6	0.082 – 0.37

Step 1 – Identify CO Control Technologies for the Flares

From research, the Department identified the following technologies as available for CO control of the flares:

- (a) Flare Work Practice Requirements
Flare work practice requirements can be found in 40 CFR 60.18 (c) through (f). Flare design and monitoring are key elements in emissions performance of flares. Flares must be properly operated and maintained in order to achieve the anticipated emission rates guaranteed by the flare manufacturer. The Department considers proper flare design and good combustion practices as technically feasible control options for the flares.
- (b) Flaring Minimization Plan
Flaring minimization plans define the procedures intended to reduce the frequency, magnitude, and duration of flaring events, without compromising plant operations or safety. By limiting the volume of gas going to the flare, all emissions types are minimized. The Department considers flaring minimization plans a technically feasible control options for the flares.
- (c) Flare Gas Recovery
Flare gas recovery has been implemented at some facilities that produce and use internally generated fuel gas streams, such as petroleum refineries, to reduce gaseous emissions to the atmosphere by recovering waste gas to be reused in the production process. However, flare gas recovery is not part of the GTP flare system design, as there would be no routine and continuous venting of gas to the flare. Therefore, consideration of flare gas recovery is unnecessary as a potential control technology.

Step 2 – Eliminate Technically Infeasible CO Control Options for the Flares

¹³ This 500 hour flaring limit does not include pilot and purge, emergency, or process upset flaring.

As explained in Step 1, flare gas recovery is not feasible to control CO emissions from the flares.

Step 3 – Rank Remaining CO Control Technologies for the Flares

AGDC has accepted the remaining two technically feasible control options for the flares EUs 45 – 52. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

RBLC Review

A review of similar units in the RBLC indicates that use of flare work practice requirements (including proper flare design and good combustion practices) as well as a flaring minimization plan are the principle control methods for CO emissions from flares. Since these are not add-on controls, there are no additional environmental impacts.

Applicant Proposal

AGDC proposed to use good combustion practices, proper flare design, and create a flaring minimization plan for the flares EUs 45 – 52 as BACT for reducing CO emissions. Additionally, EUs 45 – 52 will be limited to 500 hours of flaring per 12-month rolling period per flare. CO emissions from EUs 45 – 52 will not exceed 0.31 lb/MMBtu.

Step 5 – Selection of CO BACT for the Flares

The Department's finding is that BACT for CO emissions from the flares is as follows:

- (a) CO emissions from EUs 45 – 52 shall be minimized by proper flare work practice requirements and establishing a flaring minimization plan;
- (b) Limit the number of hours EUs 45 through 52 flare during startup, shutdown, and maintenance events, to no more than 500 hours per 12 consecutive month period per flare¹³; and
- (c) CO emissions from EUs 45 – 52 shall not exceed 0.37 lb/MMBtu averaged over a 3-hour period (AP-42 Table 13.5-1, CO emissions rate for flare operations).

8.3 Particulates

Possible particulate emission control technologies for the flares were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 19: Miscellaneous combustion (19:300 is specific to flares) and 50: Petroleum/Natural Gas Production and Refining. The search results were then filtered to include only emissions units with flares. The search results are summarized in Table 8-3.

Table 8-3: Particulate Controls for Flares

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Flare Work Practice Requirements	10	0.007 – 0.016
Flaring Minimization Plan	25	0.0019 – 0.0075
No Control Specified	9	0.0019 – 0.0264

Step 1 – Identify Particulate Control Technologies for the Flares

From research, the Department identified the following technologies as available for particulate control of the flares:

(a) Flare Work Practice Requirements

Flare work practice requirements can be found in 40 CFR 60.18 (c) through (f). Flare design and monitoring are key elements in emissions performance of flares. Flares must be properly operated and maintained in order to achieve the anticipated emission rates guaranteed by the flare manufacturer. The Department considers proper flare design and good combustion practices as technically feasible control options for the flares.

(b) Flaring Minimization Plan

Flaring minimization plans define the procedures intended to reduce the frequency, magnitude, and duration of flaring events, without compromising plant operations or safety. By limiting the volume of gas going to the flare, all emissions types are minimized. The Department considers flaring minimization plans a technically feasible control options for the flares.

(c) Flare Gas Recovery

Flare gas recovery has been implemented at some facilities that produce and use internally generated fuel gas streams, such as petroleum refineries, to reduce gaseous emissions to the atmosphere by recovering waste gas to be reused in the production process. However, flare gas recovery is not part of the GTP flare system design, as there would be no routine and continuous venting of gas to the flare. Therefore, consideration of flare gas recovery is unnecessary as a potential control technology.

Step 2 – Eliminate Technically Infeasible Particulate Control Options for the Flares

As explained in Step 1, flare gas recovery is not feasible to control particulate emissions from the flares.

Step 3 – Rank Remaining Particulate Control Technologies for the Flares

AGDC has accepted the remaining two technically feasible control options for the flares EUs 45 – 52. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

RBLC Review

A review of similar units in the RBLC indicates that use of flare work practice requirements (including proper flare design and good combustion practices) as well as a flaring minimization plan are the principle control methods for Particulate emissions from flares. Since these are not add-on controls, there are no additional environmental impacts.

Applicant Proposal

AGDC proposed to use good combustion practices, proper flare design, and create a flaring minimization plan for the flares EUs 45 – 52 as BACT for reducing particulate emissions. Additionally, EUs 45 – 52 will be limited to 500 hours of flaring per 12-month rolling period per flare. Particulate emissions from EUs 45 – 52 will not exceed 40 µg/L (equivalent to 0.028 lb/MMBtu).

Step 5 – Selection of Particulate BACT for the Flares

The Department's finding is that BACT for particulate emissions from the flares is as follows:

- (a) Particulate emissions from EUs 45 – 52 shall be minimized by proper flare work practice requirements and establishing a flaring minimization plan;

- (b) Limit the number of hours EUs 45 through 52 flare during startup, shutdown, and maintenance events, to no more than 500 hours per 12 consecutive month period per flare¹³; and
- (c) Particulate emissions from EUs 45 – 52 shall not exceed 40 µg/L (0.028 lb/MMBtu) averaged over a 3-hour period (AP-42 Table 13.5-1, particulate emissions rate for lightly smoking flares).

8.4 SO₂

Possible SO₂ emission control technologies for the flares were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 19: Miscellaneous combustion (19:300 is specific to flares) and 50: Petroleum/Natural Gas Production and Refining. The search results were then filtered to include only emissions units with flares. The search results are summarized in Table 8-4.

Table 8-4: SO₂ Controls for Flares

Control Technology	Number of Determinations	Emission Limits (lb/hr)
Flare Work Practice Requirements	3	0.0001 – 0.0008
Flaring Minimization Plan	1	13,023.6
No Control Specified	4	0.01 – 1,303.99

Step 1 – Identify SO₂ Control Technologies for the Flares

From research, the Department identified the following technologies as available for SO₂ control of the flares:

- (a) Flare Work Practice Requirements
Flare work practice requirements can be found in 40 CFR 60.18 (c) through (f). Flare design and monitoring are key elements in emissions performance of flares. Flares must be properly operated and maintained in order to achieve the anticipated emission rates guaranteed by the flare manufacturer. The Department considers proper flare design and good combustion practices as technically feasible control options for the flares.
- (b) Flaring Minimization Plan
Flaring minimization plans define the procedures intended to reduce the frequency, magnitude, and duration of flaring events, without compromising plant operations or safety. By limiting the volume of gas going to the flare, all emissions types are minimized. The Department considers flaring minimization plans a technically feasible control options for the flares.
- (c) Flare Gas Recovery
Flare gas recovery has been implemented at some facilities that produce and use internally generated fuel gas streams, such as petroleum refineries, to reduce gaseous emissions to the atmosphere by recovering waste gas to be reused in the production process. However, flare gas recovery is not part of the GTP flare system design, as there would be no routine and continuous venting of gas to the flare. Therefore, consideration of flare gas recovery is unnecessary as a potential control technology.

Step 2 – Eliminate Technically Infeasible SO₂ Control Options for the Flares

As explained in Step 1, flare gas recovery is not feasible to control SO₂ emissions from the flares.

Step 3 – Rank Remaining SO₂ Control Technologies for the Flares

AGDC has accepted the remaining two technically feasible control options for the flares EUs 45 – 52. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

RBLC Review

A review of similar units in the RBLC indicates that use of flare work practice requirements (including proper flare design and good combustion practices) as well as a flaring minimization plan are the principle control methods for SO₂ emissions from flares. Since these are not add-on controls, there are no additional environmental impacts.

Applicant Proposal

AGDC proposed to use good combustion practices, proper flare design, and create a flaring minimization plan for the flares EUs 45 – 52 as BACT for reducing SO₂ emissions. Additionally, EUs 45 – 52 will be limited to 500 hours of flaring per 12-month rolling period per flare. AGDC will utilize only natural gas in the flares EUs 45 – 52 with a total sulfur content not to exceed 96 ppmv.

Step 5 – Selection of SO₂ BACT for the Flares

The Department's finding is that BACT for SO₂ emissions from the flares is as follows:

- (a) SO₂ emissions from EUs 45 – 52 shall be minimized by burning natural gas with a total sulfur content not to exceed 96 ppmv, following proper flare work practice requirements and establishing a flaring minimization plan;
- (b) Limit the number of hours EUs 45 through 52 flare during startup, shutdown, and maintenance events, to no more than 500 hours per 12 consecutive month period per flare;¹³ and
- (c) Compliance with the proposed fuel sulfur content limit will be demonstrated with fuel shipment receipts and/or fuel test results for total sulfur content.

8.5 VOC

Possible VOC emission control technologies for the flares were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 19: Miscellaneous combustion (19:300 is specific to flares) and 50: Petroleum/Natural Gas Production and Refining. The search results were then filtered to include only emissions units with flares. The search results are summarized in Table 8-5.

Table 8-5: VOC Controls for Flares

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Flare Work Practice Requirements	4	0.0054
Flaring Minimization Plan	9	0.0054
No Control Specified	4	0.0054 – 0.14

Step 1 – Identify VOC Control Technologies for the Flares

From research, the Department identified the following technologies as available for VOC control of the flares:

(a) Flare Work Practice Requirements

Flare work practice requirements can be found in 40 CFR 60.18 (c) through (f). Flare design and monitoring are key elements in emissions performance of flares. Flares must be properly operated and maintained in order to achieve the anticipated emission rates guaranteed by the flare manufacturer. The Department considers proper flare design and good combustion practices as technically feasible control options for the flares.

(b) Flaring Minimization Plan

Flaring minimization plans define the procedures intended to reduce the frequency, magnitude, and duration of flaring events, without compromising plant operations or safety. By limiting the volume of gas going to the flare, all emissions types are minimized. The Department considers flaring minimization plans a technically feasible control options for the flares.

(c) Flare Gas Recovery

Flare gas recovery has been implemented at some facilities that produce and use internally generated fuel gas streams, such as petroleum refineries, to reduce gaseous emissions to the atmosphere by recovering waste gas to be reused in the production process. However, flare gas recovery is not part of the GTP flare system design, as there would be no routine and continuous venting of gas to the flare. Therefore, consideration of flare gas recovery is unnecessary as a potential control technology.

Step 2 – Eliminate Technically Infeasible VOC Control Options for the Flares

As explained in Step 1, flare gas recovery is not feasible to control VOC emissions from flares.

Step 3 – Rank Remaining VOC Control Technologies for the Flares

AGDC has accepted the remaining two technically feasible control options for the flares EUs 45 – 52. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

RBLC Review

A review of similar units in the RBLC indicates that use of flare work practice requirements (including proper flare design and good combustion practices) as well as a flaring minimization plan are the principle control methods for VOC emissions from flares. Since these are not add-on controls, there are no additional environmental impacts.

Applicant Proposal

AGDC proposed to use good combustion practices, proper flare design, and create a flaring minimization plan for the flares EUs 45 – 52 as BACT for reducing VOC emissions. Additionally, EUs 45 – 52 will be limited to 500 hours of flaring per 12-month rolling period per flare. VOC emissions from EUs 45 – 52 will not exceed 0.57 lb/MMBtu.

Step 5 – Selection of VOC BACT for the Flares

The Department's finding is that BACT for VOC emissions from the flares is as follows:

- (a) VOC emissions from EUs 45 – 52 shall be minimized by proper flare work practice requirements and establishing a flaring minimization plan;
- (b) Limit the number of hours EUs 45 through 52 flare during startup, shutdown, and maintenance events, to no more than 500 hours per 12 consecutive month period per flare;¹³ and
- (c) VOC emissions from EUs 45 – 52 shall not exceed 0.57 lb/MMBtu averaged over a 3-hour period.

8.6 GHG

Possible GHG emission control technologies for the flares were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 19: Miscellaneous combustion (19:300 is specific to flares) and 50: Petroleum/Natural Gas Production and Refining. The search results were then filtered to include only emissions units with flares. The search results are summarized in Table 8-6.

Table 8-6: GHG Controls for Flares

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Flare Work Practice Requirements & Flaring Minimization Plan	11	116.89 – 117
No Control Specified	2	116.89

Step 1 – Identify GHG Control Technologies for the Flares

From research, the Department identified the following technologies as available for GHG control of the flares:

- (a) Flare Work Practice Requirements
Flare work practice requirements can be found in 40 CFR 60.18 (c) through (f). Flare design and monitoring are key elements in emissions performance of flares. Flares must be properly operated and maintained in order to achieve the anticipated emission rates guaranteed by the flare manufacturer. The Department considers proper flare design and good combustion practices as technically feasible control options for the flares.
- (b) Flaring Minimization Plan
Flaring minimization plans define the procedures intended to reduce the frequency, magnitude, and duration of flaring events, without compromising plant operations or safety. By limiting the volume of gas going to the flare, all emissions types are minimized. The Department considers flaring minimization plans a technically feasible control options for the flares.
- (c) Flare Gas Recovery
Flare gas recovery has been implemented at some facilities that produce and use internally generated fuel gas streams, such as petroleum refineries, to reduce gaseous emissions to the atmosphere by recovering waste gas to be reused in the production

process. However, flare gas recovery is not part of the GTP flare system design, as there would be no routine and continuous venting of gas to the flare. Therefore, consideration of flare gas recovery is unnecessary as a potential control technology.

Step 2 – Eliminate Technically Infeasible GHG Control Options for the Flares

As explained in Step 1, flare gas recovery is not feasible to control GHG emissions from the flares.

Step 3 – Rank Remaining GHG Control Technologies for the Flares

AGDC has accepted the remaining two technically feasible control options for the flares EUs 45 – 52. Therefore, ranking is not required.

Step 4 – Evaluate the Most Effective Controls

RBLC Review

A review of similar units in the RBLC indicates that use of flare work practice requirements (including proper flare design and good combustion practices) as well as a flaring minimization plan are the principle control methods for GHG emissions from flares. Since these are not add-on controls, there are no additional environmental impacts.

Applicant Proposal

AGDC proposed to use good combustion practices, proper flare design, and create a flaring minimization plan for the flares EUs 45 – 52 as BACT for reducing GHG emissions. Additionally, EUs 45 – 52 will be limited to 500 hours of flaring per 12-month rolling period per flare. GHG emissions from EUs 45 – 52 will not exceed 117.1 lb/MMBtu, which is the CO₂e emissions rates for burning natural gas in 40 CFR Part 98: Mandatory Greenhouse Gas Reporting. The total CO₂e emissions rate is calculated with the equation CO₂(1) + CH₄(25) + N₂O(298).

Step 5 – Selection of GHG BACT for the Flares

The Department's finding is that BACT for GHG emissions from the flares is as follows:

- (a) GHG emissions from EUs 45 – 52 shall be minimized by proper flare work practice requirements and establishing a flaring minimization plan;
- (b) Limit the number of hours EUs 45 through 52 flare during startup, shutdown, and maintenance events, to no more than 500 hours per 12 consecutive month period per flare¹³; and
- (c) GHG emissions from EUs 45 – 52 shall not exceed 117.1 lb/MMBtu averaged over a 3-hour period.

9.0 FUEL TANKS

GTP will have a total of nine fuel tanks (EUs 53 – 61). EUs 53 through 60 will hold diesel fuel with EU 53 having the largest capacity at 19,573 gallons. EU 61 will hold gasoline with a capacity of 10,000 gallons. These tanks will be used to supply fuel to the diesel EUs at the facility as well as support equipment and vehicles. The fuel tanks will emit VOCs. The following section provides the BACT review for VOC.

9.1 VOC

Possible VOC emission control technologies for fuel tanks were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 42.005 Petroleum Liquid Storage in Fixed Roof Tanks and 42.006 Petroleum Liquid Storage in Floating Roof Tanks. The search results are summarized in Table 9-1.

Table 9-1. VOC Control for Fuel Tanks

Control Technology	Number of Determinations	Emission Limits (tpy)
Floating Roof	30	0.88 - 18.57
Submerged Fill	7	0.8 - 72.5
Fixed Roof	5	0.8 - 72.5
Vapor Recovery System	4	3.95 - 7.33
NSPS	3	114.1
Leak Detection and Repair	1	28.3
No Control Specified	15	0.05 - 81.57

Step 1 – Identify VOC Control Technologies for Fuel Tanks

From research, the Department identified the following technologies as available for VOC control of the fuel tanks:

(a) Floating Roof

Floating roof tanks contain a roof that floats on the surface of the liquid that will rise and fall with the liquid level in the level in the tank, creating no vapor space except for when tanks have low liquid levels. External floating roof tanks are designed with a roof consisting of a double deck or pontoon single deck which rests or floats on the liquid being contained. An internal floating roof includes a fixed roof over the floating roof, to protect the floating roof from damage and deterioration. In general, the floating roof covers the entire liquid surface except for a small perimeter rim space. Under normal floating conditions, the roof floats essentially flat and is centered within the tank shell. The floating roof must be designed with perimeter seals (primary and secondary seals) which slide against the tank wall as the roof moves up and down. The use of perimeter seals minimizes emissions of VOCs from the tank. Sources of emissions from floating roof tanks include standing storage loss and withdrawal losses. Standing losses occur due to improper fits between tank seal and the tank shell. Withdrawal losses occur when liquid is removed from the tank, lowering the floating roof, revealing a liquid on the tank walls which vaporize. The Department considers floating roof tanks as a technically feasible control option for fuel tanks.

(b) Flare or Thermal Oxidizer

Enclosed flares combust the vent gases inside of the stack, avoiding the aesthetic concerns that can accompany visible flames produced by open flares. More burner tips are provided than for the open flare and the burner tips are located low enough inside the stack that there is no visible flame outside the stack. Air is drawn in through an adjustable opening in the bottom of the flare stack. A continuously lit pilot ensures that vent gases are combusted at the flare tip. A properly operated flare can achieve a destruction efficiency of 98 percent or greater. The GTP project does not currently include the

operation of a thermal oxidizer, the addition of a new combustion unit to control emissions from the tanks would create an undesired additional source of emissions.

(c) Submerged Fill

Submerged filling involves filling a tank through an opening underneath the liquid surface level (pipe opening usually 12" or less from bottom of tank) in order to minimize the production of vapors. The use of submerged fill during tank loading operations can reduce vaporization of the liquid between 40 – 60% from traditional splash loading operations. Note that the use of submerged fill is a control technique specific to the filling of a tank and does not affect the day-to-day emissions of the tank. The Department considers submerged fill as a technically feasible control option for the fuel tanks.

(d) Vapor Recovery System

A vapor recovery system (VRS) can be used to draw vapors out of the storage tank, which are routed through a compressor. Compressed vapors may be used onsite as fuel for combustion units or routed to sales gas compressors for further compression to pipeline specifications. VRSs can recover over 95% of the hydrocarbon emissions that accumulate in the storage tanks.

(e) Leak Detection and Repair

A system of detecting tank leaks for repairs. This can range from a visual inspection to a computerized system with in-tank probes.

Step 2 – Eliminate Technically Infeasible VOC Control Options for Fuel Tanks

As explained in step 1, the addition of a thermal oxidizer/flare to control emissions would result in the addition of a combustion unit with a continuously lit pilot light that may offset the emissions reduction expected from the fuel tanks, which have modest VOC emissions to begin with. Therefore a flare or thermal oxidizer is eliminated from further consideration.

Step 3 – Rank Remaining VOC Control Options for Fuel Tanks

The following control technologies have been identified and ranked for control of VOC from the tanks:

- | | |
|-------------------------------|-------------------|
| (a) Floating Roof | (99% Control) |
| (b) Vapor Recovery System | (95% Control) |
| (c) Submerged Fill | (40%-60% Control) |
| (d) Leak Detection and Repair | (40% Control) |

Step 4 – Evaluate the Most Effective Controls

A floating roof system is the most effective control for the fuel tanks at GTP. A floating roof system will not have any harsh environmental impacts and requires no consumables. Separately, submerged fill has the best VOC emissions control without requiring an add-on control, other than proper tank design.

RBLC Review

A review of similar units in the RBLC indicates add-on control technology is not practical for small tanks of diesel and gasoline fuel. Based on the small potential to emit of less than one tpy

for all nine tanks combined, add on controls are not a cost effective control technology for GTP's tanks.

Applicant Proposal

AGDC provided an economic analysis of a vapor recovery system to demonstrate that this control is not economically feasible for the fuel tank EUs 53 through 61. A summary of AGDC's analysis for the fuel tanks are shown below in Tables 9-2 and 9-3. The case with all tanks combined on the same VRS (Table 9-2) is presented as a conservative estimate of cost-effectiveness. In reality, tanks storing gasoline would not be connected to the same VRS as tanks storing diesel fuel (Table 9-3) due to potential cross-contamination issues. However, for this analysis, if all tanks connected to the same VRS is not cost-effective, the cost-effectiveness of separate VRS systems would likewise be less cost-effective.

Table 9-2: AGDC Economic Analysis for Technically Feasible VOC Controls (EUs 53-61)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
VRS	0.03	0.55	\$46,726	\$16,285	\$29,462
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

Table 9-3: AGDC Economic Analysis for Technically Feasible VOC Controls (EUs 53-60)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
VRS	0.0002	0.0032	\$46,726	\$16,285	\$5,049,828
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

AGDC contends that the economic analysis indicates the level of VOC reduction from VRS does not justify the use of VRS for the fuel tanks based on the excessive cost per ton of VOC removed per year.

AGDC proposes the following as BACT for VOC emissions from the fuel tanks:

- (a) VOC emissions from the operation of the fuel tanks EUs 53 – 61 will be controlled with the use of submerged fill; and
- (b) VOC emissions from fuel tanks EUs 53 – 61 will not exceed 0.59 tons per year.

Department Evaluation of BACT for VOC Emissions from Fuel Tank

The Department revised the emissions tables to reflect the equipment life revised to a 25 year lifespan and adjusted the interest rate to the current bank prime interest rate of 5.5%. A summary of the analyses for all fuel tanks EUs 53 through 61 is shown in Table 9-4, and a summary of the analyses for the diesel fuel tanks EUs 53 through 60 is shown in Table 9-5. Note that the cost analysis is for all EUs combined.

Table 9-4: Department Economic Analysis for Technically Feasible VOC Controls (EUs 53-61)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
VRS	0.03	0.55	\$46,726	\$13,116	\$23,729
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

Table 9-5: Department Economic Analysis for Technically Feasible VOC Controls (EUs 53-60)

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
VRS	0.0002	0.0032	\$46,726	\$13,116	\$4,067,053
Capital Recovery Factor = 0.0745 (5.5% interest rate for a 25 year equipment life)					

The Department's economic analysis indicates the level of VOC reduction does not justify the use of VRS as BACT for the fuel tanks at the Gas Treatment Plant.

Step 5 – Selection of VOC BACT for Fuel Tanks

The Department's finding is that BACT for VOC emissions from the fuel tanks is as follows:

- VOC emissions from the operation of the fuel tanks EUs 53 – 61 will be controlled with the use of submerged fill;
- VOC emissions from fuel tanks EUs 53 – 61 will not exceed 0.59 tons per year combined; and
- Initial compliance with the proposed VOC emission limit will be demonstrated by supplying the Department with schematics of the fuel tank EU 61 demonstrating that the submerged fill pipe is no more than 6 inches from the bottom of the tank.

Appendix C: BACT Summary

Table C-1. NO_x BACT Limits

EU ID	Description	BACT Limit	BACT Control
1 – 6 & 13 – 18	42 MW Cogeneration Compressor Gas Turbines with 190 MMBtu/hr Waste Heat Recovery Units	17 ppmvd at 15% O ₂	Dry Low NO _x ; Good Combustion Practices
7 – 12 & 19 – 24	26 MW Cogeneration Compressor Gas Turbines with 140 MMBtu/hr Waste Heat Recovery Units	17 ppmvd at 15% O ₂	Dry Low NO _x ; Good Combustion Practices
25 – 30	40 MW Simple Cycle Power Generation Gas Turbines	15 ppmvd at 15% O ₂	Dry Low NO _x ; Good Combustion Practices
31 – 33	275 MMBtu/hr Gas-Fired Building Medium Heaters	0.036 lb/MMBtu	Low NO _x Burners; Good Combustion Practices
34 & 35	Buyback Gas Bath Heaters (Gas-Fired, ≤ 25 MMBtu/hr)	0.036 lb/MMBtu	Low NO _x Burners; Limited Operation; Good Combustion Practices
36 – 38	Operations Camp Heaters (Gas-Fired, 32 MMBtu/hr)	0.036 lb/MMBtu	Low NO _x Burners; Good Combustion Practices
39	2,500 kW Black Start Generator (ULSD)	3.3 g/hp-hr	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
40 – 42	Firewater Pump Engines (ULSD, 190 kW)	3.6 g/hp-hr	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
43 & 44	Emergency Diesel Generators (ULSD, ≤ 250 kW)	3.6 g/hp-hr	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
45 – 52	Vent Gas Disposal (Flares) 1.3 – 76,000 MMscf/hr	0.068 lb/MMBtu	Limited Operation; Flare Work Practices; Flaring Minimization Plan

Table C-2. CO BACT Limits

EU ID	Description	BACT Limit	BACT Control
1 – 6 & 13 – 18	42 MW Cogeneration Compressor Gas Turbines with 190 MMBtu/hr Waste Heat Recovery Units	5 ppmvd at 15% O ₂	Oxidation Catalyst; Good Combustion Practices
7 – 12 & 19 – 24	26 MW Cogeneration Compressor Gas Turbines with 140 MMBtu/hr Waste Heat Recovery Units	5 ppmvd at 15% O ₂	Oxidation Catalyst; Good Combustion Practices
25 – 30	40 MW Simple Cycle Power Generation Gas Turbines	15 ppmvd at 15% O ₂	Clean Fuel; Good Combustion Practices
31 – 33	275 MMBtu/hr Gas-Fired Building Medium Heaters	0.007 lb/MMBtu	Oxidation Catalyst; Good Combustion Practices
34 & 35	Buyback Gas Bath Heaters (Gas-Fired, ≤ 25 MMBtu/hr)	0.087 lb/MMBtu	Clean Fuel; Limited Operation; Good Combustion Practices
36 – 38	Operations Camp Heaters (Gas-Fired, 32 MMBtu/hr)	0.087 lb/MMBtu	Clean Fuel; Good Combustion Practices
39	2,500 kW Black Start Generator (ULSD)	3.3 g/hp-hr	Oxidation Catalyst; Limited Operation; 40 CFR 60 Subpart IIII
40 – 42	Firewater Pump Engines (ULSD, 190 kW)	3.3 g/hp-hr	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
43 & 44	Emergency Diesel Generators (ULSD, ≤ 250 kW)	3.3 g/hp-hr	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
45 – 52	Vent Gas Disposal (Flares) 1.3 – 76,000 MMscf/hr	0.37 lb/MMBtu	Limited Operation; Flare Work Practices; Flaring Minimization Plan

Table C-3. Particulate Matter (PM-10 & PM-2.5) BACT Limits

EU ID	Description	BACT Limit	BACT Control
1 – 6 & 13 – 18	42 MW Cogeneration Compressor Gas Turbines with 190 MMBtu/hr Waste Heat Recovery Units	0.0063 lb/MMBtu	Clean Fuel; Good Combustion Practices
7 – 12 & 19 – 24	26 MW Cogeneration Compressor Gas Turbines with 140 MMBtu/hr Waste Heat Recovery Units	0.0063 lb/MMBtu	Clean Fuel; Good Combustion Practices
25 – 30	40 MW Simple Cycle Power Generation Gas Turbines	0.0070 lb/MMBtu	Clean Fuel; Good Combustion Practices
31 – 33	275 MMBtu/hr Gas-Fired Building Medium Heaters	0.0079 lb/MMBtu	Clean Fuel; Good Combustion Practices
34 & 35	Buyback Gas Bath Heaters (Gas-Fired, ≤ 25 MMBtu/hr)	0.0079 lb/MMBtu	Clean Fuel; Limited Operation; Good Combustion Practices
36 – 38	Operations Camp Heaters (Gas-Fired, 32 MMBtu/hr)	0.0079 lb/MMBtu	Clean Fuel; Good Combustion Practices (GCP)
39	2,500 kW Black Start Generator (ULSD)	0.045 g/hp-hr	GCP & ULSD; Limited Operation; 40 CFR 60 Subpart IIII
40 – 42	Firewater Pump Engines (ULSD, 190 kW)	0.19 g/hp-hr	GCP & ULSD; Limited Operation; 40 CFR 60 Subpart IIII
43 & 44	Emergency Diesel Generators (ULSD, ≤ 250 kW)	0.19 g/hp-hr	GCP & ULSD; Limited Operation; 40 CFR 60 Subpart IIII
45 – 52	Vent Gas Disposal (Flares) 1.3 – 76,000 MMscf/hr	40 μ g/L 0.028 lb/MMBtu	Limited Operation; Flare Work Practices; Flaring Minimization Plan

Table C-4. SO₂ BACT Limits

EU ID	Description	BACT Limit	BACT Control
1 – 6 & 13 – 18	42 MW Cogeneration Compressor Gas Turbines with 190 MMBtu/hr Waste Heat Recovery Units	≤96 ppmv sulfur content in natural gas	Clean Fuel; Good Combustion Practices
7 – 12 & 19 – 24	26 MW Cogeneration Compressor Gas Turbines with 140 MMBtu/hr Waste Heat Recovery Units	≤96 ppmv sulfur content in natural gas	Clean Fuel; Good Combustion Practices
25 – 30	40 MW Simple Cycle Power Generation Gas Turbines	≤96 ppmv sulfur content in natural gas	Clean Fuel; Good Combustion Practices
31 – 33	275 MMBtu/hr Gas-Fired Building Medium Heaters	≤96 ppmv sulfur content in natural gas	Clean Fuel; Good Combustion Practices
34 & 35	Buyback Gas Bath Heaters (Gas-Fired, ≤ 25 MMBtu/hr)	≤96 ppmv sulfur content in natural gas	Clean Fuel; Limited Operation; Good Combustion Practices
36 – 38	Operations Camp Heaters (Gas-Fired, 32 MMBtu/hr)	≤96 ppmv sulfur content in natural gas	Clean Fuel; Good Combustion Practices
39	2,500 kW Black Start Generator (ULSD)	≤15 ppmw sulfur content in diesel fuel	Good Combustion Practices & ULSD; Limited Operation; 40 CFR 60 Subpart IIII
40 – 42	Firewater Pump Engines (ULSD, 190 kW)	≤15 ppmw sulfur content in diesel fuel	Good Combustion Practices & ULSD; Limited Operation; 40 CFR 60 Subpart IIII
43 & 44	Emergency Diesel Generators (ULSD, ≤ 250 kW)	≤15 ppmw sulfur content in diesel fuel	Good Combustion Practices & ULSD; Limited Operation; 40 CFR 60 Subpart IIII
45 – 52	Vent Gas Disposal (Flares) 1.3 – 76,000 MMscf/hr	≤96 ppmv sulfur content in natural gas	Limited Operation; Flare Work Practices; Flaring Minimization Plan

Table C-5. VOC BACT Limits

EU ID	Description	BACT Limit	BACT Control
1 – 6 & 13 – 18	42 MW Cogeneration Compressor Gas Turbines with 190 MMBtu/hr Waste Heat Recovery Units	0.0022 lb/MMBtu	Oxidation Catalyst; Good Combustion Practices
7 – 12 & 19 – 24	26 MW Cogeneration Compressor Gas Turbines with 140 MMBtu/hr Waste Heat Recovery Units	0.0022 lb/MMBtu	Oxidation Catalyst; Good Combustion Practices
25 – 30	40 MW Simple Cycle Power Generation Gas Turbines	0.0022 lb/MMBtu	Clean Fuel; Good Combustion Practices
31 – 33	275 MMBtu/hr Gas-Fired Building Medium Heaters	0.0057 lb/MMBtu	Clean Fuel; Good Combustion Practices
34 & 35	Buyback Gas Bath Heaters (Gas-Fired, ≤ 25 MMBtu/hr)	0.0057 lb/MMBtu	Clean Fuel; Limited Operation; Good Combustion Practices
36 – 38	Operations Camp Heaters (Gas-Fired, 32 MMBtu/hr)	0.0057 lb/MMBtu	Clean Fuel; Good Combustion Practices
39	2,500 kW Black Start Generator (ULSD)	0.18 g/hp-hr	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
40 – 42	Firewater Pump Engines (ULSD, 190 kW)	0.19 g/hp-hr	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
43 & 44	Emergency Diesel Generators (ULSD, ≤ 250 kW)	0.19 g/hp-hr	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
45 – 52	Vent Gas Disposal (Flares) 1.3 – 76,000 MMscf/hr	0.57 lb/MMBtu	Limited Operation; Flare Work Practices; Flaring Minimization Plan
53 – 61	Fuel Tanks (Diesel and Gasoline)	0.59 tpy	Submerged Fill

Table C-6. GHG BACT Limits

EU ID	Description	BACT Limit	BACT Control
1 – 6 & 13 – 18	42 MW Cogeneration Compressor Gas Turbines with 190 MMBtu/hr Waste Heat Recovery Units	117.1 lb/MMBtu	Clean Fuel; Good Combustion Practices
7 – 12 & 19 – 24	26 MW Cogeneration Compressor Gas Turbines with 140 MMBtu/hr Waste Heat Recovery Units	117.1 lb/MMBtu	Clean Fuel; Good Combustion Practices
25 – 30	40 MW Simple Cycle Power Generation Gas Turbines	117.1 lb/MMBtu	Clean Fuel; Good Combustion Practices
31 – 33	275 MMBtu/hr Gas-Fired Building Medium Heaters	117.1 lb/MMBtu	Clean Fuel; Good Combustion Practices
34 & 35	Buyback Gas Bath Heaters (Gas-Fired, ≤ 25 MMBtu/hr)	117.1 lb/MMBtu	Clean Fuel; Limited Operation; Good Combustion Practices
36 – 38	Operations Camp Heaters (Gas-Fired, 32 MMBtu/hr)	117.1 lb/MMBtu	Clean Fuel; Good Combustion Practices
39	2,500 kW Black Start Generator (ULSD)	163.6 lb/MMBtu	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
40 – 42	Firewater Pump Engines (ULSD, 190 kW)	163.6 lb/MMBtu	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
43 & 44	Emergency Diesel Generators (ULSD, ≤ 250 kW)	163.6 lb/MMBtu	Good Combustion Practices; Limited Operation; 40 CFR 60 Subpart IIII
45 – 52	Vent Gas Disposal (Flares) 1.3 – 76,000 MMscf/hr	117.1 lb/MMBtu	Limited Operation; Flare Work Practices; Flaring Minimization Plan

Appendix D: Modeling Report

Alaska Department of Environmental Conservation
Air Permit Program

Review of
AGDC's Ambient Demonstration
for the
Alaska LNG Project's
Gas Treatment Plant

Construction Permit AQ1524CPT01

Prepared by: Alan Schuler
Reviewed by: James Renovatio
Date: July 12, 2019

G:\AQ\PERMITS\AIRFACS\Alaska Gasline Dev Corp (AK LNG Project)\Gas Treatment Plant
(1524)\Construction\CPT01\Pre\AQ1524CPT01 Modeling Review.docx

Table of Contents

1.	INTRODUCTION.....	1
2.	PROJECT BACKGROUND.....	1
	2.1. Area Classification.....	1
	2.2. Ambient Demonstration Requirements	2
	2.3. Increments and Baseline Dates	2
	2.4. Additional Comments Regarding Various Procedural Issues	3
3.	REPORT OUTLINE	5
4.	PRE-CONSTRUCTION MONITORING DATA	5
5.	SOURCE IMPACT ANALYSES	7
	5.1. Approach.....	7
	5.2. Model Selection	8
	5.3. Meteorological Data	9
	5.4. Coordinate System.....	13
	5.5. Terrain.....	13
	5.6. EU Inventory	13
	5.7. GTP Emission Rates and Stack Parameters.....	16
	5.8. Off-Site Emissions and Stack Parameters	21
	5.9. Shoreline Fumigation Analysis.....	23
	5.10. Pollutant Specific Considerations.....	24
	5.11. Downwash	28
	5.12. Ambient Air Boundary	30
	5.13. Worker Housing.....	30
	5.14. Receptor Grid.....	30
	5.15. Off-Site Impacts.....	31
	5.16. Design Concentrations.....	33
6.	MODELING RESULTS AND DISCUSSION	34
7.	OZONE IMPACTS	36
8.	ADDITIONAL IMPACT ANALYSES	37
	8.1. Associated Growth Analysis.....	37
	8.2. Visibility Impacts.....	38
	8.3. Soil and Vegetation Impacts.....	39
9.	CONCLUSIONS	40

1. INTRODUCTION

This report summarizes the Alaska Department of Environmental Conservation's (Department's) findings regarding the ambient analysis submitted by the Alaska Gasline Development Corporation (AGDC) for the Gas Treatment Plant (GTP) of the Alaska Liquefied Natural Gas Project (AK LNG Project). AGDC submitted this analysis in support of their December 29, 2017 air quality control permit application for GTP (AQ1524CPT01) submitted under the Prevention of Significant Deterioration (PSD) requirements listed in 18 AAC 50.306 and the major source of hazardous air pollutant (HAP) requirements listed in 18 AAC 50.316. The potential GTP emissions trigger the PSD permit requirements for the following air pollutants: oxides of nitrogen (NO_x), particulate matter with an aerodynamic diameter of 10 microns or less (PM-10), particulate matter with an aerodynamic diameter of 2.5 microns or less (PM-2.5), sulfur dioxide (SO₂), carbon monoxide (CO), volatile organic compounds (VOC), and greenhouse gases (GHG).

AGDC provided the PSD source impact analysis required under 40 CFR 52.21(k), the pre-construction monitoring analysis required under 40 CFR 52.21(m)(1), and the additional impact analysis required under 40 CFR 52.21(o). AGDC demonstrated that operating the GTP emissions units (EUs) within the restrictions listed in this report will not cause or contribute to a violation of the following Alaska Ambient Air Quality Standards (AAQS) listed in 18 AAC 50.010: 1-hour nitrogen dioxide (NO₂), annual NO₂, 24-hour PM-10, 24-hour PM-2.5, annual PM-2.5, 1-hour SO₂, 3-hour SO₂, 24-hour SO₂, annual SO₂, 1-hour CO, 8-hour CO, and 8-hour ozone (O₃). AGDC also demonstrated that the GTP emissions will not cause or contribute to a violation of the following Class II maximum allowable increases (increments) described in 18 AAC 50.020: annual NO₂, 24-hour PM-10, annual PM-10, 24-hour PM-2.5, annual PM-2.5, 3-hour SO₂, 24-hour SO₂, and annual SO₂.¹

2. PROJECT BACKGROUND

GTP will be a new stationary source located within the Prudhoe Bay Unit (PBU) of the Alaska North Slope. The project scope is fully described in AGDC's *Resource Report 1* (General Project Information) of the AK LNG Project, which AGDC provided as Attachment 2 of their permit application. In summary, GTP would treat and process gas received from the Alaska North Slope for delivery into a gas pipeline, which would deliver the gas to a Liquefaction Plant where the gas would be liquefied and transported to market. GTP will have three parallel production trains to treat and process the gas. Each train will include two Treated Gas Compression turbines and two Byproduct (CO₂) Compression turbines. Additional background information regarding GTP, the ambient demonstration requirements, and various procedural issues, are provided below.

2.1. Area Classification

The project site is in an area that is unclassified in regards to compliance with the AAQS. For purposes of increment compliance, the project site is within a Class II area of the

¹ There are no ambient demonstration requirements for GHG emissions since there are no GHG AAQS or increments.

Northern Alaska Intrastate Air Quality Control Region. The nearest Class I area,² Denali National Park, is located approximately 750 kilometers (km) to the south.

2.2. Ambient Demonstration Requirements

The State of Alaska's PSD requirements are described in 18 AAC 50.306. PSD applicants must essentially comply with the federal PSD requirements in 40 CFR 52.21. Except as noted in 40 CFR 52.21(i), the ambient requirements include:

- Stack Height considerations, per 40 CFR 52.21(h);
- A Source Impact Analysis, i.e., an ambient demonstration for the PSD-triggered pollutants with an associated ambient air quality standard or increment, per 40 CFR 52.21(k);
- An Air Quality Analysis, i.e., pre-construction monitoring data, for the PSD-triggered pollutants with an associated ambient air quality standard or increment, per 40 CFR 52.21(m);
- An Additional Impact Analysis per 40 CFR 52.21(o); and
- A Class I Impact Analysis, for stationary sources that may affect a Class I area, per 40 CFR 52.21(p).

GTP is located too far from Denali National Park to warrant a Class I Impact Analysis. The Department nevertheless notified the National Park Service (NPS) of the pending permit application upon receipt of the PSD modeling protocol (see Section 2.4.2 of this report) and asked them to confirm that they would not be requesting a PSD Class I analysis under 40 CFR 52.21(p).³ The NPS confirmed that they would not be requesting a Class I analysis on October 11, 2017.⁴

There are no ambient demonstration requirements under the major HAP permit classification. Therefore, AGDC was only required to provide the PSD demonstrations described at the beginning of Section 2.2.

2.3. Increments and Baseline Dates

For air quality modeling purposes, the term "increment" regards the maximum allowed increase in ambient concentration that may occur in a given area. The increment is determined relative to the "baseline concentration," which reflects the concentration that occurred, or was accounted for, at the time of a set baseline date. Congress set January 6, 1975 as the major source baseline date for the 24-hour and annual PM-10 increments, and

² Class I areas are defined as national parks over 6,000 acres and wilderness areas and memorial parks over 5,000 acres, established as of 1977. All other federally managed areas are designated as Class II areas. The Class I areas within Alaska are listed in Table 1 of 18 AAC 50.015(c)(2).

³ The Department initially contacted the NPS in a September 18, 2017 email from Alan Schuler to John Notar, *AK LNG GTP Protocol*; and sent a follow-up email from Alan Schuler to Andrea Stacy, *FW: AK LNG GTP Protocol*, on October 10, 2017.

⁴ Email from Andrea Stacy (NPS) to Alan Schuler (Department), *Re: FW: AK LNG GTP Protocol*; October 11, 2017.

the 3-hour, 24-hour, and annual SO₂ increments. EPA established February 8, 1988 as the major source baseline date for the annual NO₂ increment, and October 20, 2010 as the major source baseline date for the 24-hour and annual PM-2.5 increments. There are no 1-hour SO₂ or 1-hour NO₂ increments. The minor source baseline dates for the Northern Alaska Intrastate Air Quality Control Region are listed in Table 2 of 18 AAC 50.020. All of the combustion-related EUs at GTP will consume increment for the pollutants and averaging periods described within this paragraph since the emissions will occur after the applicable major source baseline dates.

2.4. Additional Comments Regarding Various Procedural Issues

2.4.1. Interface with the National Environmental Policy Act

AGDC conducted various air quality demonstrations under the National Environmental Policy Act (NEPA) prior to submitting their permit application for GTP.⁵ They therefore relied on these previous demonstrations, to the extent possible, for the ambient analyses required under PSD. This type of coordinated approach is encouraged by EPA under 40 CFR 52.21(s). The Department has not adopted this citation by reference (since it has no control over the federal actions conducted under NEPA), but the Department nevertheless agrees that the analyses should be consistent where possible.

The Department notes, however, that while the PSD and NEPA requirements contain a number of similar air quality provisions, they are not fully identical. This report does not delve into those differences; but AGDC summarized them with respect to the GTP project in Attachment 4 of their PSD modeling protocol.

2.4.2. Modeling Protocol Submittal

AGDC submitted a modeling protocol for the PSD ambient demonstration for GTP on September 18, 2017. They submitted supplemental information on October 11, 2017. The Department approved the protocol, with comment, on December 13, 2017.

The protocol stated that the two nearest off-site facilities, the PBU Central Compressor Plant (CCP) and PBU Central Gas Facility (CGF),⁶ would be included in the cumulative impact analyses. The protocol also included the results of a wind tunnel study that AGDC conducted to determine more realistic downwash parameters for some of the CCP/CGF exhaust stacks – see related discussion in Section 5.11 (**Downwash**) of this report.

The Department asked the Region 10 (R10) office of the U.S. Environmental Protection Agency (EPA) for technical assistance in reviewing the wind tunnel study, along with the resulting Equivalent Building Dimensions (EBDs). R10 provided their recommendations in a December 11, 2017 letter, *Review of equivalent building*

⁵ The Federal Energy Regulatory Commission (FERC) is the lead agency for the NEPA review.

⁶ CCP and CGF are a single stationary source for purposes of Title I and Title V permitting.

dimension study for the Alaska LNG Gas Treatment Plant. The Department accepts R10's recommendations, which are summarized below:

- AGDC's EBD study complies with current EPA guidance; and
- The EBD results may be used in AGDC's cumulative modeling analyses for GTP.⁷

2.4.3. Guideline on Air Quality Models

The ambient demonstrations submitted in support of a permit application must comply with the air quality models, databases, and requirements specified of 40 CFR 51, Appendix W (*Guideline on Air Quality Models*), per 18 AAC 50.215(b), or an alternative modeling approach approved under 18 AAC 50.215(c). This basic requirement is reiterated for PSD applicants in 40 CFR 52.21(l), which the Department has adopted by reference in 18 AAC 50.040(h)(10).

EPA has made a number of updates to the *Guideline on Air Quality Models* (Guideline) over time. The Department used the 2005 version of the Guideline for the GTP modeling review since that was the version adopted by reference in 18 AAC 50.040(f) at the time of the protocol review.⁸ EPA had previously promulgated an update to the Guideline on January 17, 2017, but they also provided a one year transition period for the permitting authorities to incorporate the update into their air permit programs. EPA further stated:

During the 1-year period following promulgation, protocols for modeling analyses bases on the 2005 version of the Guideline, which are submitted in a timely manner, may be approved at the discretion of the reviewing authority.

The Department approved AGDC's PSD modeling protocol on December 13, 2017, which is within the 1-year transition period. The Department's reliance on the 2005 version of the Guideline for the GTP permit is therefore consistent with State rule, and allowed under Federal rule.

2.4.4. Application Submittal

AGDC submitted their permit application on December 28, 2017. They retransmitted the application on February 14, 2018 due to missing/corrupted electronic files in the original submittal. The Department requested additional information (which included

⁷ R10 limited their recommended approval of AGDC's EBD study to just the GTP cumulative impact analyses. R10 stated that further review is warranted prior to using the EBD study results in a permit application for CCP/CGF. They also provided recommendations to EPA's Model Clearinghouse regarding future EBD guidance. The Department acknowledged these additional recommendations in its approval of the PSD modeling protocol, but it did not elaborate on them since those issues are beyond the scope of the GTP Project.

⁸ At the time of the protocol review, 18 AAC 50.040(f) referred to the version of the Guideline "*revised as of July 1, 2015.*" The date refers to the latest version of 40 CFR 51 available when 18 AAC 50.040(f) was last updated. However, the latest version of the Guideline at that time was the version published in the Federal Register on November 9, 2005.

modeling-related information) on March 6, 2018. AGDC provided the missing documents on May 1, 2018, and the associated modeling files on May 4, 2018.⁹

3. REPORT OUTLINE

The Department's findings regarding AGDC's approach for meeting the pre-construction monitoring requirement in 40 CFR 52.21(m) is described in Section 4 (**Pre-Construction Monitoring Data**) of this report. The Department's findings regarding the additional impact analysis conducted under 40 CFR 52.21(o) is described in Section 8 (**Additional Impact Analysis**) of the report.

AGDC used a variety of means to address the ambient demonstration requirement in 40 CFR 52.21(k). AGDC used computer analyses (modeling) to predict the ambient NO₂, SO₂, PM-10, CO, and direct PM-2.5 air quality impacts; ambient data to represent the existing secondary PM-2.5 impacts; and a qualitative analysis to address the ambient O₃ impacts and project-related secondary PM-2.5 impacts. The Department's findings regarding AGDC's NO₂, SO₂, CO, PM-10, and PM-2.5 modeling analyses are provided in Section 5 (**Source Impact Analyses**) of this report. The results from these assessments are discussed in Section 6 (**Modeling Results and Discussion**). The Department's findings regarding AGDC's O₃ analysis is in Section 7 (**Ozone Impacts**) of the report.

4. PRE-CONSTRUCTION MONITORING DATA

40 CFR 52.21(m)(1) requires PSD applicants to submit ambient air monitoring data describing the air quality in the vicinity of the project, unless the existing concentration or the project impact is less than the applicable Significant Monitoring Concentration provided in 40 CFR 52.21(i)(5). The requirement only pertains to those pollutants that are subject to PSD review and have a National Ambient Air Quality Standard (NAAQS).¹⁰ If monitoring is required, the data are to be collected prior to construction. Hence, these data are referred to as "pre-construction monitoring" data. Ambient "background" data may also be needed to supplement the estimated ambient impact from the proposed project. AGDC's approach for meeting the pre-construction data requirement is discussed below. Their approach for meeting the "background" data needs is described in Section 5.15 (**Off-Site Impacts**) of this report.

Pre-construction monitoring data must be collected at a location and in a manner that is consistent with the EPA's *Ambient Monitoring Guidelines for Prevention of Significant Deterioration* (EPA-450/4-87-007), which the Department adopted by reference in 18 AAC 50.035(a)(5). In summary, the data must be collected at the location(s) of existing and proposed maximum impacts, the data must be current, and the data must meet PSD quality

⁹ The Department made additional information requests regarding non-modeling related issues, but they are not discussed in this Modeling Report.

¹⁰ EPA has the authority under 40 CFR 52.21(m)(1)(ii) to require pre-construction monitoring for PSD-triggered pollutants that do not have a NAAQS (when they have shown a need for the data), but they have not made this determination for those pollutants.

assurance requirements. The current quality assurance requirements are described in 18 AAC 50.215(a).

AGDC used ambient pollutant data measured by BP Exploration Alaska, Inc. (BPXA) at their CCP monitoring station to fulfill the pre-construction monitoring requirement. They provided their justification for using this dataset in Attachment 3 of their permit application. As noted by AGDC, the Department originally approved the CCP site in March 21, 2011 when the Project was under the auspices of the Alaska Pipeline Project (APP).^{11, 12} The Department confirmed the adequacy of this location during a January 15, 2015 pre-application meeting, and in its December 13, 2017 approval of the PSD modeling protocol (see Section 2.4.2 of this report).

AGDC provided data from calendar year 2015 in Attachment 3 of their permit application. This was the most recent year of Department-approved data when they were preparing their application. The Department has subsequently approved the CCP data from 2016 as well.¹³

The maximum concentrations (as measured according to the form of the given AAAQS) from both 2015 and 2016 are provided in Table 1 below. The Department is reporting the gaseous pollutants on a mass basis (micrograms per cubic meter – $\mu\text{g}/\text{m}^3$) which is the convention used in modeling, rather than the volumetric basis (parts per million – ppm) typically used in monitoring reports. Particulates are only measured and reported on a mass basis and are therefore, presented on a mass basis. Table 1 shows that the local air quality currently complies with the AAAQS for each PSD-triggered pollutant with an ambient air quality standard.

**Table 1. Pre-Construction Monitoring Data
(from BPXA's CCP Monitoring Station)**

Air Pollutant	Avg. Period	Max. Conc. ($\mu\text{g}/\text{m}^3$) measured in Calendar Year:		AAAQS ($\mu\text{g}/\text{m}^3$)
		2015	2016	
NO ₂	1-hour	147	167	188
	Annual	18.8	20.7	100
SO ₂	1-hour	22.8	24.4	196
	3-hour	23.6	0.0	1,300
	24-hour	20.2	26.2	365
	Annual	3.4	2.6	80
PM-10	24-hour	60	40	150

¹¹ Letter from Alan Schuler (Department) to Myron Fedak (Alaska Pipeline Project); *Approval of Revised Ambient Air Quality Monitoring Site for the Alaska Pipeline Project Gas Treatment Plant*; March 21, 2011.

¹² The Department's March 21, 2011 approval was for a stand-alone monitoring station located roughly 100-feet from BPXA's CCP monitoring station. However, the Department confirmed in a July 1, 2011 email to APP's consultant (AECOM) that BPXA's CCP monitoring site would be equally adequate. The email was from Alan Schuler to Jamie Christopher and Tom Damiana of AECOM, and had the subject line, *RE: Can we have a quick call regarding the [AK Pipeline] GTP Monitoring in Prudhoe Bay Today*.

¹³ *Alaska Department of Environmental Conservation Findings Regarding the BP Exploration (Alaska) Inc. (BPXA) 2016 Prudhoe Bay Unit CCP Ambient Air Monitoring Program Data*; December 14, 2017.

Air Pollutant	Avg. Period	Max. Conc. ($\mu\text{g}/\text{m}^3$) measured in Calendar Year:		AAQs ($\mu\text{g}/\text{m}^3$)
		2015	2016	
PM-2.5	24-hour	9	16	35
	Annual	3.2	3.0	12
O ₃	8-hour	82	82	140
CO	1-hour	1,145	1,140	40,000
	8-hour	1,145	1,140	10,000

5. SOURCE IMPACT ANALYSES

As previously mentioned in Section 3, AGDC conducted air quality modeling analyses to estimate their ambient NO₂, SO₂, CO, PM-10, and direct PM-2.5 impacts. The various aspects of their modeling analyses are discussed below.

5.1. Approach

AGDC modeled the “normal operations” scenario where all three production trains would be operating at full capacity. Additional information regarding this scenario may be found in Section 4.1.1 of the GTP Modeling Report that they submitted to FERC (Appendix F of Resource Report 9). AGDC did not model the other operational scenarios (e.g., plant start-up, early plant operations, and maintenance operations) since those scenarios would have fewer emissions and smaller ambient impacts. They likewise did not model the construction phase for the reasons described in Section 5.6.3 of this report. AGDC’s approach of just modeling the normal operations scenario is reasonable.

AGDC used a two-step approach for modeling the normal operations scenario. They first compared the ambient impact from just the GTP EUs (i.e., the project impacts) to the significant impact levels (SILs) listed in Table 5 of 18 AAC 50.215(d). Impacts less than the SIL are considered negligible. They then conducted a cumulative impact analysis for those pollutants and averaging periods with significant impacts. The cumulative impacts are compared to the AAQs or increment, as applicable.

A cumulative AAQs demonstration incorporates the impacts from natural and regional sources, along with long-range transport from far away sources. The impacts are accounted for through a combination of modeling and representative air quality monitoring data (aka background data). EPA discusses this overall approach in Section 8.2 of the Guideline. As stated in Section 8.2.3, “...all sources expected to cause a significant concentration gradient in the vicinity of the [applicant’s source] should be explicitly modeled.” The impact from other sources can be accounted for through representative background data.

The increment consuming impact from off-site sources must likewise be accounted for in a cumulative increment demonstration. The approach for incorporating these impacts must be evaluated on a case-specific basis for each pollutant. Background data is not generally used

in a cumulative increment analysis since it typically overstates the off-site increment consumption – i.e., it reflects the total air quality concentration rather than the *change* in concentration subsequent to the increment baseline date (see Section 2.3 of this report). Applicants instead typically model the nearby increment consuming EUs, and when warranted, the off-site increment expanding EUs.

As subsequently discussed in Section 6 (**Modeling Results and Discussion**) of this report, the project impacts for GTP exceed the SIL for most of the modeled pollutants and averaging periods. AGDC therefore included the nearby CCP/CGF EUs in their cumulative impact analyses since the CCP/CGF stationary source likely has significant concentration gradients near GTP. The following sub-sections provide additional details regarding AGDC's modeling analysis.

5.2. Model Selection

There are a number of air dispersion models available to applicants and regulators. EPA lists these models in the Guideline. AGDC used EPA's AERMOD Modeling System (AERMOD) for their ambient analyses. AERMOD is an appropriate modeling system for this permit application.

The AERMOD Modeling System consists of three major components: AERMAP, used to process terrain data and develop elevations for the receptor grid and EUs; AERMET, used to process the meteorological data; and the AERMOD dispersion model, used to estimate the ambient pollutant concentrations.

AGDC used the versions of AERMET and AERMOD that were current at the time that they conducted their NEPA analysis: AERMET version 15181 (AERMET 15181) and AERMOD version 15181 (AERMOD 15181). AERMAP was not used, nor required, since the North Slope coastal plain is considered featureless (see Section 5.5 of this report).

EPA has issued two AERMOD and AERMET updates subsequent to AGDC's NEPA analysis. EPA released the first update on December 20, 2016, with a subsequent correction to AERMOD on January 18, 2017. EPA identified the updates as AERMET version 16216 (AERMET 16216) and AERMOD version 16216r (AERMOD 16216r). AGDC acknowledged these updates in their PSD modeling protocol, but they also expressed a desire to maintain consistency with the NEPA analysis (see the related discussion in Section 2.4.1). However, AGDC stated that they would conduct a sensitivity analysis to confirm that the results using AERMOD/AERMET 15181 are still valid. The Department conditionally approved AGDC's proposed use of AERMOD/AERMET 15181, but noted that AGDC would need to use the current version of AERMET and AERMOD if:

- The sensitivity analysis shows that the maximum impacts may have been underestimated when using AERMET/AERMOD 15181;
- There are substantive changes in the EU inventory, emissions, or stack parameters that warrant an updated modeling analysis, and/or;

- AGDC (or the Department) finds that the tall tower meteorological data collected at Deadhorse leads to notably greater impacts than the A-Pad meteorological data used for the NEPA analysis (see Section 5.3.3 of this report).

AGDC provided the sensitivity analysis as Attachment 8 of their permit application. AGDC reran the cumulative impact analysis for the worst-case pollutants (1-hour NO₂ and 24-hour PM-2.5) for all five meteorological data years (see Section 5.3 of this report) using AERMET 16216 and AERMOD 16216r. The 1-hour NO₂ impacts were identical to the NEPA results to the second decimal. The 24-hour PM-2.5 impacts were identical to the NEPA results to the fifth decimal. AGDC's sensitivity analysis demonstrates that AERMET/AERMOD 15181 does not underestimate the impacts generated by AERMET 16216 and AERMOD 16216r.

EPA released another AERMET/AERMOD update on April 24, 2018. They identified these updates as AERMET version 18081 (AERMET 18081) and AERMOD version 18081 (AERMOD 18081). The Department does not generally make applicants update their ambient demonstrations if there is a model update subsequent to the Department's approval of the modeling protocol. The Department nevertheless conducted a quick sensitivity analysis by rerunning the annual NO₂ project impact analysis for the worst-case year (2009) using AERMOD/AERMET 18081. The maximum annual impact is compared to the previous maximum impact in Table 2 of this report. The maximum impact from AERMET/AERMOD 18081 match the maximum impact from AERMET/AERMOD 15181 to the second decimal. This similarity in modeled impacts further confirms that AGDC's use of AERMET/AERMOD 15181 remains acceptable for the GTP PSD application.

**Table 2. Department AERMOD
Sensitivity Results (µg/m³)**

Maximum Annual NO₂ Conc. When Using AERMET/ AERMOD Version:	
15181	18081
2.61720	2.61614

5.3. Meteorological Data

AERMOD requires hourly meteorological data to estimate plume dispersion. A *minimum* of one-year of site-specific data, or five years of representative National Weather Service (NWS) data should be used, per Section 8.3 of the Guideline. When modeling with site-specific data, the Guideline states that up to five years should be used, when available, to account for year-to-year variation in meteorological conditions.

AGDC used five years of surface meteorological data collected by BPXA at their PBU A-Pad monitoring station. The data was collected from calendar years 2009 through 2013. AGDC also used concurrent upper air data from the nearest NWS upper air station, which is

located in Utqiagvik.¹⁴ The use of A-Pad surface data with concurrent Utqiagvik upper air data is the routinely used meteorological data set for modeling PBU stationary sources with AERMOD.¹⁵

5.3.1. Quality Assurance Review and Data Processing

Site-specific meteorological data must meet the PSD quality assurance (QA) requirements outlined in EPA's *Meteorological Monitoring Guidance for Regulatory Modeling Applications* (EPA-454/R-99-005), per 18 AAC 50.215(a)(3). BPXA has routinely submitted annual A-Pad datasets for Department review over the past decade. The 2009 through 2013 data used by AGDC meets the QA requirements.

The Department has been posting the A-Pad/Utqiagvik data in an AERMOD-ready format so that it can be readily used by PBU permit applicants.¹⁶ A-Pad/Utqiagvik data for calendar years 2007 – 2011 was available when AGDC prepared the NEPA analysis. The data had been processed by another permit applicant, using AERMET 15181. AGDC shifted the data period by two years for the NEPA analysis, but they used the same approach to process the two newer years of meteorological data.

AERMET requires the area surrounding the surface meteorological tower to be characterized with regard to the following three surface characteristics: noon-time albedo, Bowen ratio, and surface roughness length. The A-Pad data posted on the Department's web-site, as well as the additional data processed by AGDC, was processed using the Department approved surface parameters for tundra.¹⁷ The approved surface parameters are repeated below in Table 3.

Table 3. Approved AERMET Surface Parameters for PBU A-Pad

Surface Parameter	Winter Value	Summer Value
Albedo	0.8	0.18
Bowen Ratio	1.5	0.80
Surface Roughness Length (m)	0.004	0.02

Table Note: Summer is defined as June through September, and winter is October through May, for purposes of processing A-Pad meteorological data with AERMET.

5.3.2. Low Wind Speed Adjustments

AERMET contains an option for adjusting the surface friction velocity (ADJ_u*) parameter. EPA developed this option to correct AERMOD's tendency to overpredict

¹⁴ Utqiagvik was formerly known as Barrow.

¹⁵ The Department routinely accepts the use of A-Pad meteorological data for the modeling of PBU EUs with stacks that are less than 50 meters tall – which is the standard case. The Department has noted in various meetings with applicants that the modeling of taller stacks would warrant additional review and the possible need for tall tower meteorological data.

¹⁶ AERMOD ready meteorological dataset may be found at: <http://dec.alaska.gov/air/air-permit/aeromod-met-data/>

¹⁷ The Department has previously reported the approved surface parameters for tundra in numerous North Slope modeling reviews, as well as Section 2.6.4.2 of the Department's [Modeling Procedures Review Manual](#).

impacts under stable, low wind conditions. AGDC did not use the ADJ_u* option for the GTP modeling analysis.¹⁸ Some of the modeled results may therefore be overstated.

5.3.3. Tall Tower Sensitivity Analysis

The Department and the previous owner of the AK LNG Project discussed the adequacy of using A-Pad meteorological data for modeling GTP during a January 15, 2015 pre-application meeting. The Department noted that the A-Pad data is collected on a 10-meter (m) tower and that it would be acceptable as long as the GTP exhaust stacks are less than 50 m tall. However, the Department noted that additional justification would be needed if the stack heights exceed 50 m. The owner discussed the possibility of collecting tall tower meteorological data from a separate site to help address the concern.

5.3.3.1 Deadhorse Data Collection

The project owner subsequently decided to install a 60 m tall meteorological tower in Deadhorse in order to collect wind data at the 10 m, 30 m, and 60 m levels; along with the other meteorological parameters needed for modeling with AERMOD. The Department approved the proposed location for the tower on October 27, 2015, and the Quality Assurance Project Plan on July 15, 2016. The owner collected data from June 1, 2016 through May 31, 2017, and submitted the data for Department review on September 1, 2017. The Department found all parameters to be PSD quality, except for the 30 m vertical wind speed and vertical wind speed standard deviation values.¹⁹ The Department notified AGDC of its findings on October 13, 2017.²⁰

5.3.3.2 Analysis Criteria

The Department asked AGDC to provide a sensitivity analysis using the tall tower Deadhorse data in the Department's December 13, 2017 approval of the PSD modeling protocol. The Department asked for the analysis since some of the exhaust stacks will be more than 50 m tall (see Section 5.7.6 of this report). The Department stated that the analysis could be provided as part of the permit application. The Department further stated:

The sensitivity analysis should compare the modeled design concentrations when using just the 2-meter and 10-meter Deadhorse data (i.e., data that is commensurate with the A-Pad data) to the modeled design concentrations when using the data from all measurement levels. AGDC may limit the analysis to just the worst-case pollutants, rather than

¹⁸ The ADJ_u* option was considered as an alternative modeling technique when AGDC conducted their NEPA modeling analysis. Alternative modeling techniques require case-specific justification and Department/R10 approval under 18 AAC 50.215(c).

¹⁹ The 30 m vertical wind speed data and vertical wind speed standard deviation data did not meet the QA requirements due to inadequate data capture.

²⁰ Email from Elizabeth Nakanishi (Department) to Kalb Stevenson (AGDC); *AK LNG GTP Meteorological data review findings 2016-2016*; October 13, 2017.

modeling all of the PSD-triggered pollutants, as long as AGDC assesses an annual impact, a 24-hour impact, and a 1-hour impact. The analysis should be conducted at the project impact level (i.e., just the GTP EUs) rather than cumulative impact level (i.e., GTP plus off-site EUs).

5.3.3.3 Analysis and Review

AGDC provided the tall tower sensitivity analysis as part of their May 1, 2018 submittal. They modeled the 1-hour NO₂, annual NO₂, 24-hour PM-2.5, and annual PM-2.5 project impacts for the two meteorological scenarios requested by the Department (i.e., just 2/10-m data, and data from all measurement levels). They used the version of AERMET and AERMOD that was current at the time: AERMET 16216 and AERMOD 16216r.

AGDC used a cursory approach for deriving the Deadhorse surface characteristics. They noted that a “more detailed analysis” would likely be required for regulatory applications, but that the “generalized approach is adequate for the intended purpose of this study.” The Department found several errors in their write-up and was unable to replicate some of the derived surface parameters. However, the Department agrees that the values are “close enough” for purposes of this sensitivity analysis.

AGDC used the Plume Volume Molar Ratio (PVMRM) to estimate their ambient NO₂ impacts (see Section 5.10.1 of this report) – which is the same approach that they used in their NEPA analysis. However, they used a single O₃ value, rather than the hourly O₃ values used in their NEPA analysis. The Department reran the 1-hour and annual NO₂ analyses for the “all” meteorological data scenario using hourly O₃ data to see if this more detailed approach would significantly alter the results. It did not.

AGDC found essentially identical design concentrations between the “10-m” and “all” data scenarios. In some cases, the “10-m” scenario lead to marginally larger values than the “all” scenario. Based on this analysis, AGDC concluded: *“Given the model results are insensitive to the integration of tall-tower meteorological data demonstrates that use of lower single-level meteorological data is appropriate for modeling tall sources.”*

AGDC included a number of source groups in the AERMOD runs, which was helpful in deciphering the results. It turns out that the maximum impacts are mostly caused by several EUs with relatively short stacks (i.e., less than 10 m tall). The Department further found from its review of the source group results and from its own runs of the two meteorological scenarios, that 10-m meteorological data may not be adequately representative if GTP had a different mix of EUs/stack heights. ***The Department therefore agrees that the use of 10-m meteorological data is acceptable for modeling the proposed GTP stationary source, but notes that this conclusion cannot be generally applied to all stationary sources with tall stacks.***

5.4. Coordinate System

Air quality models need to know the relative location of the EUs, structures (if applicable), and receptors, in order to properly estimate ambient pollutant concentrations. Therefore, applicants must use a consistent coordinate system in their analysis.

AGDC used the Universal Transverse Mercator (UTM) grid for their coordinate system. This is the most commonly used approach in AERMOD assessments. The UTM system divides the world into 60 zones, extending north-south, and each zone is 6 degrees wide in longitude. The modeled EUs, structures, and receptors are all located in UTM Zone 6. AGDC used the North American Datum of 1983 reference for each UTM coordinate.

5.5. Terrain

Terrain features can influence plume dispersion and the resulting ambient concentration. Digitized terrain elevation data is therefore generally included in a modeling analysis, unless the modeling domain is featureless.

AGDC did not need to obtain terrain elevation data since the North Slope coastal plain is fairly flat. They instead set all receptor elevations and hill heights to zero meters. They also used the pad elevations as the base heights for the exhaust stacks. According to AGDC, the GTP pad will be 1.83 m above the tundra. For the off-site EUs, AGDC used the same 1.52 m base height as previously used by BPXA in their modeling of CCP/CGF.

5.6. EU Inventory

The modeled EU inventory for GTP is described below, along with the off-site inventory that AGDC used in the cumulative impact analyses. The secondary emissions required in a cumulative impact analysis are also discussed.

5.6.1. GTP EU Inventory

AGDC modeled the combustion turbines, heaters, reciprocating engines, and flares described throughout their permit application, including Table 4-1 of the GTP Modeling Report. The EU locations are illustrated in Figures 5-5 and 5-6 of the GTP Modeling Report. AGDC characterized all of the EUs as point sources (see related discussion in Section 5.7 of this report).

AGDC assumed all EUs are concurrently operating, except as noted below. AGDC assumed that:

- Only two of the three Building Heat Medium Heaters (**EUs 31 – 33**) are operating at any time; and
- Only two of the three Operations Camp Heaters (**EUs 36 – 38**) are operating at any time.

The Department is imposing the non-concurrent operating assumption for **EUs 31 – 33** and **36 – 38** as an ambient air condition.

5.6.2. Off-site EU Inventory

As previously noted in Section 5.1 of this report, AGDC included the CCP/CGF stationary source in their cumulative impact analyses. The modeled EUs are listed in Appendix A of the GTP Modeling Report. The off-site EU inventory used by AGDC for the AAAQS analyses accurately incorporates the gas-fired combustion turbines, gas-fired heaters, diesel-fired equipment, and flares listed in the current Title V permits for CCP and CGF.²¹

AGDC used the installation/modification date listed in the CCP/CGF operating permits to determine which off-site EUs are increment consuming.²² The off-site inventory therefore varied by pollutant since the baseline date is pollutant-specific (see the related discussion in Section 2.3 of this report). The Department agrees with the off-site inventories selected for the NO₂, PM-10, and PM-2.5 increment analyses. However, the Department partially disagrees with the off-site inventory selected for the SO₂ increment analyses.

CCP/CGF underwent PSD review for SO₂ in 2008-2009 to accommodate an increase in the fuel gas hydrogen sulfide level. The resulting increase in SO₂ emissions, including the increases from the baseline EUs, is increment consuming. The Department therefore expanded the off-site SO₂ inventory so that it matches the CCP/CGF EU inventory used by BPXA in their SO₂ increment demonstration.²³ The Department then reran the 3-hour and 24-hour SO₂ increment analyses for all five meteorological data years.^{24, 25, 26} The gas-fired CCP/CGF EUs that the Department added to the SO₂ increment analyses are listed below in Table 4. The maximum SO₂ impacts increased by various margins, but they still demonstrate compliance with the 3-hour and 24-hour Class II increments. The Department's SO₂ modeling results are reported in Section 6 of this report.

²¹ The off-site EU inventories listed in Appendix A of the GTP Modeling Report do not include the BS&B TEG Reboilers at CCP (EUs 21 and 22; Model IDs 703 and 704). These EUs have been decommissioned, but they are still listed in Operating Permit 166TVP01. AGDC included them in the AAAQS analyses.

²² AGDC summarized the installation/modification date and increment consuming status of the off-site EUs in Appendix A of the GTP Modeling Report.

²³ The Department reported its findings regarding BPXA's SO₂ modeling analysis in the September 2009 memorandum, *Review of BPXA's Ambient SO₂ Assessment for CGF/CCP – Revised*. The memorandum may be found in Exhibit B of the Technical Analysis Report for Construction Permits AQ0166CPT04 and AQ0270CPT04.

²⁴ The Department did not need to conduct an annual SO₂ increment analysis since the GTP project impacts are less than the annual SO₂ SIL. See Section 6 of this report for details.

²⁵ The Department used AERMOD/AERMET 18081 for the revised SO₂ increment analyses.

²⁶ The Department also assumed continuous GTP flaring, as discussed in Section 5.7.3 of this report.

Table 4. CCP/CGF EUs Added to the SO₂ Increment Analyses

Facility	EU	Model ID	Description
CCP	17	814	Broach Glycol Heater
	18	815	Broach Glycol Heater
	19	702	Eclipse Glycol Heater
	20	701	Eclipse Glycol Heater
	26 - 29	819 - 825	Flares
CGF	<i>None – AGDC already included all gas-fired EUs</i>		

Table Note: The Department did not add the two BS&B TEG Reboilers at CCP (EUs 21 and 22) since they have been decommissioned. The actual SO₂ emissions for these EUs is 0 grams per second.

5.6.3. Secondary Emissions Inventory

PSD applicants must include “secondary emissions” in their ambient demonstration, per 40 CFR 52.21(k)(1). EPA defines the term in 40 CFR 52.21(b)(18) as, “*emissions which would occur as a result of the construction or operation of a major stationary source... but do not come from the major stationary source...*” However, secondary emissions do not include “*any emissions which come directly from a mobile source.*” Subsequent EPA guidance further clarifies that the definition in 40 CFR 52.21(b)(18) “*sets out four tests to be used in determining whether such emissions are to be included in air quality impact assessments for PSD purposes: the emissions must be specific, well defined, quantifiable, and impact the same general area.*”²⁷

The only secondary emissions that would occur due to the construction and operation of the GTP are the construction emissions that would occur within the local area. The emissions that would occur due to the remaining aspects of the AK LNG Project, including the construction/operation of the Pipeline Stations and Liquefaction Plant, are not secondary emissions for purposes of the GTP PSD review since they will not occur in the same general area as the GTP emissions.²⁸

AGDC provided a general discussion regarding their construction emissions in Section 4.1.3 of the GTP Modeling Report, and a more detailed discussion in their May 1, 2018 submittal. AGDC stated the GTP construction phase would last approximately 8 years. However, they noted that the majority of GTP would consist of modules constructed off-site and transported to the site via seagoing barge. This

²⁷ EPA letter from Edward F. Tuerk (Acting Assistant Administrator for Air, Noise and Radiation) to Allyn M. Davis (Director, Air and Hazardous Materials Division); *PSD Evaluation of Secondary Emissions for Houston Lighting and Power*; March 17, 1981.

²⁸ The Liquefaction Plant, and each of the Pipeline Stations, are separate stationary sources for air quality permitting purposes. The ambient impacts associated with each of those stationary sources will be assessed, as warranted, under the permit requirements for that stationary source.

approach would generally lead to secondary emissions that are less than the operational emissions used in the modeling analysis. AGDC further noted that the various construction activities/emissions would change during the 8-year period. They verbally clarified that even the temporary construction camp would be moving between various locations until the permanent worker housing camp becomes operational.²⁹

Developing the parameters needed to correctly characterize and simulate constantly changing construction emissions, especially fugitive dust emissions, is challenging. In some cases, the resulting concentrations are questionable, if not overly conservative. The Department further notes that the modeling results generally lead to: fugitive dust control plans (to minimize the fugitive dust impacts); and/or requirements to install vertical, uncapped exhaust stacks on the camp engines (to reduce the impacts from the combustion sources – see Sections 5.7.7 and 5.8.2 of this report). The Department therefore decided to impose the typical endpoint (i.e., ambient air conditions) rather than requiring AGDC to develop the details needed to model the construction phase emissions.

The Department imposed the following ambient air conditions for the GTP construction phase:

- Fugitive dust control;
- A requirement to construct and maintain vertical, uncapped stacks on all temporary camp engines; and
- A requirement to install and operate PM-10 and PM-2.5 ambient air monitoring stations throughout the construction phase.

The ambient air monitoring provision includes an action plan that requires evaluation and possible further control of the dust-generating activities at set concentration levels.

5.7. GTP Emission Rates and Stack Parameters

The Department generally found the modeled emission rates to be consistent with the emissions information provided throughout their application. The modeled stack parameters are likewise generally reasonable. The exceptions, or items that otherwise warrant additional comment, are discussed below.

AGDC used the same EU inventory, emission rates, and stack parameters in the Class II increment analyses as used in the AAAQS demonstrations. This is an appropriate approach since the GTP EUs are fully increment consuming (see the related discussion in Section 2.3 of this report).

5.7.1. Turbines

Each of the compression turbines (**EUs 1 – 12**) will have two exhaust stacks: one with a Waste Heat Recovery Unit (WHRU) that includes a supplemental firing system

²⁹ Jim Pfeiffer and Kalb Stevenson of AGDC described the portable nature of the temporary construction camp during a June 7, 2018 teleconference with Aaron Simpson, Dave Jones, and Alan Schuler (Department).

(EUs 13 – 24); and the other as a WHRU bypass. Both stacks would be designed to accept the full exhaust stream from the turbine. The WHRU stack would have greater emissions than the bypass stack (due to the emissions from the supplemental firing system), which in turn could lead to larger ambient impacts. However, the additional exhaust from the supplemental firing system could also lead to decreased impacts due to the increase in plume buoyancy. AGDC resolved these conflicting factors by using a simplified, but conservative, modeling approach. They used the WHRU stacks for the modeling analysis and included the supplemental firing emissions, but they did not include the additional exhaust flow rate. AGDC also used the WHRU exit temperature (410°F) rather than the more buoyant bypass temperature (1,650°F).

AGDC stated the Combustion Turbine Generators (EUs 25 – 30) will operate between 60 percent and 100 percent load. They conservatively addressed this variation by using the worst-case emissions and stack conditions, regardless of load, in their modeling analysis: i.e., the full-load emission rate, and 60-percent load exhaust conditions.

AGDC increased the modeled emissions rate for all turbines by 10 percent in the 1-hour NO₂ and 1-hour SO₂ AAAQS demonstrations. They stated the 10 percent “safety factor” accounts for short-term load variations.

5.7.2. Buyback Gas Bath Heaters

AGDC stated the two Buyback Gas Bath Heaters (EUs 34 and 35) would typically operate in a standby low-load mode, with infrequent instances of full-load operation. They characterized this operating scenario in the modeling analysis by representing each condition with an exhaust stack: one stack with an exhaust flow that represents a 10 percent load condition; and the other stack with an exhaust flow that represents a full-load condition. They also used emissions that reflect continuous, year-round operation at 10 percent load for the low-load stack. For the full-load stack, AGDC assumed the full-load condition occurs for only 500 hours per year (hr/yr) for the annual, and 1-hour NO₂/SO₂ assessments. They used the maximum hourly emission rate for the remaining short-term AAAQS and increments.³⁰

The Department typically imposes a part-year operating assumption as a permit restriction. However, creating a viable condition that varies the annual cap by load is both unusual and challenging. The Department therefore conducted two sensitivity analyses to determine whether a 500 hr/yr restriction is needed to protect the AAAQS/increments.

The Department reran the annual NO₂ increment analysis for the worst-case year (2010), and the 1-hour NO₂ AAAQS analysis.³¹ The Department assumed the Buyback Heaters are continuously operating year-round under full-load, as well as 10 percent load. This represents more emissions than what could actually occur, but it provides for

³⁰ “Short-term” refers to less than annual: i.e., the 1-hour, 3-hour, 8-hour, and 24-hour averaging periods.

³¹ The Department used AERMOD/AERMET 18081 in the Buyback Heater sensitivity analyses.

a conservative sensitivity analysis. The Department also corrected a NO₂-to-NO_x in-stack ratio error that is discussed in Section 5.10.1.2 of this report. The maximum annual impact increased from the 11.3 µg/m³ value discussed in Section 5.10.1.2 of this report to 11.4 µg/m³. This is an inconsequential change, especially given the wide margin of compliance with the 25 µg/m³ Class II NO₂ increment. The high eighth-high (h8h) 1-hour NO₂ impact increased by only 0.003 µg/m³, which is also inconsequential. Similar findings are expected for the other pollutants. The sensitivity analyses show that the full load operation does not need to be restricted in order to protect the AAAQS and increments. The Department is reporting the 11.4 µg/m³ value as the annual NO₂ increment consumption in Section 6 of this report.

5.7.3. Flares

GTP will have two sets of emergency flares: one operational and one spare. Each set includes a High Pressure (HP) hydrocarbon flare, a Low Pressure (LP) hydrocarbon flare, a HP carbon dioxide (CO₂) flare, and a LP CO₂ flare. Pilot and purge gas would be continuously combusted at each of the eight flares during normal operations. AGDC therefore included the pilot/purge operation of all eight flares in their modeling analysis. However, they also included the flaring events that could occasionally occur at the four operational flares. AGDC used the rated capacity of the flares to calculate the emissions and plume characteristics of the flaring event. Including flaring events and pilot/purge conditions as if they are simultaneously occurring makes that part of their modeling analysis conservative since these scenarios are mutually exclusive.

Flares can typically be treated as point sources, but they require special handling since the emissions are generated outside of the flare stack. Most applicants use the approach described in Section 2.1.2 of EPA's AERSCREEN User's Guide, whereby the exhaust temperature is set to 1273K, the exit velocity is set to 20 meters per second (m/s), the stack height is the physical height plus flame length, and the stack diameter is based on the heat release rate. AGDC used the AERSCREEN approach for characterizing the pilot/purge conditions as well as the flaring events.

AGDC assumed the flaring events would occur for 500 hr/yr for purposes of modeling the annual impacts as well as the 1-hour NO₂ and 1-hour SO₂ impacts. However, they assumed the flaring events would occur for only 30 minutes per day (min/day) for all other pollutants/averaging periods. Neither assumption substantially affects the modeled results or conclusions for the reasons described below.

The maximum impact from flaring events generally occurs well beyond the area of the total maximum impact from a North Slope stationary source. This trend holds especially true for GTP due to the tall height of the flare stacks (see Section 5.7.6 of this report) and extremely buoyant nature of the flaring events. The effective stack height of the flaring events range from 107 m for the HP Byproduct (CO₂) Flares to 256 m for the HP Hydrocarbon Flares. These heights, along with the additional plume rise from the high temperature release, lead to relatively large travel distances prior to plume touchdown. For example, the high first-high (h1h) 24-hour PM-2.5 impact from just the GTP flaring

event occurs 15 km from GTP.³² This is substantially further than the h1h project impact, which occurs along the pad edge – i.e., in the immediate near-field.

Increased travel distance allows for increased dispersion. The resulting impact from flaring therefore tends to be substantially smaller than the maximum total impact. For example, the h1h 24-hour PM-2.5 impact from the 30 min/day flaring event is only 0.033 $\mu\text{g}/\text{m}^3$ whereas the h1h project impact is 3.88 $\mu\text{g}/\text{m}^3$. The maximum flare impact increases to 1.6 $\mu\text{g}/\text{m}^3$ if one conservatively assumes continuous flaring, but even this value is less than half of the project impact. The Department further notes that the GTP flare event impacts are inconsequential within the immediate near-field. Similar findings would occur for the other averaging periods due to the general principals discussed above. Therefore, there is no need to incorporate the 500 hr/yr or 30 min/day assumptions as permit conditions.

In spite of the above findings, the Department assumed continuous flaring events when it remodeled the 3-hour and 24-hour AAAQS/increment impacts for the various reasons described in this report. The Department used this very conservative approach to further show that the flaring events do not need operating restrictions.

5.7.4. Reciprocating Engines

AGDC assumed the six reciprocating engines (**EUs 39 – 44**) each operate for only 500 hr/yr. AGDC used this assumption to derive the emission rates used in the annual AAAQS/increment demonstrations, as well as the 1-hour NO₂ and 1-hour SO₂ AAAQS demonstrations. The annual emission rate may be used to characterize intermittently operated EUs in the 1-hour NO₂ and 1-hour SO₂ AAAQS demonstrations per EPA policy.³³ The Department is imposing the 500 hr/yr assumption as an ambient condition to protect the annual AAAQS/increments, as well as the 1-hour NO₂ and 1-hour SO₂ AAAQS.

5.7.5. Sulfur Compound Emissions

SO₂ emissions are directly related to the sulfur content of the fuel. AGDC assumed their diesel-fired EUs use fuel with a sulfur content of 15 parts per million by weight (ppmw). They assumed their gas-fired EUs use treated gas with a total sulfur content of 96 parts per million by volume (ppmv). The Department is imposing these assumptions as permit conditions to protect the SO₂ AAAQS/increments.

³² The Department conducted a 24-hour PM-2.5 analysis of just the GTP flaring events to determine the range and magnitude of the maximum impact. The Department initially used the cumulative impact receptor grid described in Section 5.14 of this report, but the maximum impact occurred at the outer range of that receptor grid. The Department therefore extended the grid in the predominate downwind direction in order to find the true range of the maximum impact.

³³ EPA Memorandum from Tyler Fox to Regional Air Division Directors, *Additional Clarification Regarding Application of Appendix W Modeling Guidance for the 1-hour NO₂ National Ambient Air Quality Standard*; March 1, 2011.

5.7.6. Stack Heights

Most of the GTP exhaust stacks are substantially taller than what is common for a North Slope stationary source. The heights used in the modeling analysis comply with the stack height requirements listed in 40 CFR 52.21(h) and 18 AAC 50.045(e) – (f), but they are nevertheless noteworthy. For example, AGDC assumed the turbine stacks are 73 m tall, which is twice the height of the CCP/CGF turbine stacks. The height is also twice the height of the host buildings, which is likely intentional for purposes of minimizing downwash (see the related discussion in Section 5.11 of this report).

AGDC assumed the building heater stacks are nearly 71 m tall, and that the black start generator stack is 35 m tall. These are unusually tall heights for North Slope EUs, especially considering that the EUs are not in or adjacent to a building. The camp heater stacks are also taller than expected considering that they too do not have a host building.

The physical height of the flare stacks will be 67.056 m, which is taller than the typical height of a North Slope flare. However, AGDC used 65 m as the physical height in their modeling analysis, per the Good Engineering Practice (GEP) requirement in 40 CFR 52.21(h)(1)(i) and 18 AAC 50.045(f)(1).

The Department is imposing the assumed stack heights for the EUs described above as a minimum height requirement to protect the AAAQS and increments. The modeled stack heights are reiterated below in Table 5. The assumed stack heights for the remaining EUs are either within expectations, or they have designs that would maximize downwash. The Department is imposing the GEP height for the flares rather than the actual physical height, since GEP establishes the upper bound of what may be used in the ambient demonstration.

Table 5. Minimum Stack Height Requirements

EU	Model ID	Description	Min. Stack Height (m)
1 - 6	1A – 3B	Treated Gas Compressors	73.15
7 - 12	4A – 6B	Byproduct (CO ₂) Compressors	73.15
25 - 30	7A_1A – 7A_3B	Combustion Turbine Generators	73.15
31 - 33	14_1 – 14_3	Building Heat Medium Heaters	70.71
36 - 38	CAMPHT1 – CAMPHT3	Operations Camp Heaters	9.75
39	9_1	Black Start Generator	35.05
45 - 52	10E – 13W	Flares: Hydrocarbon and Byproduct (CO ₂)	65.00

Table Note: For EUs 1 – 12, the stack height requirement applies to both the WHRU bypass stack and the WHRU stack (i.e., EUs 13 – 24).

5.7.7. Horizontal/Capped Stacks

Capped stacks or horizontal releases generally lead to higher impacts in the immediate near-field than what would occur from uncapped, vertical releases. The presence of non-vertical stacks or stacks with rain caps therefore requires special handling in an AERMOD analysis (see the related discussion in Section 5.8.2 of this report).

AGDC characterized all of the GTP EUs as having uncapped, vertical releases. This is a typical stack design for combustion turbines. However, heaters can have rain caps and reciprocating engines can have horizontal releases. Since the impacts from horizontal or capped stacks are typically greater than the impacts from stacks with vertical, uncapped discharges, the Department is imposing AGDC's vertical, uncapped assumption for the heaters and reciprocating engines as an ambient air condition.

5.8. Off-Site Emissions and Stack Parameters

AGDC used the current CCP/CGF operating permits and past modeling analyses to develop the off-site emission rates and stack parameters for the cumulative impact analyses. They used the potential to emit (PTE) emission rates, rather than the actual emission rates allowed under the Guideline, in the annual assessments.³⁴ The use of PTE rather than actual emissions makes the annual analyses conservative. The modeled short-term emission rates, along with the characterization of several horizontal stacks, warrants discussion.

5.8.1. CCP/CGF Short-Term Emission Rates

The gas-fired CCP/CGF EUs are authorized to continuously operate on a year-round bases. AGDC therefore characterized these EUs with unrestricted emissions in the ambient demonstrations with 1-hour, 3-hour, or 24-hour averaging periods. This approach is consistent with Table 8-2 of the 2005 Guideline.

In contrast to the gas-fired EUs, the diesel-fired EUs at CCP/CGF are intermittently operated emergency generators and fire water pumps with operating limits ranging from 200 to 295 hr/yr. The annual emission rates may therefore be used to characterize these EUs in the 1-hour NO₂ and 1-hour SO₂ AAAQS demonstrations per EPA guidance (see Section 5.7.4 of this report). AGDC appropriately used this approach in the 1-hour NO₂ and 1-hour SO₂ AAAQS demonstrations.

AGDC also used the annual emission rates for modeling the other short-term AAAQS/increments. The Department questions this approach. EPA's intermittent emissions guidance is limited to the 1-hour NO₂ and 1-hour SO₂ "probabilistic" ambient air quality standards. The Department is unaware of any EPA guidance which states that the annual emission rate may be used for the 24-hour PM-2.5 probabilistic ambient air quality standard, or the short-term "deterministic" AAAQS/increments.

³⁴ Appendix A of the GTP Modeling Report states AGDC used the actual emissions for the Class II increment analyses. However, the modeling files show that they actually used the PTE rates.

The Department likewise does not have a written policy for characterizing intermittently operated EUs within the off-site EU inventory. This lack of written policy made the Department's review challenging. The Department understands that AGDC did not want to use an overly conservative characterization of these highly restricted EUs. However, using the annual emissions for the 3-hour/24-hour AAAQS/increment demonstrations may understate what likely happens during those averaging periods. The 200 hr/yr limit equates to 33 min/day, and the 295 hr/yr limit equates to 49 min/day. The Department suspects that BPXA operates these EUs for longer periods than that during their periodic reliability checks.

The Department reviewed the Triennial Emission Inventory provided by AGDC for the nearest off-site facility (CGF). BPXA operated emergency EUs up to 61 hours in the reporting year. This averages to 5.1 hours per month, which could be conservatively rounded up to 6 hours per month. This means the reliability check would occur for up to 6 hours per day (hrs/day) if BPXA conducted monthly checks. The 6 hr/day assumption seems to provide a better approach for characterizing the intermittently operated off-site EUs in the 3-hour and 24-hour AAAQS/increment demonstrations than the 33 to 49 min/day assumption. The Department therefore reran the 3-hour and 24-hour AAAQS/increment demonstrations using the 6 hrs/day assumption.³⁵

The Department also made one other change to the off-site emission rates. AGDC used a total particulate matter (PM) emissions factor for most of the diesel-fired CCP/CGF EUs, rather than the substantially smaller PM-10 emissions factor. This approach seemed overly conservative, especially when used in conjunction with the 6 hr/day operating assumption. The Department therefore used the PM-10 emissions factor from Table 3.4-2 of EPA's *Compilation of Air Emissions Emission Factors* to recalculate the PM-10/PM-2.5 emission rates for all but one of the CCP/CGF reciprocating engines rated at greater than 600 horsepower. The exception regards one of the three GM Emergency Generators at CGF (EU 15), which has a short-term PM emissions rate that was determined through a Best Available Control Technology (BACT) analysis. AGDC appropriately used the BACT emissions rate to calculate the PM-10/PM-2.5 emissions for this EU. The Department's modeling results are provided in Section 6 of this report.

5.8.2. Characterization of Off-site Horizontal Stacks

As noted in Section 5.7.7 (**Horizontal/Capped Stacks**) of this report, the presence of non-vertical stacks or stacks with rain caps requires special handling in an AERMOD analysis. While all of the GTP EUs have uncapped, vertical releases, two of the off-site EUs have horizontal releases.³⁶

³⁵ The Department did not need to rerun the 24-hour PM-2.5 increment analysis since the CCP/CGF EUs do not consume PM-2.5 increment.

³⁶ The two off-site EUs with horizontal stacks are the Solar Centaur Standby Turbine at CCP (Model ID 816) and the fire water pump at CGF (Model ID 1122).

EPA describes the proper approach for characterizing capped and horizontal stacks in their *AERMOD Implementation Guide*.³⁷ EPA has also developed an option in AERMOD that will revise the release parameters according to their guidance for any stack identified as horizontal (using the POINTHOR keyword) or capped (using the POINTCAP keyword).

AGDC used the POINTHOR option to characterize the two off-site EUs with horizontal stacks. The option is an approved modeling technique under the 2016 version of the Guideline, but it is considered as an alternative technique under the 2005 version that the Department used for its review (see Section 2.4.3 of this report). AGDC's use of the POINTHOR option therefore requires case-specific approval under 18 AAC 50.215(c).

5.8.2.1 Technical Justification

18 AAC 50.215(c)(1) requires a demonstration that the alternative approach is more appropriate than the preferred air quality model. EPA provided the required demonstration when they promulgated the 2016 version of the Guideline. A summary of this demonstration may be found in the January 17, 2017 Federal Register notice of the 2016 Guideline (see [82 FR 5182](#)).

5.8.2.2 EPA and Department Approval

18 AAC 50.215(c)(2) requires approval of an alternative modeling technique from the EPA Regional Administrator and the Commissioner's designee. The Commissioner delegated the responsibility for approving alternative modeling methods to the Air Permits Program (APP) Manager on June 3, 2008.

AGDC noted their desire to use the POINTHOR option for the cumulative impact analysis in their PSD modeling protocol. The APP Manager approved AGDC's request on October 24, 2017. R10 approved the request on December 12, 2017.

5.8.2.3 Public Comment

In addition to complying with the Department's modeling requirements in 18 AAC 50.215(c), PSD applicants must also comply with the PSD modeling requirements in 40 CFR 52.21(l). 40 CFR 52.21(l)(2) says the use of a non-Guideline modeling technique, "*must be subject to notice and opportunity for public comment.*" Therefore, the Department is soliciting public comment regarding AGDC's use of the POINTHOR algorithm in the public notice of the preliminary construction permit.

5.9. Shoreline Fumigation Analysis

Section 7.2.8 of the Guideline describes various complex wind scenarios that may need to be addressed in an air quality modeling analysis. One of those scenarios, shoreline fumigation, warranted assessment in the GTP analysis.

³⁷ [AERMOD Implementation Guide](#) (EPA-454/B-18-003); April 2018.

Fumigation “occurs when a plume that was originally emitted into a stable layer is mixed rapidly to ground-level when unstable air below the plume reaches plume level.”³⁸ The phenomena can cause high ground-level concentrations. In coastal areas, fumigation can occur when a plume that is emitted from a tall stack interacts with the “thermal internal boundary layer” (TIBL) at some downwind distance. The phenomena is illustrated in Figure 5-7 of Attachment 5 of the permit application.

GTP will be located approximately 2 km from the Beaufort Sea coast-line, and the tallest exhaust stacks will be 73 m high. This proximity and stack height is what warrants the shoreline fumigation analysis. AGDC correctly noted that AERMOD does not have the ability to evaluate fumigation impacts. However, AERSCREEN will calculate shoreline fumigation for EUs located within 3 km of a coastline.

AGDC ran AERSCREEN for the EUs with the tallest stacks – i.e., the turbines. AERSCREEN found that the plume heights are below the TIBL height. Therefore, shoreline fumigation would not occur from the turbine emissions. AGDC concluded that shoreline fumigation likewise would not occur from the other EUs.

5.10. Pollutant Specific Considerations

The following pollutants warrant additional discussion.

5.10.1. Ambient NO₂ Modeling

The NO_x emissions from combustion sources are partly nitric oxide (NO) and partly NO₂. After the combustion gas exits the stack, additional NO₂ can be created due to atmospheric reactions. Section 5.2.4 of the Guideline describes a tiered approach for estimating the resulting annual average NO₂ concentration, ranging from the simplest but very conservative assumption that 100 percent of the NO is converted to NO₂, to other more complex methods. These approaches are also generally applicable in modeling the 1-hour NO₂ impacts.

AGDC used PVMRM³⁹ to estimate their ambient NO₂ concentrations. PVMRM is an EPA-approved modeling technique under the 2016 version of the Guideline, but it is considered as an alternative technique under the 2005 version (see Section 2.4.3 of this report). PVMRM therefore requires case-specific approval under 18 AAC 50.215(c). Applicants must also provide the assumed NO₂-to-NO_x in-stack ratio (ISR) for each NO_x-emitting EU, along with the ambient O₃ data used by PVMRM to estimate the NO to NO₂ conversion. Each of these aspects is further discussed below.

³⁸ Section 4.5.3 of EPA's *Screening Procedures for Estimating the Air Quality Impact of Stationary Sources, Revised* (EPA-454/R-92-019)

³⁹ The PVMRM algorithm in AERMOD 16216r and AERMOD 18081 was designated as “PVMRM2” in AERMOD 15181.

5.10.1.1 Procedural Requirements

As previously discussed in Section 5.8.2.1 of this report, 18 AAC 50.215(c)(1) requires a demonstration that the alternative approach is more appropriate than the preferred air quality model. EPA provided the required demonstration when they promulgated the 2016 version of the Guideline (see [82 FR 5182](#)).

18 AAC 50.215(c)(2) requires R10 and Department approval of the alternative modeling technique. The APP Manager approved AGDC's request to use PVMRM on October 24, 2017, and R10 approved the request on December 12, 2017. The Department is soliciting public comment regarding the use of PVMRM in the public notice for the preliminary permit, as required under 40 CFR 52.21(l)(2).

5.10.1.2 NO₂-to-NO_x In-Stack Ratio

The assumed ISR is a variable that must be set for each NO_x-emitting EU. Source-specific data should be used to define this ratio when available. When source-specific data is not available, an ISR of 0.5 may be used per EPA guidance.³³ EPA and the Department have data that applicants frequently use for finding representative ISRs. EPA's data may be found on their *Support Center of Regulatory Atmospheric Modeling* (SCRAM) web-site⁴⁰ and the Department's data may be found on its modeling web-site.⁴¹ AGDC used the ISRs shown in Table 6.

Table 6. ISRs Used in the GTP Modeling Analysis

Stationary Source	EU Description/Category	ISR
GTP	Treated Gas Compressor Turbines	0.4
	Byproduct (CO ₂) Compressor Turbines	0.2
	Power Generation Turbines	0.4
	Gas-fired Heaters	0.5
	Diesel-fired Reciprocating Engines	0.5
	Flares	0.5
CCP/CGF	Uncontrolled Turbines	0.1
	Turbines w/LHE Liners ^a	0.4
	Gas-fired Heaters	0.1
	Diesel-fired Reciprocating Engines	0.1
	Flares	0.5

Table Note a: LHE = Lean Head End. LHE Combustion Liners are designed to reduce NO_x formation during the combustion process.

⁴⁰ The ISR database on SCRAM may be found at: https://www3.epa.gov/ttn/scram/no2_isr_database.htm.

⁴¹ The Department's ISR database may be found at: <http://dec.alaska.gov/air/air-permit/dispersion-modeling/>.

AGDC did not include an ISR for one of the CGF emergency generators (EU 15; Model ID 1121) in the annual NO₂ increment analysis. It appears to be an inadvertent oversight since they did include the ISR for this EU in the 1-hour and annual NO₂ AAAQS demonstrations. ADEC corrected the oversight and reran the annual NO₂ increment analysis.⁴² The maximum annual NO₂ impact increased from 6.6 µg/m³ to 11.3 µg/m³.⁴³ The Department is reporting the revised value, as subsequently modified by the Department's Buyback Gas Bath Heater sensitivity analyses, in Section 6 of this report.

The 0.5 value used for GTP diesel-fired reciprocating engines is conservative since most North Slope applicants justify and use values ranging from 0.1 to 0.2. The 0.1 value used for the CCP/CGF engines is a commonly used value for existing diesel-fired engines based on the source test data in the Department and EPA databases.

The 0.5 values used for the GTP heaters is likewise more conservative than what most North Slope applicants use. The 0.1 value used for the CCP/CGF heaters is consistent with commonly used values.

The 0.4 ISR for the Treated Gas Compression turbines and the Power Generation turbines is an acceptable value for gas-fired turbines with dry low NO_x combustors. AGDC's 0.2 ISR for the Byproduct (CO₂) Compression turbines on the other hand lacked justification. The Department therefore conducted a sensitivity analysis using a 0.5 ISR for *all* GTP turbines. The Department reran the 1-hour NO₂ cumulative impact analysis, as well as the annual NO₂ increment analysis for the worst-case year (2010). The h8h 1-hour NO₂ impact increased by only 0.0002 percent (0.00031 µg/m³), which is inconsequential. The maximum annual NO₂ increment impact increased by only 0.09 percent (0.00983 µg/m³), which is also inconsequential.⁴⁴ The Department therefore accepts the ISRs for the GTP turbines since the maximum impacts are insensitive to this parameter. The ISRs for the CCP/CGF turbines are based on source tests of representative EUs at CCP/CGF.

5.10.1.3 Ambient O₃ Data

PVMMR requires ambient O₃ data to determine how much of the NO is converted to NO₂. AGDC used an hourly O₃ dataset that they compiled from five years of ambient data measured by BPXA at their A-Pad monitoring station. BPXA

⁴² The Department made the ISR correction prior to conducting the Buyback Heater sensitivity analysis discussed in Section 5.7.2 of this report. However, the Department kept the ISR correction in all subsequent NO₂ sensitivity analyses.

⁴³ AERMOD 15181 inappropriately assigned an ISR of -9 for the missing EU, which led to an underestimated annual NO₂ impact. ISRs can only range from 0 to 1, so it's unclear why AERMOD assigned a negative value. EPA corrected this error in AERMOD 16216r. Missing ISRs now lead to a fatal error in the model execution.

⁴⁴ The Department used AERMOD/AERMET 18081 for the ISR sensitivity analysis. Therefore, some of the reported variation may be due to the change in model version rather than the change in ISR value. Either way, the variation is inconsequential.

collected the data from 2009 through 2013. The Department found the O₃ data to be PSD-quality in its review of BPXA's annual data reports.

AGDC developed a composite O₃ dataset for the NO₂ modeling analysis rather than using concurrent O₃ data. They did so by taking the maximum O₃ concentration for a given day and hour from the five years of data. They used the seasonal maximum value for the given hour if any year had a missing or invalid concentration for that Julian day and hour.

AGDC's use and processing of the hourly A-Pad O₃ data is reasonable and appropriate. The A-Pad data generally represents the ambient O₃ concentration that would be present at GTP. However, the Department is aware of periodic NO_x scavenging events at A-Pad. This can lead to underestimated NO₂ concentrations in a modeling analysis, since small O₃ values can lead to less NO to NO₂ conversion than large O₃ values. Conservatively combining multiple years of O₃ measurements into a composite dataset counters the effect of periodic scavenging and helps to ensure that the resulting NO₂ concentrations are not underestimated. It's an approach that has been commonly used by North Slope applicants for the past decade. The Department continues to accept this approach, along with the composite dataset used by AGDC for the GTP modeling analysis.

5.10.2. PM-2.5

PM-2.5 is either directly emitted from a source or formed through chemical reactions in the atmosphere (secondary formation) from other pollutants (NO_x and SO₂).⁴⁵ AERMOD is an acceptable model for performing near-field analyses of the direct emissions, but EPA has not developed a near-field model that includes the necessary chemistry algorithms for estimating the secondary impacts. They instead issued guidance as to how secondary formation could be accounted for under the 2005 version of the Guideline.⁴⁶

EPA noted that the maximum direct impacts and the maximum secondary impacts from a stationary source "*...are not likely well-correlated in time or space*", i.e., they will likely occur in different locations and at different times. This difference occurs because secondary PM-2.5 formation is a complex photochemical reaction that requires a mix of precursor pollutants in sufficient quantities for significant formation to occur. As such, it is highly unlikely that there is sufficient time for the reaction to substantively occur within the immediate near-field, which is where the maximum direct impacts from the GTP EUs occur.

EPA further stated that representative ambient monitoring data could be used in the ambient standard demonstration to address the secondary formation that occurs from existing sources. AGDC met this objective by using the CCP PM-2.5 data as the

⁴⁵ The NO_x and SO₂ emissions are also referred to as "precursor emissions" in a PM-2.5 assessment.

⁴⁶ *Guidance for PM_{2.5} Permit Modeling* (EPA-454/B-14-001); May 2014.

background concentration in their 24-hour PM-2.5 AAAQS analysis (see Section 5.15 of this report).

AGDC noted in Attachment 3 of their permit application that the ambient 24-hour and annual PM-2.5 concentrations measured at a number of North Slope monitoring stations are well below the AAAQS. They further observed that the values *“are all well below the standards even with the presence of large regional sources of direct and precursor emissions.”* They provided the regional NOx emissions, as reported in the 2011 National Emissions Inventory (NEI), to support this observation. Their presentation is further evidence that the precursor emissions should not cause or contribute to a violation of the PM-2.5 AAAQS.

The portion of the existing secondary PM-2.5 concentration that is increment consuming is probably negligible. The major source baseline date for PM-2.5 is October 20, 2010. The minor source baseline date within the Northern Alaska Intrastate Air Quality Control Region is November 2, 2012. Most of the regional precursor emissions were authorized long before these dates. Therefore, the change in regional precursor emissions subsequent to these dates is likely inconsequential with respect to secondary formation.

5.11. Downwash

Downwash refers to the situation where local structures influence the plume from an exhaust stack. Downwash can occur when a stack height is less than GEP, which is defined in 18 AAC 50.990(42). It is a consideration when there are receptors relatively near the applicant's structures and exhaust stacks.

EPA developed the “Building Profile Input Program – PRIME” (BPIPPRM) program to determine which stacks could be influenced by nearby structures and to generate the cross-sectional profiles needed by AERMOD to determine the resulting downwash. AGDC used the current version of BPIPPRM, version 04274, to determine the building profiles needed by AERMOD for the GTP EUs.

AGDC also used BPIPPRM to determine most of the building profiles for the off-site EUs. However, as discussed in Section 2.4.2 (**Modeling Protocol Submittal**) of this report, AGDC used the results from their EBD wind tunnel study for select wind directions for several of the EUs. The wind directions and EUs are listed in Table 5 of Attachment 3 of the protocol (*Study Report Equivalent Building Determination for the Central Gas Facility and the Central Compression Plant at Prudhoe Bay*). The Department approved the use of the EBD parameters in its December 13, 2017 approval of the PSD modeling protocol.

The Department used a proprietary 3-D visualization program to review AGDC's characterization of the exhaust stacks and structures. The characterization of the GTP EUs match the main pad and camp pad layouts shown in Figures 5-5 and 5-6, respectively, of Attachment 5 of the permit application. AGDC's characterization of the CCP/CGF EUs and building configurations match the facility layouts on file from previous BPXA submittals,

along with the oblique photographs provided by AGDC in Figures 11 and 12 of Attachment 3 of the PSD modeling protocol. BPIPPRM indicated that the GTP exhaust stacks are within the GEP stack height requirements.

5.12. Ambient Air Boundary

The AAAQS and increments only apply in *ambient air* locations, which has been defined by EPA as, “*that portion of the atmosphere, external to buildings, to which the general public has access.*”⁴⁷ Applicants may therefore exclude areas that they own or lease from their ambient demonstration if public access is “*precluded by a fence or other physical barrier.*”⁴⁸

AGDC used the edge of the main pad, and the edge of the camp pad, as their ambient air boundaries. Using the pad edge is a standard and acceptable approach for modeling North Slope stationary sources.

5.13. Worker Housing

AGDC will need to house their workers on-site due to the project's remote location. Worker housing areas must be treated as ambient air, except under the conditions described in the Department's *Ambient Air Quality Issues at Worker Housing* policy.⁴⁹ The conditions are:

- 1) the worker housing area is located within a secure or remote site;
- 2) the worker housing area is for official business/worker use only; and
- 3) the operator has a written policy stating that the on-site workers are on 24-hour call.

The GTP worker housing area meets the above exception. AGDC therefore did not treat the worker housing area as ambient air.

5.14. Receptor Grid

A dispersion model will calculate the concentration of the modeled pollutant at locations defined by the user. These locations are called receptors. Designated patterns of receptors are called receptor grids.

AGDC described their receptor grid in Section 5.4 of Attachment 5 of their permit application. In summary, AGDC used a receptor grid of decreasing resolution with distance from the ambient boundary for their project impact analysis. The receptor resolutions are:

- Every 25 m along the ambient boundary (pad edge);
- 25 m from the ambient boundary to a distance of at least 100 m from pad edge;
- 50 m from 100 m to 300 m (or more) from pad edge;
- 100 m from 300 m to 1 km (or more) from pad edge; and

⁴⁷ The term “ambient air” is defined in 40 CFR 50.1. The Alaska Legislature has also adopted the definition by reference in AS 46.14.90(2).

⁴⁸ EPA has written a number of guidance documents regarding ambient air issues which may be found in their Modeling Clearinghouse Information Storage and Retrieval System (<http://cfpub.epa.gov/oarweb/MCHISRS/>). The documents routinely use the phrase “fence or other physical barrier” when discussing an acceptable means for precluding public access at onshore locations. The phrase originated in a December 19, 1980 letter from EPA Administrator Douglas Costle to Senator Jennings Randolph.

⁴⁹ Policy and Procedure 04.02.108: *Ambient Air Quality Issues at Worker Housing*; October 8, 2004.

- On the eastern side (near CCP and CGF), 250 m from 1 km to 1.5 km.

AGDC expanded the receptor grid and added increased resolution around the CCP and CGF pads in the cumulative impact analyses. However, they did not include receptors within the CCP and CGF ambient air boundaries since the GTP impacts were already assessed at those locations. This approach is consistent with EPA and Department guidance.^{50, 51} For the cumulative impact analyses, the receptor resolutions are:

- Every 25 m along the ambient boundary (pad edge) for each stationary source (i.e., along the GTP boundary and along the CCP/CGF boundary);
- 25 m from the ambient boundary to a distance of at least 100 m from each stationary source;
- 50 m from 100 m to 300 m (or more) from pad edge;
- 100 m from 300 m to 1 km (or more) from pad edge;
- 250 m from 1 km to 5 km; and
- 500 m from 5 km to 10 km.

AGDC's grid has sufficient resolution and coverage to determine the maximum impacts. The maximum impacts generally occur near the GTP pad, or near the CCP/CGF pads.

5.15. Off-Site Impacts

The air quality impact from natural and regional sources, along with long-range transport from far away sources, must be accounted for in a cumulative AAAQS demonstration. The increment consuming impact from nearby off-site anthropogenic sources must likewise be accounted for in a cumulative increment demonstration. The approach for incorporating these impacts must be evaluated on a case-specific basis for each type of assessment and for each pollutant.

The two nearest off-site facilities, CCP and CGF, are close enough to have significant concentration gradients in the vicinity of GTP. The more distant facilities would not. AGDC therefore included CCP/CGF in the cumulative AAAQS, and cumulative increment, modeling analyses. They used ambient data collected within PBU to represent the impacts from all other sources in their cumulative AAAQS demonstrations.

AGDC used the NO₂ and SO₂ data collected by BPXA at their A-Pad monitoring station to represent the background NO₂ and SO₂ concentrations. A-Pad is located approximately 11.5 km southwest of GTP. BPXA established the station in 1986 in order to measure the general background concentrations within PBU. The data is frequently used in AAAQS analyses of stationary sources located in the greater Prudhoe Bay area.

⁵⁰ EPA memorandum from Robert D. Bauman to Gerald Fontenot; *Ambient Air*; October 17, 1989.

⁵¹ Letter from Alan Schuler (Department) to William Steigers (Steigers Corporation); *Request for ADEC Approval of Multi-Source Receptor Grid Modeling Protocol*; April 3, 1996. The letter is posted on the Department's website at: <http://dec.alaska.gov/air/air-permit/dispersion-modeling/>.

AGDC used the A-Pad data collected from 2010 through 2014 for their SO₂ and annual NO₂ AAAQS analyses. They used 2009 through 2013 data for the 1-hour NO₂ AAAQS analysis for the reason described later in this subsection. In both cases, the data were previously reviewed by the Department and approved as PSD-quality. The resulting maximum measured concentrations are also publicly available through the *Industrial Data Summary* that the Department posts at <http://dec.alaska.gov/air/air-permit>. The values selected by AGDC are listed in Table 3-1 of the GTP Modeling Report, as well as Table 11 of this report. AGDC selected generally reasonable values for the background concentrations.⁵²

BPXA does not measure PM at A-Pad. However, they do measure both PM-10 and PM-2.5 at their CCP station. AGDC used CCP monitoring data to represent the background PM-10 and PM-2.5 concentrations. The use of CCP data provides for a conservative AAAQS analysis since the CCP/CGF impacts are also accounted for through modeling.

AGDC stated that they used the 2014 PM concentrations. However, the selected values do not match the values posted in the Department's *Industrial Data Summary*. The Department is therefore using the subsequently measured values listed in Table 7 below in Section 6 of this report.

Table 7. PM Background Concentrations

Pollutant	Averaging Period	Background Concentration (µg/m³)	Comments
PM-10	24-hr	60	Largest 2 nd high concentration measured in calendar years 2013 - 2016
PM-2.5	24-hr	12	Three-year average of 98 th percentile for calendar years 2014 - 2016

There are various ways to add a background concentration to the modeled concentration in an AERMOD analysis. The long-standing practice is to manually add the two numbers. However, the most recent versions of AERMOD include an option where the background concentration can be automatically added to the modeled concentration. This option also allows applicants to include temporarily-varying background concentrations in their ambient demonstrations. AGDC used the manual approach in their annual NO₂, 24-hr PM-10, 24-hr PM-2.5, 1-hr SO₂, 3-hr SO₂, and 24-hr SO₂ AAAQS demonstrations. They used the more detailed, temporarily-varying option for their 1-hour NO₂ AAAQS demonstration.

AGDC's approach for varying the 1-hour NO₂ background concentration is described in Section 3.2 of the GTP Modeling Report. Their approach is both reasonable and consistent with EPA guidance.³³ In summary, AGDC noted that the NO₂ concentrations measured at A-Pad are strongly dependent on wind speed. They therefore sorted the measured 1-hour concentrations by the wind speed, using the default wind speed categories listed in the

⁵² Table 3-1 of the GTP Modeling Report states the maximum annual NO₂ concentration measured at A-Pad in calendar years 2010 through 2014 is 6.0 µg/m³. The actual value reported in the Department's *Industrial Data Summary* is 6.2 µg/m³. The Department is reporting the 6.2 µg/m³ value in the results section of this report.

AERMOD User's Guide. They then selected the 98th percentile of the hourly NO₂ concentrations as the background concentration for the given wind speed category. They used concurrent 2009 – 2013 NO₂ and meteorological data, which provided a robust analysis. The resulting background concentrations are reiterated below in Table 8 in both parts per billion by volume (ppbv) and µg/m³. AGDC's approach for temporarily varying the 1-hour NO₂ background concentration is identical to the approach used by the *Workgroup for Global Air Permit Policy Development for Temporary Oil and Gas Drill Rigs* (Workgroup) and approved by the Department for use in the Minor General Permit 2 ambient demonstration.⁵³ The Department continues to approve the approach, along with the resulting background concentrations.

Table 8. 1-hour NO₂ Background Concentrations by Wind Speed

Wind Speed (Ws) Category (m/s)	NO ₂ Concentration	
	ppbv	µg/m ³
Ws < 1.54	25.9	48.8
1.54 ≤ Ws < 3.09	22.3	41.9
3.09 ≤ Ws < 5.14	15.9	29.9
5.14 ≤ Ws < 8.23	10.3	19.4
8.23 ≤ Ws < 10.8	10.7	20.1
Ws ≥ 10.8	13.4	25.2

5.16. Modeled Design Concentrations

EPA allows applicants to use modeled concentrations that are consistent with the form of the given standard or increment as their design concentrations. The highest concentrations must generally be used when comparing the modeled impacts to the SILs. However, the multi-year average of the highest concentrations may be used when comparing the 1-hour NO₂, 1-hour SO₂, 24-hour PM-2.5, and annual PM-2.5 impacts to the SILs – for purposes of demonstrating compliance with the AAAQS.⁵⁴ AGDC used the modeled concentrations that are consistent with the above description. The design concentrations used in AGDC's cumulative modeling analyses to demonstrate compliance with the AAAQS and Class II increments are summarized in Table 9.

⁵³ The 1-hour NO₂ background concentrations developed by the Workgroup is described in Appendix D of the October 17, 2017 report, *Ambient Demonstration for the North Slope Portable Oil and Gas Operation Simulation*. The report may be found on the Department's web-site at: <http://dec.alaska.gov/media/9166/north-slope-pogo-simulation-modeling-report-final-101717.pdf>.

⁵⁴ The maximum value from any year must be used for the other pollutants and averaging periods, and when comparing the 24-hour PM-2.5 and annual PM-2.5 impacts to the SILs for purposes of demonstrating compliance with the Class II increments.

**Table 9. AGDC's Approach for Determining
The Modeled Design Concentrations**

Pollutant	Avg. Period	AAAS	Class II Increment
NO ₂	1-hour	h8h	--
	Annual	HY	HY
PM-10	24-hour	h6h	h2h
	Annual	--	HY
PM-2.5	24-hour	h8h	h2h
	Annual	MA	HY
SO ₂	1-hour	h4h	--
	3-hour	h2h	h2h
	24-hour	h2h	h2h
	Annual	HY	HY
CO	1-hour	h2h	--
	8-hour	h2h	--

Table Notes:

h2h = the maximum high second-high concentration from any year.

h4h = the multi-year average of the high fourth-high daily maximum 1-hour concentrations.

h6h = the high sixth-high 24-hour concentration over five years.

h8h = high eighth-high. For purposes of 1-hour NO₂, the h8h is the five-year average of the high, eighth-high of the daily maximum 1-hour NO₂ concentrations. For purposes of 24-hour PM-2.5, the h8h is the five-year average of the high, eighth-high of the 24-hour PM-2.5 concentrations.

HY = highest annual average from any year.

MA = highest multi-year average of the annual concentrations at a given receptor.

-- = there is no AAAS/increment (as applicable) for this pollutant/averaging period.

6. MODELING RESULTS AND DISCUSSION

The maximum project impacts are presented in Table 10. The SIL for each pollutant and averaging period is also presented for comparison. The maximum impacts exceed the applicable SIL for most pollutants and averaging periods. The annual SO₂, annual PM-2.5, annual PM-10, 1-hour CO, and 8-hour CO impacts are the exception. The Department further notes that the existing margin of compliance with the AAAS exceeds the SIL for each of those pollutants.⁵⁵ Therefore, the GTP emissions will not cause or contribute to a violation of the annual SO₂, annual PM-2.5, 1-hour CO, and 8-hour CO AAAS; or the annual SO₂, annual PM-2.5, and annual PM-10 Class II increments.

⁵⁵ The existing margin of compliance for a given AAAS can be derived by subtracting the ambient concentration shown in Table 1 from the numerical value for the AAAS. The existing margin of compliance is greater than the SIL for all pollutants and averaging periods modeled by AGDC.

Table 10. Maximum Project Impacts Compared to the SILs

Pollutant	Avg. Period	Max. Modeled Conc. ($\mu\text{g}/\text{m}^3$)	SIL ($\mu\text{g}/\text{m}^3$)
NO ₂	1-hour	74.7	8
	Annual	2.6	1
SO ₂	1-hour	27.9	8
	3-hour	49.0	25
	24-hour	20.6	5
	Annual	0.5	1
PM-2.5 (multi-year avg.)	24-hour	3.9	1.2
	Annual	0.22	0.3
PM-2.5 (max. impact from any year)	24-hour	8.9	1.2
	Annual	0.26	0.3
PM-10	24-hour	8.8	5
	Annual	0.26	1
CO	1-hour	448	2,000
	8-hour	180	500

Table Note: The multi-year average of the maximum PM-2.5 impacts may be compared to the PM-2.5 SILs for purposes of demonstrating compliance with the PM-2.5 AAAQS. However, the maximum PM-2.5 impact from any year must be compared to the PM-2.5 SILs for purposes of demonstrating compliance with the PM-2.5 increments. (See Section 5.16 of this report.)

The results from the cumulative AAAQS analyses, as revised by the Department, are presented in Table 11. The background concentrations, total impact, and AAAQS are also shown. All of the total impacts are less than the AAAQS.

Table 11. Maximum Impacts Compared to the AAAQS

Pollutant	Avg Period	Modeled Design Conc. ($\mu\text{g}/\text{m}^3$)	Bkgd Conc. ($\mu\text{g}/\text{m}^3$)	Total Impact ($\mu\text{g}/\text{m}^3$)	AAAQS ($\mu\text{g}/\text{m}^3$)
NO ₂	1-hour	158.0	<i>See Note</i>	158.0	188
	Annual	14.0	6.2	20.2	100
PM-10	24-hour	21.4	60	81.4	150
PM-2.5	24-hour	14.5	12	26.5	35
SO ₂	1-hour	39.2	9.4	48.6	196
	3-hour	226.9	21.0	247.9	1,300
	24-hour	32.1	8.1	40.2	365

Table Note: The 1-hour NO₂ background concentration is included in the modeled concentration. See Section 5.15 of this report.

The results from the cumulative increment analysis, as revised by the Department, are presented in Table 12. The modeled design concentrations are less than the Class II increment for all pollutants and averaging periods.

Table 12. Maximum Modeled Impacts Compared to the Class II Increments

Pollutant	Avg. Period	Modeled Design Conc. ($\mu\text{g}/\text{m}^3$)	Class II Increment ($\mu\text{g}/\text{m}^3$)
NO ₂	Annual	11.4	25
PM-10	24-hour	17.0	30
PM-2.5	24-hour	4.8	9
SO ₂	3-hour	153.8	512
	24-hour	31.2	91

7. OZONE IMPACTS

As discussed in Section 1 (**Introduction**) of this report, VOC is a triggered PSD-pollutant for the GTP project. There is no VOC AAAQS, but VOC and NO_x emissions can form O₃, which does have an AAAQS. AGDC was therefore required to demonstrate compliance with the O₃ AAAQS per 40 CFR 52.21(k).

O₃ is not usually emitted directly into the air. It is instead created in the atmosphere through chemical reactions between NO_x and VOC in the presence of sunlight. It is inherently a regional pollutant, the result of chemical reactions between emissions from many NO_x and VOC sources over a period of hours or days, and over a large area.

The 2005 version of the Guideline does not list a recommended model for assessing the O₃ impact from an individual stationary source. Qualitative approaches are instead generally used to meet the 40 CFR 52.21(k) ambient demonstration requirement.

AGDC provided a background discussion regarding O₃ formation in Section 8 of the GTP Modeling Report. The discussion includes a trajectory analysis for days with “elevated” ozone concentrations using the HYSPLIT model. They also discussed several lower-48 Photochemical Grid Model (PGM) ozone analyses, and what the findings could mean with respect to the GTP project.

The Department did not take the time to review AGDC's trajectory analysis or PGM discussion since the following aspect of their O₃ demonstration is adequately convincing. AGDC provided a table in Attachment 3 of their permit application that summarized the 8-hour O₃ concentrations measured at various North Slope locations. They obtained the concentrations from the *Industrial Data Summary* that the Department posted on its web-site (see <http://dec.alaska.gov/air/air->

[permit](#)). AGDC then noted that the ambient O₃ concentrations are well below the AAAQS, even with the presence of large regional sources of precursor emissions. The maximum measured fourth high 8-hour concentration listed by AGDC is 0.054 ppm, which is less than the 0.070 ppm AAAQS.⁵⁶ AGDC summarized the regional NO_x and VOC emissions, as reported in the 2011 NEI, to support their observation regarding the existing precursor emissions. AGDC estimated the regional emissions by using only the emissions from point sources located between the Arctic National Wildlife Refuge (ANWR) and the National Petroleum Reserve – Alaska.⁵⁷ The total regional emissions summarized by AGDC are substantially larger than the proposed GTP emissions, as shown below in Table 13. Therefore, the project should not cause or contribute to a violation of the 8-hour O₃ AAAQS given the current margin of compliance.

Table 13. GTP and 2011 NEI Emissions Comparison

Source	O ₃ Precursor Emissions (tpy)		
	NO _x	VOC	Total
GTP PTE (without maximum flaring)	2,231	304	2,535
Regional Emissions (per 2011 NEI)	37,399	125,535	162,934

Table Note: The Department was still evaluating AGDC’s BACT analyses when it developed Table 13. The PTE therefore reflects the PTE provided by AGDC, which is the upper bound of what the final PTE may be for GTP.

8. ADDITIONAL IMPACT ANALYSES

PSD applicants must assess the impact from the proposed project and associated growth on visibility, soils, and vegetation, per 40 CFR 52.21(o) – *Additional Impact Analyses*. AGDC provided their additional impact analyses in Attachment 10 of their permit application. The Department’s findings regarding their analyses are reported below.

8.1. Associated Growth Analysis

40 CFR 52.21(o)(2) requires PSD applicants to “*provide an analysis of the air quality impact projected for the area as a result of general commercial, residential, industrial and other growth associated with the source or modification.*” AGDC does not expect industrial or commercial growth in the immediate vicinity of GTP, but they noted that some growth is possible in the Deadhorse area. With respect to employment, AGDC stated that they would be providing the infrastructure that would support the majority of growth in the worker population (see the related discussion in Section 5.13 of this report). AGDC noted that there could be some increase in worker population needed to support aviation and subcontractors within the Deadhorse area. However, they did not expect a significant net change from historical levels due to the recent decline in the worker population. AGDC concluded, “Any

⁵⁶ AGDC compared the maximum fourth-high concentration from any given year to the 8-hour O₃ AAAQS. This is a conservative approach since the *three-year* average of the annual fourth-highest daily maximum 8-hour O₃ concentration must exceed 0.070 ppm before there is an actual violation of the AAAQS – see 18 AAC 50.010(4).

⁵⁷ See Attachment 3 of AGDC’s permit application for additional details.

actual growth resulting in emissions increases would be minimal..." The Department accepts AGDC's assessment.⁵⁸

8.2. Visibility Impacts

PSD applicants must assess whether the emissions from their stationary source, including associated growth, will impair visibility. Visibility impairment means any humanly perceptible change in visibility, such as visual range, contrast, or coloration, from that which would have existed under natural conditions. Visibility impacts can occur as visible plumes, i.e., "plume blight," or in a general, area-wide reduction in visibility, also known as "regional haze". Alaska does not have standards for plume blight. For Class I areas, the Federal Land Manager provides the desired thresholds. There are no established thresholds for Class II areas. The typical tool for assessing plume blight is EPA's VISCREEN model.

The maximum range of VISCREEN is 50 km. When Class I areas lie beyond that range, as in the case at hand, the Department recommends that the applicant use the 50 km maximum range as the source to observer distance. This approach provides the upper bound of the potential plume blight impacts at more distance locations. This same distance (50 km) would also be used as the "nearest" source to boundary distance per page 24 of EPA's *Workbook for Plume Visual Impact Screening and Analysis (Revised)*.⁵⁹

Since there are no Class II visibility thresholds, VISCREEN compares the visibility impacts to the Class I thresholds. VISCREEN provides results for impacts located inside a Class I area and for impacts located outside a Class I area. The latter is used in situations where there is an "integral vista." In situations where there are no integral vistas, applicants only need to use the results for impacts located inside a Class I area. Alaska only has two integral vistas, both of which are associated with Denali National Park. Since the integral vistas are well beyond the 50 km range of VISCREEN, the Department informed AGDC that they only needed to report the "inside" results.

AGDC conducted two VISCREEN runs: one with the source to observer distance set at 50 km (as recommended by the Department); and the other (for informational purposes), with the source to observer distance at 93 km (the nearest distance to ANWR). They provided their findings in Attachment 10 of their permit application.

AGDC used the current version of VISCREEN, version 13190, to estimate their worst-case plume blight. They appropriately assumed an O₃ concentration of 40 ppbv and a "background visual range" of 258 km. AGDC used the "Level 1" approach of assuming a constant 1.0 m/s wind speed and extremely stable atmospheric conditions ("F" stability class). This approach showed potential plume blight at 50 km.

⁵⁸ AGDC did not include the Pipeline Stations and Liquefaction Plant in their Associated Growth Analyses since those stationary sources will not be located in the same area as GTP. As previously noted in Section 5.6.3 of this report, the ambient impacts associated with each of those stationary sources will be assessed, as warranted, under the permit requirements for that stationary source.

⁵⁹ *Workbook for Plume Visual Impact Screening and Analysis (Revised)*, (EPA-454/R-92-023); October 1992.

The Department did not require AGDC to conduct a more rigorous visibility analysis since there are no plume blight thresholds for Class II areas. The Department also notes that a Level 1 analysis for a source to observer distance of 50 km is *extremely* conservative. It represents a scenario that is unlikely to occur since the wind would need to hold steady for the entire 87.5 hours (three and a half days) needed for the plume to travel that distance at only 1.0 m/s.

8.3. Soil and Vegetation Impacts

The ambient demonstration provided by applicants is typically adequate for showing that their air emissions will not cause adverse soil or vegetation impacts. Congress established “primary” NAAQS and “secondary” NAAQS in Section 109(b) of the CAA. The primary NAAQS protect public health, while the secondary NAAQS protect public welfare. Congress further stated in Section 302(h) of the CAA, “*All language referring to the effects of **welfare** includes, but is not limited to, effects on **soils**, water, crops, **vegetation**, ...*” (emphasis added). The AAAQS and primary NAAQS are identical for each of the modeled pollutants. However, the annual PM-2.5 secondary NAAQS ($15 \mu\text{g}/\text{m}^3$) is less stringent than the annual PM-2.5 primary NAAQS/AAAQS ($12 \mu\text{g}/\text{m}^3$). Therefore, a modeling analysis that demonstrates compliance with the AAAQS also demonstrates compliance with the secondary NAAQS.

AGDC demonstrated that they can comply with the AAAQS. Therefore, their ambient analysis generally demonstrates that they will not have adverse soil or vegetation impacts. The maximum cumulative impacts for the PSD-triggered pollutants with secondary NAAQS are reiterated in Table 14.⁶⁰

Table 14. Maximum Total Impacts Compared to the Secondary NAAQS

Pollutant	Avg. Period	Total Impact ($\mu\text{g}/\text{m}^3$)	Secondary NAAQS ($\mu\text{g}/\text{m}^3$)
NO ₂	Annual	20.2	100
PM-2.5	24-hour	26.5	35
PM-10	24-hour	81.4	150
SO ₂	3-hour	247.9	1,300

AGDC conducted an additional assessment on the potential impact on lichens. Lichens are more sensitive to air pollutants than vascular plants since they lack roots and derive all growth requirements from the atmosphere. Some lichen species are adversely affected when the annual average SO₂ concentration ranges between 13 to $26 \mu\text{g}/\text{m}^3$.⁶¹ While it is not known whether lichens on the North Slope have this same sensitivity, these values provide a

⁶⁰ AGDC demonstrated that the annual PM-2.5 project impact is less than the SIL. The analysis therefore also demonstrates that the annual PM-2.5 impacts will not adversely affect local soil and vegetation.

⁶¹ *Air Quality Monitoring on the Tongass National Forest* (USDA – Forest Service); September 1994.

surrogate measure of the potential sensitivity threshold. The maximum modeled concentration plus background is $4.6 \mu\text{g}/\text{m}^3$. This is well below the $13 \mu\text{g}/\text{m}^3$ threshold.

9. CONCLUSIONS

The Department concludes the following based on its review of AGDC's permit application and ambient demonstrations:

1. AGDC's characterizations of the proposed exhaust stacks comply with the stack height and dispersion requirements described in 40 CFR 52.21(h) **Stack Heights**.
2. AGDC's ambient demonstration, as modified by the Department, satisfies the **Source Impact Analysis** requirements of 40 CFR 52.21(k). AGDC demonstrated that the NO_x, SO₂, PM-10, PM-2.5, CO, and VOC emissions associated with operating the stationary source, within the restrictions listed in this report, will not cause or contribute to a violation of the NO₂, SO₂, PM-10, PM-2.5, CO, and O₃ AAAQS. They also demonstrated that the emissions will not cause or contribute to a violation of the NO₂, SO₂, PM-10, and PM-2.5 Class II increments.
3. AGDC appropriately used the models and methods required under 40 CFR 52.21(l) **Air Quality Models**.
4. AGDC conducted their modeling analysis in a manner consistent with the Guideline, as required under 18 AAC 50.215(b)(1).
5. The 2015 and 2016 ambient pollutant data measured at CCP satisfies the **Preapplication Analysis** requirements of 40 CFR 52.21(m)(1).
6. AGDC provided the **Additional Impact Analyses** required under 40 CFR 52.21(o).

The Department developed permit conditions in Construction Permit AQ1524CPT01 to ensure AGDC complies with the AAAQS and Class II increments. These conditions are *summarized* as follows:

- To protect the NO₂, CO, PM-10, PM-2.5, and SO₂ AAAQS, and the NO₂, PM-10 and PM-2.5 Class II increments:

Stack Configuration

- o Construct and maintain vertical, uncapped exhaust stacks for all heaters and reciprocating engines (**EUs 31 – 44**), and on all temporary camp engines. AGDC may nevertheless use flapper-style rain covers, or other similar designs, that do not hinder the vertical momentum of the exhaust plume.

Stack Heights

- o Construct and maintain exhaust stacks with release points above the gravel pad surface that equals or exceeds the minimum height listed in Table 5 for that EU.

Concurrent Operating Limits

- o Do not operate more than two of the three Building Heat Medium Heaters (**EUs 31 – 33**) at a time, except for periodic load shifting purposes.
 - o Do not operate more than two of the three Operations Camp Heaters (**EUs 36 – 38**) at a time, except for periodic load shifting purposes.
- To protect the 1-hour and annual NO₂ AAAQS, the 1-hour and annual SO₂ AAAQS, the annual PM-2.5 AAAQS, the annual NO₂ Class II increment, the annual SO₂ Class II increment, the annual PM-10 Class II increment, and the annual PM-2.5 Class II increment, limit the operation of each of the six reciprocating engines (**EUs 39 – 44**) to 500 hr/yr.
- To protect the 24-hour PM-10 AAAQS, the 24-hour PM-2.5 AAAQS, and the annual PM-2.5 AAAQS during the construction phase:
 - o Use the best management practices described in the permit to minimize the fugitive dust emissions from construction activities.
 - o Install and operate one or more air quality monitoring stations to measure the actual PM-2.5 and PM-10 ambient concentrations. Take additional actions to reduce the fugitive dust emissions if the AAAQS become threatened.
- To protect the 1-hour, 3-hour, 24-hour, and annual SO₂ AAAQS; and the 3-hour, 24-hour, and annual SO₂ Class II increments, AGDC shall:
 - o Limit the sulfur content of the diesel fuel to 15 ppmw; and
 - o Limit the total sulfur content of the fuel gas to 96 ppmv.