



**DEPARTMENT OF THE AIR FORCE
PACIFIC AIR FORCES**

AUG 31 2020

MEMORANDUM FOR AK DEPARTMENT OF ENVIRONMENTAL CONSERVATION
Attn: Brittany Crutchfield/Air Permit Intake Technician
555 Cordova Street
Anchorage, AK 99501

FROM: 354 FW/CC
354 Broadway Street Unit 19A
Eielson AFB AK 99702

SUBJECT: Addendum to Title V Renewal Application for Permit #AQ0264TVP02, Revision 5 (AQ0264TVP03A) for United States Air Force, Eielson Air Force Base (EAFB)

1. The United States Air Force (USAF) is submitting an addendum to the application for renewal of its Title V operating permit for EAFB. The original permit application was submitted in October 2017. Specifications and estimated emissions for replaced, removed, and new emission units have been documented with the required forms and are provided as an attachment to this letter.
2. Based on information and belief formed after reasonable inquiry, I certify that the statements and information in and attached to this document are true, accurate, and complete. If you have any questions regarding the information being submitted, please contact Heidi Young, Air Program Manager, at (907) 377-1815 or heidi.young.6@us.af.mil.

BERKLAND.DAV Digitally signed by
BERKLAND.DAVID.J.1146964946
Date: 2020.08.27 17:46:17 -08'00'
ID.J.1146964946
DAVID J. BERKLAND, Colonel, USAF
Commander

Attachment:
ADEC Forms A1-R, B, B2, and B1

cc:
USEPA Region 10, Air Compliance, 1200 Sixth Avenue, Suite 155, 20-C04, Seattle WA 98101

FORM A1-R

Stationary Source Supplemental Information or Application Revision

Permit Number: AQ0264TVP02, Rev 5

| | | |
|---|------------------------|---------------------------|
| Permit Contact: | Name | David J. Berkland |
| | Title | Commander |
| | Mailing Address Line 1 | 354 FW/CC |
| | Mailing Address Line 2 | 354 Broadway St. Unit 19A |
| | Phone Number | 907-377-6101 |
| | Email | david.berkland@us.af.mil |
| Brief Description of Supplemental Information or Application Revision: Emission unit detail forms for new and replacement internal combustion equipment (Form B2) and external combustion equipment (Form B1) are provided to be added to permit renewal application information. Supporting emission calculations are included after each respective form. Additionally, potential emission calculations are included for new sources that meet the emission limits for insignificant sources and are not subject to federal regulations or standards that require inclusion in the permit. | | |

Statement of Certification:

Based on information and belief formed after reasonable inquiry, I certify that the statements and information in and attached to this document are true, accurate, and complete.

DAVID J. BERKLAND

Name of Responsible Official

Commander

Title



Signature (blue ink)

27 AUG 20

Date

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Permit Number: _____

| | | |
|-----|--|--|
| 1. | Emission Unit ID Number // Operating Scenario | |
| 2. | Date installation/construction commenced ¹ | |
| 3. | Date installed | |
| 4. | Emission Unit serial number | |
| 5. | Special control requirements? [if yes, describe] | |
| 6. | Manufacturer and model number | |
| 7. | Type of combustion device | |
| 8. | Rated design capacity (horsepower rating for engines) | |
| 9. | Rated design capacity (heat input, MMBtu/hr rating for turbines) | |
| 10. | If used for power generation, electrical output (kW) | |

¹. See page 2 of the Form B instructions regarding installation/construction date and consult regulations under 40 C.F.R. 60 (NSPS) and 40 C.F.R. 63 (NESHAP) for applicability dates, e.g.,
- NSPS Subparts IIII and JJJJ, and NESHAP Subpart ZZZZ for engines, and
- NSPS Subparts GG and KKKK, and NESHAP Subpart YYYYY for turbines.
Note that other regulations may apply in addition to the regulations cited.

11. Fuel usage: [for EACH fuel, enter]:

| Fuel | Maximum hourly firing rate (specify units) |
|------|--|
| | |
| | |
| | |
| | |

| | |
|-----|--|
| 12. | Describe any specific modifications to the emission unit that must be addressed in the permit: |
|-----|--|

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (*attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements*):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|--|--|-------------------------------|--------------------------|--|
| Condition 138 | 18 AAC 50.346 (b)(4) | NO _x , CO, PM, SO ₂ , and VOCs | insignificant emission source | NA | Track emergency and non-emergency hours and certify status of insignificance with the annual compliance certification. |
| Condition 68 | 40 CFR 60.4200(a), 60.4206, and 60.4211(a) | operations | NA | NA | Operate and maintain in accordance with manufacturer's written instructions for the life of the unit. |
| Condition 70.2 | 40 CFR 60.4205(b), 40 CFR 60.4202(a) (2) | NA | emission standards | NA | Maintain manufacturer's certificate of conformity to demonstrate that the emission standards are met for the year the CI ICE was manufactured. |
| Condition 71 | 40 CFR 60.4209(a), 60.4214(b), 60.4211(b) | NA | limited non-emergency hours | NA | Install a non-resettable hours meter and track emergency (unlimited) and non-emergency (100 hours). Ensure the engine is labeled as an emergency engine. |
| NA | 40 CFR 60.14, 60.17, and 60.19 | NA | NA | NA | General provisions under 40 CFR 60. |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (*attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements*):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|--|----------------------|-----------------------------|--------------------------|--|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Non-applicable Requirements Specific to Emission Unit (*attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Permit Shield Request*):

| Non-Applicable Requirements ¹ | Reason for non-applicability and citation/basis |
|--|---|
| | |
| | |
| | |
| | |
| | |
| | |
| | |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

Engine<600hp Emission Calculations

ENGINE SPECIFICATIONS

| Source Identification | Rated Capacity Hp | Fuel Type | Rated Capacity MMBtu/yr | Operating Hours (hrs) |
|-----------------------|----------------------|-----------|----------------------------|--------------------------|
| <i>EUID 55A</i> | 67 | ULSD | 235 | 500 |

using full standby emissions data for criteria pollutants when available

CALCULATIONS

| Pollutants | Emission Facotrs ^{3,4,6} | | GWP ⁶ | Estimated Emissions | | |
|------------------------|-----------------------------------|----------|------------------|----------------------|-----------------|---------------------------------|
| | | Unit | | AP-42 or MB (SO2) | emissions data* | Unit |
| <i>Criteria</i> | | | | | | |
| NO _x | 3.10E-02 | lb/hp-hr | N/A | 0.52 | 0.11 | tpy |
| CO | 6.68E-03 | lb/hp-hr | N/A | 0.11 | 0.07 | tpy |
| PM ₁₀ | 2.20E-03 | lb/hp-hr | N/A | 0.04 | 6.28E-03 | tpy |
| SO ₂ | 1.11E-05 | lb/hp-hr | N/A | 3.71E-04 | 7.38E-03 | tpy |
| VOC | 0.00056 | lb/hp-hr | N/A | 0.01 | NA | tpy |
| <i>GHGs</i> | | | | | | |
| CO ₂ | 73.96 | kg/MMBtu | 1 | 17.34 | NA | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.01 | NA | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 0.04 | NA | metric ton CO _{2e} /yr |
| <i>Total GHGs</i> | | | | 17 | | metric ton CO _{2e} /yr |
| <i>HAPs</i> | | | | | | |
| Acetaldehyde | 5.369E-06 | lb/hp-hr | N/A | 8.99E-05 | NA | tpy |
| Acrolein | 6.475E-07 | lb/hp-hr | N/A | 1.08E-05 | NA | tpy |
| Benzene | 6.531E-06 | lb/hp-hr | N/A | 1.09E-04 | NA | tpy |
| 1,3-Butadiene | 2.737E-07 | lb/hp-hr | N/A | 4.58E-06 | NA | tpy |
| Formaldehyde | 0.00000826 | lb/hp-hr | N/A | 1.38E-04 | NA | tpy |
| Naphthalene | 5.936E-07 | lb/hp-hr | N/A | 9.94E-06 | NA | tpy |
| Propylene oxide | 0.00001806 | lb/hp-hr | N/A | 3.03E-04 | NA | tpy |
| Toluene | 2.863E-06 | lb/hp-hr | N/A | 4.80E-05 | NA | tpy |
| Xylene (mixed isomers) | 1.995E-06 | lb/hp-hr | N/A | 3.34E-05 | NA | tpy |
| <i>total HAPs</i> | | | | 7.47E-04 | | tpy |

*Used the highest emissions of all standby operations tested

Notes:

1. Based on 18 AAC 50.326(e)
 2. Based on 18 AAC 50.502 C(3)
 3. All Criteria Emission Factors from AP-42 - Distillate Oil - Engines < 600 hp
 4. density of diesel fuel (876 kg/m³)*0.000015 (15 ppm SO₂) = EF of 0.0001095 lb/gallon, 0.0001095lb/gal*4 gal/hr*500hr/yr/2000lb/ton*64/32 = tpy
7,000 Btu/hp-hr (USEPA AP-42 Table 3.3-1)
 4. Based on an average brake-specific fuel consumption (BSFC)
 5. GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
 6. GWP = Global warming potential. Values from 40 CFR 98 Table A-1.
- density of ULSD = 7.05 lb/gal

Boiler Emission Calculations - Change in PTE for Generator Replacement (EUID 55)

| Source Identification | Rated Capacity Hp | Fuel Type | Rated Capacity MMBtu/yr | Operating Hours (hrs) |
|----------------------------------|----------------------|-----------|----------------------------|--------------------------|
| EUID55 | 102 | DFA | 143 | 200 |
| EUID55A (replacement) | 67 | ULSD | 235 | 500 |

Emission Comparisons

| Pollutants | Unit Comparisons | | Increase in emissions* | Units |
|------------------------------|------------------|-----------|------------------------|---------------------------------|
| | EUID 55 | EUID 55A | | |
| Criteria Pollutants | | | | |
| NO _x | 0.3162 | 0.1096435 | -0.2066 | tpy |
| CO | 0.068136 | 0.0188277 | -0.0493 | tpy |
| PM ₁₀ | 0.02244 | 0.0036917 | -0.0187 | tpy |
| SO ₂ ⁴ | 0.011305 | 0.0005907 | -0.0107 | tpy |
| VOC | 0.02514715 | 0.00938 | -0.0158 | tpy |
| GHGs | | | | |
| CO ₂ | 11.6418519 | 17.34362 | 5.7018 | metric ton CO _{2e} /yr |
| CH ₄ | 0 | 0.0147735 | 0.0148 | metric ton CO _{2e} /yr |
| N ₂ O | 0 | 0.043617 | 0.0436 | metric ton CO _{2e} /yr |
| Total GHGs | 11.6 | 17.402011 | 5.7602 | metric ton CO _{2e} /yr |
| HAPs | | | | |
| Acetaldehyde | 5.48E-05 | 8.993E-05 | 3.52E-05 | tpy |
| Acrolein | 6.60E-06 | 1.085E-05 | 4.24E-06 | tpy |
| Benzene | 6.66E-05 | 0.0001094 | 4.28E-05 | tpy |
| 1,3-Butadiene | 2.79E-06 | 4.584E-06 | 1.79E-06 | tpy |
| Formaldehyde | 8.43E-05 | 0.0001384 | 5.41E-05 | tpy |
| Naphthalene | 6.05E-06 | 9.943E-06 | 3.89E-06 | tpy |
| Propylene oxide | 0.00018421 | 0.0003025 | 1.18E-04 | tpy |
| Toluene | 2.9203E-05 | 4.796E-05 | 1.88E-05 | tpy |
| Xylene (mixed isome | 2.0349E-05 | 3.342E-05 | 1.31E-05 | tpy |
| total HAPs | 0.00045485 | 0.0007469 | 2.92E-04 | tpy |

*A negative increase is a decrease in emissions.

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- Emission Factors from AP-42 - Distillate Oil - Engines < 600 hp
- All Criteria Emission Factors from AP-42 - Distillate Oil - Boilers less than 100MMBtu/hr
- Weight percent sulfur in FS-1 diesel 0.15 wt% S (Title V AQ0264TVPO)
- Fuel Consumption based on Steam Generating Unit
Heating Value of diesel/JP-8: 137,000 Btu/gal
Density of JP-8/diesel: 7.05 lb/gal (AP-42, Appendix A)
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Permit Number: AQ0264TVP02, Rev 5

| | | |
|-----|--|---------------------------------|
| 1. | Emission Unit ID Number // Operating Scenario | TBD - emergency generator |
| 2. | Date installation/construction commenced ¹ | unknown |
| 3. | Date installed | 18 Jun 19 |
| 4. | Emission Unit serial number | B190503805 |
| 5. | Special control requirements? [if yes, describe] | None |
| 6. | Manufacturer and model number | Cummins C125D6C, QSB5-G6 engine |
| 7. | Type of combustion device | CI RICE |
| 8. | Rated design capacity (horsepower rating for engines) | 208 hp |
| 9. | Rated design capacity (heat input, MMBtu/hr rating for turbines) | |
| 10. | If used for power generation, electrical output (kW) | 125 kW |

¹. See page 2 of the Form B instructions regarding installation/construction date and consult regulations under 40 C.F.R. 60 (NSPS) and 40 C.F.R. 63 (NESHAP) for applicability dates, e.g.,
 - NSPS Subparts IIII and JJJJ, and NESHAP Subpart ZZZZ for engines, and
 - NSPS Subparts GG and KKKK, and NESHAP Subpart YYYYY for turbines.
Note that other regulations may apply in addition to the regulations cited.

11. Fuel usage: [for EACH fuel, enter]:

| Fuel | Maximum hourly firing rate (specify units) |
|---------------|--|
| Non-Road ULSD | 10.3 gal/hr |
| | |
| | |
| | |

| | |
|-----|--|
| 12. | Describe any specific modifications to the emission unit that must be addressed in the permit: No modifications will be made to the emission unit. The generator will be installed, operated, and maintained in accordance with manufacturer's written instructions. |
|-----|--|

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (*attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements*):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|--|--|-------------------------------|--------------------------|--|
| Condition 138 | 18 AAC 50.346 (b)(4) | NO _x , CO, PM, SO ₂ , and VOCs | insignificant emission source | NA | Track emergency and non-emergency hours and certify status of insignificance with the annual compliance certification. |
| Condition 68 | 40 CFR 60.4200(a), 60.4206, and 60.4211(a) | operations | NA | NA | Operate and maintain in accordance with manufacturer's written instructions for the life of the unit. |
| Condition 70.2 | 40 CFR 60.4205(b), 40 CFR 60.4202(a) (2) | NA | emission standards | NA | Maintain manufacturer's certificate of conformity to demonstrate that the emission standards are met for the year the CI ICE was manufactured. |
| Condition 71 | 40 CFR 60.4209(a), 60.4214(b), 60.4211(b) | NA | limited non-emergency hours | NA | Install a non-resettable hours meter and track emergency (unlimited) and non-emergency (100 hours). Ensure the engine is labeled as an emergency engine. |
| NA | 40 CFR 60.14, 60.17, and 60.19 | NA | NA | NA | General provisions under 40 CFR 60. |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

FORM B2
Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|---|----------------------|--|--------------------------|--|
| NA | 40 CFR 63.6590(c)(1) | HAPs | NA | NA | A new stationary RICE located at an area source meets the requirements of NESHAP Subpart ZZZZ by complying with the requirements of NSPS Subpart IIII. |
| NA | 40 CFR 60.4204(b), 60.4201 | PM, NOx, CO | by purchasing an engine with the appropriate tier for the manufacturer year and installing it in accordance with the manufacturer's instructions | NA | Owners must confirm that the engine is certified for its manufacturer year (2020 EPA Tier 3) and must keep a copy of the certificate of conformity and maintenance records for the engine. |
| NA | 40 CFR 60.12, 60.14, 60.17, 60.19 | NA | NA | NA | General provisions under 40 CFR 60. |
| Condition 38.3 | 40 CFR 60.4207(b) and 40 CFR 80.510 (b) | SO2 | Purchase ULSD (NR) that meets the 15 ppm maximum sulfur content and have a cetane index of 40 or a maximum aromatic content of 35 volume percent | NA | Owners must keep fuel delivery and analysis records and analyze fuel if not provided by the supplier |
| Condition 51-53 | 18 AAC 50.326(d)(1), 18 AAC 50.040 (a)(1), 40 CFR 60.11 (d) and (g) Subpart A, 40 CFR 60.12 | NA | NA | NA | General provisions of 40 CFR 60, Subpart A |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

Engine<600hp Emission Calculations

Cummins Model QSB5-G6 engine for Generator Set 2017 EPA Tier 3 Emergency Generator using diesel with 0.03-0.05% sulfur content (by weight), and 40-48 cetane number.

Insignificant emissions but subject to 40 CFR 60 Subpart IIII and 40 CFR 63 Subpart ZZZZ

ENGINE SPECIFICATIONS

| Source Identification | Rated Capacity BHp | Fuel Type | Fuel Consumption ⁴ MMBtu/yr | Operating Hours (hrs) |
|--|-----------------------|-----------|---|--------------------------|
| OSS/Weapons/Intel Facility Emergency Generator | 208 | ULSD | 728 | 500 |

CALCULATIONS

| Pollutants | Emission Facotrs ^{3, 5} | | GWP ⁶ | Estimated Emissions | |
|------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| <i>Criteria</i> | | | | | |
| NO _x | 5.01 | g/Bhp-hr | N/A | 0.57 | tpy |
| CO | 1.03 | g/Bhp-hr | N/A | 0.12 | tpy |
| PM ₁₀ | 0.17 | g/Bhp-hr | N/A | 1.95E-02 | tpy |
| SO ₂ | mass bal. | NA | N/A | 5.45E-04 | tpy |
| VOC | 5.60E-04 | lb/hp-hr | N/A | 0.03 | tpy |
| <i>GHGs</i> | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 53.33 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.05 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 0.14 | metric ton CO _{2e} /yr |
| <i>Total GHGs</i> | | | | 54 | metric ton CO _{2e} /yr |
| <i>HAPs</i> | | | | | |
| Acetaldehyde | 5.369E-06 | lb/hp-hr | N/A | 2.79E-04 | tpy |
| Acrolein | 6.475E-07 | lb/hp-hr | N/A | 3.37E-05 | tpy |
| Benzene | 6.531E-06 | lb/hp-hr | N/A | 3.40E-04 | tpy |
| 1,3-Butadiene | 2.737E-07 | lb/hp-hr | N/A | 1.42E-05 | tpy |
| Formaldehyde | 0.00000826 | lb/hp-hr | N/A | 4.30E-04 | tpy |
| Naphthalene | 5.936E-07 | lb/hp-hr | N/A | 3.09E-05 | tpy |
| Propylene oxide | 0.00001806 | lb/hp-hr | N/A | 9.39E-04 | tpy |
| Toluene | 2.863E-06 | lb/hp-hr | N/A | 1.49E-04 | tpy |
| Xylene (mixed isomers) | 1.995E-06 | lb/hp-hr | N/A | 1.04E-04 | tpy |
| <i>total HAPs</i> | | | | 2.32E-03 | tpy |

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- All Criteria Emission Factors except SO₂ are from AP-42 - Distillate Oil - Engines < 600 hp
- Fuel Consumption based on the followings:
An average brake-specific fuel consumption (BSFC) 7,000 Btu/hp-hr
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.

10.3 gal/hr fuel at full standby capacity
453.6 g/lb

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Permit Number: AQ0264TVP02, Rev 5

| | | |
|-----|--|---------------------------------|
| 1. | Emission Unit ID Number // Operating Scenario | TBD - emergency generator |
| 2. | Date installation/construction commenced ¹ | unknown |
| 3. | Date installed | 17 JUn 20 |
| 4. | Emission Unit serial number | I190642518 |
| 5. | Special control requirements? [if yes, describe] | None |
| 6. | Manufacturer and model number | Cummins C60D6C, QSB5-G13 engine |
| 7. | Type of combustion device | CI RICE |
| 8. | Rated design capacity (horsepower rating for engines) | 173 hp (nameplate) |
| 9. | Rated design capacity (heat input, MMBtu/hr rating for turbines) | |
| 10. | If used for power generation, electrical output (kW) | 60kW |

¹. See page 2 of the Form B instructions regarding installation/construction date and consult regulations under 40 C.F.R. 60 (NSPS) and 40 C.F.R. 63 (NESHAP) for applicability dates, e.g.,
 - NSPS Subparts IIII and JJJJ, and NESHAP Subpart ZZZZ for engines, and
 - NSPS Subparts GG and KKKK, and NESHAP Subpart YYYYY for turbines.
Note that other regulations may apply in addition to the regulations cited.

11. Fuel usage: [for EACH fuel, enter]:

| Fuel | Maximum hourly firing rate (specify units) |
|---------------|--|
| Non-Road ULSD | 6.1 gal/hr |
| | |
| | |
| | |

| | |
|-----|--|
| 12. | Describe any specific modifications to the emission unit that must be addressed in the permit: No modifications will be made to the emission unit. The generator will be installed, operated, and maintained in accordance with manufacturer's written instructions. |
|-----|--|

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (*attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements*):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|--|----------------------------|-------------------------------|--------------------------|--|
| Condition 138 | 18 AAC 50.346 (b)(4) | NOx, CO, PM, SO2, and VOCs | insignificant emission source | NA | Track emergency and non-emergency hours and certify status of insignificance with the annual compliance certification. |
| Condition 68 | 40 CFR 60.4200(a), 60.4206, and 60.4211(a) | operations | NA | NA | Operate and maintain in accordance with manufacturer's written instructions for the life of the unit. |
| Condition 70.2 | 40 CFR 60.4205(b), 40 CFR 60.4202(a) (2) | NA | emission standards | NA | Maintain manufacturer's certificate of conformity to demonstrate that the emission standards are met for the year the CI ICE was manufactured. |
| Condition 71 | 40 CFR 60.4209(a), 60.4214(b), 60.4211(b) | NA | limited non-emergency hours | NA | Install a non-resettable hours meter and track emergency (unlimited) and non-emergency (100 hours). Ensure the engine is labeled as an emergency engine. |
| NA | 40 CFR 60.14, 60.17, and 60.19 | NA | NA | NA | General provisions under 40 CFR 60. |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|---|----------------------|--|--------------------------|--|
| NA | 40 CFR 63.6590(c)(1) | HAPs | NA | NA | A new stationary RICE located at an area source meets the requirements of NESHAP Subpart ZZZZ by complying with the requirements of NSPS Subpart IIII. |
| NA | 40 CFR 60.4204(b), 60.4201 | PM, NOx, CO | by purchasing an engine with the appropriate tier for the manufacturer year and installing it in accordance with the manufacturer's instructions | NA | Owners must confirm that the engine is certified for its manufacturer year (2020 EPA Tier 3) and must keep a copy of the certificate of conformity and maintenance records for the engine. |
| NA | 40 CFR 60.12, 60.14, 60.17, 60.19 | NA | NA | NA | General provisions under 40 CFR 60. |
| Condition 38.3 | 40 CFR 60.4207(b) and 40 CFR 80.510 (b) | SO2 | Purchase ULSD (NR) that meets the 15 ppm maximum sulfur content and have a cetane index of 40 or a maximum aromatic content of 35 volume percent | NA | Owners must keep fuel delivery and analysis records and analyze fuel if not provided by the supplier |
| Condition 51-53 | 18 AAC 50.326(d)(1), 18 AAC 50.040 (a)(1), 40 CFR 60.11 (d) and (g) Subpart A, 40 CFR 60.12 | NA | NA | NA | General provisions of 40 CFR 60, Subpart A |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

Engine<600hp Emission Calculations

C60D6C Generator Set 2018 EPA Tier 3 Emergency Generator using diesel with 0.03-0.05% sulfur content (by weight), and 40-48 cetane number.

Insignificant emissions but subject to 40 CFR 60 Subpart IIII and 40 CFR 63 Subpart ZZZZ

ENGINE SPECIFICATIONS

| Source Identification | Rated Capacity BHp | Fuel Type | Fuel Consumption ⁴ MMBtu/yr | Operating Hours (hrs) |
|--|--------------------|-----------|--|-----------------------|
| <i>Consolidated Munitions Facility Emergency Generator</i> | 109 | ULSD | 382 | 500 |

(nameplate 173 hp)

CALCULATIONS

| Pollutants | Emission Facotrs ^{3, 5} | | GWP ⁶ | Estimated Emissions | |
|------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| <i>Criteria</i> | | | | | |
| NO _x | 3.00 | g/Bhp-hr | N/A | 0.18 | tpy |
| CO | 1.33 | g/Bhp-hr | N/A | 0.08 | tpy |
| PM ₁₀ | 0.24 | g/Bhp-hr | N/A | 0.01 | tpy |
| SO ₂ | mass bal. | NA | N/A | 3.23E-04 | tpy |
| VOC | 5.60E-04 | lb/hp-hr | N/A | 0.02 | tpy |
| <i>GHGs</i> | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 27.94 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.02 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 0.07 | metric ton CO _{2e} /yr |
| <i>Total GHGs</i> | | | | 28 | metric ton CO _{2e} /yr |
| <i>HAPs</i> | | | | | |
| Acetaldehyde | 5.369E-06 | lb/hp-hr | N/A | 1.46E-04 | tpy |
| Acrolein | 6.475E-07 | lb/hp-hr | N/A | 1.76E-05 | tpy |
| Benzene | 6.531E-06 | lb/hp-hr | N/A | 1.78E-04 | tpy |
| 1,3-Butadiene | 2.737E-07 | lb/hp-hr | N/A | 7.46E-06 | tpy |
| Formaldehyde | 0.00000826 | lb/hp-hr | N/A | 2.25E-04 | tpy |
| Naphthalene | 5.936E-07 | lb/hp-hr | N/A | 1.62E-05 | tpy |
| Propylene oxide | 0.00001806 | lb/hp-hr | N/A | 4.92E-04 | tpy |
| Toluene | 2.863E-06 | lb/hp-hr | N/A | 7.80E-05 | tpy |
| Xylene (mixed isomers) | 1.995E-06 | lb/hp-hr | N/A | 5.44E-05 | tpy |
| <i>total HAPs</i> | | | | 1.22E-03 | tpy |

Notes:

1. Based on 18 AAC 50.326(e)
2. Based on 18 AAC 50.502 C(3)
3. All Criteria Emission Factors from AP-42 - Distillate Oil - Engines < 600 hp
4. Based on an average brake-specific fuel consumption (BSFC) 7,000 Btu/hp-hr
5. GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
6. GWP = Global warming potential. Values from 40 CFR 98 Table A-1.

6.1 gal/hr fuel at full standby capacity
453.6 g/lb

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Permit Number: AQ0264TVP02, Rev 5

| | | |
|-----|--|--|
| 1. | Emission Unit ID Number // Operating Scenario | TBD - emergency generator |
| 2. | Date installation/construction commenced ¹ | unknown - stored in warehouse since 2012 |
| 3. | Date installed | TBD |
| 4. | Emission Unit serial number | CA0014 |
| 5. | Special control requirements? [if yes, describe] | None |
| 6. | Manufacturer and model number | Kubota V3V3300-BG-ET011 engine (1 of 2) |
| 7. | Type of combustion device | CI RICE |
| 8. | Rated design capacity (horsepower rating for engines) | 48.9 hp @1800 RPM |
| 9. | Rated design capacity (heat input, MMBtu/hr rating for turbines) | |
| 10. | If used for power generation, electrical output (kW) | 36.5 kW |

- ¹. See page 2 of the Form B instructions regarding installation/construction date and consult regulations under 40 C.F.R. 60 (NSPS) and 40 C.F.R. 63 (NESHAP) for applicability dates, e.g.,
 - NSPS Subparts IIII and JJJJ, and NESHAP Subpart ZZZZ for engines, and
 - NSPS Subparts GG and KKKK, and NESHAP Subpart YYYYY for turbines.
Note that other regulations may apply in addition to the regulations cited.

11. Fuel usage: [for EACH fuel, enter]:

| Fuel | Maximum hourly firing rate (specify units) |
|---------------|--|
| Non-Road ULSD | 2.5 gal/hr |
| | |
| | |
| | |

| | |
|-----|--|
| 12. | Describe any specific modifications to the emission unit that must be addressed in the permit: No modifications will be made to the emission unit. The generator will be installed, operated, and maintained in accordance with manufacturer's written instructions. |
|-----|--|

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (*attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements*):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|--|--|-------------------------------|--------------------------|--|
| Condition 138 | 18 AAC 50.346 (b)(4) | NO _x , CO, PM, SO ₂ , and VOCs | insignificant emission source | NA | Track emergency and non-emergency hours and certify status of insignificance with the annual compliance certification. |
| Condition 68 | 40 CFR 60.4200(a), 60.4206, and 60.4211(a) | operations | NA | NA | Operate and maintain in accordance with manufacturer's written instructions for the life of the unit. |
| Condition 70.2 | 40 CFR 60.4205(b), 40 CFR 60.4202(a) (2) | NA | emission standards | NA | Maintain manufacturer's certificate of conformity to demonstrate that the emission standards are met for the year the CI ICE was manufactured. |
| Condition 71 | 40 CFR 60.4209(a), 60.4214(b), 60.4211(b) | NA | limited non-emergency hours | NA | Install a non-resettable hours meter and track emergency (unlimited) and non-emergency (100 hours). Ensure the engine is labeled as an emergency engine. |
| NA | 40 CFR 60.14, 60.17, and 60.19 | NA | NA | NA | General provisions under 40 CFR 60. |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|---|----------------------|--|--------------------------|--|
| NA | 40 CFR 63.6590(c)(1) | HAPs | NA | NA | A new stationary RICE located at an area source meets the requirements of NESHAP Subpart ZZZZ by complying with the requirements of NSPS Subpart IIII. |
| NA | 40 CFR 60.4204(b), 60.4201 | PM, NOx, CO | by purchasing an engine with the appropriate tier for the manufacturer year and installing it in accordance with the manufacturer's instructions | NA | Owners must confirm that the engine is certified for its manufacturer year (2020 EPA Tier 3) and must keep a copy of the certificate of conformity and maintenance records for the engine. |
| NA | 40 CFR 60.12, 60.14, 60.17, 60.19 | NA | NA | NA | General provisions under 40 CFR 60. |
| Condition 38.3 | 40 CFR 60.4207(b) and 40 CFR 80.510 (b) | SO2 | Purchase ULSD (NR) that meets the 15 ppm maximum sulfur content and have a cetane index of 40 or a maximum aromatic content of 35 volume percent | NA | Owners must keep fuel delivery and analysis records and analyze fuel if not provided by the supplier |
| Condition 51-53 | 18 AAC 50.326(d)(1), 18 AAC 50.040 (a)(1), 40 CFR 60.11 (d) and (g) Subpart A, 40 CFR 60.12 | NA | NA | NA | General provisions of 40 CFR 60, Subpart A |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

New lift station generators - 2012 Tier 4 engines

Engine<600hp Emission Calculations

| Source Identification | Rated Capacity Hp | Fuel Type | Fuel Consumption ⁴ MMBtu/yr | Operating Hours (hrs) |
|----------------------------------|----------------------|-----------|---|--------------------------|
| Lift Station Generator 1 of 2 | 49 | ULSD | 171 | 500 |

for PTE

@1800RPM

SN: CA0014

Model: V3300-BG-ET01

Family: CKBXL03.3 BCC

| Pollutants | Emission Facotrs ^{3, 5} | | GWP ⁶ | Estimated Emissions | |
|------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| <i>Criteria</i> | | | | | |
| NO _x * | 3.10E-02 | lb/hp-hr | N/A | 0.13 | tpy |
| CO * | 6.68E-03 | lb/hp-hr | N/A | 0.02 | tpy |
| PM ₁₀ * | 3.30E-03 | lb/hp-hr | N/A | 3.02E-03 | tpy |
| SO ₂ | 1.11E-05 | lb/hp-hr | N/A | 2.71E-04 | tpy |
| VOC | 0.00056 | lb/hp-hr | N/A | 0.01 | tpy |
| <i>GHGs</i> | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 12.54 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.01 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 0.03 | metric ton CO _{2e} /yr |
| <i>Total GHGs</i> | | | | 13 | metric ton CO _{2e} /yr |
| <i>HAPs</i> | | | | | |
| Acetaldehyde | 5.369E-06 | lb/hp-hr | N/A | 6.56E-05 | tpy |
| Acrolein | 6.475E-07 | lb/hp-hr | N/A | 7.92E-06 | tpy |
| Benzene | 6.531E-06 | lb/hp-hr | N/A | 7.98E-05 | tpy |
| 1,3-Butadiene | 2.737E-07 | lb/hp-hr | N/A | 3.35E-06 | tpy |
| Formaldehyde | 0.00000826 | lb/hp-hr | N/A | 1.01E-04 | tpy |
| Naphthalene | 5.936E-07 | lb/hp-hr | N/A | 7.26E-06 | tpy |
| Propylene oxide | 0.00001806 | lb/hp-hr | N/A | 2.21E-04 | tpy |
| Toluene | 2.863E-06 | lb/hp-hr | N/A | 3.50E-05 | tpy |
| Xylene (mixed isomers) | 1.995E-06 | lb/hp-hr | N/A | 2.44E-05 | tpy |
| <i>total HAPs</i> | | | | 5.45E-04 | tpy |

*Calculations based on emissions data for engine.

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- Emission Factors from AP-42 - Distillate Oil - Engines < 600 hp used for VOC, mass balance for ULSD used for SO₂, manufacturer emission data used for NO_x, CO, and PM (assuming all PM is PM₁₀)
- Fuel Consumption based on the followings:
An average brake-specific fuel consumption (BSFC) 7,000 Btu/hp-hr
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Permit Number: AQ0264TVP02, Rev 5

| | | |
|-----|--|--|
| 1. | Emission Unit ID Number // Operating Scenario | TBD - emergency generator |
| 2. | Date installation/construction commenced ¹ | unknown - stored in warehouse since 2012 |
| 3. | Date installed | TBD |
| 4. | Emission Unit serial number | CA0592 |
| 5. | Special control requirements? [if yes, describe] | None |
| 6. | Manufacturer and model number | Kubota V3V3300-BG-ET011 engine (2 of 2) |
| 7. | Type of combustion device | CI RICE |
| 8. | Rated design capacity (horsepower rating for engines) | 48.9 hp @1800 RPM |
| 9. | Rated design capacity (heat input, MMBtu/hr rating for turbines) | |
| 10. | If used for power generation, electrical output (kW) | 36.5 kW |

- ¹. See page 2 of the Form B instructions regarding installation/construction date and consult regulations under 40 C.F.R. 60 (NSPS) and 40 C.F.R. 63 (NESHAP) for applicability dates, e.g.,
 - NSPS Subparts IIII and JJJJ, and NESHAP Subpart ZZZZ for engines, and
 - NSPS Subparts GG and KKKK, and NESHAP Subpart YYYYY for turbines.
Note that other regulations may apply in addition to the regulations cited.

11. Fuel usage: [for EACH fuel, enter]:

| Fuel | Maximum hourly firing rate (specify units) |
|---------------|--|
| Non-Road ULSD | 2.5 gal/hr |
| | |
| | |
| | |

| | |
|-----|--|
| 12. | Describe any specific modifications to the emission unit that must be addressed in the permit: No modifications will be made to the emission unit. The generator will be installed, operated, and maintained in accordance with manufacturer's written instructions. |
|-----|--|

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (*attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements*):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|--|--|-------------------------------|--------------------------|--|
| Condition 138 | 18 AAC 50.346 (b)(4) | NO _x , CO, PM, SO ₂ , and VOCs | insignificant emission source | NA | Track emergency and non-emergency hours and certify status of insignificance with the annual compliance certification. |
| Condition 68 | 40 CFR 60.4200(a), 60.4206, and 60.4211(a) | operations | NA | NA | Operate and maintain in accordance with manufacturer's written instructions for the life of the unit. |
| Condition 70.2 | 40 CFR 60.4205(b), 40 CFR 60.4202(a) (2) | NA | emission standards | NA | Maintain manufacturer's certificate of conformity to demonstrate that the emission standards are met for the year the CI ICE was manufactured. |
| Condition 71 | 40 CFR 60.4209(a), 60.4214(b), 60.4211(b) | NA | limited non-emergency hours | NA | Install a non-resettable hours meter and track emergency (unlimited) and non-emergency (100 hours). Ensure the engine is labeled as an emergency engine. |
| NA | 40 CFR 60.14, 60.17, and 60.19 | NA | NA | NA | General provisions under 40 CFR 60. |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

FORM B2

Emission Unit Detail Form - Internal Combustion Equipment (Engines and Turbines)

Applicable Requirements Specific to Emission Unit (attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|---|----------------------|--|--------------------------|--|
| NA | 40 CFR 63.6590(c)(1) | HAPs | NA | NA | A new stationary RICE located at an area source meets the requirements of NESHAP Subpart ZZZZ by complying with the requirements of NSPS Subpart IIII. |
| NA | 40 CFR 60.4204(b), 60.4201 | PM, NOx, CO | by purchasing an engine with the appropriate tier for the manufacturer year and installing it in accordance with the manufacturer's instructions | NA | Owners must confirm that the engine is certified for its manufacturer year (2020 EPA Tier 3) and must keep a copy of the certificate of conformity and maintenance records for the engine. |
| NA | 40 CFR 60.12, 60.14, 60.17, 60.19 | NA | NA | NA | General provisions under 40 CFR 60. |
| Condition 38.3 | 40 CFR 60.4207(b) and 40 CFR 80.510 (b) | SO2 | Purchase ULSD (NR) that meets the 15 ppm maximum sulfur content and have a cetane index of 40 or a maximum aromatic content of 35 volume percent | NA | Owners must keep fuel delivery and analysis records and analyze fuel if not provided by the supplier |
| Condition 51-53 | 18 AAC 50.326(d)(1), 18 AAC 50.040 (a)(1), 40 CFR 60.11 (d) and (g) Subpart A, 40 CFR 60.12 | NA | NA | NA | General provisions of 40 CFR 60, Subpart A |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

New lift station generators - 2012 Tier 4 engines

Engine<600hp Emission Calculations

| Source Identification | Rated Capacity Hp | Fuel Type | Fuel Consumption ⁴ MMBtu/yr | Operating Hours (hrs) |
|----------------------------------|----------------------|-----------|---|--------------------------|
| Lift Station Generator 2 of 2 | 49 | ULSD | 171 | 500 |

for PTE

@1800RPM

SN: CA0592

Model: V3300-BG-ET01

Family: CKBXL03.3 BCC

| Pollutants | Emission Facotrs ^{3,5} | | GWP ⁶ | Estimated Emissions | |
|------------------------|---------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| <i>Criteria</i> | | | | | |
| NO _x * | 3.10E-02 | lb/hp-hr | N/A | 0.13 | tpy |
| CO * | 6.68E-03 | lb/hp-hr | N/A | 0.02 | tpy |
| PM ₁₀ * | 3.30E-03 | lb/hp-hr | N/A | 3.02E-03 | tpy |
| SO ₂ | 1.11E-05 | lb/hp-hr | N/A | 2.71E-04 | tpy |
| VOC | 0.00056 | lb/hp-hr | N/A | 0.01 | tpy |
| <i>GHGs</i> | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 12.54 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.01 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 0.03 | metric ton CO _{2e} /yr |
| <i>Total GHGs</i> | | | | 13 | metric ton CO _{2e} /yr |
| <i>HAPs</i> | | | | | |
| Acetaldehyde | 5.369E-06 | lb/hp-hr | N/A | 6.56E-05 | tpy |
| Acrolein | 6.475E-07 | lb/hp-hr | N/A | 7.92E-06 | tpy |
| Benzene | 6.531E-06 | lb/hp-hr | N/A | 7.98E-05 | tpy |
| 1,3-Butadiene | 2.737E-07 | lb/hp-hr | N/A | 3.35E-06 | tpy |
| Formaldehyde | 0.00000826 | lb/hp-hr | N/A | 1.01E-04 | tpy |
| Naphthalene | 5.936E-07 | lb/hp-hr | N/A | 7.26E-06 | tpy |
| Propylene oxide | 0.00001806 | lb/hp-hr | N/A | 2.21E-04 | tpy |
| Toluene | 2.863E-06 | lb/hp-hr | N/A | 3.50E-05 | tpy |
| Xylene (mixed isomers) | 1.995E-06 | lb/hp-hr | N/A | 2.44E-05 | tpy |
| <i>total HAPs</i> | | | | 5.45E-04 | tpy |

*Calculations based on emissions data for engine.

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- Emission Factors from AP-42 - Distillate Oil - Engines < 600 hp used for VOC, mass balance for ULSD used for SO₂, manufacturer emission data used for NO_x, CO, and PM (assuming all PM is PM₁₀)
- Fuel Consumption based on the followings:
An average brake-specific fuel consumption (BSFC) **7,000** Btu/hp-hr
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.

FORM B1

Emission Unit Detail Form – External Combustion Equipment (Boilers and Heaters)

Permit Number: AQ0264TVP02, Rev 5

| | | |
|-----|--|-------------------------------------|
| 1. | Emission Unit ID Number // Operating Scenario | Process Heater for comfort heat |
| 2. | Date installation/construction commenced | 2021 (estimated) TBD |
| 3. | Date installed | 2021 (estimated) TBD |
| 4. | Emission Unit serial number | unknown |
| 5. | Special control requirements? [if yes, describe] | none |
| 6. | Manufacturer | Burnam |
| 7. | Description of emission unit, including type of boiler/heater and firing method: This is the larger of two process heaters that will be installed at a firing range under Project #EIE 391. Each vessel will be filled with a glycol/water mixture, which meets the definition of a process heater under 40 CFR 63, and is indirect fired (the stack only includes exhaust from the combustion of the diesel). The heat from diesel combustion is transferred to the glycol/water mixture in the vessel. The glycol/water mixture from the smaller unit heats a slab for sustained building heat. The larger unit transfers the heat from the glycol/water mixture to an air curtain to maintain building heat during range operations. | |
| 8. | Rated design capacity (heat input, MMBtu/hr) | 1.9 MMBtu/hr |
| 9. | Maximum steam production rate (lbs/hr) | NA - using glycol and water mixture |
| 10. | Maximum steam pressure (psi) | NA - using glycol and water mixture |
| 11. | Maximum steam temperature (°F) | NA - using glycol and water mixture |

12. Fuel usage: [for EACH fuel, enter]:

| Fuel | Maximum hourly firing rate (specify units) |
|---------------|--|
| diesel (FS-1) | 13.8 gal/hr |
| | |
| | |
| | |

| | |
|-----|---|
| 13. | Is waste heat utilized for any purpose? If yes, describe: No |
|-----|---|

FORM B1

Emission Unit Detail Form – External Combustion Equipment (Boilers and Heaters)

Applicable Requirements Specific to Emission Unit (attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Applicable Requirements):

| Permit and Condition Number | Applicable Requirement Citation ¹ | Parameter/ Pollutant | Limit/Standard/ Requirement | Currently in Compliance? | Monitoring, Recordkeeping and Reporting Methods Used to Demonstrate Compliance |
|-----------------------------|---|--|---|--------------------------|---|
| 1.2 | 18 AAC 50.326 (e) | PM | <0.75 tpy to be considered an insignificant source | NA | Operational hours will be tracked to ensure the unit remains insignificant by operating less than 4400 hours per year. |
| 3, 4, 5 | 18 AAC 50.040(j), 18 AAC 50.326(j), 40 CFR. 71.6(a)(3)(i) | Opacity, permit content and recordkeeping requirements | Observe for 18 minutes within 30 days of triggering a change in status. | NA | Observe exhaust using Method 9 plan or smoke/no smoke plan if unit becomes significant based on operating hours, record observations, and report under Condition 137. |
| 10.2, 12-17 | 18 AAC 50.040(j), 18 AAC 50.326(j) & (e), 18 AAC 50.346 (c), 40 C.F.R. 71.6(a)(3) | PM | <0.75 tpy to be considered an insignificant source | NA | if actual emissions are considered insignificant by operating no more than 4400 hours per 12-month rolling period, monitoring shall consist of an annual compliance certification in Conditions 38 and 138 with the particulate matter standard. Otherwise, monitor, record and report in accordance with Conditions 12 through 17. |
| 18, 22, 23 | 18 AAC 50.035 (b)-(c) and 40 CFR 60.17 | SO2 | fuel sulfur content limit of 0.15 percent sulfur by weight | NA | For each shipment of fuel, keep receipts that specify fuel grade and amount received. Report under Condition 137. |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

FORM B1

Emission Unit Detail Form – External Combustion Equipment (Boilers and Heaters)

Non-applicable Requirements Specific to Emission Unit (attach additional sheets as needed. Form B Supplement - Emission Unit-Specific Permit Shield Request):

| Non-Applicable Requirements ¹ | Reason for non-applicability and citation/basis |
|---|--|
| 40 CFR 63 Subpart JJJJJJ applies to boilers. 40 CFR 63.11237 defines boilers and process heaters. | Waste heat boilers, process heaters, and autoclaves are excluded from the definition of Boiler. A process heater is an enclosed device using controlled flame, and the unit's primary purposed is to transfer heat indirectly to a process material (liquid, gas, or solid) or to a heat transfer material (glycol or a mixture of glycol and water) for use in a process unit instead of generating steam or hot water. |
| | |
| | |
| | |
| | |
| | |
| | |

¹ Citations must be specific. Include sub-paragraph level detail [e.g. 18 AAC 50.055(a)(1), or 40 C.F.R. 60.332(a)(2).]

Process Heater Emission Calculations based on PTE

Significant based on capacity (>1.7mmBtu/hr, 18 AAC 50.326(g)(7)) or potential emissions, not subject to 40 CFR 63 Subpart JJJJJJ (process heater, not a boiler by definition, glycol and water mixture is heated in vessel)

BOILER SPECIFICATIONS - one of two boilers to be installed at firing range, second boiler at range is insignificant by capacity and therefore, not included in total emissions

| Source Identification | Rated Capacity (MMBtu/hr)* | Fuel Type | Fuel Consumption ⁵ (gallons) | Operating Hours (hrs)* |
|----------------------------------|----------------------------|-----------|---|------------------------|
| CATM Range Process Heater 1 of 2 | 2.2 | DFA | 139,021 | 8760 |

PTE - continuous operations

*Increased rated capacity from manufacturer by 15% for calculations, because the combustion of diesel will be heating glycol/water mixture instead of water.

CALCULATIONS

| Pollutants | Emission Factors ^{3, 6} | | GWP ⁷ | Estimated Emissions | |
|------------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| <i>Criteria</i> | | | | | |
| NO _x | 0.0200 | lb/gal | N/A | 1.39 | tpy |
| CO | 0.005 | lb/gal | N/A | 0.35 | tpy |
| PM ₁₀ | 0.0033 | lb/gal | N/A | 1.48 | tpy |
| SO ₂ ⁴ | 0.0213 | lb/gal | N/A | 0.23 | tpy |
| VOC | 0.00056 | lb/gal | N/A | 0.04 | tpy |
| <i>GHGs</i> | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 1,425.66 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 1.23 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 3.62 | metric ton CO _{2e} /yr |
| <i>Total GHGs</i> | | | | 1,431 | metric ton CO _{2e} /yr |

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- All Criteria Emission Factors from AP-42 - Distillate Oil - Boilers less than 100MMBtu/hr except for SO₂
- Mass balance with weight percent sulfur in diesel (F 0.15 wt% S (Title V #AQ0264TVP02 limit))
- Fuel Consumption based on Steam Generating Unit
Heating Value of diesel: 140,000 Btu/gal
This number was calculated from specifications for the Burnham Series 4FH-50 240A boiler
Density of diesel: 7.05 lb/gal (AP-42, Appendix A) using diesel as a fuel
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.

Boiler Emission Calculations - Insignificant Emission Unit

Based on calculations and operations, the boiler is insignificant under 18 AAC 50 and not subject to 40 CFR 63 Subpart JJJJJJ. Each is a hot water boiler with a capacity of less than 120 gallons (49 gallons). These boilers are not subject to 18 AAC 50.326(g)(7), since the rated capacity of each is less than 1.7 MMBtu/hr and the boilers will use #2 fuel oil.

| Source Identification | Rated Capacity (MMBtu/hr) | Fuel Type | Fuel Consumption ⁵ (gallons) | Operating Hours (hrs) |
|--|------------------------------|-------------|--|--------------------------|
| EIE 431 - Conventional Munitions Maintenance Facility (1 of 3) | 0.5 | #2 fuel oil | 29,784 | 8760 |

Emission Calculations for Each Boiler

| Pollutants | Emission Factors ^{3, 6} | | GWP ⁷ | Estimated Emissions | |
|------------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| Criteria | | | | | |
| NO _x | 0.0200 | lb/gal | N/A | 0.30 | tpy |
| CO | 0.005 | lb/gal | N/A | 0.07 | tpy |
| PM ₁₀ | 0.0033 | lb/gal | N/A | 0.32 | tpy |
| SO ₂ ⁴ | 0.0213 | lb/gal | N/A | 0.05 | tpy |
| VOC | 0.00056 | lb/gal | N/A | 0.01 | tpy |
| GHGs | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 315.06 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.27 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 0.80 | metric ton CO _{2e} /yr |
| Total GHGs | | | | 316 | metric ton CO _{2e} /yr |

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- All Criteria Emission Factors from AP-42 - Distillate Oil - Boilers less than 100MMBtu/hr
- Weight percent sulfur in JP-8/diesel 0.15 wt% S (Title V (264TVP02) limit)
- Fuel Consumption based on Steam Generating Unit
 Heating Value of #2 fuel oil: 140,000 Btu/gal
 Density of JP-8/diesel: 7.05 lb/gal (AP-42, Appendix A)
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.
 Based on submittal: 3.4 gal/hr of #2 diesel

Boiler Emission Calculations - Insignificant Emission Unit /

Based on calculations and operations, the boiler is insignificant under 18 AAC 50 and not subject to 40 CFR 63 Subpart JJJJJJ. Each is a hot water boiler with a capacity of less than 120 gallons (49 gallons). These boilers are not subject to 18 AAC 50.326(g)(7), since the rated capacity of each is less than 1.7 MMBtu/hr and the boilers will use #2 fuel oil.

| Source Identification | Rated Capacity (MMBtu/hr) | Fuel Type | Fuel Consumption ⁵ (gallons) | Operating Hours (hrs) |
|--|------------------------------|-------------|--|--------------------------|
| EIE 431 - Conventional Munitions Maintenance Facility (2 of 3) | 0.5 | #2 fuel oil | 29,784 | 8760 |

Emission Calculations for Each Boiler

| Pollutants | Emission Factors ^{3, 6} | | GWP ⁷ | Estimated Emissions | |
|------------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| Criteria | | | | | |
| NO _x | 0.0200 | lb/gal | N/A | 0.30 | tpy |
| CO | 0.005 | lb/gal | N/A | 0.07 | tpy |
| PM ₁₀ | 0.0033 | lb/gal | N/A | 0.32 | tpy |
| SO ₂ ⁴ | 0.0213 | lb/gal | N/A | 0.05 | tpy |
| VOC | 0.00056 | lb/gal | N/A | 0.01 | tpy |
| GHGs | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 315.06 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.27 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 0.80 | metric ton CO _{2e} /yr |
| Total GHGs | | | | 316 | metric ton CO _{2e} /yr |

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- All Criteria Emission Factors from AP-42 - Distillate Oil - Boilers less than 100MMBtu/hr
- Weight percent sulfur in JP-8/diesel 0.15 wt% S (Title V (264TVP02) limit)
- Fuel Consumption based on Steam Generating Unit
 Heating Value of #2 fuel oil: 140,000 Btu/gal
 Density of JP-8/diesel: 7.05 lb/gal (AP-42, Appendix A)
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.
 Based on submittal: 3.4 gal/hr of #2 diesel

Boiler Emission Calculations - Insignificant Emission Unit

Based on calculations and operations, the boiler is insignificant under 18 AAC 50 and not subject to 40 CFR 63 Subpart JJJJJJ. Each is a hot water boiler with a capacity of less than 120 gallons (49 gallons). These boilers are not subject to 18 AAC 50.326(g)(7), since the rated capacity of each is less than 1.7 MMBtu/hr and the boilers will use #2 fuel oil.

| Source Identification | Rated Capacity (MMBtu/hr) | Fuel Type | Fuel Consumption ⁵ (gallons) | Operating Hours (hrs) |
|--|------------------------------|-------------|--|--------------------------|
| EIE 431 - Conventional Munitions Maintenance Facility (3 of 3) | 0.5 | #2 fuel oil | 29,784 | 8760 |

Emission Calculations for Each Boiler

| Pollutants | Emission Factors ^{3, 6} | | GWP ⁷ | Estimated Emissions | |
|------------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| Criteria | | | | | |
| NO _x | 0.0200 | lb/gal | N/A | 0.30 | tpy |
| CO | 0.005 | lb/gal | N/A | 0.07 | tpy |
| PM ₁₀ | 0.0033 | lb/gal | N/A | 0.32 | tpy |
| SO ₂ ⁴ | 0.0213 | lb/gal | N/A | 0.05 | tpy |
| VOC | 0.00056 | lb/gal | N/A | 0.01 | tpy |
| GHGs | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 315.06 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.27 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 0.80 | metric ton CO _{2e} /yr |
| Total GHGs | | | | 316 | metric ton CO _{2e} /yr |

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- All Criteria Emission Factors from AP-42 - Distillate Oil - Boilers less than 100MMBtu/hr
- Weight percent sulfur in JP-8/diesel 0.15 wt% S (Title V (264TVP02) limit)
- Fuel Consumption based on Steam Generating Unit
 Heating Value of #2 fuel oil: 140,000 Btu/gal
 Density of JP-8/diesel: 7.05 lb/gal (AP-42, Appendix A)
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.
 Based on submittal: 3.4 gal/hr of #2 diesel

Process Heater Emission Calculations based on PTE

Boiler is Insignificant based on PTE and rated capacity (<1.7mmBtu/hr, 18 AAC 50.326(g)(7)) and not subject to 40 CFR 63 Subpart JJJJJJ (process heater not a boiler, heated glycol and water mixture in vessel).

BOILER SPECIFICATIONS - second of two boilers to be installed at range - first is significant based on capacity

| Source Identification | Rated Capacity (MMBtu/hr)* | Fuel Type | Fuel Consumption ⁵ (gallons) | Operating Hours (hrs) |
|--|-------------------------------|-----------|--|--------------------------|
| CATM Range Process Heater 2 of 2 | 0.9 | DFA | 53,392 | 8760 |

*Increased rated capacity by 15% because will be heating glycol/water mixture instead of water.

CALCULATIONS

| Pollutants | Emission Factors ^{3, 6} | | GWP ⁷ | Estimated Emissions | |
|------------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| <i>Criteria</i> | | | | | |
| NO _x | 0.0200 | lb/gal | N/A | 0.53 | tpy |
| CO | 0.005 | lb/gal | N/A | 0.13 | tpy |
| PM ₁₀ | 0.0033 | lb/gal | N/A | 0.57 | tpy |
| SO ₂ ⁴ | 0.0213 | lb/gal | N/A | 0.09 | tpy |
| VOC | 0.00056 | lb/gal | N/A | 0.01 | tpy |
| <i>GHGs</i> | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 547.54 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.47 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 1.39 | metric ton CO _{2e} /yr |
| <i>Total GHGs</i> | | | | 549 | metric ton CO _{2e} /yr |

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- All Criteria Emission Factors from AP-42 - Distillate Oil - Boilers less than 100MMBtu/hr
- Weight percent sulfur in diesel **0.15** wt% S (Title V #AQ0264TVP02 limit)
- Fuel Consumption based on Steam Generating Unit
Heating Value of diesel/Jp-8: **140,000** Btu/gal
This number was calculated from specifications for the Burnham Series 4FH-50 92A boiler
Density of JP-8/diesel: **7.05** lb/gal (AP-42, Appendix A) - using diesel as fuel
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.

Process Heater Emission Calculations based on PTE

Each of the two boilers are Insignificant based on calculated PTE and rated capacity (<1.7mmBtu/hr, 18 AAC 50.326(g)(7)) and not subject to 40 CFR 63 Subpart JJJJJJ (process heater not a boiler, heated glycol and water mixture).

Boiler Specifications - One of two boilers installed as primary and backup

| Source Identification | Rated Capacity (MMBtu/hr)* | Fuel Type | Fuel Consumption ⁵ (gallons) | Operating Hours (hrs) |
|--|-------------------------------|-----------|--|--------------------------|
| Missile Maintenance Facility Process Heater (1 of 2) | 0.8 | DFA | 49,056 | 8760 |

*Increased rated capacity by 15% because will be heating glycol/water mixture instead of water.

CALCULATIONS

| Pollutants | Emission Factors ^{3, 6} | | GWP ⁷ | Estimated Emissions | |
|------------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| <i>Criteria</i> | | | | | |
| NO _x | 0.0200 | lb/gal | N/A | 0.49 | tpy |
| CO | 0.005 | lb/gal | N/A | 0.12 | tpy |
| PM ₁₀ | 0.0033 | lb/gal | N/A | 0.52 | tpy |
| SO ₂ ⁴ | 0.0213 | lb/gal | N/A | 0.08 | tpy |
| VOC | 0.00056 | lb/gal | N/A | 0.01 | tpy |
| <i>GHGs</i> | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 503.07 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.43 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 1.28 | metric ton CO _{2e} /yr |
| <i>Total GHGs</i> | | | | 505 | metric ton CO _{2e} /yr |

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- All Criteria Emission Factors from AP-42 - Distillate Oil - Boilers less than 100MMBtu/hr
- Weight percent sulfur in diesel (FS-1) **0.15** wt% S (Title V #AQ0264TVP02 limit)
- Fuel Consumption based on Steam Generating Unit
Heating Value of diesel: **140,000** Btu/gal
This number was calculated from specifications for the Burnham C-20 boiler
Density of diesel: **7.05** lb/gal (AP-42, Appendix A) - using diesel (FS1) as fuel
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.

Process Heater Emission Calculations based on PTE

Each of the two boilers are Insignificant based on calculated PTE and rated capacity (<1.7mmBtu/hr, 18 AAC 50.326(g)(7)) and not subject to 40 CFR 63 Subpart JJJJJJ (process heater not a boiler, heated glycol and water mixture).

Boiler Specifications - One of two boilers installed as primary and backup

| Source Identification | Rated Capacity (MMBtu/hr)* | Fuel Type | Fuel Consumption ⁵ (gallons) | Operating Hours (hrs) |
|--|-------------------------------|-----------|--|--------------------------|
| Missile Maintenance Facility Process Heater (2 of 2) | 0.8 | DFA | 49,056 | 8760 |

*Increased rated capacity by 15% because will be heating glycol/water mixture instead of water.

CALCULATIONS

| Pollutants | Emission Factors ^{3, 6} | | GWP ⁷ | Estimated Emissions | |
|------------------------------|----------------------------------|----------|------------------|---------------------|---------------------------------|
| | | Unit | | | Unit |
| <i>Criteria</i> | | | | | |
| NO _x | 0.0200 | lb/gal | N/A | 0.49 | tpy |
| CO | 0.005 | lb/gal | N/A | 0.12 | tpy |
| PM ₁₀ | 0.0033 | lb/gal | N/A | 0.52 | tpy |
| SO ₂ ⁴ | 0.0213 | lb/gal | N/A | 0.08 | tpy |
| VOC | 0.00056 | lb/gal | N/A | 0.01 | tpy |
| <i>GHGs</i> | | | | | |
| CO ₂ | 73.25 | kg/MMBtu | 1 | 503.07 | metric ton CO _{2e} /yr |
| CH ₄ | 0.003 | kg/MMBtu | 21 | 0.43 | metric ton CO _{2e} /yr |
| N ₂ O | 0.0006 | kg/MMBtu | 310 | 1.28 | metric ton CO _{2e} /yr |
| <i>Total GHGs</i> | | | | 505 | metric ton CO _{2e} /yr |

Notes:

- Based on 18 AAC 50.326(e)
- Based on 18 AAC 50.502 C(3)
- All Criteria Emission Factors from AP-42 - Distillate Oil - Boilers less than 100MMBtu/hr
- Weight percent sulfur in diesel (FS-1) **0.15** wt% S (Title V #AQ0264TVP02 limit)
- Fuel Consumption based on Steam Generating Unit
Heating Value of diesel: **140,000** Btu/gal
This number was calculated from specifications for the Burnham C-20 boiler
Density of diesel: **7.05** lb/gal (AP-42, Appendix A) - using diesel (FS1) as fuel
- GHGs Emission factors are from Tables C-1 and C-2 of 40 CFR 98 Subpart C.
- GWP = Global warming potential. Values from 40 CFR 98 Table A-1.