

STATE OF ALASKA

SEAN PARNELL, GOVERNOR

DEPT. OF ENVIRONMENTAL CONSERVATION

**DIVISION OF SPILL PREVENTION AND RESPONSE
CONTAMINATED SITES PROGRAM**

555 Cordova Street
Anchorage, AK 99501
PHONE (907) 269-3077
FAX (907) 269-7649
www.dec.state.ak.us

File No: 2649.38.001

January 6, 2012

Keith Barnack, Remedial PM
United States Air Force
611 Air Support Group
Environmental Restoration Section
10471 20th Street Ste 302
JBER, AK 99506-2200

Re: Eareckson Air Station Leaking Underground Storage Tank 1001-1 ADEC Tank
#71 Site Closure


Dear Mr. Barnack:

The Alaska Department of Environmental Conservation (ADEC) Federal Facilities Oversight group is concerned about a large number of Leaking Underground Storage Tanks (LUST) sites that are located at Eareckson Air Station. Tank 1001-1 was a 2,500 gallon diesel storage tank that contained the fuel supply for the heating system at Building 1001.

ADEC has reviewed the available information regarding Tank 1001-1 (ADEC Tank #71) and its removal in July 1997. Based on the sampling and analysis performed in 1997 and again in 1999, the maximum concentration of DRO was 1,700 mg/kg, but this concentration was not found in subsequent sampling in 1999. Additionally, the pipeline feeding Building 1001 was removed and its path investigated for any past releases from the pipeline. It was determined that the soil in this area was not impacted. The extent of the impacted soil has been delineated and there is no concern for the contaminant's migration to groundwater because of the great depth of groundwater in this area. This site will be closed on the ADEC Contaminated Sites database.

The State appreciates your continued coordination on this and other projects at Eareckson Air Station. If you have any questions regarding this letter, please contact me at (907) 269-3077 or jonathan.schick@alaska.gov.

Sincerely,



Jonathan Schick
Environmental Program Specialist