



THE STATE  
of **ALASKA**  
GOVERNOR MICHAEL J. DUNLEAVY

## Department of Environmental Conservation

DIVISION OF SPILL PREVENTION AND RESPONSE  
Contaminated Site Program

43335 Kalifornsky Beach Road, Suite 11  
Soldotna, AK 99669  
Main: 907.262.5210  
Fax: 907.262.2294

File: 2540.38.017

April 6, 2023

Ms. Christina Bentz  
Delta Western, LLC  
420 L Street, Suite 101  
Anchorage, AK 99501

Re: Delta Western Tank Farm - Dillingham  
Hazard ID No. 25770  
2022 Groundwater Monitoring Report  
ADEC Approval

Dear Ms. Bentz:

On March 14, 2023, the Alaska Department of Environmental Conservation (ADEC) received the 2022 Groundwater Monitoring Report Delta Western Terminal - Dillingham, dated March 8, 2023, for the Delta Western Tank Farm – Dillingham site. Farallon Consulting, L.L.C. prepared this report on behalf of Delta Western, LLC. Thank you for providing this report for our review. The report is approved.

In future reports, please document conditions of the sheet pile wall. If there are active seeps, photograph and collect representative water samples. Inspect and document the condition of drain holes in the sea wall, dike drain and seeps. These observations are to determine if outfall from precipitation, impacted groundwater or tidal drainage are impacting the Nushagak River.

Please contact me at [peter.campbell@alaska.gov](mailto:peter.campbell@alaska.gov) or by phone at 262-3412 if you have any comments or questions regarding this letter, or any other aspect of this project.

Sincerely,

*Peter Campbell*

Peter Campbell  
Environmental Program Specialist

CC: Stuart Brown – Farallon Consulting by email