



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

**Department of Environmental
Conservation**

DIVISION OF SPILL PREVENTION AND RESPONSE
Prevention, Preparedness, and Response Program

555 Cordova Street
Anchorage, AK 99501-2617
Main: 907-269-3094
Fax: 907-269-7687#
www.dec.alaska.gov

Facility #: 2291

March 12, 2020

Mr. Scott Mulvihill
Crowley Fuels LLC
201 Arctic Slope Avenue
Anchorage, AK 99518

Subject: Crowley Fuels St Mary's Oil Discharge Prevention and Contingency Plan, ADEC Plan #:16-CP-2190; Temporary Waiver of Tank Truck Loading Area Secondary Containment

Dear Mr. Mulvihill:

The Alaska Department of Environmental Conservation (department) received a waiver request for the Crowley Fuels St. Mary's Oil Discharge Prevention and Contingency Plan (plan) on March 12, 2020. The temporary waiver request has been evaluated and approved in accordance with 18 AAC 75.015 by the department, subject to the following:

Waiver description: Crowley Fuels LLC (Crowley), St Mary's Bulk Fuel Facility requires a temporary waiver of 18 AAC 75.075(g)(1) tank truck loading area secondary containment requirements. The permanent tank truck loading area containment system at the facility is currently frozen over and ineffective to contain 2500 gallons of their largest fuel truck compartment. Crowley is the only petroleum company in St. Mary's Alaska providing essential fuel support for the St. Mary's community and to the local regional airport. Crowley needs to maintain critical deliveries of home heating oil and jet fuel support until materials arrive on-site to construct a temporary tank truck loading area containment system. The temporary system will be constructed using snow/sandbagged berms and lined with of 20 mil liner (doubled 10 mil with felt) material. Crowley has indicated in their letter dated March 12, 2020 that material are en-route to St. Marys and the temporary containment set-up is scheduled to be completed on/before March 15, 2020.

Effective date: March 12, 2020 thru March 30, 2020

Condition(s) of approval: The approval is subject to the following conditions:


1. Crowley facility operators must perform a visual inspections of the loading area prior too and after positioning the truck in the temporary containment system to ensure the liner material is not damaged,
2. Two employees must be at the truck/loading rack during filling operations,
3. Civacon On-Tank Overfill Prevention System must be used during filling operations,

4. Provide photographs of the temporary containment system to the department.

Please be advised that this approval does not relieve Crowley Fuels, LLC of the responsibility for securing other state, federal, or local approvals or permits, and that Crowley Fuels, LLC is still required to comply with all other applicable laws and regulations.

If you have any questions, please contact me at 907-269-7682 or contact Mark Sielaff at 907-269-7532 or mark.sielaff@alaska.gov.

Sincerely,



Crystal Smith
Central Region Manager

cc:

Megan Johnnie, Crowley Fuels LLC
Bernie Nowicki, ADEC
Jeanette Alas, ADF&G
DNR.CPlans@alaska.gov, ADNR
Chris Burns, Chadux
Sector Anchorage, USCG