

# Monitoring Summary for COLLEGE UTILITIES CORPORATION

Public water system ID#AK2310900

Population: 27000

March 27, 2026

Community Water System, Ground water purchased

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	07/30/2024	2027
<b>DS COLLEGE UTILITIES CORPORATION (Facility ID:DS001)</b>				
COLIFORM (TCR)	SPDS001TCR	30 sample(s) monthly	02/19/2026	Monthly, according to Sample Siting Plan
TTHM & HAA5 (DBP2)	SPDS1DBP2-4	4 sample(s) quarterly	01/06/2026	See stage 2 sampling detail information below
LEAD AND COPPER	SPDS001PC	30 sample(s) every 3 years	09/19/2025	2028
<b>TP EAST RAMP RESERVOIR (Facility ID:TP002)</b>				
PFAS INITIAL MON	SPTP002	1 sample(s) quarterly		Collect 4 Quarterly samples, 2-4 months apart

## Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
DBP2	SPDS1DBP2-1	REWAK / (A)	1	January, April, July, and October
DBP2	SPDS1DBP2-2	TAMARACK AIR / (C)	1	January, April, July, and October
DBP2	SPDS1DBP2-3	YAK PLR / (G)	1	January, April, July, and October
DBP2	SPDS1DBP2-4	BALLAINE / (D)	1	January, April, July, and October

## Operator Report

Requirement	Location	Sampling Frequency	Last Report
CHLORINE	Distribution System	Same time/place as routine TCR sample	

## Compliance Schedules

Schedule/Action	Due	Comments
<b>Sanitary Survey Corrective Actions</b>		
CORRECTIVE ACTIONS	08/31/2026	A new chemical feed pump was installed at the East Ramp pump and booster chlorination station without obtaining prior approval. In order to construct, install, alter, renovate, operate, or improve a public water system, or a part of one, the owner must have prior written approval of engineering plans in accordance with 18 AAC 80.200(b). Schedule extended to account for engineering review.
<b>AWIA</b>		
AWIA RISK ASSESSMENT UPDATE DUE TO EPA	06/30/2026	For additional information, refer to: <a href="http://dec.alaska.gov/eh/dw/security/regulations/awia-regulations">http://dec.alaska.gov/eh/dw/security/regulations/awia-regulations</a>
AWIA EMERG. RESP PLAN UPDATE DUE TO EPA	12/30/2026	For additional information, refer to: <a href="http://dec.alaska.gov/eh/dw/security/regulations/awia-regulations">http://dec.alaska.gov/eh/dw/security/regulations/awia-regulations</a>

LSLN		
SUBMIT CERT LSL/GRR/UNKNOWN NOTIFICATION	07/01/2026	PWS required to notify affected consumers in 2025 and certify to state by 7/1/26
Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2026	CCR due to customers and DEC by July 1, 2026
CCR - CERTIFICATION PAGE	09/30/2026	CCR Certification due to DEC by October 1, 2026

\*\*NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2026 - 12/31/2028 and the next period will be 1/1/2029 - 12/31/2031. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2026 - 12/31/2031, the next 6 year period will be 01/01/2032 - 12/31/2037. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2026 - 12/31/2034 and the next cycle is 01/01/2035 - 12/31/2043.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at [dec.water.fco.opcert@alaska.gov](mailto:dec.water.fco.opcert@alaska.gov).

**Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.**

Monitoring summary completed by Mike Sharp, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-451-2178 or 1-800-770-2137 Email: [mike.sharp@alaska.gov](mailto:mike.sharp@alaska.gov) Fax: (907) 451-2188.

Sincerely,

Mike Sharp  
Environmental Program Specialist