

# Monitoring Summary for CRAIG PUBLIC WORKS

Public water system ID#AK2120193

Population: 1475

February 7, 2024

Community Water System, Surface water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	03/22/2023	2026
<b>DS NORTH FORK LAKE (Facility ID:DS001)</b>				
COLIFORM (TCR)	SPDS001TCR	2 sample(s) monthly	01/08/2024	Monthly, according to Sample Siting Plan
HAA5 (HALOACETIC)	SPDS1DBP2-H	1 sample(s) quarterly	10/09/2023	See stage 2 sampling detail information below
TOTAL TRIHALOMETHANE	SPDS1DBP2-T	1 sample(s) quarterly	10/09/2023	See stage 2 sampling detail information below
LEAD AND COPPER	SPDS001PC	10 sample(s) every 3 years	09/21/2023	2026
<b>IN NORTH FORK LAKE (Facility ID:IN001)</b>				
TOC & ALKALINITY	SPIN001	1 sample(s) quarterly	12/13/2023	Quarterly
<b>TP FOR NORTH FORK LAKE (Facility ID:TP001)</b>				
SOC	SPTP001	1 sample(s) quarterly	06/20/2006	Submit SOC waiver renewal application by Sept 30, 2024
CARBON, TOTAL	SPTP001	1 sample(s) quarterly	12/13/2023	Quarterly
NITRATE	SPTP001	1 sample(s) annually	10/02/2023	2024
VOC	SPTP001	1 sample(s) annually	10/02/2023	2024
ARSENIC - SINGLE	SPTP001	1 sample(s) per 9 year cycle	08/16/2022	Between 2029 and 2037
INORGANICS	SPTP001	1 sample(s) per 9 year cycle	08/16/2022	Between 2029 and 2037
RADIUM 226 AND 228	SPTP001	1 sample(s) per 9 year cycle	08/16/2022	Between 2026 and 2034
TOTAL GROSS ALPHA	SPTP001	1 sample(s) per 9 year cycle	08/16/2022	Between 2026 and 2034

## Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
TTHM	SPDS1DBP2-T	BEACH & CEDAR	1	January, April, July, and October
HAA5	SPDS1DBP2-H	EAST SCHOOL DR.	1	January, April, July, and October

## Operator Report

Requirement	Location	Sampling Frequency	Last Report	
TURBIDITY	After Filters	Daily - Every 4 hours while treatment plant is operating	12/01/2023	Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).
CHLORINE	Distribution System	Same time/place as routine TCR sample	01/01/2024	
CHLORINE	Entry Point	Daily	12/01/2023	

Compliance Schedules		
Schedule/Action	Due	Comments
<b>LCRR</b>		
SUBMIT DRAFT LSL INVENTORY	04/24/2024	Submit Draft of Lead Service Line Inventory to DEC by 4/24/2024. For more information visit DW LCRR website <a href="https://dec.alaska.gov/eh/dw/lcrr/">https://dec.alaska.gov/eh/dw/lcrr/</a>
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	Please submit a completed Lead Service Line Inventory to DEC by 10/16/2024.
<b>Sanitary Survey Corrective Actions</b>		
CORRECTIVE ACTION	10/10/2023	Hose used to fill sand filter after a backwash was submerged in the filter while filling. This must be shortened or fitted with a BFP to resolve the deficiency. -MHYDE
CORRECTIVE ACTION	10/10/2023	Turbidimeter waste lines go into the sewer collection point. These must be shortened to have an appropriate air gap. -MHYDE
CORRECTIVE ACTION	10/10/2023	THIS IS FOR TWO DEFICIENCIES -MHYDE  Petro Marine dock and north and south harbors need backflow preventers.  Bunkhouse connection point was disconnected and open to the air. This line must be capped when not in use. --06/29/2023 Tony sent me a picture of the connected bunkhouse. I asked if there was a cap to keep the hose protected when it's not in use. -MHYDE
<b>LCNT</b>		
LCR- CONSUMER NOTICE DUE TO CONSUMER	01/08/2024	OVERDUE: Craig Public Works had one high lead sample results but did not exceed the 90th percentile. Please complete & distribute consumer notices to applicable sample sites by 1/8/2024.
LCR- CONSUMER NOTICE CERT. DUE TO STATE	01/18/2024	OVERDUE: A copy of the completed consumer notices will be due to DEC by 1/18/2024.
<b>Consumer Confidence Report</b>		
CCR - SUBMITTAL	06/30/2024	CCR due to customers and DEC by July 1, 2024
CCR - CERTIFICATION PAGE	09/30/2024	CCR Certification due to DEC by October 1, 2024

\*\*NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified

Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at [dec.water.fco.opcert@alaska.gov](mailto:dec.water.fco.opcert@alaska.gov).

**Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.**

Monitoring summary completed by Christina Harris, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-262-3420 or 1-866-956-7656 Email: [christina.harris@alaska.gov](mailto:christina.harris@alaska.gov) Fax: (907) 262-2294.

Sincerely,

Christina Harris  
Environmental Program Specialist