

# Monitoring Summary for WARD COVE DELI & LIQUOR

Public water system ID#AK2120729

Population: 110

March 27, 2025

Non community water system, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 5 years	11/17/2020	2025
<b>DS ROOF CATCHMENT (Facility ID:DS001)</b>				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	12/10/2024	Overdue; Collect ASAP
<b>TP FOR ROOF CATCHMENT (Facility ID:TP001)</b>				
NITRATE	SPTP001	1 sample(s) annually	12/10/2024	2025

Operator Report				
Requirement	Location	Sampling Frequency	Last Report	
TURBIDITY	After Filters	Daily when making water	01/01/2025	Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).
CHLORINE	Distribution System	Same time/place as routine TCR sample	01/01/2025	
CHLORINE	Entry Point	Daily	01/01/2025	

Compliance Schedules		
Schedule/Action	Due	Comments
<b>Sanitary Survey Corrective Actions</b>		
CORRECTIVE ACTION	03/14/2021	OVERDUE: This has incurred a violation that will remain open until an engineering submittal addressing this issue has been submitted to the Department. The galvanized steel storage tank and recently installed aluminum roof may not meet the requirements for contact with potable water. Please contact DEC engineer, Charity Bare at <a href="mailto:charity.bare@alaska.gov">charity.bare@alaska.gov</a> or by phone at 907-262-3400 to discuss requirements.
CORRECTIVE ACTION	03/14/2021	OVERDUE: This has incurred a violation that will remain open until an engineering submittal addressing this issue has been submitted to the Department. The surveyor noted there is no flow control valve and the rate of flow through the filters might not be adequately controlled to meet filtration objective/requirements. Please contact Charity Bare ( <a href="mailto:charity.bare@alaska.gov">charity.bare@alaska.gov</a> ; 907-262-3400) to provide an update on this issue. - 3/18/2022 CRH

\*\*NSF = No sample found

- Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.

- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at [dec.water.fco.opcert@alaska.gov](mailto:dec.water.fco.opcert@alaska.gov).

**Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.**

Monitoring summary completed by Christina Harris, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-262-3420 or 1-866-956-7656 Email: [christina.harris@alaska.gov](mailto:christina.harris@alaska.gov) Fax: (907) 262-2294.

Sincerely,

Christina Harris  
Environmental Program Specialist