## **Monitoring Summary for CLOVER BAY LODGE**

Public water system ID#AK2121034

Non community water system, Surface water

Population: 59

April 4, 2024

	Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample				
	Sanitary Survey		Every 5 years	08/15/2023	2028				
DI	DISTRIBUTION SYSTEM (Facility ID:DS001)								
	COLIFORM (TCR)	SPDS001TCR	1 sample monthly	08/14/2023	Monthly during operation				
TP	TP FOR CLOVER BAY LODGE (Facility ID:TP001)								
	NITRATE	SPTP001	1 sample annually	06/26/2023	2024				

<b>Operator Report</b>				
Requirement	Location	Sampling Frequency	Last Report	
TURBIDITY	After Filters	1 sample each day water is filtered		Test and record daily. Send reports to ADEC on
Distribution Chlorine	Distribution System	Same time/place as routine TCR sample - record on TCR lab form	mo	the last day of the month (before the 10th day of the following month).
Entry Point Chlorine	Entry Point	1 sample per day		

Compliance Schedules							
Schedule/Action	Due	Comments					
Seasonal Start Up							
RTCR-SEASONAL START-UP PROCEDURES	06/25/2024	Complete start up procedures BEFORE serving water to the public					
RTCR-SUBMIT SEASONAL START-UP CERT FORM	07/06/2024	Submit Seasonal Start-up certification form to DEC within 10 days of serving water to the public. Electronic forms can be found on the DEC website: https://dec.alaska.gov/eh/dw/forms/					

## \*\*NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 12/31/2025 and the next period will be 1/1/2026 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 12/31/2028 and the next cycle is 1/1/2029 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 12/31/2025, the next 6 year period will be 01/01/2026 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 12/31/2025 and the next cycle is 01/01/2026 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at http://dec.alaska.gov/eh/dw/soc/.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx? p=OperatorSearch. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by James Latimer, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907 -262-3410 or Email: james.latimer@alaska.gov Fax: 907-262-2294.

Sincer	elv.

James Latimer Environmental Program Specialist