

Monitoring Summary for SNOWCREST VIEW SOUTH

Public water system ID#AK2210891

Population: 25

February 20, 2025

Community Water System, Ground water

	Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
	Sanitary Survey		Every 3 years	06/06/2022	2025
DISTRIBUTION SYSTEM (Facility ID:DS001)					
	COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	01/30/2025	Monthly, according to Sample Siting Plan
	LEAD AND COPPER	SPDS001PC	5 sample(s) annually	05/30/2024	2025
1 WELL (Facility ID:WL001)					
	SOC	SPWL001	1 sample(s) quarterly	02/01/2016	Quarterly in 2025
	NITRATE	SPWL001	1 sample(s) annually	09/30/2024	2025
	VOC	SPWL001	1 sample(s) per 3 year period	03/02/2023	Between 2026 and 2028
	RADIUM 226 AND 228	SPWL001	1 sample(s) per 9 year cycle	03/07/2016	Between 2017 and 2025
	TOTAL GROSS ALPHA	SPWL001	1 sample(s) per 9 year cycle	03/07/2016	Between 2017 and 2025
	ARSENIC - SINGLE	SPWL001	1 sample(s) per 9 year cycle	02/01/2019	Between 2020 and 2028
	INORGANICS	SPWL001	1 sample(s) per 9 year cycle	02/01/2019	Between 2020 and 2028

Compliance Schedules

Schedule/Action	Due	Comments
LCRR		
SUBMIT DRAFT LSL INVENTORY	01/24/2024	Submit Draft of Lead Service Line Inventory for more information visit DW LCRR website https://dec.alaska.gov/eh/dw/lcrr/
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
LCNT		
LCR- CONSUMER NOTICE DUE TO CONSUMER	10/05/2023	Send LCN to consumer
LCR- CONSUMER NOTICE CERT. DUE TO STATE	12/04/2023	certification due to DEC via email at elizabeth.nakanishi.gov
Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2024	Overdue
CCR - CERTIFICATION PAGE	09/30/2024	Overdue
LCNT		
LCR- CONSUMER NOTICE DUE TO CONSUMER	04/05/2024	Provide Lead Consumer Notifications to the consumers
LCR- CONSUMER NOTICE CERT. DUE TO STATE	06/04/2024	Lead Consumer Notification Certification due to DEC at elizabeth.nakanishi@alaska.gov

LCNT		
LCR- CONSUMER NOTICE DUE TO CONSUMER	07/22/2024	LCN due to the consumers -
LCR- CONSUMER NOTICE CERT. DUE TO STATE	10/29/2024	LCN cert due to DEC via email to elizabeth.nakanishi@alaska.gov
Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2025	CCR due to customers and DEC by July 1st annually
CCR - CERTIFICATION PAGE	09/30/2025	CCR Certification due to DEC by October 1st annually. A copy of the template can be found at: https://dec.alaska.gov/eh/dw/forms/

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Elizabeth Nakanishi, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-269-7517 or 1-866-956-7656 Email: elizabeth.nakanishi@alaska.gov Fax: 907-269-7650.

Sincerely,

Elizabeth Nakanishi
Environmental Program Specialist