

Monitoring Summary for EAST ANCHORAGE MHP

Public water system ID#AK2211025

Population: 480

March 29, 2019

Community Water System, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	12/08/2011	Overdue Survey; Schedule ASAP
DISTRIBUTION SYSTEM (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	02/11/2019	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	5 sample(s) every 3 years	12/08/2015	Overdue (Submit materials evaluation & Sampling pool section prior to sampling)
WELL #2 (Facility ID:WL002)				
SOC	SPWL002	1 sample(s) quarterly		Jan-March; April-June; July-Sept; Oct-Dec
NITRATE	SPWL002	1 sample(s) annually	03/21/2017	Overdue; Collect ASAP
VOC	SPWL002	1 sample(s) per 3 year period	03/21/2017	Between 2020 and 2022
INORGANICS	SPWL002	1 sample(s) per 9 year cycle	12/13/2011	Between 2020 and 2028
RADIUM 226 AND 228	SPWL002	1 sample(s) per 9 year cycle	03/21/2017	Between 2026 and 2034
TOTAL GROSS ALPHA	SPWL002	1 sample(s) per 9 year cycle	03/21/2017	Between 2026 and 2034
ARSENIC - SINGLE	SPWL002	1 sample(s) per 9 year cycle	01/09/2019	Between 2020 and 2028

Compliance Schedules		Due	Comments
Emergency Preparedness Regulation			
EPR-PMP CERTIFICATION		08/20/2013	CWS serving population of less than 1,000 persons, required to complete a Priority Measures Plan (PMP). Contact EPS Justin Fenzl at 269-7517 or Justin.Fenzl@alaska.gov to get help completing this requirement.
Sample Siting Plan			
RTCR-SAMPLE SITING PLAN		03/31/2016	This is a plan that outlines where to take total coliform sample in the distribution system. Contact EPS Justin Fenzl at 269-7517 or Justin.Fenzl@alaska.gov with questions on how to develop the sampling plan.
SOC			
SOC – SUBMIT INITIAL SOC WAIVER APPLICAT		09/30/2018	PWS did not submit SOC Waiver renewal application for 2014-2016 mon period so if system plans to request a waiver for 2017-2019 mon period, must submit an initial waiver application.

Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2019	The 2018 Consumer Confidence Report is required to be submitted to DEC each year by June 30. Please contact Justin Fenzl at 269-7517 or Justin.Fenzl@alaska.gov if you have any questions or need help completing the report.
CCR - CERTIFICATION PAGE	09/30/2019	The 2018 CCR Certification page is required to be submitted to DEC each year by September 30. Please contact Justin Fenzl at 269-7517 or Justin.Fenzl@alaska.gov if you have any questions or need help completing the report.

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2017 - 12/31/2019 and the next period will be 1/1/2020 - 12/31/2022. Cycles are nine years in length. The current cycle is from 1/1/2011 - 12/31/2019 and the next cycle is 1/1/2020 - 12/31/2028.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2014 - 12/31/2019, the next 6 year period will be 01/01/2020 - 12/31/2025. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://www.dec.alaska.gov/eh/dw/publications/forms.html>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring summaries reflect sampling information the Drinking Water Program receives from certified laboratories and public water systems. If you notice any errors in this data, please contact your local ADEC Drinking Water Program office. Public water systems are responsible for compliance with monitoring requirements.

Monitoring summary completed by Justin Fenzl, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at (907) 269-7517 or 1-866-956-7656 Email: justin.fenzl@alaska.gov Fax: (907) 269-7650.

Sincerely,

Justin Fenzl
Environmental Program Specialist