

# Monitoring Summary for CREEKWOOD INN AND RV PARK

Public water system ID#AK2213140

Population: 107

April 29, 2024

Non community water system, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 5 years	12/20/2023	2028
<b>DISTRIBUTION SYSTEM (Facility ID:DS001)</b>				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	09/06/2023	Monthly
<b>WELL (Facility ID:WL001)</b>				
NITRATE	SPWL001	1 sample(s) annually	04/28/2023	2024

## Compliance Schedules

Schedule/Action	Due	Comments
<b>Seasonal Start Up</b>		
RTCR-SEASONAL START-UP PROCEDURES	06/10/2024	Complete start up procedures BEFORE serving water to the public.
RTCR-SUBMIT SEASONAL START-UP CERT FORM	06/20/2024	Submit Seasonal Start-up certification form to DEC within 10 days of serving water to the public. Electronic forms can be found on the DEC website: <a href="https://dec.alaska.gov/eh/dw/forms/">https://dec.alaska.gov/eh/dw/forms/</a>
<b>Sanitary Survey Corrective Actions</b>		
CORRECTIVE ACTIONS	07/05/2024	Improper Drainage (DRNG)- The well is located in a pit/below grade which allows water to pool around the casing. The sump pump in the well house only comes on when someone manually plugs it into an outlet, and there is no water alarm installed. The surveyor noted cracks in the concrete, as well as, the basements history of flooding. The PWS must contact a registered engineer to assess the existing facilities and coordinate with engineering plan review to implement a system that will protect the well. Please contact Chris Pletnikoff at (907) 269-6064 or <a href="mailto:chris.pletnikoff@alaska.gov">chris.pletnikoff@alaska.gov</a> to get corrective action plan approved before commencing work.

\*\*NSF = No sample found

- Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.

8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at [dec.water.fco.opcert@alaska.gov](mailto:dec.water.fco.opcert@alaska.gov).

**Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.**

Monitoring summary completed by Elizabeth Nakanishi, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-269-7517 or 1-866-956-7656 Email: [elizabeth.nakanishi@alaska.gov](mailto:elizabeth.nakanishi@alaska.gov) Fax: 907-269-7650.

Sincerely,

Elizabeth Nakanishi  
Environmental Program Specialist