

Monitoring Summary for OCEAN VIEW CENTER - LOT VANDER HOEK 2D

Public water system ID#AK2214609

Population: 30

September 14, 2020

Non-transient non-community, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 5 years		Overdue Survey; Schedule ASAP
DS VANDER HOEK S/D QUIK STOP (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	10/16/2019	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	2 consecutive 6 month sets, 5 sample(s) per set		Collect sample set during 1st half (Jan.-June) and 2nd half (July-Dec.) of the year.
ARSENIC - SINGLE	SPDS001	1 sample(s) quarterly		Quarterly
ASBESTOS - SINGLE	SPDS001	1 sample(s) per 3 year period		Between 2020 and 2022
WL VANDER HOEK S/D QUIK STOP (Facility ID:WL001)				
GROSS ALPHA	SPWL001	1 sample(s) quarterly		Collect four consecutive quarters for composite analysis.
RADIUM 226 AND 228	SPWL001	1 sample(s) quarterly		Collect four consecutive quarters for composite analysis.
SOC	SPWL001	1 sample(s) quarterly		Submit 2020-2022 SOC Initial Waiver Application by September 30, 2021
VOC	SPWL001	1 sample(s) quarterly		Quarterly
NITRATE	SPWL001	1 sample(s) annually	10/16/2019	2020
INORGANICS	SPWL001	1 sample(s) per 3 year period		Between 2020 and 2022

Compliance Schedules		
	Due	Comments
Notice of Violation Schedule		
RTCR-SAMPLE SITING PLAN	03/06/2019	Please fill in the RTCR sample siting plan template and submit it for approval to your EPS via email at elizabeth.nakanishi@alaska.gov
ENGI-INTERIM APPROVAL TO OPERATE	03/06/2019	Please contact your Drinking Water Program engineer Darlene Galido at 907-269-7516 or via email at darlene.galido@alaska.gov

**NSF = No sample found

- Periods are three years in length. The current period is 1/1/2020 - 12/31/2022 and the next period will be 1/1/2023 - 12/31/2025. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://www.dec.alaska.gov/eh/dw/publications/forms.html>.

Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking

8) water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring summaries reflect sampling information the Drinking Water Program receives from certified laboratories and public water systems. If you notice any errors in this data, please contact your local ADEC Drinking Water Program office. Public water systems are responsible for compliance with monitoring requirements.

Monitoring summary completed by Elizabeth Nakanishi, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at (907) 269-7517 or 1-866-956-7656 Email: elizabeth.nakanishi@alaska.gov Fax: (907) 269-7650.

Sincerely,

Elizabeth Nakanishi
Environmental Program Specialist