

Monitoring Summary for CREEKWOOD PARK WATER SYSTEM

Public water system ID#AK2220154

Population: 192

March 28, 2024

Community Water System, Surface water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	10/27/2022	2025
DS DISTRIBUTION SYSTEM (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	02/16/2024	Monthly, according to Sample Siting Plan
TTHM & HAA5 (DBP2)	SPDS1DBP2-6	2 sample(s) quarterly	01/30/2024	See stage 2 sampling detail information below
LEAD AND COPPER	SPDS001PC	5 sample(s) every 3 years	12/29/2022	2025
TREATMENT-SURFACE WATER SOURCE (Facility ID:TP002)				
SOC	SPTP002	1 sample(s) quarterly		Submit SOC waiver renewal application by Sept 30, 2024
ARSENIC - SINGLE	SPTP002	1 sample(s) annually	11/09/2023	2024
NITRATE	SPTP002	1 sample(s) annually	11/09/2023	2024
VOC	SPTP002	1 sample(s) annually	12/07/2023	2024
TOTAL GROSS ALPHA	SPTP002	1 sample(s) per 6 year period	02/02/2017	Between 2020 and 2025
RADIUM 226 AND 228	SPTP002	1 sample(s) per 9 year cycle	07/21/2016	Between 2017 and 2025
INORGANICS	SPTP002	1 sample(s) per 9 year cycle	05/14/2019	Between 2020 and 2028

Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
DBP2	SPDS1DBP2-5	1975 N. CREEKWOOD PARK CIR. UNIT D	1	January, April, July, and October
DBP2	SPDS1DBP2-6	1940 N. CREEKWOOD PARK CIR., UNIT B	1	January, April, July, and October

Operator Report

Requirement	Location	Sampling Frequency	Last Report	
TURBIDITY	After Filters	1 samples 20 days per month	02/01/2024	Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).
CHLORINE	Distribution System	Same time/place as routine TCR sample	02/01/2024	
CHLORINE	Entry Point	1 samples 20 days per month	02/01/2024	

Compliance Schedules

Schedule/Action	Due	Comments
LCRR		
COMPLETE INITIAL LSL INVENTORY	10/16/2024	LSLI draft submitted via EXCEL 1/24/2024. Awaiting DEC review.

Consumer Confidence Report

CCR - SUBMITTAL	06/30/2024
CCR - CERTIFICATION PAGE	09/30/2024

Public Notice Schedules

PN Action	PN Due	Certification Due	Comments
PN-TIER 2 PUBLIC NOTICE REQUIRED	07/31/2023	09/30/2023	Tier 2 PN required for exceeding TTHM & HAA5 LRAA in 2nd quarter.

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Amy Hill, Environmental Program Manager/ADEC. If you have any questions please contact ADEC at 907-376-1861 or 1-866-956-7656 Email: amy.hill@alaska.gov Fax: 907-376-2382.

Sincerely,

Amy Hill
Environmental Program Manager