## **Monitoring Summary for FORKS ROADHOUSE REBORN**

Public water system ID#AK2223527

Non community water system, Ground water

Population: 130 February 7, 2024

	Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample		
	Sanitary Survey		Every 5 years	10/03/2023	2028		
NEW DISTRIBUTION SYSTEM (Facility ID:DS001)							
	COLIFORM (TCR)	SPDS002TCR	1 sample(s) quarterly	12/15/2023	Quarterly, according to Sample Siting Plan		
NEW WELL (Facility ID:WL002)							
	NITRATE	SPWL002	1 sample(s) annually	12/15/2023	2024		

Compliance Schedules					
Schedule/Action	Due	Comments			
Sanitary Survey Corrective Actions					
CORRECTIVE ACTIONS	03/29/2024	The sanitary seal is missing a bolt that is near the wire conduit. There is a gap and the sanitary seal is not seated correctly. The system owner or operator will need to install a bolt in the sanitary seal and seat the seal so the gasket is tight. Please correct his significant deficiency by the corrective action date listed above. Please provide photos and a written response to the Department.			

## \*\*NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 12/31/2025 and the next period will be 1/1/2026 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 12/31/2028 and the next cycle is 1/1/2029 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 12/31/2025, the next 6 year period will be 01/01/2026 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 12/31/2025 and the next cycle is 01/01/2026 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at http://dec.alaska.gov/eh/dw/soc/.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx? p=OperatorSearch. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Courtney Schuman, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-269-7584 or Email: courtney.schuman@alaska.gov Fax: .

Courtney Schuman Environmental Program Specialist