

Monitoring Summary for OCEAN MARINE SERVICES LLC WATER HAULING

Public water system ID#AK2249229

Population: 449

July 23, 2025

Non-transient non-community, Ground water purchased

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 5 years	10/09/2023	2028
GWP FROM HILCORP RIG TENDERS WL3 249211 (Facility ID:CC002)				
TTHM & HAA5 (DBP2)	-See below-	1 sample annually		See stage 2 sampling detail information below
DISTRIBUTION FOR ALL OMS 249229 VESSELS (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	3 samples monthly	05/01/2017	Collect 1 monthly sample from each active vessel & record chlorine residual on lab form.

Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
DBP2	SPCC2DBP2-1	TTHM/HAA5 SAMPLE POINT	1	August 2025

Operator Report

Requirement	Location	Sampling Frequency	Last Report	
Chlorine residual	Distribution System	Same time/place as each routine TCR sample		Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).

**NSF = No sample found

- Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by James Latimer, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-262-3410 or Email: james.latimer@alaska.gov Fax: 907-262-2294.

Sincerely,

James Latimer
Environmental Program Specialist