

# Monitoring Summary for ATKA

Public water system ID#AK2260058

Population: 50

February 15, 2024

Community Water System, Surface water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
-------------	-----------------	-----------------------------	-------------	-------------

Sanitary Survey		Every 3 years	06/28/2022	2025
-----------------	--	---------------	------------	------

## DISTRIBUTION SYSTEM (Facility ID:DS001)

COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	11/13/2023	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	5 sample(s) every 3 years	12/02/2023	2026
HAA5 (HALOACETIC)	SPDS1DBP2-H	1 sample(s) annually	11/21/2023	See stage 2 sampling detail information below
TOTAL TRIHALOMETHANE	SPDS1DBP2-T	1 sample(s) annually	11/21/2023	See stage 2 sampling detail information below

## NEW TREATMENT PLANT (Facility ID:TP002)

SOC	SPTP002	1 sample(s) quarterly	05/21/1992	Submit SOC waiver renewal application by Sept 30, 2024
NITRATE	SPTP002	1 sample(s) annually	12/05/2022	Overdue; Collect ASAP
VOC	SPTP002	1 sample(s) annually	11/21/2023	2024
ARSENIC - SINGLE	SPTP002	1 sample(s) per 9 year cycle	10/15/2012	Between 2020 and 2028
RADIUM 226 AND 228	SPTP002	1 sample(s) per 9 year cycle	10/15/2012	Between 2017 and 2025
TOTAL GROSS ALPHA	SPTP002	1 sample(s) per 9 year cycle	10/15/2012	Between 2017 and 2025
INORGANICS	SPTP002	1 sample(s) per 9 year cycle	10/15/2012	Between 2020 and 2028

## Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
HAA5	SPDS1DBP2-H	CLINIC	1	September 2024
TTHM	SPDS1DBP2-T	CLINIC	1	August 2024

## Operator Report

Requirement	Location	Sampling Frequency	Last Report	
TURBIDITY	After Filters	1 samples 20 days per month	12/01/2023	Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).
CHLORINE	Distribution System	Same time/place as routine TCR sample	12/01/2023	
CHLORINE	Entry Point	1 samples 20 days per month	12/01/2023	
CHLORINE	Entry Point	1 samples 20 days per month	12/01/2023	

## Compliance Schedules

Schedule/Action	Due	Comments
<b>LCRR</b>		
SUBMIT DRAFT LSL INVENTORY	04/24/2024	Submit Draft of Lead Service Line Inventory for more information visit DW LCRR website <a href="https://dec.alaska.gov/eh/dw/lcrr/">https://dec.alaska.gov/eh/dw/lcrr/</a>
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
<b>Sanitary Survey Corrective Actions</b>		
CORRECTIVE ACTION	05/31/2024	Airgap on backwash discharge pipe is not 2 times the diameter of the pipe. Submit documentation of corrective action to <a href="mailto:darryl.gillespie@alaska.gov">darryl.gillespie@alaska.gov</a>
<b>Consumer Confidence Report</b>		
CCR - SUBMITTAL	06/30/2024	2023 CCR due in 2024
CCR - CERTIFICATION PAGE	09/30/2024	Signed certification page for 2023 CCR due in 2024

\*\*NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at [dec.water.fco.opcert@alaska.gov](mailto:dec.water.fco.opcert@alaska.gov).

**Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.**

Monitoring summary completed by Monica Ague, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at (907) 269-7653 or 1-866-9567656 Email: [monica.ague@alaska.gov](mailto:monica.ague@alaska.gov) Fax: (907) 2697650.

Sincerely,

Monica Ague  
Environmental Program Specialist