

Monitoring Summary for CLARKS POINT WATER SYSTEM

Public water system ID#AK2260202

Population: 128

March 15, 2024

Community Water System, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	11/24/2021	2024
DS CLARKS POINT WATER SYSTEM (Facility ID:DS001)				
LEAD AND COPPER	SPDS001PC	2 consecutive 6 month sets, 10 sample(s) per set	08/18/2017	Overdue; Collect ASAP
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	02/27/2024	Monthly, according to Sample Siting Plan
WL CLARKS POINT WATER SYSTEM (Facility ID:WL001)				
SOC	SPWL001	1 sample(s) quarterly	06/20/2003	Submit SOC waiver renewal application by Sept 30, 2024
NITRATE	SPWL001	1 sample(s) annually	08/18/2017	Overdue; Collect ASAP
ARSENIC - SINGLE	SPWL001	1 sample(s) per 3 year period	07/18/2012	Overdue; Collect ASAP
VOC	SPWL001	1 sample(s) per 3 year period	08/12/2014	Overdue; Collect ASAP
INORGANICS	SPWL001	1 sample(s) per 9 year cycle	12/29/2004	Overdue; Collect ASAP
RADIUM 226 AND 228	SPWL001	1 sample(s) per 9 year cycle	10/23/2014	Between 2017 and 2025
TOTAL GROSS ALPHA	SPWL001	1 sample(s) per 9 year cycle	10/23/2014	Between 2017 and 2025

Compliance Schedules

Schedule/Action	Due	Comments
Lead/Copper Exceedance Schedule		
PBCU EXC SCHED - ST DESIGNATE OPT WQP		
PBCU EXC SCHED - STATE DESIGNATE OCCT		
PBCU EXC SCHED - FLW UP PBCU SAMPLING		
PBCU EXC SCHED - INSTALL OCCT		
PBCU EXC SCHED - SOU WATER TESTING	12/31/2017	
PBCU EXC SCHED - WQP TESTING	12/31/2017	
PBCU EXC SCHED - TT REC/DESK TOP STUDY	06/30/2018	

LCRR		
SUBMIT LSLI CERTIFICATION		
SUBMIT DRAFT LSL INVENTORY	04/24/2024	System has 26 service connections and requesting deadline shift to April 24, 2024. Granted by Darlene as noted in call log (FE 3/5/2024) Submit Draft of Lead Service Line Inventory for more information visit DW LCRR website https://dec.alaska.gov/eh/dw/lcrr/
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
Sanitary Survey Corrective Actions		
CORRECTIVE ACTIONS	08/04/2023	The wellhead height was measured to be 9 inches above the ground surface. The well casing needs to extend at least 12 inches above the ground or 12 inches above the well house floor.
CORRECTIVE ACTIONS	08/04/2023	The sink drain located in the well house is less than 100ft from the source. The system owner will need to apply for a separation distance waiver for a private sewer line less than 100 feet from a public water source with the DEC. The system operator is required to contact Chris Pletnikoff at 907-269-6064 or chris.pletnikoff@alaska.gov .
Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2024	
CCR - CERTIFICATION PAGE	09/30/2024	

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution system must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by John Davis, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-262-8201 or Email: john.davis@alaska.gov Fax: 907-262-2294.

Sincerely,

John Davis
Environmental Program Specialist