

Monitoring Summary for SAINT PAUL WATER SYSTEM

Public water system ID#AK2260286

Population: 380

March 13, 2024

Community Water System, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
-------------	-----------------	-----------------------------	-------------	-------------

Sanitary Survey		Every 3 years	05/11/2021	2024
-----------------	--	---------------	------------	------

DISTRIBUTION SYSTEM (Facility ID:DS001)

COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	03/05/2024	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	5 sample(s) every 3 years	10/18/2023	2026
HAA5 (HALOACETIC)	SPDS1DBP2-2	1 sample(s) annually	08/21/2023	See stage 2 sampling detail information below
TOTAL TRIHALOMETHANE	SPDS1DBP2-2	1 sample(s) annually	09/18/2023	See stage 2 sampling detail information below

TP 1 SAINT PAUL WS (Facility ID:TP001)

SOC	SPTP001	1 sample(s) quarterly	12/27/2004	Submit SOC waiver renewal application by Sept 30, 2024
NITRATE	SPTP001	1 sample(s) annually	04/03/2023	2024
VOC	SPTP001	1 sample(s) per 3 year period	04/03/2023	Between 2026 and 2028
ARSENIC - SINGLE	SPTP001	1 sample(s) per 9 year cycle	04/18/2012	Between 2020 and 2025
RADIUM 226 AND 228	SPTP001	1 sample(s) per 9 year cycle	07/05/2017	Between 2026 and 2034
TOTAL GROSS ALPHA	SPTP001	1 sample(s) per 9 year cycle	07/05/2017	Between 2026 and 2034
INORGANICS	SPTP001	1 sample(s) per 9 year cycle	05/15/2023	Between 2029 and 2037

Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
HAA5	SPDS1DBP2-2	PUBLIC WORKS	1	August 2024
TTHM	SPDS1DBP2-2	PUBLIC WORKS	1	September 2024

Operator Report

Requirement	Location	Sampling Frequency	Last Report
CHLORINE	Distribution System	Same time/place as routine TCR sample	2/29/2024

Compliance Schedules

Schedule/Action	Due	Comments
LCRR		
SUBMIT DRAFT LSL INVENTORY	04/24/2024	Submit Draft of Lead Service Line Inventory for more information visit DW LCRR website https://dec.alaska.gov/eh/dw/lcrr/
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	

Sanitary Survey Corrective Actions

CORRECTIVE ACTIONS	08/31/2024	For SF001 - "The city has #24 mesh and the appropriate safety gear on hand and will coordinate an effort to scale the tanks and install a band of mesh around the vents to prevent contaminant intrusion.
CORRECTIVE ACTIONS	08/31/2024	For SF002 - "The city has #24 mesh and the appropriate safety gear on hand and will coordinate an effort to scale the tanks and install a band of mesh around the vents to prevent contaminant intrusion. Due by September 30, 2023 " per RMW
CORRECTIVE ACTIONS	08/31/2024	Well Pump Turns on But Trips the Breaker (PGOC – WL003) - The operators and public works crew will troubleshoot this issue and correct it. Due by September 30, 2023
CORRECTIVE ACTIONS	08/31/2024	WL006 - "The operators and public works will seal the open connections and maintain this well as a backup in a safe and sealed condition. Due by September 30th, 2023."

Consumer Confidence Report

CCR - SUBMITTAL	06/30/2024	The Consumer Confidence Report is required to be submitted to DEC each year by June 30. Please contact Elizabeth Nakanishi at 269-7517 or elizabeth.nakanishi@alaska.gov if you have any questions or need help completing the report.
CCR - CERTIFICATION PAGE	09/30/2024	The Consumer Confidence Report Certification is required to be submitted to DEC each year by September 30. Please contact Elizabeth Nakanishi at 269-7517 or elizabeth.nakanishi@alaska.gov if you have any questions or need help completing the CCR Certification.

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Elizabeth Nakanishi, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-269-7517 or 1-866-956-7656 Email: elizabeth.nakanishi@alaska.gov Fax: 907-269-7650.

Sincerely,

Elizabeth Nakanishi
Environmental Program Specialist