

# Monitoring Summary for L&PSD NEWHALEN SCHOOL

Public water system ID#AK2260634

Population: 85

May 15, 2024

Non-transient non-community, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 5 years	08/12/2021	2026
<b>DISTRIBUTION SYSTEM (Facility ID:DS001)</b>				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	05/06/2024	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	5 sample(s) every 3 years	03/13/2019	Overdue (Submit materials evaluation & Sampling pool section prior to sampling)
<b>WELL (Facility ID:WL001)</b>				
SOC	SPWL001	1 sample(s) quarterly	12/30/2004	2023-2025 SOC Waiver Granted
ARSENIC - SINGLE	SPWL001	1 sample(s) annually	04/24/2024	2025
NITRATE	SPWL001	1 sample(s) annually	04/24/2024	2025
VOC	SPWL001	1 sample(s) per 3 year period	09/19/2023	Between 2026 and 2028
INORGANICS	SPWL001	1 sample(s) per 9 year cycle	09/19/2023	Between 2029 and 2037

<b>Compliance Schedules</b>		
Schedule/Action	Due	Comments
<b>LCRR</b>		
SUBMIT LSLI CERTIFICATION		
SUBMIT DRAFT LSL INVENTORY	01/24/2024	Submit Draft of Lead Service Line Inventory. For more information visit DW LCRR website <a href="https://dec.alaska.gov/eh/dw/lcrr/">https://dec.alaska.gov/eh/dw/lcrr/</a>
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
<b>Sanitary Survey Corrective Actions</b>		
CORRECTIVE ACTIONS	08/31/2024	Work with DEC engineers to meet the separation distance requirements for the potential source of contamination near the well.
CORRECTIVE ACTIONS	08/31/2024	Work with DEC engineers to address grout around the well casing.
<b>LCSP</b>		
LCR- SUBMIT LEAD/COPPER SAMPLE POOL	08/01/2024	Submit the Lead and Copper Rule - Materials Evaluation and Sample Siting Plan form.

\*\*NSF = No sample found

- Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.

- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at [dec.water.fco.opcert@alaska.gov](mailto:dec.water.fco.opcert@alaska.gov).

**Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.**

Monitoring summary completed by Jordan Ebert, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-269-3068 or Email: [jordan.ebert@alaska.gov](mailto:jordan.ebert@alaska.gov) Fax: 907-269-7650.

Sincerely,

Jordan Ebert  
Environmental Program Specialist