

Monitoring Summary for SILVER BAY SEAFOODS FALSE PASS

Public water system ID#AK2263076

Population: 470

April 28, 2025

Non-transient non-community, Ground water under the influence of surface water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 5 years	07/13/2023	2028
FOUR GU -WELLS BLENDED (Facility ID:CH001)				
E. COLI	SPCH001	2 sample(s) monthly		Sample according to approved LT2 source sampling plan
DISTRIBUTION SYSTEM (Facility ID:DS001)				
LEAD AND COPPER	SPDS001PC	2 consecutive 6 month sets, 10 sample(s) per set		This year January - June & July - December
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	04/22/2025	Monthly during operation
TTHM & HAA5 (DBP2)	SPDS1DBP2-2	2 sample(s) annually		See stage 2 sampling detail information below
WATER TREATMENT PLANT (Facility ID:TP001)				
SOC	SPTP001	1 sample(s) quarterly		Submit New (Initial) SOC waiver application by September 30, 2027
VOC	SPTP001	1 sample(s) quarterly		Quarterly
ARSENIC - SINGLE	SPTP001	1 sample(s) annually		2025
INORGANICS	SPTP001	1 sample(s) annually		2025
NITRATE	SPTP001	1 sample(s) annually	07/24/2024	2025

Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
DBP2	SPDS1DBP2-1	MESS HALL BUILDING	1	May 2025
DBP2	SPDS1DBP2-2	WAREHOUSE BUILDING	1	May 2025

Operator Report

Requirement	Location	Sampling Frequency	Last Report	
TURBIDITY	After Filters	Test and record turbidity every 4 hours while filtering.		Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).
CHLORINE	Distribution System	Same time/place as routine TCR sample	04/01/2025	
CHLORINE	Entry Point	Test and record chlorine residual twice daily.		
CHLORINE	Entry Point	Test and record chlorine residual twice daily, maintain residual about 0.8 mg/L		

Compliance Schedules

Schedule/Action	Due	Comments
SOC		
SOC – SUBMIT NEW SOC WAIVER APPLICAT	09/30/2027	PWS re-classified as NTNC in April 2025 and must apply for an initial SOC waiver or monitor during the 2026-2028 monitoring period.

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Monica Ague, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at (907) 269-7653 or 1-866-9567656 Email: monica.ague@alaska.gov Fax: (907) 2697650.

Sincerely,

Monica Ague
Environmental Program Specialist