

Monitoring Summary for EMMONAK WATER SYSTEM

Public water system ID#AK2270299

Population: 820

March 19, 2024

Community Water System, Surface water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	11/08/2018	Overdue Survey; Schedule ASAP
DS EMMONAK PIPED WEST AND EAST SIDES (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	03/13/2024	Monthly, according to Sample Siting Plan
HAA5 (HALOACETIC)	SPDS1DBP2-H	1 sample(s) quarterly	12/13/2023	See stage 2 sampling detail information below
TOTAL TRIHALOMETHANE	SPDS1DBP2-T	1 sample(s) quarterly	12/13/2023	See stage 2 sampling detail information below
TTHM & HAA5 (DBP2)	SPDS1DBP2-1	1 sample(s) quarterly	12/13/2023	See stage 2 sampling detail information below
LEAD AND COPPER	SPDS001PC	10 sample(s) every 3 years	08/24/2021	2024
IN EMMONAK WATER SYSTEM (Facility ID:IN001)				
TOC & ALKALINITY	SPIN001	1 sample(s) monthly	12/13/2023	Monthly
TP CONVENTIONAL EMMONAK (Facility ID:TP001)				
TOC	SPTP001	1 sample(s) monthly	12/13/2023	Monthly
SOC	SPTP001	1 sample(s) quarterly	10/31/2006	Submit SOC waiver renewal application by Sept 30, 2024
NITRATE	SPTP001	1 sample(s) annually	05/24/2023	2024
VOC	SPTP001	1 sample(s) annually	05/24/2023	2024
ARSENIC - SINGLE	SPTP001	1 sample(s) per 9 year cycle	11/21/2011	Between 2020 and 2028
INORGANICS	SPTP001	1 sample(s) per 9 year cycle	06/12/2013	Between 2020 and 2028
GROSS ALPHA	SPTP001	1 sample(s) per 9 year cycle	07/16/2019	Between 2026 and 2034
RADIUM 226 AND 228	SPTP001	1 sample(s) per 9 year cycle	07/16/2019	Between 2026 and 2034

Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
DBP2	SPDS1DBP2-1	YKHC CLINIC BREAKROOM	1	February, May, August, and November
TTHM	SPDS1DBP2-T	YKHC CLINIC BREAKROOM SINK	1	February 2024
HAA5	SPDS1DBP2-H	YKHC CLINIC CONF RM SINK	1	February 2024

Operator Report

Requirement	Location	Sampling Frequency	Last Report	
TURBIDITY	After Filters	6 samples 31 days per month	01/01/2024	Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).
CHLORINE	Distribution System	Same time/place as routine TCR sample	02/01/2024	
CHLORINE	Entry Point	2 samples 31 days per month	01/01/2024	

Compliance Schedules		
Schedule/Action	Due	Comments
Sanitary Survey Corrective Actions		
CORRECTIVE ACTION	03/04/2020	Repair or replace chemical feed pump for chlorine so all chemical dosing is controlled by a flow switch.
CORRECTIVE ACTION	03/04/2020	Intake needs to be re-constructed in a manner that protects it from ice & silt build up, and ensures a reliable source of water.
LCRR		
SUBMIT DRAFT LSL INVENTORY	04/24/2024	Submit Draft of Lead Service Line Inventory for more information visit DW LCRR website https://dec.alaska.gov/eh/dw/lcrr/
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
DBP Operational Evaluation Level Report		
DBP- SUBMIT TTHM OEL REPORT	03/31/2022	Overdue - Submit OEL Report to monica.ague@alaska.gov
RTCR Level 1 Assessment		
RTCR-LEVEL 1 – MULTIPLE TC+	06/23/2023	Overdue - Level 1 Assessment received on 6/26/23 was incomplete. Contact your EPS at monica.ague@alaska.gov or 907-269-7653 to complete the Assessment.
DBP Operational Evaluation Level Report		
DBP- SUBMIT TTHM OEL REPORT	01/22/2024	Overdue - Submit OEL Report to monica.ague@alaska.gov
DBP Operational Evaluation Level Report		
DBP- SUBMIT TTHM OEL REPORT	01/22/2024	Overdue - Submit OEL Report to monica.ague@alaska.gov
Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2024	2023 CCR due in 2024
CCR - CERTIFICATION PAGE	09/30/2024	Certification page for 2023 CCR due in 2024

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Heather Murray, Environmental Program Manager/ADEC. If you have any questions please contact ADEC at 907-269-7619 or 1-866-956-7656 Email: heather.murray@alaska.gov Fax: (907) 269-7650.

Sincerely,

Heather Murray
Environmental Program Manager