

Monitoring Summary for CITY OF HOOPER BAY

Public water system ID#AK2270312

Population: 1200

March 12, 2024

Community Water System, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey			04/19/2023	2026
DISTRIBUTION SYSTEM (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	2 sample(s) monthly	09/18/2023	Overdue; Collect ASAP
LEAD AND COPPER	SPDS001PC	10 sample(s) every 3 years	12/31/2021	2024
HAA5 (HALOACETIC)	-See below-	1 sample(s) annually	01/12/2023	See stage 2 sampling detail information below
TOTAL TRIHALOMETHANE	-See below-	1 sample(s) annually	01/12/2023	See stage 2 sampling detail information below
TREATMENT, FOR IRON/MANG/ARSN/COLOR (Facility ID:TP001)				
SOC	SPTP001	1 sample(s) quarterly	10/12/2016	Submit SOC waiver renewal application by Sept 30, 2024
NITRATE	SPTP001	1 sample(s) annually	04/20/2022	Overdue; Collect ASAP
VOC	SPTP001	1 sample(s) per 3 year period	01/12/2023	Between 2026 and 2028
RADIUM 226 AND 228	SPTP001	1 sample(s) per 9 year cycle	08/31/2016	Between 2017 and 2025
TOTAL GROSS ALPHA	SPTP001	1 sample(s) per 9 year cycle	08/31/2016	Between 2017 and 2025
ARSENIC - SINGLE	SPTP001	1 sample(s) per 9 year cycle	01/12/2023	Between 2029 and 2037
INORGANICS	SPTP001	1 sample(s) per 9 year cycle	01/12/2023	Between 2029 and 2037

Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
TTHM	SPDS1DBP2-T	CLINIC	1	October - December 2024
HAA5	SPDS1DBP2-H	SCHOOL	1	October - December 2024

Operator Report

Requirement	Location	Sampling Frequency	Last Report	
CHLORINE	Distribution System	Same time/place as routine TCR sample		Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).

Compliance Schedules

Schedule/Action	Due	Comments
LCRR		
SUBMIT DRAFT LSL INVENTORY	04/24/2024	Submit Draft of Lead Service Line Inventory for more information visit DW LCRR website https://dec.alaska.gov/eh/dw/lcrr/
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	

Sanitary Survey Corrective Actions

CONSULT DEC - SIG DEFICIENCY (GW)	12/08/2023	State/PWS consultation on significant deficiencies must occur within 30 days.
CORRECTIVE ACTIONS	03/07/2024	The system operator will need to build up the ground around well 3 so the water does not pool around the well casing. See updated photo the operator sent to the department. The system operator will need to build up the ground around well 6 (W-01-05) so the water does not pool around the well casing or provide a photo showing the ground slopes away from the well. The surveyor did not provide a photo.
CORRECTIVE ACTIONS	03/07/2024	The surveyor noted that the system has ordered new reagent for testing chlorine. The system will need to provide a photo of the new reagent by the due date.

Consumer Confidence Report

CCR - SUBMITTAL	06/30/2024	
CCR - CERTIFICATION PAGE	09/30/2024	

Public Notice Schedules

PN Action	PN Due	Certification Due	Comments
-----------	--------	-------------------	----------

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Kristine Crippen, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-269-7521 or 1-866-956-7656 Email: kristine.crippen@alaska.gov Fax: (907) 269-7650.

Sincerely,

Kristine Crippen
Environmental Program Specialist