

Monitoring Summary for KIPNUK WATER SYSTEM

Public water system ID#AK2270736

Population: 639

March 20, 2024

Community Water System, Surface water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
-------------	-----------------	-----------------------------	-------------	-------------

Sanitary Survey		Every 3 years	08/07/2021	2024
-----------------	--	---------------	------------	------

DS UNNAMED TUNDRA POND (Facility ID:DS001)

COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	03/05/2024	Monthly, according to Sample Siting Plan
HAA5 (HALOACETIC)	-See below-	1 sample(s) quarterly	06/06/2022	See stage 2 sampling detail information below
TOTAL TRIHALOMETHANE	SPDS1DBP2-T	1 sample(s) quarterly	06/06/2022	See stage 2 sampling detail information below
LEAD AND COPPER	SPDS001PC	10 sample(s) every 3 years	09/13/2020	Overdue; Collect ASAP

NEW WTP UNNAMED TUNDRA POND (Facility ID:TP002)

SOC	SPTP002	1 sample(s) quarterly		Submit SOC waiver renewal application by Sept 30, 2024
NITRATE	SPTP002	1 sample(s) annually	06/06/2022	Overdue; Collect ASAP
VOC	SPTP002	1 sample(s) annually	06/06/2022	Overdue; Collect ASAP
ARSENIC - SINGLE	SPTP002	1 sample(s) per 9 year cycle	03/14/2011	Between 2020 and 2028
RADIUM 226 AND 228	SPTP002	1 sample(s) per 9 year cycle	04/27/2012	Between 2017 and 2025
TOTAL GROSS ALPHA	SPTP002	1 sample(s) per 9 year cycle	04/27/2012	Between 2017 and 2025
INORGANICS	SPTP002	1 sample(s) per 9 year cycle	10/03/2013	Between 2020 and 2028

Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
HAA5	SPDS1DBP-H2	BOYS' BATHROOM SINK	1	Overdue; Collect ASAP
TTHM	SPDS1DBP2-T	WATERING POINT	1	Overdue; Collect ASAP

Operator Report

Requirement	Location	Sampling Frequency	Last Report	
TURBIDITY	After Filters	6 samples 31 days per month	01/01/2024	Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).
CHLORINE	Distribution System	Same time/place as routine TCR sample	03/01/2024	
CHLORINE	Entry Point	2 samples 20 days per month	01/01/2024	

Compliance Schedules

Schedule/Action	Due	Comments
Sanitary Survey Corrective Actions		
CORRECTIVE ACTION	02/07/2022	The flow switch is broken and the chlorine must be adjusted manually. Please repair or replace the flow switch and provide documentation to the Department.

LCRR		
SUBMIT LSLI CERTIFICATION	01/28/2024	LSLI draft was completed by L Morrison and sent to PWS for review. Certification due by 1/28/2024. - Im 12/29/2023
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2024	
CCR - CERTIFICATION PAGE	09/30/2024	

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by John Davis, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-262-8201 or Email: john.davis@alaska.gov Fax: 907-262-2294.

Sincerely,

John Davis
Environmental Program Specialist