## Monitoring Summary for BETHEL NATIVE CORP OFFICES

Public water system ID#AK2271106

Population: 99 Non-transient non-community, Ground water

June 13, 2024

	Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample			
	Sanitary Survey		Every 5 years	11/04/2019	2024			
DS DISTRIBUTION SYSTEM (Facility ID:DS001)								
	COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	06/04/2024	Monthly, according to Sample Siting Plan			
	LEAD AND COPPER	SPDS001PC	5 sample(s) every 3 years	11/16/2021	2024			
TP	TP TREATMENT PLANT (Facility ID:TP001)							
	SOC	SPTP001	1 sample(s) quarterly	12/21/2004	Submit SOC waiver renewal application by Sept 30, 2024			
	NITRATE	SPTP001	1 sample(s) annually	12/27/2022	Overdue; Collect ASAP			
	VOC	SPTP001	1 sample(s) per 3 year period	11/16/2021	Between 2023 and 2025			
	ARSENIC - SINGLE	SPTP001	1 sample(s) per 9 year cycle	10/29/2019	Between 2020 and 2028			
	INORGANICS	SPTP001	1 sample(s) per 9 year cycle	10/29/2019	Between 2020 and 2028			

Compliance Schedules					
Schedule/Action	Due	Comments			
LCRR					
COMPLETE INITIAL LSL INVENTORY	10/16/2024	Complete Lead Service Line Inventory. For more information visit DW LCRR website https://dec.alaska.gov/eh/dw/lcrr/ or call engineer Darlene Galido at 907-269-7516.			

## \*\*NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 12/31/2025 and the next period will be 1/1/2026 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 -12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at http://dec.alaska.gov/eh/dw/soc/.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx? p=OperatorSearch. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Jordan Ebert, Environmental Progran	n Specialist/ADEC. If you have any questions please contact ADEC at 907-
269-3068 or Email: iordan.ebert@alaska.gov Fax: 907-269-7650.	

Sincerely,

Jordan Ebert Environmental Program Specialist