

# Monitoring Summary for LKSD KONGIGANAK HS & ELEM

Public water system ID#AK2271245

Population: 143

April 17, 2024

Non-transient non-community, Surface water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
-------------	-----------------	-----------------------------	-------------	-------------

Sanitary Survey		Every 5 years	09/24/2021	2026
-----------------	--	---------------	------------	------

## DS DISTRIBUTION SYSTEM SCHOOL (Facility ID:DS001)

COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	03/28/2024	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	5 sample(s) every 3 years	12/09/2020	Overdue; Collect ASAP
HAA5 (HALOACETIC)	SPDSDBP2-H	1 sample(s) annually	11/28/2023	See stage 2 sampling detail information below
TOTAL TRIHALOMETHANE	SPDSDBP2-T	1 sample(s) annually	02/22/2024	See stage 2 sampling detail information below

## TP TREATMENT PLANT SCHOOL (Facility ID:TP001)

SOC	SPTP001	1 sample(s) quarterly	12/27/2005	Submit SOC waiver renewal application by Sept 30, 2024
NITRATE	SPTP001	1 sample(s) annually	11/28/2023	2024
VOC	SPTP001	1 sample(s) annually	11/28/2023	2024
ARSENIC - SINGLE	SPTP001	1 sample(s) per 9 year cycle	09/13/2021	Between 2029 and 2037
INORGANICS	SPTP001	1 sample(s) per 9 year cycle	11/14/2022	Between 2029 and 2037

## Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
TTHM	SPDSDBP2-T	ROOM 123	1	February 2024
HAA5	SPDSDBP2-H	ROOM 123	1	November 2024

## Operator Report

Requirement	Location	Sampling Frequency	Last Report
TURBIDITY	After Filters	1 samples 31 days per month	02/01/2024
CHLORINE	Distribution System	Same time/place as routine TCR sample	03/01/2024
CHLORINE	Entry Point	1 samples 31 days per month	02/01/2024

## Compliance Schedules

Schedule/Action	Due	Comments
<b>Sanitary Survey Corrective Actions</b>		
CORRECTIVE ACTION	12/31/2025	<p>11/01/2023: Funding for this has been secured for FY2025. Extending deadline - lm</p> <p>03/23/2023: Rec'd email from Darrin Bartz that LKSD has formally decided to secure funding and an engineering firm to address this. Extending due date 6 mo. from today to allow time to get more information. - lm</p> <p>01/26/2023: Correspondence from Darrin Bartz indicates that LKSD is currently in discussion about how to best resolve this issue. Further discussion will occur in mid-February 2023 and an approach should be decided on at that time. Not updating the due date until this information is obtained. - lm</p> <p>The raw water storage tank foundation is severely compromised (see photos 3 and 4 of the photo log.) The foundation has serious erosion issues and sandbags are supporting the tank. Not only could treating water become difficult should the tank collapse, but the tank also poses a safety hazard in its current state. Contact the Department within 30 days with a corrective action plan for tank rehabilitation or replacement.</p>

\*\*NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at [dec.water.fco.opcert@alaska.gov](mailto:dec.water.fco.opcert@alaska.gov).

**Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.**

Monitoring summary completed by Elizabeth Nakanishi, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-269-7517 or 1-866-956-7656 Email: [elizabeth.nakanishi@alaska.gov](mailto:elizabeth.nakanishi@alaska.gov) Fax: 907-269-7650.

Sincerely,

Elizabeth Nakanishi  
Environmental Program Specialist