## **Monitoring Summary for KSD ANIAK SECONDARY SCHOOL**

Public water system ID#AK2271732

Non-transient non-community, Ground water

August 22, 2024

	Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample	
	Sanitary Survey		Every 5 years	08/05/2024	2029	
DS	DS DISTRIBUTION SYSTEM (Facility ID:DS001)					
	COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	05/21/2024	Monthly, according to Sample Siting Plan	
	LEAD AND COPPER	SPDS001PC	2 consecutive 6 month sets, 5 sample(s) per set	04/29/2024	This year January - June & July - December	
WL	WL WELL (Facility ID:WL001)					
	SOC	SPWL001	1 sample(s) quarterly	03/28/2016	Submit SOC waiver renewal application by Sept 30, 2024	
	NITRATE	SPWL001	1 sample(s) annually	04/29/2024	2025	
	VOC	SPWL001	1 sample(s) per 3 year period	04/29/2024	Between 2026 and 2028	
	ARSENIC - SINGLE	SPWL001	1 sample(s) per 9 year cycle	10/30/2019	Between 2020 and 2028	
	INORGANICS	SPWL001	1 sample(s) per 9 year cycle	10/30/2019	Between 2020 and 2028	

Population: 80

Compliance Schedules						
Schedule/Action	Due	Comments				
Lead/Copper Exceedance Schedule						
PBCU EXC SCHED - PUBLIC NOTICE	02/18/2021	Overdue				
PBCU EXC SCHED - PUBLIC EDUCATION	03/22/2021	Overdue				
PBCU EXC SCHED - TT REC/DESK TOP STUDY	06/30/2021	Overdue				
LCRR						
SUBMIT LSLI CERTIFICATION	04/12/2024	LSLI draft completed by Chris Jackson and sent to PWS for review. Certification requested by 4/12/2024 CJ 3/13/2024.				
COMPLETE INITIAL LSL INVENTORY	10/16/2024					
LCNT						
LCR- CONSUMER NOTICE DUE TO CONSUMER	12/29/2022	Overdue				
LCR- CONSUMER NOTICE CERT. DUE TO STATE	02/27/2023	Overdue				
Sample Siting Plan						
RTCR-SAMPLE SITING PLAN	05/31/2024	Update the Revised Total Coliform Rule (RTCR) Sample Siting Plan. For a template and more information, visit the DW RTCR website https://dec.alaska.gov/eh/dw/rtcr				
LCSP						
LCR- SUBMIT LEAD/COPPER SAMPLE POOL	09/06/2024	Submit PbCu sample pool via email to elizabeth.nakanishi@alaska.gov				

## \*\*NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 12/31/2025 and the next period will be 1/1/2026 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 12/31/2028 and the next cycle is 1/1/2029 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 12/31/2025, the next 6 year period will be 01/01/2026 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 12/31/2025 and the next cycle is 01/01/2026 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at http://dec.alaska.gov/eh/dw/soc/.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx? p=OperatorSearch. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Elizabeth Nakanishi, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-269-7517 or 1-866-956-7656 Email: elizabeth.nakanishi@alaska.gov Fax: 907-269-7650.

Sincerely,

Elizabeth Nakanishi
Environmental Program Specialist