

Monitoring Summary for MERTARVIK WATER SYSTEM

Public water system ID#AK2272756

Population: 170

March 25, 2025

Community Water System, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	05/29/2024	2027
DISTRIBUTION SYSTEM (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	02/19/2025	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	5 sample(s) annually	09/23/2024	2025
TEMP TREATMENT PLANT (Facility ID:TP001)				
SOC	SPTP001	1 sample(s) quarterly		2023-2025 SOC Waiver Granted
RADIUM 226 AND 228	SPTP001	1 sample(s) quarterly	10/08/2024	Quarterly
TOTAL GROSS ALPHA	SPTP001	1 sample(s) quarterly	10/08/2024	Quarterly
VOC	SPTP001	1 sample(s) quarterly	10/08/2024	Quarterly
NITRATE	SPTP001	1 sample(s) annually	10/08/2024	2025
ARSENIC - SINGLE	SPTP001	1 sample(s) per 3 year period	07/30/2020	Between 2023 and 2025
INORGANICS	SPTP001	1 sample(s) per 3 year period	07/30/2020	Between 2023 and 2025

Compliance Schedules		
Schedule/Action	Due	Comments
LCRR		
SUBMIT LSLI CERTIFICATION	01/28/2024	7/23 - forwarded to Calvin. 5/24 - reminder sent 1/31 - reminder sent. Draft inventory completed by L Morrison and sent to WS for review on 12/29/2023. Certification due back by 1/28/2024. - lm
LCNT		
LCR- CONSUMER NOTICE DUE TO CONSUMER	04/23/2025	submit to consumer by due date
LCR- CONSUMER NOTICE CERT. DUE TO STATE	06/23/2025	Send completed documentation to DEC via email at elizabeth.nakanishi@alaska.gov
Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2025	CCR due to customers and DEC by July 1st annually
CCR - CERTIFICATION PAGE	09/30/2025	CCR Certification due to DEC by October 1st annually. A copy of the template can be found at: https://dec.alaska.gov/eh/dw/forms/

**NSF = No sample found

1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.

2)

Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.

- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Elizabeth Nakanishi, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-269-7517 or 1-866-956-7656 Email: elizabeth.nakanishi@alaska.gov Fax: 907-269-7650.

Sincerely,

Elizabeth Nakanishi
Environmental Program Specialist