

Monitoring Summary for VILLAGE MOBILE HOME PARK

Public water system ID#AK2310803

Population: 65

March 13, 2025

Community Water System, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	09/24/2018	Overdue Survey; Schedule ASAP
DS VILLAGE MOBILE HOME PARK (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	02/21/2025	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	2 consecutive 6 month sets, 5 sample(s) per set	12/22/2024	This year January - June & July - December
WL VILLAGE MOBILE HOME PARK (Facility ID:WL001)				
SOC	SPWL001			2023-2025 SOC Waiver Granted
NITRATE	SPWL001	1 sample(s) annually	12/22/2024	2025
VOC	SPWL001	1 sample(s) per 3 year period	12/28/2022	2025
TOTAL GROSS ALPHA	SPWL001	1 sample(s) per 9 year cycle	12/21/2010	2025
ARSENIC - SINGLE	SPWL001	1 sample(s) per 9 year cycle	03/29/2017	Between 2020 and 2028
INORGANICS	SPWL001	1 sample(s) per 9 year cycle	12/19/2019	Between 2020 and 2028
RADIUM 226 AND 228	SPWL001	1 sample(s) per 9 year cycle	12/19/2019	Between 2026 and 2034

Compliance Schedules

Schedule/Action	Due	Comments
LCRR		
SUBMIT DRAFT LSL INVENTORY	04/24/2024	OVERDUE: Submit Draft of Lead Service Line Inventory for more information visit DW LCRR website https://dec.alaska.gov/eh/dw/lcrr
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	OVERDUE
Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2025	CCR due to customers and DEC by July 1, 2025
CCR - CERTIFICATION PAGE	09/30/2025	CCR Certification due to DEC by October 1, 2025
Lead/Copper Exceedance Schedule		
PBCU EXC SCHED - INSTALL OCCT		The system shall install optimal corrosion control treatment within 24 months after the State designates such treatment.
PBCU EXC SCHED - WQP TESTING	12/31/2024	Within the same monitoring period that the action level was exceeded WQP testing is required. WQP testing includes pH, alkalinity, calcium, conductivity and temperature.
PBCU EXC SCHED - TT REC/DESK TOP STUDY	06/30/2025	A system exceeding the lead or copper action level must recommend optimal corrosion control treatment within 6 months after the end of the monitoring period during which it exceeds one of the action levels.

PBCU EXC SCHED - SOU WATER TESTING	06/30/2025	One sample must be taken at each entry point to the distribution system to determine how much lead and/or copper is coming from the water source. The source water test is required within 6 months after the end of the monitoring period in which the lead and/or copper action level was exceeded.
------------------------------------	------------	---

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Jennifer Roberts, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-451-2137 or 1-866-770-2137 Email: jenny.roberts@alaska.gov Fax: (907) 451-2188.

Sincerely,

Jennifer Roberts
Environmental Program Specialist