

# Monitoring Summary for WILDWOOD HOMES LLC

Public water system ID#AK2310853

Population: 114

March 18, 2025

Community Water System, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	12/19/2021	Overdue Survey; Schedule ASAP
<b>DS WILDWOOD MOBILE HOME PARK (Facility ID:DS001)</b>				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	01/27/2025	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	5 sample(s) every 3 years	01/04/2024	2027
<b>WL WILDWOOD MOBILE HOME PARK (Facility ID:WL001)</b>				
SOC			12/07/2004	2023-2025 SOC Waiver Granted
NITRATE	SPWL001	1 sample(s) quarterly	12/18/2024	Quarterly in 2025
VOC	SPWL001	1 sample(s) per 3 year period	11/29/2022	2025
TOTAL GROSS ALPHA	SPWL001	1 sample(s) per 6 year period	12/30/2019	2025
INORGANICS	SPWL001	1 sample(s) per 9 year cycle	12/30/2019	Between 2020 and 2028
RADIUM 226 AND 228	SPWL001	1 sample(s) per 9 year cycle	12/30/2019	Between 2026 and 2034
ARSENIC - SINGLE	SPWL001	1 sample(s) per 9 year cycle	01/28/2020	Between 2029 and 2037

## Compliance Schedules

Schedule/Action	Due	Comments
<b>LCRR</b>		
SUBMIT DRAFT LSL INVENTORY	04/24/2024	OVERDUE: Submit ASAP Draft of Lead Service Line Inventory for more information visit DW LCRR website <a href="https://dec.alaska.gov/eh/dw/lcrr/">https://dec.alaska.gov/eh/dw/lcrr/</a>
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	OVERDUE: Submit ASAP.
<b>Sanitary Survey Corrective Actions</b>		
CORRECTIVE ACTIONS	12/31/2023	OVERDUE: Modifications were made to the water system without prior approval from DEC, including, but not limited to, well pipe replacement and reconfiguration of the pressure tank manifold. Please continue to work with your engineer and DEC to complete the engineer review process and obtain final approval to operator for the modifications made to the system.
CORRECTIVE ACTIONS	12/31/2023	OVERDUE: There is a separation distance issue between the current well and wastewater lines. A waiver request has been submitted. Please continue to work with your engineer and DEC to complete the engineer review process to obtain final approval to operate and all applicable separation distance waivers.

LCNT		
LCR- CONSUMER NOTICE DUE TO CONSUMER	02/24/2024	OVERDUE: Within 30 days of learning the lead and copper results, all systems must provide individual lead tap results to people who receive water from sites that were sampled, regardless of whether the results exceed the lead action level, 40 CFR 141.85(d).
LCR- CONSUMER NOTICE CERT. DUE TO STATE	03/31/2024	OVERDUE: Submit ASAP.
Consumer Confidence Report		
CCR - SUBMITTAL	06/30/2025	CCR due to customers and DEC by July 1, 2025
CCR - CERTIFICATION PAGE	09/30/2025	CCR Certification due to DEC by October 1, 2025

\*\*NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at [dec.water.fco.opcert@alaska.gov](mailto:dec.water.fco.opcert@alaska.gov).

**Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.**

Monitoring summary completed by Gretchen Keim, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-451-2231 or 1-800-770-2137 Email: [gretchen.keim@alaska.gov](mailto:gretchen.keim@alaska.gov) Fax: 907-451-2188.

Sincerely,

Gretchen Keim  
Environmental Program Specialist