

Monitoring Summary for GAMBELL WATER SYSTEM

Public water system ID#AK2340751

Population: 669

March 26, 2025

Community Water System, Ground water under the influence of surface water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 3 years	07/15/2024	2027
DS GAMBELL DISTRIBUTION SYSTEM (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) monthly	02/12/2025	Monthly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	10 sample(s) annually	04/24/2023	Overdue; Collect ASAP
HAA5 (HALOACETIC)	SPDS1DBP2-2	1 sample(s) quarterly	02/18/2025	See stage 2 sampling detail information below
TOTAL TRIHALOMETHANE	SPDS1DBP2-1	1 sample(s) quarterly	02/18/2025	See stage 2 sampling detail information below
TP DIRECT FILTRATION FOR GAMBELL (Facility ID:TP002)				
SOC	SPTP002		10/28/2019	2023-2025 SOC Waiver Granted
NITRATE	SPTP002	1 sample(s) annually	07/26/2023	Overdue; Collect ASAP
VOC	SPTP002	1 sample(s) annually	07/26/2023	Overdue; Collect ASAP
ARSENIC - SINGLE	SPTP002	1 sample(s) per 9 year cycle	09/14/2011	Between 2020 and 2028
RADIUM 226 AND 228	SPTP002	1 sample(s) per 9 year cycle	12/19/2012	2025
TOTAL GROSS ALPHA	SPTP002	1 sample(s) per 9 year cycle	12/19/2012	2025
INORGANICS	SPTP002	1 sample(s) per 9 year cycle	08/15/2017	Between 2020 and 2028
WL INFILTRATION GALLERY (Facility ID:WL001)				
CARBON, TOTAL	SPWL001	1 sample(s) monthly (when pumping)	01/28/2025	Monthly during operation

Stage 2 Sampling Detail Information - Sample frequency listed in requirements above

Contaminant	Sample Pt. ID	Location	Sample Count	Sample Dates
HAA5	SPDS1DBP2-2	LOOP A RETURN	1	February, May, August, and November
TTHM	SPDS1DBP2-1	LOOP-B END	1	February, May, August, and November

Operator Report

Requirement	Location	Sampling Frequency	Last Report	
TURBIDITY	After Filters	Continuous monitoring; Report 1 sample every 4 hours on the hour	01/01/2025	Test and record daily. Send reports to ADEC on the last day of the month (before the 10th day of the following month).
CHLORINE	Distribution System	Same time/place as routine TCR sample	02/01/2025	
CHLORINE	Entry Point	2 samples daily, keep chlorine level above 0.2 mg/L	01/01/2025	

Compliance Schedules

Schedule/Action	Due	Comments
-----------------	-----	----------

Consumer Confidence Report

CCR - SUBMITTAL	06/30/2025	CCR due to customers and DEC by July 1, 2025
-----------------	------------	--

**NSF = No sample found

- 1) Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- 2) Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- 3) WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- 4) Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- 5) Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- 6) Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- 7) SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- 8) Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Mike Sharp, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-451-2178 or 1-800-770-2137 Email: mike.sharp@alaska.gov Fax: (907) 451-2188.

Sincerely,

Mike Sharp
Environmental Program Specialist