

Monitoring Summary for DENALI BOROUGH SD - CANTWELL

Public water system ID#AK2390146

Population: 25

February 27, 2023

Non-transient non-community, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 5 years	07/06/2017	Overdue Survey; Schedule ASAP
DS DENALI BOROUGH SD - CANTWELL (Facility ID:DS001)				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) quarterly	08/03/2022	Quarterly, according to Sample Siting Plan
LEAD AND COPPER	SPDS001PC	5 sample(s) every 3 years	02/22/2021	2024
WL CANTWELL SCHOOL WELL # 2 (Facility ID:WL002)				
SOC	SPWL002			Submit SOC waiver renewal application by Sept 30, 2024
NITRATE	SPWL002	1 sample(s) annually	04/12/2022	2023
VOC	SPWL002	1 sample(s) per 3 year period	08/03/2022	Between 2023 and 2025
INORGANICS	SPWL002	1 sample(s) per 9 year cycle	06/28/2015	Between 2020 and 2028
ARSENIC - SINGLE	SPWL002	1 sample(s) per 9 year cycle	04/07/2016	Between 2020 and 2028

Compliance Schedules

Schedule/Action	Due	Comments
LCRR		
SUBMIT DRAFT LSL INVENTORY	11/01/2023	Submit Draft of Lead Service Line Inventory. For more information visit the DW LCRR website https://dec.alaska.gov/eh/dw/lcrr/ .
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	

**NSF = No sample found

- Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- Water systems with multiple water sources that do not combine before entering the distribution must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?p=OperatorSearch>. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at dec.water.fco.opcert@alaska.gov.

Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.

Monitoring summary completed by Teslyn Visscher , Environmental Program Manager/ADEC. If you have any questions please contact ADEC at (907) 451-3038 or 1-800-770-2137 Email: teslyn.visscher@alaska.gov Fax: (907) 451-2188.

Sincerely,

Teslyn Visscher
Environmental Program Manager