

# Monitoring Summary for 49TH STATE BREWING COMPANY HEALY

Public water system ID#AK2391786

Population: 524

March 30, 2023

Non community water system, Ground water

Requirement	Sample Point ID	Required Sampling Frequency	Last Sample	Next Sample
Sanitary Survey		Every 5 years	07/24/2018	2023
<b>DS PRIVATE WELL (Facility ID:DS001)</b>				
COLIFORM (TCR)	SPDS001TCR	1 sample(s) quarterly	08/02/2022	Quarterly, according to Sample Siting Plan
<b>WL PRIVATE WELL (Facility ID:WL001)</b>				
NITRATE	SPWL001	1 sample(s) annually	05/17/2022	2023 sample must arrive to lab on ice

Compliance Schedules		
Schedule/Action	Due	Comments
<b>Sanitary Survey Corrective Actions</b>		
CORRECTIVE ACTIONS	04/30/2023	Modification were made to the water system without prior approval. In addition, the system may have separation distance issues. Please continue to work with your engineer to address this deficiency.
CORRECTIVE ACTIONS	04/30/2023	Provide photo documentation that the water system is adequately protected from the brewing operation. Please continue to work with your engineer to address this deficiency.
<b>Seasonal Start Up</b>		
RTCR-SEASONAL START-UP PROCEDURES	05/05/2023	Complete start up procedures BEFORE serving water to the public (due date noted is flexible based on start-up date).
RTCR-SUBMIT SEASONAL START-UP CERT FORM	05/15/2023	Submit Seasonal Start-up Certification form to DEC within 10 days of serving water to public. Electronic form is located on DEC website: <a href="http://dec.alaska.gov/eh/dw/rtrcr/">http://dec.alaska.gov/eh/dw/rtrcr/</a> (due date noted is flexible based on start-up date)

\*\*NSF = No sample found

- Periods are three years in length. The current period is 1/1/2023 - 12/31/2025 and the next period will be 1/1/2026 - 12/31/2028. Cycles are nine years in length. The current cycle is from 1/1/2020 - 12/31/2028 and the next cycle is 1/1/2029 - 12/31/2037.
- Periods for radionuclides (gross alpha, radium 226/228, and uranium) are three or six years in length. The current 6 year period is 01/01/2020 - 12/31/2025, the next 6 year period will be 01/01/2026 - 12/31/2031. Cycles for radionuclides are nine years in length. The current cycle is from 01/01/2017 - 12/31/2025 and the next cycle is 01/01/2026 - 12/31/2034.
- WL (well) or TP (treatment plant) is the entry point to the distribution system, except for raw water samples and WL (well) is the raw water tap. DS (distribution system) is the home and buildings that receive water from a piped water system.
- Water quality parameters are tested in order to conduct a corrosion control study. Please contact your engineer, health corporation, or certified laboratories for assistance.
- Lead/Copper samples on an annual or 3 year schedule should be collected in month of warmest water temperature.
- Water systems with multiple water sources that do not combine before entering the distribution system must take one sample from each entry point to the distribution and may do a composite sample according to 18AAC80.325(17), 18AAC80.315(4).
- SOC waiver renewal forms are due every three year period. SOC waiver, new and renewal, forms can be found at <http://dec.alaska.gov/eh/dw/soc/>.
- Each public water system is required to have a water operator (or operators) certified at or above the drinking water treatment and drinking water distribution level assigned to the system. To check on current level of certification for your water operator please see the Alaska Certified Water/Wastewater Operator Database maintained by the Division of Water: <https://dec.alaska.gov/Applications/Water/OpCert/Home.aspx?>

p=OperatorSearch. If you have questions regarding the water system level or the operator certification level please contact Operator Certification at 907-465-1139 or at [dec.water.fco.opcert@alaska.gov](mailto:dec.water.fco.opcert@alaska.gov).

**Monitoring Summaries reflect sample results the Drinking Water Program has record of at the time the summary is drafted (see date at top of summary). If information appears incorrect or is inconsistent with previous monitoring summaries please contact DW staff. Monitoring summaries are part of the DW Program's compliance assistance efforts to summarize requirements to help water systems stay in compliance. However, they do not cover all items that may be required of a Public Water System (PWS), nor does it supersede the regulation requirement as outlined in the Code of Federal Regulations or the Alaska Administrative Code. The PWS owner/operator is required to understand or seek assistance in understanding what regulations apply to their PWS.**

Monitoring summary completed by Miki Smelter, Environmental Program Specialist/ADEC. If you have any questions please contact ADEC at 907-451-2231 or 1-800-770-2137 Email: [miki.smelter@alaska.gov](mailto:miki.smelter@alaska.gov) Fax: (907) 451-2188.

Sincerely,

Miki Smelter  
Environmental Program Specialist