



STATE OF ALASKA
 Department of Environmental Conservation
Swimming Pool Monthly Report

Date Monthly Water Sample Taken: _____

Month/Year: _____

Facility: _____

Reviewed By: _____

Day	Free Chlorine	Total Chlorine	Combined Chlorine	pH	Total Alkalinity	Calcium Hardness	Total Hardness	TDS	Saturation Index	Water Temp.	Flow Rate	Pump Vacuum	Pump Pressure	Filter Pressure	Suction Outlet(s)	Chemicals or Water Added	Hours of Operation	NOTES (Repairs, Closures, Backwash, etc.)
1																		
2																		
3																		
4																		
5																		
6																		
7																		
8																		
9																		
10																		
11																		
12																		
13																		
14																		
15																		
16																		
17																		
18																		
19																		
20																		
21																		
22																		
23																		
24																		
25																		
26																		
27																		
28																		
29																		
30																		
31																		

Free Chlorine: Molecular hypochlorous yield ≥ 0.3 ppm; Spas 2 - 10ppm
 Combined Chlorine: Less than 50% total chlorine
 pH: 7.0 - 8.0; Spas 7.2 - 7.6
 Total Alkalinity: 50 - 200ppm; Spas 100 - 140ppm
 Total Hardness: 100 - 1000ppm
 Calcium Hardness: At least 70% total hardness

Saturation Index: ± 0.5
 TDS (Total Dissolved Solids): Spas drained at 1,500ppm
 Maximum Water Temperature: 104°F
 Pool Minimum Flow Rate: (Gallons in pool) / (480 minutes)
 Spa Minimum Flow Rate: (Gallons in spa) / (30 minutes)
 Suction Outlets: Must be visible, intact and properly attached

NOTES: _____

